

Structural Details and Calculations Generator Exhaust Support

ENGINEERS NORTHWEST, INC. is not responsible for this design or performance of this product.
ENGINEERS NORTHWEST, INC. has reviewed the applied loads only for conformance to the construction documents and has reviewed absolutely nothing else
CAR 08-10-2020
Date By

Costco Building-5 Garage

755 Lake Dr,
Issaquah, WA 98027

Prepared for:
Holaday-Parks, Inc.
On:
July 28, 2020
Job No.
20118



TABLE OF CONTENTS

Costco Generator Exhaust Supports

Location Plan3-4
Details5-13

Support Calcs

Generator Exhaust Support 1,2,3, 4 and 6 calc14-74
Generator Exhaust Support A and B calc.....75-100
Thermal Expansion Design..... 101-135

Appendix

Project Seismic Criteria, Floor Framing Plan, cutsheets

COSTCO BLDG-5 GARAGE

DESIGNED BY: Designer
DRAWN BY: Author
APPROVED BY: Approver
JOB NUMBER:
FILENAME:


NOT APPROVED
FOR CONSTRUCTION
SUBMITTAL

3/6/2020 3:41:05 PM

No.	Date	By	Description
A	3/6/20	MH	SUBMITTAL

LEVEL 1 SOUTH
SUBMITTAL EXHAUST
ROUTING SUPPORT




SMP4.01EXH



Note:
Expansion Bellows only shown on View 3 for horizontal pipe.
Bellows shown on View 4 for vertical pipe

Expansion Joint Bellow Legend

	Metraflex EX402000
	Metraflex EX302000



Flexible Connection as Per the Vendor Specification.
If using the MetraFlex EX30 or 40 (20\"/>

LOCATION PLAN FOR REFERENCE ONLY

1 1/8" = 1'-0"

4 1/8" = 1'-0"

COSTCO BLDG-5 GARAGE

DESIGN TEAM

Designed by: Designer
 Drawn by: Author
 Approved by: Approver
 Job Number:
 Filename:

REGISTRATION

NOT APPROVED
 FOR CONSTRUCTION

SUBMITTAL

4/14/2020 2:48:45 PM

REVISIONS


No.	Date	By	Description

SHEET TITLE



EXHAUST RISER CLAMP DETAIL

SHEET NUMBER

SMP3.02




1" = 1'-0"






3" = 1'-0"

LOCATION PLAN FOR REFERENCE ONLY




- NOTES:
- 1) MIN. TWO RACKS NEEDED TO SUPPORT FILTER.
 - 2) CONTRACTOR TO VERIFY ALL FINAL DIMENSIONS AND WEIGHT BEFORE CONSTRUCTION.
 - 3) EACH SUPPORT CAN ALSO CARRY 150 LBS FLANGE WEIGHT, 20" STEEL PIPE(123 PLF MAX.)-5'-0" TRIBUTARY. WEIGHT AND METRAFLEX EX402000 WEIGHT.






- NOTES:
- 1) SUPPORT SPACING = 10'-0" MAX
 - 2) CONTRACTOR TO VERIFY ALL FINAL DIMENSIONS BEFORE CONSTRUCTION.
 - 3) DESIGN IS APPLICABLE FOR (1) 20" STEEL PIPE WITH 3" INSULATION (123 PLF MAX/PIPE) , 506 LBS FOR 90 DEGREE FITTING(IF REQUIRED),(2)150 LBS FLANGE WEIGHT (IF REQUIRED) AND METRAFLEX EX402000 WEIGHT .
 - 4) FOR ROLLER SUPPORT SEE DETAIL 5.





2 RIGID RACK -SUPPORT FOR 20" STEEL PIPE
N.T.S.





NOTES:

- 1) SUPPORT SPACING = 7'-0" MAX
- 2) CONTRACTOR TO VERIFY ALL FINAL DIMENSIONS BEFORE CONSTRUCTION.
- 3) DESIGN IS ONLY APPLICABLE FOR MAX. (2) 20" STEEL PIPE WITH 3" INSULATION (123 PLF MAX/PIPE), 506 LBS FOR 90 DEGREE FITTING(IF REQUIRED) AND (2)150 LBS FLANGE WEIGHT (IF REQUIRED).
- 4) FOR ROLLER SUPPORT SEE DETAIL 5.




Section B-B

2A RIGID RACK -SUPPORT FOR 20" STEEL PIPE
N.T.S.









NOTES:

- 1) SUPPORT SPACING = 10'-0" MAX
- 2) CONTRACTOR TO VERIFY ALL FINAL DIMENSIONS BEFORE CONSTRUCTION.
- 3) DESIGN IS ONLY APPLICABLE FOR (2) 20" STEEL PIPE WITH 3" INSULATION (123 PLF MAX/PIPE) ,506 LBS FOR 90 DEGREE FITTING(IF REQUIRED), AND (2)150 LBS FLANGE WEIGHT (IF REQUIRED)
- 4) FOR ROLLER SUPPORT SEE DETAIL 5.



3 RIGID RACK FOR 20" STEEL PIPE -ATTACHED TO WALL AND CEILING
N.T.S.



Section B-B

- NOTES:
- 1) CONTRACTOR TO VERIFY ALL FINAL DIMENSIONS BEFORE CONSTRUCTION.
 - 2) DESIGN IS ONLY APPLICABLE FOR (3) 20" STEEL PIPE WITH 3" INSULATION (123 PLF MAX/PIPE) AND 506 LBS FOR 90 DEGREE FITTING(IF REQUIRED) .
 - 3) FOR ROLLER SUPPORT SEE DETAIL 5.

4

FOR 20" STEEL PIPE -ATTACHED TO WALL AND CEILING
N.T.S.

B3117SL Steel Roller Stand (TOLCO Fig.327)

Size Range: 2" (50mm) thru 42" (1067mm)

Material: Cast Iron Roller and Steel Base


Function: Designed to support pipe where movement may occur due to thermal expansion. When used with insulated pipe, see B3160-B3165 pipe covering protection saddle charts for proper sizing on pages 155 thru 160.

Approvals: Conforms to Federal Specification WW-H-171E & A-A-1192A, Type 45 and Manufacturers Standardization Society ANSI/MSS SP-69 & SP-58, Type 44.

Standard Finish: Plain, Available in Electro-Galvanized and HDG finish or Stainless Steel material

Order By: Part number and finish.

Notes: If using D.I. pipe refer to page 298 for sizing. Non-metallic rollers with stainless steel stand and hardware are available for most sizes (B3117SLNM-Pipe Size). Contact B-Line Engineering for more information. Not for continuous cycling applications.



B3118SL Adjustable Roller Stand with Base Plate (TOLCO Fig.328)

Size Range: 2" (50mm) thru 30" (750mm)

Material: Cast Iron Roller and Steel Base

Function: Designed to support pipe where movement may occur due to thermal expansion. Set screws allow for vertical adjustment. When used with insulated pipe, see B3160-B3165 pipe covering protection saddle charts for proper sizing on pages 155 thru 160.


Approvals: Conforms to Federal Specification WW-H-171E & A-A-1192A, Type 47 and Manufacturers Standardization Society ANSI/MSS SP-69 & SP-58, Type 46.

Finish: Plain, Available in Electro-Galvanized and HDG finish or Stainless Steel material

Order by: Part number and finish.

Notes: If using D.I. pipe refer to page 298 for sizing. Non-metallic rollers with stainless steel stand and hardware are available for most sizes (B3118SLNM-Pipe Size). Contact B-Line Engineering for more information. Not for continuous cycling applications.

C
Center of pipe to bottom of base plate.
D
Center to center of mounting holes in bottom plate.
E Dia.
Mounting holes in bottom plate.



Part No.	Pipe Size in. (mm)	A in. (mm)	B in. (mm)	C in. (mm)	D in. (mm)	E in. (mm)
B3117SL-2 to 3 1/2	2" (50)	1 3/4" (44.4)	8 3/8" (212.7)	6" (152.4)	4" (101.6)	3 1/16" (93.7)
	2 1/2" (65)	1 3/4" (44.4)	8 3/8" (212.7)	6" (152.4)	4" (101.6)	3 5/16" (100.0)
	3" (80)	1 3/4" (44.4)	8 3/8" (212.7)	6" (152.4)	4" (101.6)	4 1/4" (107.9)
	3 1/2" (90)	1 3/4" (44.4)	8 3/8" (212.7)	6" (152.4)	4" (101.6)	4 1/2" (114.3)
B3117SL-4 to 6	4" (100)	2 1/16" (52.4)	9 7/8" (250.8)	6" (152.4)	4 1/4" (107.9)	5" (127.0)
	5" (125)	2 1/16" (52.4)	9 7/8" (250.8)	6" (152.4)	4 1/4" (107.9)	5 9/16" (141.3)
	6" (150)	2 1/16" (52.4)	9 7/8" (250.8)	6" (152.4)	4 1/4" (107.9)	6 1/16" (154.0)
B3117SL-8 to 10	8" (200)	3 7/16" (87.3)	8 5/8" (219.1)	8" (203.2)	5" (127.0)	8 13/16" (223.8)
	10" (250)	3 7/16" (87.3)	8 5/8" (219.1)	8" (203.2)	5" (127.0)	9 7/8" (250.8)
B3117SL-12 to 14	12" (300)	3 7/8" (98.4)	10 15/16" (277.8)	8" (203.2)	6" (152.4)	11 7/16" (290.5)
	14" (350)	3 7/8" (98.4)	10 15/16" (277.8)	8" (203.2)	6" (152.4)	12 1/16" (306.4)
B3117SL-16 to 20	16" (400)	4 1/4" (107.9)	12 3/8" (314.3)	10" (254.0)	6 1/2" (165.1)	13 5/8" (346.1)
	18" (450)	4 1/4" (107.9)	12 3/8" (314.3)	10" (254.0)	6 1/2" (165.1)	14 11/16" (373.1)
B3117SL-24	24" (600)	4 3/8" (111.1)	13 1/2" (342.9)	10" (254.0)	6 1/2" (165.1)	17 11/16" (449.3)
	30" (750)	5 1/8" (130.2)	17" (431.8)	10 3/4" (273.0)	8" (203.2)	21 3/4" (552.4)
B3117SL-36 to 42	36" (900)	5 3/4" (146.0)	20" (508.0)	12" (304.8)	9" (228.6)	25 5/16" (642.9)
	42" (1050)	5 3/4" (146.0)	20" (508.0)	12" (304.8)	9" (228.6)	28 5/16" (719.1)


Part No.	Pipe Size in. (mm)	A in. (mm)	B in. (mm)	Minimum C in. (mm)	Maximum C in. (mm)	D in. (mm)
B3118SL-2 to 3 1/2	2" (50)	6 7/8" (174.6)	6" (152.4)	4 3/4" (120.6)	5 5/8" (142.9)	3 7/8" (98.4)
	2 1/2" (65)	6 7/8" (174.6)	6" (152.4)	5" (127.0)	5 7/8" (142.9)	3 7/8" (98.4)
	3" (80)	6 7/8" (174.6)	6" (152.4)	5 5/16" (134.9)	6 3/16" (157.2)	3 7/8" (98.4)
B3118SL-4 to 6	3 1/2" (90)	6 7/8" (174.6)	6" (152.4)	5 9/16" (141.3)	6 7/16" (163.5)	3 7/8" (98.4)
	4" (100)	8 1/8" (206.4)	6" (152.4)	6 3/16" (157.2)	7 7/16" (188.9)	5 1/8" (130.2)
	5" (125)	8 1/8" (206.4)	6" (152.4)	6 3/4" (171.4)	8" (203.2)	5 1/8" (130.2)
B3118SL-8 to 10	6" (150)	8 1/8" (206.4)	6" (152.4)	7 1/4" (184.1)	8 1/8" (215.9)	5 1/8" (130.2)
	8" (200)	10 5/8" (269.9)	8" (203.2)	10 1/8" (257.2)	11 11/16" (296.9)	7 3/8" (187.3)
B3118SL-12 to 14	10" (250)	10 5/8" (269.9)	8" (203.2)	11 3/16" (284.2)	12 3/4" (323.8)	7 3/8" (187.3)
	12" (300)	13" (330.2)	8" (203.2)	12 3/4" (323.8)	14 1/8" (358.8)	9 1/2" (241.3)
B3118SL-16 to 20	14" (350)	13" (330.2)	8" (203.2)	13 3/8" (339.7)	14 3/8" (365.1)	9 1/2" (241.3)
	16" (400)	14 5/8" (371.5)	10" (254.0)	15 3/8" (390.5)	17 1/4" (438.1)	11 1/8" (282.6)
B3118SL-24	18" (450)	14 5/8" (371.5)	10" (254.0)	16 3/8" (415.9)	18 1/4" (463.5)	11 1/8" (282.6)
	20" (500)	14 5/8" (371.5)	10" (254.0)	17 3/8" (441.3)	19 1/4" (488.9)	11 1/8" (282.6)
B3118SL-30	24" (600)	15 3/4" (400.0)	10" (254.0)	19 1/4" (488.9)	21 1/4" (539.7)	12 1/4" (311.1)
	30" (750)	19 1/4" (488.9)	10 1/2" (266.7)	24 7/16" (620.7)	26 11/16" (677.9)	15 3/4" (400.0)

Part No.	E in. (mm)	F in. (mm)	Design Load Lbs. (kN)	Approx. Wt./100 Lbs. (kg)
B3118SL-2 to 3 1/2	1" (25.4)	1" (25.4)	390 (1.73)	1100 (498.9)
B3118SL-4 to 6	1" (25.4)	1" (25.4)	950 (4.22)	1310 (594.2)
B3118SL-8 to 10	1" (25.4)	1 1/8" (28.6)	2100 (9.34)	2725 (1236.0)
B3118SL-12 to 14	1" (25.4)	1 1/8" (28.6)	3075 (13.68)	3612 (1638.4)
B3118SL-16 to 20	1" (25.4)	1 1/4" (31.7)	4980 (22.15)	6384 (2895.8)
B3118SL-24	1" (25.4)	1 3/8" (34.9)	6100 (27.13)	8437 (3827.0)
B3118SL-30	1" (25.4)	1 5/8" (41.3)	7500 (33.36)	12528 (5682.7)

Pipe Rollers & Pipe Supports

Part No.	Dia. F in. (mm)	Dia. G in. (mm)	H in. (mm)	J in. (mm)	Design Load Lbs. (kN)	Approx. Wt./100 Lbs. (kg)
B3117SL-2 to 3 1/2	1 1/2" (12.7)	1" (25.4)	3 7/16" (87.3)	6 3/8" (161.9)	390 (1.73)	508 (230.4)
B3117SL-4 to 6	1 1/2" (12.7)	1" (25.4)	4 1 1/16" (119.1)	7 7/8" (200.0)	950 (4.22)	631 (286.2)
B3117SL-8 to 10	5/8" (15.9)	1" (25.4)	7" (177.8)	4" (101.6)	2100 (9.34)	1271 (576.5)
B3117SL-12 to 14	3/4" (19.0)	1" (25.4)	9 1/16" (230.2)	5 3/4" (146.0)	3075 (13.68)	1994 (904.5)
B3117SL-16 to 20	13/16" (20.6)	1" (25.4)	10 1/4" (260.3)	6 3/4" (171.4)	4980 (22.15)	3423 (1552.7)
B3117SL-24	13/16" (20.6)	1" (25.4)	11 3/8" (288.9)	7 1/2" (190.5)	6100 (27.13)	4710 (2136.4)
B3117SL-30	1 1/16" (27.0)	1" (25.4)	14 1/4" (361.9)	10" (254.0)	7500 (33.36)	7132 (3235.1)
B3117SL-36 to 42	1 3/16" (30.2)	1" (25.4)	17" (431.8)	12" (304.8)	12000 (53.37)	10386 (4711.1)


NOTES:
 1) USE B117SL OR B118SL OR EQUAL TYP.




Section B-B

5

ROLLER STAND TO RIGID RACK ATTACHED
 N.T.S.




- NOTES:
1) SUPPORT SPACING = 10'-0" MAX
2) CONTRACTOR TO VERIFY ALL FINAL DIMENSIONS BEFORE CONSTRUCTION.
3) DESIGN IS ONLY APPLICABLE FOR (1) 20" STEEL PIPE WITH 3" INSULATION (123 PLF MAX/PIPE) AND 506 LBS FOR 90 DEGREE FITTING(IF REQUIRED) .





6

RIGID RACK -SUPPORT FOR 20" STEEL PIPE
N.T.S.



C 12X30 CONTINUOUS CHANNEL OR EQUAL. TYP. SEE LOCATION PLAN FOR MORE INFO.



12"x12"x 0.5" EMBEDDED PLATE (TOTAL 4 -PER CONTINUOUS CHANNEL-AT EACH SIDE @48" O.C)



NOTES:

- 1) **BOLTS ON CLAMP ARE ONLY TO BE SNUG TIGHT AT ALL LEVELS, EXCEPT LEVEL 4, AND 8 SO THAT PIPE CAN SLIDE THRU CLAMP. LEVEL 4 AND 8, CLAMP IS TO BE TIGHTENED PER MANUFACTURER INSTRUCTION.**
- 2) **CONTRACTOR TO VERIFY ALL FINAL DIMENSIONS BEFORE CONSTRUCTION.**
- 3) **DESIGN IS ONLY APPLICABLE FOR (3) 20" STEEL PIPE (123 PLF MAX/PIPE).**
- 4) **THE FIRST EMBEDDED PLATE ANCHORAGE EDGE DISTANCE HAS TO BE 7" MIN. FROM THE WALL.**

Model E2200, Model E2210, Model E2220, Model E2230 Insulated Pipe Riser Clamps for Upward or Downward Loads



- a) If thrust plate thickness "B" is greater than pipe wall thickness, consult factory.
- b) One pair thrust plates supplied loose for field welding, top only.

Note: For higher load ratings, see: E2200. Available in all insulation thickness.

Pipe Size	Load lbs	A	B	C	D	E	Insul. Thk. = 1"			Insul. Thk. = 2"			Insul. Thk. = 3"			Insul. Thk. = 4"		
							F	G	H	F	G	H	F	G	H	F	G	H
2	750	0.63	0.38	0.38 x 3.00	1.50	0.625	3.94	6.19	5.38	5.00	7.25	7.5	6.00	8.25	9.5	7.06	9.31	11.63
2 1/2	900	0.63	0.38	0.38 x 3.00	1.50	0.625	4.19	6.44	5.88	5.50	7.75	8.5	6.50	8.75	10.5	7.56	9.81	12.63
3	1200	0.63	0.38	0.38 x 3.00	1.50	0.625	4.47	6.72	6.44	5.50	7.75	8.5	6.50	8.75	10.5	7.56	9.81	12.63
4	1800	0.63	0.38	0.38 x 3.00	1.50	0.625	5.00	7.25	7.5	6.00	8.25	9.5	7.06	9.31	11.63	8.06	10.31	13.63
5	2400	0.63	0.38	0.38 x 4.00	2.00	0.625	5.50	7.75	8.5	6.50	8.75	10.5	7.56	9.81	12.63	8.69	10.94	14.88
6	3000	0.63	0.38	0.38 x 4.00	2.00	0.625	6.00	8.25	9.5	7.06	9.31	11.63	8.06	10.31	13.63	9.19	11.44	15.88
8	3900	0.63	0.50	0.50 x 4.00	2.00	0.625	7.31	9.81	11.88	8.31	10.81	13.88	9.44	11.94	16.13	10.44	12.94	18.13
10	4800	0.88	0.50	0.50 x 5.00	3.00	0.625	8.31	10.81	13.88	9.44	11.94	16.13	10.44	12.94	18.13	11.44	13.94	20.13
12	5100	0.88	0.50	0.50 x 5.00	3.00	0.625	9.44	11.94	16.13	10.44	12.94	18.13	11.44	13.94	20.13	12.44	14.94	22.13
14	6000	0.88	0.50	0.50 x 5.00	3.00	0.75	10.06	12.69	17.13	11.06	13.69	19.13	12.06	14.69	21.13	13.06	15.69	23.13
16	6900	0.88	0.50	0.50 x 6.00	4.00	0.75	11.06	13.69	19.13	12.06	14.69	21.13	13.06	15.69	23.13	14.06	16.69	25.13
18	7500	0.88	0.50	0.50 x 6.00	4.00	0.75	12.06	14.69	21.13	13.06	15.69	23.13	14.06	16.69	25.13	15.06	17.69	27.13
20	8100	0.88	0.50	0.50 x 6.00	4.00	0.75	13.06	15.69	23.13	14.06	16.69	25.13	15.06	17.69	27.13	16.06	18.69	29.13
24	8400	0.88	0.50	0.50 x 6.00	4.00	0.75	15.06	17.69	27.13	16.06	18.69	29.13	17.06	19.69	31.13	18.06	20.69	33.13

Application:

Model E2200 through E2230 is designed for use on:

- Hot water
- Cold water
- Chilled water
- Dual temperature
- Steam
- Air
- Gas
- Vacuum

Intended for installation on:

- Vertical runs of insulated pipe with upward and/or downward load.

Other:

- For handling downward loads only, see E1200

Temperature Range: +40°F to +1200°F
Note: Up to 1800°F available upon request.

Features:



- All pipe sizes
- Easy installation
- Positive stop - axially upward or downward
- May be supported from below or above
- Overlapping galvanized sheet metal jacket
- Insulating structural inserts for load transfer
- Other I.D.'s and/or O.D.'s Available on Request
- Eliminates condensation sweating on chilled water risers

Performance Test Results on File:
Available upon request.

Material Data:

- **E2200 - E2230:** specification document: No. 209.
 - **Steel Inner Thrust Plates:**

Model	ASTM	For Pipe Material
E2200	A36	Carbon-Steel
E2210	A387GR.11	Chrome-Moly
E2220	A515GR.70	Carbon Silicon
E2230	A304L	Stainless Steel
 - Insulation: Calcium silicate asbestos-free, treated with water repellent.
 - Jackets: Galvanized steel ASTM A-653.
 - Glue: Industrial contact adhesive
 - Structural Inserts: High-density calcium silicate asbestos free, treated with water repellent.
 - Steel Straps/Base: Carbon steel ASTM A-36.
 - Fasteners: ASTM A-307 plated.
 - Coating: Primer coated or hot dipped galvanized
 - Other coatings available upon request.
- Formal submittal sheets available



- NOTES:
 1) LATERAL SUPPORT = 13'-0" MAX TRIBUTARY .
 2) CONTRACTOR TO VERIFY ALL FINAL DIMENSIONS BEFORE CONSTRUCTION.
 3) DESIGN IS ONLY APPLICABLE FOR (1) 20" STEEL PIPE (123 PLF MAX/PIPE).

B STANCHION PIPES SUPPORT
 N.T.S.

**SUPPORT-1
CONTROLS SUPPORT-2,2A AND 6
(DETAIL 1 , 2, 2A AND 6)**

Support 1(Worst Case)-Controls Support 2 AND 2A and 6

1. Seismic Design Criteria

Governing Code CBC 2016/ ASCE 7-10

$$a_p := 2.5 \quad R_p := 2.5 \quad (\text{Table 13.6-1-Worst case})$$

$$I_p := 1.5 \quad (\text{Per S 0.01})$$

$$S_{DS} := 0.634 = 0.634 \quad (\text{Eq: 11.4-3})$$

$$z := 18 \cdot \text{ft} \quad (\text{Location-Level 2})$$

$$h := 104 \cdot \text{ft} \quad (\text{Height of structure above ground})$$

Horizontal Seismic Design Coefficients: Strength Design

$$F_{phe} := \left(\frac{0.4 \cdot a_p \cdot S_{DS}}{\left(\frac{R_p}{I_p} \right)} \right) \cdot \left(1 + 2 \cdot \frac{z}{h} \right) = 0.512 \quad (\text{Eq: 13.3-1}) \quad \text{Controls}$$

$$F_{phUc} := 1.6 \cdot S_{DS} \cdot I_p = 1.522 \quad (\text{Eq: 13.3-2, Upper Limit})$$

$$F_{phLc} := 0.3 \cdot S_{DS} \cdot I_p = 0.285 \quad (\text{Eq: 13.3-3, Lower Limit})$$

Vertical Seismic Design Coefficients: Strength Design

$$F_{pvc} := 0.2 \cdot S_{DS} = 0.127 \quad (\text{Eq: 12.4-4})$$

2A. Design Loads

$$W1 := 3652 \text{ lbf} = 3652 \text{ lbf} \quad (\text{Filter Total weight-W/(2) Additional element=3652 lbs})$$

$$W2 := 300 \text{ lbf} = 300 \text{ lbf} \quad (\text{Flange weight=150 /flange})$$

$$W3 := 123 \text{ plf} = 123 \text{ plf} \quad (\text{20" steel pipe})$$

$$b_1 := 10 \text{ ft} \quad (\text{Max Tributary Dead Load on each support})$$

$$W_{3t} := W3 \cdot b_1 = 1230 \text{ lbf} \quad (\text{Weight on Support})$$

$$W4 := 95 \text{ lbf} = 95 \text{ lbf} \quad (\text{Matraflex EX402000/EX302000-Worst case is 95 lbs})$$

$$W_p := (0.5 (W1 + W2 + W_{3t})) + W4 = 2686 \text{ lbf} \quad (\text{Total weight on each side Support of Filter: worst case})$$

$$F_{pv1} := F_{pvc} \cdot W_p = 341 \text{ lbf} \quad (\text{Vertical Seismic Load: Each support})$$

$$F_{ph2} := F_{phe} \cdot W_p = 1375 \text{ lbf} \quad (\text{Horizontal Seismic Load:})$$

$$T := 190 \cdot \text{lbf} = 190 \text{ lbf} \quad (\text{Horizontal Thermal Load max-worst case Both direction worst case})$$

$$F_{ph} := T + F_{ph2} = 1565 \text{ lbf} \quad (\text{Horizontal Force= Seismic+Thermal, as a worst case})$$

(As a worst case considered total horizontal force in both direction=Seismic +Thermal, anchorage calculated with over strength factor for total Horizontal Force)

(See Risa result)

Support 2(Case 1 Calculation Controls Case 2)

1. Seismic Design Criteria

Governing Code CBC 2016/ ASCE 7-10

$$a_p := 2.5 \quad R_p := 2.5 \quad (\text{Table 13.6-1-Worst case})$$

$$I_p := 1.5 \quad (\text{Per S 0.01})$$

$$S_{DS} := 0.634 = 0.634 \quad (\text{Eq: 11.4-3})$$

$$z := 18 \cdot \mathbf{ft} \quad (\text{Location-Level 2})$$

$$h := 104 \cdot \mathbf{ft} \quad (\text{Height of structure above ground})$$

Horizontal Seismic Design Coefficients: Stength Design

$$F_{phc} := \left(\frac{0.4 \cdot a_p \cdot S_{DS}}{\left(\frac{R_p}{I_p} \right)} \right) \cdot \left(1 + 2 \cdot \frac{z}{h} \right) = 0.512 \quad (\text{Eq: 13.3-1}) \quad \text{Controls}$$

$$F_{phUc} := 1.6 \cdot S_{DS} \cdot I_p = 1.522 \quad (\text{Eq: 13.3-2, Upper Limit})$$

$$F_{phLc} := 0.3 \cdot S_{DS} \cdot I_p = 0.285 \quad (\text{Eq: 13.3-3, Lower Limit})$$

Vertical Seismic Design Coefficients: Strength Design

$$F_{pvc} := 0.2 \cdot S_{DS} = 0.127 \quad (\text{Eq: 12.4-4})$$

2A. Design Loads

$$W2 := 300 \mathbf{lb} \mathbf{f} = 300 \mathbf{lb} \mathbf{f} \quad (\text{Flange weight}=150 / \text{flange})$$

$$W3 := 123 \mathbf{pl} \mathbf{f} = 123 \mathbf{pl} \mathbf{f} \quad (20" \text{ steel pipe})$$

$$W4 := 506 \mathbf{lb} \mathbf{f} = 506 \mathbf{lb} \mathbf{f} \quad (90 \text{ degree fitting})$$

$$b_1 := 10 \mathbf{ft} \quad (\text{Max Tributary Dead Load on each support})$$

$$W_{3t} := W3 \cdot b_1 = 1230 \mathbf{lb} \mathbf{f} \quad (\text{Weight on Support})$$

$$W5 := 95 \mathbf{lb} \mathbf{f} = 95 \mathbf{lb} \mathbf{f} \quad (\text{Matraflex EX402000/EX302000-Worst case is 95 lbs})$$

$$W_p := 1.1 (W2 + W_{3t} + W4 + W5) = 2344 \mathbf{lb} \mathbf{f} \quad (\text{Total weight on one Support of Filter: worst case})$$

$$F_{pv1} := F_{pvc} \cdot W_p = 297 \mathbf{lb} \mathbf{f} \quad (\text{Vertical Seismic Load: Each support})$$

$$F_{ph2} := F_{phc} \cdot W_p = 1200 \mathbf{lb} \mathbf{f} \quad (\text{Horizontal Seismic Load:})$$

$$T := 190 \cdot \mathbf{lb} \mathbf{f} = 190 \mathbf{lb} \mathbf{f} \quad (\text{Horizontal Thermal Load max-worst case Both direction})$$

$$F_{ph} := T + F_{ph2} = 1390 \mathbf{lb} \mathbf{f} \quad (\text{Horizontal Force Seismic+Thermal})$$

(As a worst case considered total horizontal force in both direction=Seismic +Thermal, anchorage calculated with over strength factor for total Horizontal Force)

(See support 1 Risa result as a worst case)

Support 2A -(2) 20" Pipes(Case 1 Calculation Controls Case 2A)

1. Seismic Design Criteria

Governing Code CBC 2016/ ASCE 7-10

$$a_p := 2.5 \quad R_p := 2.5 \quad (\text{Table 13.6-1-Worst case})$$

$$I_p := 1.5 \quad (\text{Per S 0.01})$$

$$S_{DS} := 0.634 = 0.634 \quad (\text{Eq: 11.4-3})$$

$$z := 18 \cdot \mathbf{ft} \quad (\text{Location-Level 2})$$

$$h := 104 \cdot \mathbf{ft} \quad (\text{Height of structure above ground})$$

Horizontal Seismic Design Coefficients: Strength Design

$$F_{phc} := \left(\frac{0.4 \cdot a_p \cdot S_{DS}}{\left(\frac{R_p}{I_p} \right)} \right) \cdot \left(1 + 2 \cdot \frac{z}{h} \right) = 0.512 \quad (\text{Eq: 13.3-1}) \quad \text{Controls}$$

$$F_{phUc} := 1.6 \cdot S_{DS} \cdot I_p = 1.522 \quad (\text{Eq: 13.3-2, Upper Limit})$$

$$F_{phLc} := 0.3 \cdot S_{DS} \cdot I_p = 0.285 \quad (\text{Eq: 13.3-3, Lower Limit})$$

Vertical Seismic Design Coefficients: Strength Design

$$F_{pvc} := 0.2 \cdot S_{DS} = 0.127 \quad (\text{Eq: 12.4-4})$$

2A. Design Loads

$$W_2 := 300 \mathbf{lb} \mathbf{f} = 300 \mathbf{lb} \mathbf{f} \quad (\text{Flange weight}=150 / \text{flange})$$

$$W_3 := 2 \cdot 123 \mathbf{pl} \mathbf{f} = 246 \mathbf{pl} \mathbf{f} \quad (20" \text{ steel pipe})$$

$$W_4 := 506 \mathbf{lb} \mathbf{f} = 506 \mathbf{lb} \mathbf{f} \quad (90 \text{ degree fitting})$$

$$W_5 := 95 \mathbf{lb} \mathbf{f} = 95 \mathbf{lb} \mathbf{f} \quad (\text{Matraflex EX402000/EX302000-Worst case is 95 lbs})$$

$$b_1 := 7 \mathbf{ft} \quad (\text{Max Tributary Dead Load on each support})$$

$$W_{3t} := W_3 \cdot b_1 = 1722 \mathbf{lb} \mathbf{f} \quad (\text{Weight on Support})$$

$$W_p := W_2 + W_{3t} + W_4 + W_5 = 2623 \mathbf{lb} \mathbf{f} \quad (\text{Total weight on one Support of Filter: worst case})$$

$$F_{pv1} := F_{pvc} \cdot W_p = 333 \mathbf{lb} \mathbf{f} \quad (\text{Vertical Seismic Load: Each support})$$

$$F_{ph2} := F_{phc} \cdot W_p = 1343 \mathbf{lb} \mathbf{f} \quad (\text{Horizontal Seismic Load:})$$

$$T := 190 \cdot \mathbf{lb} \mathbf{f} = 190 \mathbf{lb} \mathbf{f} \quad (\text{Horizontal Thermal Load max-worst case Both direction})$$

$$F_{ph} := T + F_{ph2} = 1533 \mathbf{lb} \mathbf{f} \quad (\text{Horizontal Force Seismic+Thermal})$$

(As a worst case considered total horizontal force in both direction=Seismic +Thermal, anchorage calculated with over strength factor for total Horizontal Force)

(See support 1 Risa result as a worst case)

Support 6(Worst Case)-Detail 6 Calculation Controls By support 1

1. Seismic Design Criteria

Governing Code CBC 2016/ ASCE 7-10

$$a_p := 2.5 \quad R_p := 2.5 \quad (\text{Table 13.6-1-Worst case})$$

$$I_p := 1.5 \quad (\text{Per S 0.01})$$

$$S_{DS} := 0.634 = 0.634 \quad (\text{Eq: 11.4-3})$$

$$z := 18 \cdot \mathbf{ft} \quad (\text{Location-Level 2})$$

$$h := 104 \cdot \mathbf{ft} \quad (\text{Height of structure above ground})$$

Horizontal Seismic Design Coefficients: Stength Design

$$F_{phc} := \left(\frac{0.4 \cdot a_p \cdot S_{DS}}{\left(\frac{R_p}{I_p} \right)} \right) \cdot \left(1 + 2 \cdot \frac{z}{h} \right) = 0.512 \quad (\text{Eq: 13.3-1}) \quad \text{Controls}$$

$$F_{phUc} := 1.6 \cdot S_{DS} \cdot I_p = 1.522 \quad (\text{Eq: 13.3-2, Upper Limit})$$

$$F_{phLc} := 0.3 \cdot S_{DS} \cdot I_p = 0.285 \quad (\text{Eq: 13.3-3, Lower Limit})$$

Vertical Seismic Design Coefficients: Strength Design

$$F_{pvc} := 0.2 \cdot S_{DS} = 0.127 \quad (\text{Eq: 12.4-4})$$

2A. Design Loads

$$W1 := 123 \mathbf{plf} = 123 \mathbf{plf} \quad (20" \text{ steel pipe})$$

$$W2 := 506 \mathbf{lb} = 506 \mathbf{lb} \quad (90 \text{ degree fitting})$$

$$b_1 := 10 \mathbf{ft} \quad (\text{Max Tributary Dead Load on each support})$$

$$W_{1t} := W1 \cdot b_1 = 1230 \mathbf{lb} \quad (\text{Weight on Support})$$

$$W5 := 95 \mathbf{lb} = 95 \mathbf{lb} \quad (\text{Matraflex EX402000/EX302000-Worst case is 95 lbs})$$

$$W_p := 1.02 (W2 + W_{1t} + W5) = 1868 \mathbf{lb} \quad (\text{Total weight on one Support of Filter: worst case})$$

$$F_{pv1} := F_{pvc} \cdot W_p = 237 \mathbf{lb} \quad (\text{Vertical Seismic Load: Each support})$$

$$F_{ph2} := F_{phc} \cdot W_p = 956 \mathbf{lb} \quad (\text{Horizontal Seismic Load:})$$

$$T := 244 \cdot \mathbf{lb} = 244 \mathbf{lb} \quad (\text{Horizontal Thermal Load max-worst case Both direction})$$

$$T1 := T + F_{ph2} = 1200 \mathbf{lb} \quad (\text{Horizontal Force Seismic+Thermal})$$

(As a worst case considered total horizontal force in both direction=Seismic +Thermal, anchorage calculated with over strength factor for total Horizontal Force)

(See support 1 Risa result as a worst case)

3. Check B3188 Standard U-bolt



$$P_d := T1 = 1200 \mathbf{lb} \quad (\text{Axial demand on brace})$$

$$P_c := 2490 \mathbf{lb} \quad (\text{Axial capacity: See Appendix})$$

$$DC := \frac{P_d}{P_c} = 0.48 \quad (<1.0 \text{ OK, D/C Ratio})$$



Thermal load on each support: (see Thermal Calc for More info.)

1- Location of the Bellows and the lateral support reaction is shown below:





Axial load
 Reactions

Weight of the pipe=(47)*123 = 5781 @ node 8
 Support Reaction on the top (node #8)= 503.48 lbs + 5781 (Weight of the pipe.)= 5284.48 lbs
 Weight of the pipe=(32)*123 = 3936 @ node 4
 Support Reaction on the top (node #4)= 143.84 lbs + 3936 (Weight of the pipe.)= 4079.84 lbs
 Weight of the pipe=(14)*123 = 1722 @ node 1
 Support Reaction on the top (node #1)= 359.64 lbs + 1722 (Weight of the pipe.)= 2081.64 lbs



Loads: BLC 1, DL
Envelope Only Solution

Fortress Structural Engine...	Rigid Frame	SK - 1
KJ		May 26, 2020 at 8:58 AM
20118		20118 - Costco Generator Exhaust...





Loads: BLC 2, SEIS-X
Envelope Only Solution

Fortress Structural Engine...
KJ
20118

Rigid Frame

SK - 1
July 28, 2020 at 12:16 PM
20118 - Costco Generator Exhaust...





Loads: BLC 3, SEIS-Z
Envelope Only Solution

Fortress Structural Engine...
KJ
20118

Rigid Frame

SK - 2
July 28, 2020 at 12:18 PM
20118 - Costco Generator Exhaust...



Envelope Only Solution

Fortress Structural Engine...	Rigid Frame	SK - 4
KJ		Apr 8, 2020 at 6:56 PM
20118		20118 - Costco Generator Exhaust...

fl `cVUL'A cXY`GYH]b[g

Öã æ Å ^ & cã } • Å Å ^ { à ^ ! Å æ & •	I Å
T æ Å Ø c } æ Å ^ & cã } • Å Å ^ { à ^ ! Å æ & •	J I Å
Q & ^ à ^ Å @ æ Å ^ { { æã } N	Y ^ •
Q & ^ à ^ Å æã } * Å æ æã Å Å Y å å N	Y ^ •
Q & ^ à ^ Å æ } å * N	Y ^ •
V æ • Å æ Å Ø c } Å Ø c ^ • Å & cã } * Å [[à Å Y æ] N	Y ^ •
CE ^ æ S æ Å T ^ • @ Å å CD	F I I
T ^ ! ^ Å ^ ! æ } & ^ Å å D	È G
UE Ø ^ cæ Å æ } • å Å ^ ! æ } &	È È Å
Q & ^ à ^ Å UE Ø ^ cæ Å Å Y æ } • N	Y ^ •
CE { { æã æã ^ Å ^ ! æ Å cã } ^ • • Å Å Y æ } • N	Y ^ •
T æ Å Ø ^ ! æã } • Å Å Y æ Å cã } ^ • •	H
Ó æ æ Å Å Ø & ^ ^ ! æã } Å cã ^ & å CD	H G G
Y æ Å ^ • @ Ú å ^ Å å D	F G
Ö å ^ } • { } cã } Å Ø } ç ^ ! ^ } & ^ Å È F È Ø È	I
X ^ ! cæ Å Ø æ	Y
Ö à æ Å T ^ { à ^ ! Å å } æã } Å æ ^	Y Z
U cæ Å Å ç ^ !	U æ ^ • Å Å & ^ ! ^ ! æ ^ å
Ö ^ } æ æ Å ç ^ !	Ø & ^ ! ^ ! æ ^ å Å ç ^ !

P [c Å à Å Ø c ^ ! Å Ø à ^	Ø Ø Ø Å c Ø H È È È M S U Ø Ø
Ö å b ^ • Å cã } ^ • • N	Y ^ • Ø ^ ! æã ^ D
U Ø Ø Ø } } ^ & cã } Å Ø à ^	Ø Ø Ø Å c Ø H È È È M S U Ø Ø
Ö à Å Ø { ^ à Å Ø c ^ ! Å Ø à ^	Ø Ø Ø Å Ø È È È K Ø Ø Ø
Y [[à Å Ø à ^	Ø Y Ø Å Ø È È F G K Ø Ø Ø
Y [[à Å ^ { } ^ ! æ ^ ! ^	L Å F È Ø
Ö } & ^ c Å Ø à ^	Ø Ø Ø Å F I È F
T æ [] ^ Å Ø à ^	Ø Ø Ø Å H È È F K Ø Ø Ø
Ø { } å ^ { } Å Ø à ^	Ø Ø Ø Å Ø T F È È K Ø Ø Ø Å Ø ^ å å å * Ø Ø Ø Å c Ø H È È È M S U Ø Ø

P ^ { à ^ ! Å Å @ æ Å ^ * å } •	I
Ü ^ * å } Å æã } * Å Ø & ^ { ^ } cã } D	I
Ö æ æ Å Ø { } Å ^ c Ø à	Ø c æ c Å Ø c ^ ! æã }
U æ { ^ Å Ø cæ Å æ c Å Ø Ø È	È I
Ö } & ^ c Å Ø ^ • • Å Ø &	Ü ^ & cæ } * ^ æ
W ^ Å Ø æ Å ^ à Å ^ & cã } • N	Y ^ •
W ^ Å Ø æ Å ^ à Å ^ & cã } • Å æ Å N	P [
Ö æ Å Ø æ å * Å Y æ } å * • N	P [
W ^ • à Å Ø & ^ Å Y æ } å * • N	Y ^ •
T å Å Å Ø cæ Å Ø æ Å æã } * N	P [
Ö } & ^ c Å ^ à æ Å ^ c	Ü Ø Ø Ø Ü ' U Ø V' Ø È V T Ø È F I
T å Å Å Ø c ^ ! Å Å Ø { }	F
T æ Å Å Ø c ^ ! Å Å Ø { }	I

9bj YcdYA Ya Vyf'GYWjcb': cfWkg'f'f'cbjbi YXL

T^ { à^!		Ú^&	ÓçpZáá SÔ	^ÁU@æÞESÔ	ÁU@æÞESÔ	V[!~^ZÞESÔ	^ÉÁ [{ ^ } çZáá SÔ	:ÉÁ [ÞESÔ			
G		H	{ æ € G	iiJÉi	FF iiÉiH	FÉ IJHÉGF	í	iiiÉHH	í	HíÉÞEÞ FH	
G			{ ä ÉiÉÞEÞ	ÉiJÉi	FH ÉiHÉi	í	É JHÉGF	J	€	G	ÉiÉÞEÞFF
G		I	{ æ € G	iiJÉi	FF iiÉiH	FÉ IJHÉGF	í	FíHJÉíí	FÉ	ííFÉÞEÞ FH	
G			{ ä ÉJÉGÉÞEÞ	ÉiJÉi	FH ÉiHÉi	í	É JHÉGF	J	ÉíÉÞEÞíí	FG	ÉíFÉÞEÞFF
G		í	{ æ € G	iiJÉi	FF iiÉiH	FÉ IJHÉGF	í	HíGíÉJi	FÉ	ííÉJÞEÞ FH	
HÉ			{ ä ÉJHJÉÞEÞ	ÉiJÉi	FH ÉiHÉi	í	É JHÉGF	J	ÉíííÉíí	FG	ÉíÉJÞEÞFF

>c]bhFYUWjcbg'f6 m7 ca V]bUjcbk

SÔ	R á cSaa\	YÁaa	YÁaa	ZÁaa	T YÁaa	T YÁaa	T ZÁaa	
F	F	PH	ÉiÉiH	FiJiÉiJ	€	€	É JÉÞEÞí	
G	F	PI	GiÉiH	FiJiÉiJ	€	€	í JÉÞEÞí	
H	F	V] çK	€	GJFÉFJ	€			
I	F	ÓUÓÇDK	YKÉFG	YKÉJH	ZKÉ			
í	G	PH	€	€	€	€	€	
í	G	PI	€	€	€	€	€	
í	G	V] çK	€	€	€			
í	G	ÓUÓÇDK	pÓ	pÓ	pÓ			
J	H	PH	ÉiÉiH	FiJiÉiJ	€	€	É JÉÞEÞí	
FÉ	H	PI	GiÉiH	FiJiÉiJ	€	€	í JÉÞEÞí	
FF	H	V] çK	€	GJFÉFJ	€			
FG	H	ÓUÓÇDK	YKÉFG	YKÉJH	ZKÉ			
FH	I	PH	ÉiÉiH	GiJiÉiH	€	€	ÉFÉiÉíí	
FI	I	PI	HiÉiH	GiJiÉiH	€	€	FFÉiÉíí	
Fí	I	V] çK	€	IííÉií	€			
Fí	I	ÓUÓÇDK	YKÉFG	YKÉJH	ZKÉ			
Fí	í	PH	ÉJÉiH	FíJiÉiF	€	€	ÉííÉií	
Fí	í	PI	GiÉiH	FíJiÉiF	€	€	JííÉií	
FJ	í	V] çK	€	HííÉiG	€			
GÉ	í	ÓUÓÇDK	YKÉFG	YKÉJH	ZKÉ			
GF	í	PH	É HFÉJi	GJHÉHG	€	€	Éí HÉFÉHi	
GG	í	PI	É HHÉEH	FÉGÉií	€	€	Éí GiÉÉG	
GH	í	V] çK	Éííí	HííÉiF	€			
G	í	ÓUÓÇDK	YKÉFG	YKÉJH	ZKÉ			
G	í	PH	ÉGÉ FJ	FííÉiH	ÉíGÉ	íííJÉÞFF	I JHÉGF	ÉÉíÉJj
G	í	PI	HGÉ FJ	FííÉiH	ÉíGÉ	íííJÉÞFF	É JHÉGF	FÉíÉJj
G	í	V] çK	€	HííÉiF	Éííí			
G	í	ÓUÓÇDK	YKÉFG	YKÉJH	ZKÉ			
GJ	í	PH	í HHÉEH	FÉGÉií	€	€	Hí GiÉÉG	
HÉ	í	PI	í HFÉJi	GJHÉHG	€	€	Hí HÉFÉHi	
HF	í	V] çK	Fííí	HííÉiF	€			
HG	í	ÓUÓÇDK	YKÉFG	YKÉJH	ZKÉ			
HH	J	PH	ÉGÉ FJ	FííÉiH	ííGÉ	ÉííJÉÞFF	É JHÉGF	ÉÉíÉJj
Hi	J	PI	HGÉ FJ	FííÉiH	ííGÉ	ÉííJÉÞFF	I JHÉGF	FÉíÉJj
Hí	J	V] çK	€	HííÉiF	Fííí			
Hí	J	ÓUÓÇDK	YKÉFG	YKÉJH	ZKÉ			
Hí	FÉ	PH	É FiÉJi	GFGÉiJ	€	€	ÉíííÉií	
Hí	FÉ	PI	É ííÉÉG	FííÉií	€	€	Éí GíÉJi	
HJ	FÉ	V] çK	Éííí	GFGÉHH	€			
IÉ	FÉ	ÓUÓÇDK	YKÉFG	YKÉJH	ZKÉ			
I F	FF	PH	ÉJÉG	FFíÉií	ÉíGÉ	íííÉJj	I JHÉGF	É FFÉHi


Hilti PROFIS Engineering 3.0.62
www.hilti.com

Company:	Fortress Structural Engineering	Page:	1
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	20118- support 1_07-28-20	Date:	7/28/2020
Fastening point:			

Specifier's comments:
1 Input data

Anchor type and diameter:	AWS D1.1 GR. B 1/2
Item number:	not available
Effective embedment depth:	$h_{ef} = 6.000$ in.
Material:	
Proof:	Design Method ACI 318-14 / CIP
Stand-off installation:	$e_b = 0.000$ in. (no stand-off); $t = 0.750$ in.
Anchor plate ^R :	$l_x \times l_y \times t = 18.000$ in. x 18.000 in. x 0.750 in.; (Recommended plate thickness: not calculated)
Profile:	no profile
Base material:	cracked concrete, 5000, $f'_c = 5,000$ psi; $h = 10.000$ in.
Reinforcement:	tension: condition B, shear: condition B; edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)	Tension load: yes (17.2.3.4.3 (d)) Shear load: yes (17.2.3.5.3 (c))

^R - The anchor calculation is based on a rigid anchor plate assumption.

Geometry [in.] & Loading [lb, in.lb]

 Input data and results must be checked for conformity with the existing conditions and for plausibility!
 PROFIS Engineering (c) 2003-2020 Hilti AG, FL-9494 Schaan Hilti is a registered Trademark of Hilti AG, Schaan



Hilti PROFIS Engineering 3.0.62

www.hilti.com

Company:	Fortress Structural Engineering	Page:	2
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	20118- support 1_07-28-20	Date:	7/28/2020
Fastening point:			

1.1 Design results

Case	Description	Forces [lb] / Moments [in.lb]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 4,371; V _x = 2,088; V _y = 1,956; M _x = 187,024; M _y = 92,805; M _z = 1,233;	yes	63

Hilti PROFIS Engineering 3.0.62
www.hilti.com

Company:	Fortress Structural Engineering	Page:	3
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	20118- support 1_07-28-20	Date:	7/28/2020
Fastening point:			

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [lb]		Utilization	Status
		Load	Capacity	β_N / β_V [%]	
Tension	Concrete Breakout Failure	18,325	29,193	63 / -	OK
Shear	Concrete edge failure in direction y+	2,861	18,708	- / 16	OK

Loading	β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads	0.628	0.153	5/3	51	OK

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!

Hilti PROFIS Engineering 3.0.62**www.hilti.com**

Company:	Fortress Structural Engineering	Page:	4
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	20118- support 1_07-28-20	Date:	7/28/2020
Fastening point:			

4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

**SUPPORT-3
(DETAIL 3)**

Support 3 - Wall Calc (2-20"pipe for 10' tributary)

1. Seismic Design Criteria

Governing Code CBC 2016/ ASCE 7-10

$$a_p := 2.5 \quad R_p := 2.5 \quad (\text{Table 13.6-1-Worst case})$$

$$I_p := 1.5 \quad (\text{Per S 0.01})$$

$$S_{DS} := 0.634 = 0.634 \quad (\text{Eq: 11.4-3})$$

$$z := 18 \cdot \text{ft} \quad (\text{Location-Level 2})$$

$$h := 104 \cdot \text{ft} \quad (\text{Height of structure above ground})$$

Horizontal Seismic Design Coefficients: Strength Design

$$F_{phc} := \left(\frac{0.4 \cdot a_p \cdot S_{DS}}{\left(\frac{R_p}{I_p} \right)} \right) \cdot \left(1 + 2 \cdot \frac{z}{h} \right) = 0.512 \quad (\text{Eq: 13.3-1}) \quad \text{Controls}$$

$$F_{phUc} := 1.6 \cdot S_{DS} \cdot I_p = 1.522 \quad (\text{Eq: 13.3-2, Upper Limit})$$

$$F_{phLc} := 0.3 \cdot S_{DS} \cdot I_p = 0.285 \quad (\text{Eq: 13.3-3, Lower Limit})$$

Vertical Seismic Design Coefficients: Strength Design

$$F_{pvc} := 0.2 \cdot S_{DS} = 0.127 \quad (\text{Eq: 12.4-4})$$

2A. Design Loads

$$W_2 := 300 \text{ lbf} = 300 \text{ lbf} \quad (\text{Flange weight}=150 /\text{flange})$$

$$W_3 := 2 \cdot 123 \text{ plf} = 246 \text{ plf} \quad (\text{20" steel pipe with 3" insulation})$$

$$W_3 := 1.0 \cdot W_3 = 246 \text{ plf} \quad (\text{Weight w/ appurtenances})$$

$$b_1 := 10 \text{ ft} \quad (\text{Max Tributary Dead Load on each support})$$

$$W_{3t} := W_3 \cdot b_1 = 2460 \text{ lbf} \quad (\text{Weight on Support})$$

$$W_4 := 506 \text{ lbf} = 506 \text{ lbf} \quad (\text{90 degree fitting})$$

$$W_5 := 95 \text{ lbf} = 95 \text{ lbf} \quad (\text{Matraflex EX402000/EX302000-Worst case is 95 lbs})$$

$$W_p := (W_2 + W_{3t} + W_4 + W_5) = 3361 \text{ lbf} \quad (\text{Total weight on Support: worst case})$$

$$F_{pv1} := F_{pvc} \cdot W_p = 426 \text{ lbf} \quad (\text{Vertical Seismic Load: Each support})$$



$$F_{ph2} := F_{phc} \cdot W_p = 1721 \text{ lbf} \quad (\text{Horizontal Seismic Load:})$$

$$T := 169 \cdot \text{lbf} = 169 \text{ lbf} \quad (\text{Horizontal Thermal Load max-worst case Both direction})$$

$$F_{ph} := T + F_{ph2} = 1890 \text{ lbf} \quad (\text{Horizontal Force Seismic+Thermal})$$



(As a worst case considered total horizontal force as a seismic load and calculated Anchorage with over strength factor)

(See Risa result)





Loads: BLC 1, DL

Fortress Structural Engine...	Rigid Frame	SK - 1
KJ		July 28, 2020 at 1:17 PM
20118		20118 - Costco Generator Exhaust...





Loads: BLC 2, SEIS-X

Fortress Structural Engine...	Rigid Frame	SK - 2
KJ		July 28, 2020 at 1:17 PM
20118		20118 - Costco Generator Exhaust...



Loads: BLC 3, SEIS-Z

Fortress Structural Engine...	Rigid Frame	SK - 3
KJ		July 28, 2020 at 1:18 PM
20118		20118 - Costco Generator Exhaust...



Fortress Structural Engine...
KJ
20118

Rigid Frame

SK - 4
July 28, 2020 at 1:19 PM
20118 - Costco Generator Exhaust...

fl `cVUL'A cXY`GYH]b[g

Óã æ Á ^ & cã } • Á Á T ^ { à ^ ! Á Ó æ & •	I Á
T æ Á Q c } æ Á ^ & cã } • Á Á T ^ { à ^ ! Á Ó æ & •	J I Á
Q & ~ á ^ Á Ú @ æ Á ^ & ~ { } æ ð } N	Y ^ •
Q & ^ æ ^ Á æ ð * Á Ó æ æ ð Á Á Y ð á N	Y ^ •
Q & ~ á ^ Á Y æ } ð * N	Y ^ •
V æ • Á æ Á Q c } Á Q c ^ • Á cã * Á Y [[á Á Y æ] N	Y ^ •
Ø E ^ æ S æ Á T ^ • @ Á Q á C D	F I I
T ^ ! * ^ Á V ^ ! æ } & ^ Á Q D	E F G
U E Ø ^ c æ Á Q æ } • á Á V ^ ! æ } &	E E E A
Q & ~ á ^ Á U E Ø ^ c æ Á Á Y æ } • N	Y ^ •
Ø E { { } æ ð æ ^ Á Q æ Á U cã } ^ • • Á Á Y æ } • N	Y ^ •
T æ Á Q æ ð } • Á Á Y æ } Á U cã } ^ • •	H
Ó æ æ Á Q B & ^ ^ ! æ ð } Á Q c ^ & á C D	H G G
Y æ Á T ^ • @ Ú á ^ Á Q D	F G
Ó á ^ } • { } cã } Á Q } c ^ ! ^ } & ^ Á V E F E Ø E D	I
X ^ ! c æ Á Q æ á	Y
Ó [á æ Á T ^ { à ^ ! Á U á } c æ ð } Á U æ ^	Y Z
U c æ Á U c ^ !	U æ ^ • Á Q B & ^ ^ ! æ ^ á
Ó ^ } æ æ Á U c ^ !	Ø B & ^ ^ ! æ ^ á U c ^ !

P [c Á U á á Á U c ^ Á Q á ^	Ø Ø Ú Á F I c Ø H I E F E D S U Z Ø
Ø á b ^ • Á U cã } ^ • • N	Y ^ • Q æ ð ^ Á D
U Ø Ø Ø } } ^ & cã } Á Q á ^	Ø Ø Ú Á F I c Ø H I E F E D S U Z Ø
Ó [á Á Q { } ^ á á Á U c ^ Á Q á ^	Ø Ø Ú Á Q Ø U E E I K Ø U Ø
Y [[á Á Q á ^	Ø Y Ø Á Q Ø U E F G K Ø U Ø
Y [[á Á V ^ { } ^ ! æ ^	L A F E Ø
Ó } & ^ c Á Q á ^	Ø Ø Q F I E F
T æ [] ^ Á Q á ^	Ø Ø Q H E E F F K Ø U Ø
Ø { } ð ~ { } Á Q á ^	Ø Ø Á Q Ø T F I E F K Ø U Ø Á Q ^ á á á * Ø Ø Ú Á F I c Ø H I E F E D S U Z Ø

P ~ { à ^ ! Á Á Ú @ æ Á ^ * ð } •	I
Ú ^ * ð } Á U æ ð * Á Q & ^ { ^ } cã D	I
Ó æ cã Á Q { } Á T ^ c Ø á	Ø c æ c Á Q c ^ æ ð }
Ú æ { ^ Á Q c æ Á Q c æ ð Á Q Ø Ø E D	E E I
Ó [] & ^ c Á U c ^ • • Á Q &	Ú ^ & cã * ~ æ
W ^ Á Q æ ð ^ á á Á ^ & cã } • N	Y ^ •
W ^ Á Q æ ð ^ á á Á ^ & cã } • Á U æ ð N	P [
Ó æ Á Q æ ð ð * Á Y æ } ð * • N	P [
W ^ • á á Á Q & ^ Á Y æ } ð * • N	Y ^ •
T ð Á Á Q c æ Á Q c æ ð Á U æ ð * N	P [
Ó [] & ^ c Á U ^ á á Á U c	Ú Ø Ø Ø Ú ' Ú Ø V' Ø E V T Ø E F I
T ð Á Á Á U c ^ Á Á Q { }	F
T æ Á Á Á U c ^ Á Á Q { }	I

fl `cVUL'A cXY`GYHjbj gZ7 cbHjbi YX

U^a{ aÁ[á^	œÜÖÖÁ È€
U^ã{ aÁœ^ÁO ^ç aã } AçD	P[(çD) ç ^á
ŌãáÁœ^ÁY ^ã @N	Y^•
ŌçY	ÈG
ŌçZ	ÈG
VÁÁç^&D	P[(çD) ç ^á
VÁZç^&D	P[(çD) ç ^á
UAY	H
UÁZ	H
ŌçÁç ÈY	ÈÍ
ŌçÁç ÈZ	ÈÍ
UOF	ÈH
UŌU	ÈH
UF	ÈÍ F
VSAç^&D	I
Uã\ Áœ	Ç Áœ
Ō äçÁœ	Uç@
U{ ÁZ	œÈ
U{ AY	œÈ
ŌãÁZ	I
ŌãAY	I
U@ÁZ	F
U@AY	F

< chFc``YX`GhY`DfcdYfHjYg

	Šçã\	ŌÁç•ã	ŌÁç•ã	P`	V@ \ ÁçFOÍ ÁçD	Ō\ •ç ZÈYã ãZ•ã	Û`	Ō`Z•ã	Ûç	
F	œHÍ ÁO ÈÍ	GJœœœ	FFFÍ I	ÈÍ	ÈÍ	ÈJ	HÍ	FÈ	ÍÍ	FÈG
G	œÍ ÁGO ÈÍ €	GJœœœ	FFFÍ I	ÈÍ	ÈÍ	ÈJ	Í €	FÈ	ÍÍ	FÈÈ
H	œJ JG	GJœœœ	FFFÍ I	ÈÍ	ÈÍ	ÈJ	Í €	FÈ	ÍÍ	FÈÈ
I	œ ÈŌ ÈÁÜPŌ	GJœœœ	FFFÍ I	ÈÍ	ÈÍ	ÈĜ	I G	FÈ	ÍÍ	FÈH
Í	œ ÈŌ ÈÁÜ^&c	GJœœœ	FFFÍ I	ÈÍ	ÈÍ	ÈĜ	I Í	FÈ	ÍÍ	FÈH
Ï	œ HÁO ÈO	GJœœœ	FFFÍ I	ÈÍ	ÈÍ	ÈJ	HÍ	FÈ	Í €	FÈG
Ï	œ È Í	GJœœœ	FFFÍ I	ÈÍ	ÈÍ	ÈJ	Í €	FÈ	ÍÍ	FÈH
Ï	ÛHFÍ	GJœœœ	FFFÍ I	ÈÍ	ÈÍ	ÈJ	H€	FÈ	ÍÍ	FÈG

> c]bh7 ccfX]bUHyg`UbX`HYa dYUhi fYg

	Šçã\	ÝÁçá	ÝÁçá	ZÁçá	V\ ÁZã	Ō`çç@O { Áœj ÈÈ
F	pF	€	€	€	€	
G	pG	Í ÈĜ	€	€	€	
H	pH	€	Í	€	€	

> c]bh6 ci bXUfm7 cbX]hcbg

	R à çŠçã\	ÝÁç á	ÝÁç á	ZÁç á	ÝÁÜ çZ Èççáá	ÝÁÜ çZ Èççáá	ZÁÜ çZ Èççáá
F	pF						
G	pG	Û^æçĜ }	Û^æçĜ }	Û^æçĜ }	Û^æçĜ }	Û^æçĜ }	Û^æçĜ }
H	pH	Û^æçĜ }	Û^æçĜ }	Û^æçĜ }	Û^æçĜ }	Û^æçĜ }	Û^æçĜ }


Hilti PROFIS Engineering 3.0.62

www.hilti.com

Company:	Fortress Structural Engineering	Page:	1
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	20118- wall- support 3-Embaded plate_07-28-20	Date:	7/28/2020
Fastening point:			


Specifier's comments:

1 Input data

Anchor type and diameter:	HIT-HY 200 + HAS-V-36 (ASTM F1554 Gr.36) 3/4	
Item number:	2198029 HAS-V-36 3/4"x8" (element) / 2022793 HIT-HY 200-R (adhesive)	
Effective embedment depth:	$h_{ef,act} = 6.000$ in. ($h_{ef,limit} = -$ in.)	
Material:	ASTM A 1554 Grade 36	
Evaluation Service Report:	ESR-3187	
Issued Valid:	4/1/2020 3/1/2022	
Proof:	Design Method ACI 318-14 / Chem	
Stand-off installation:	$e_b = 0.000$ in. (no stand-off); $t = 0.500$ in.	
Anchor plate ^R :	$l_x \times l_y \times t = 18.000$ in. x 18.000 in. x 0.500 in.; (Recommended plate thickness: not calculated)	
Profile:	no profile	
Base material:	cracked concrete, 5000, $f'_c = 5,000$ psi; $h = 10.000$ in., Temp. short/long: 32/32 °F	
Installation:	hammer drilled hole, Installation condition: Dry	
Reinforcement:	tension: condition B, shear: condition B; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar	
Seismic loads (cat. C, D, E, or F)	Tension load: yes (17.2.3.4.3 (d)) Shear load: yes (17.2.3.5.3 (c))	

^R - The anchor calculation is based on a rigid anchor plate assumption.

Geometry [in.] & Loading [lb, in.lb]





Hilti PROFIS Engineering 3.0.62

www.hilti.com

Company:	Fortress Structural Engineering	Page:	2
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	20118- wall- support 3-Embaded plate_07-28-20	Date:	7/28/2020
Fastening point:			

1.1 Design results

Case	Description	Forces [lb] / Moments [in.lb]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 4,745; V _x = 3,359; V _y = 3,359; M _x = 75,222; M _y = 62,598; M _z = 360; N _{sus} = 0; M _{x,sus} = 0; M _{y,sus} = 0;	yes	61

Hilti PROFIS Engineering 3.0.62
www.hilti.com

Company:	Fortress Structural Engineering	Page:	3
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	20118- wall- support 3-Embaded plate_07-28-20	Date:	7/28/2020
Fastening point:			

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [lb]		Utilization	Status
		Load	Capacity	β_N / β_V [%]	
Tension	Concrete Breakout Failure	10,387	17,190	61 / -	OK
Shear	Concrete edge failure in direction x+	4,750	15,151	- / 32	OK

Loading	β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads	0.609	0.314	5/3	59	OK

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!



Hilti PROFIS Engineering 3.0.62**www.hilti.com**

Company:	Fortress Structural Engineering	Page:	4
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	20118- wall- support 3-Embaded plate_07-28-20	Date:	7/28/2020
Fastening point:			

4 Remarks; Your Cooperation Duties



- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

**SUPPORT-4
(DETAIL 4)**





Loads: BLC 1, DL

Fortress Structural Engine...	Rigid Frame	SK - 1
KJ		July 28, 2020 at 2:26 PM
20118		20118 - Costco Generator Exhaust...



Loads: BLC 2, SEIS-X

Fortress Structural Engine...	Rigid Frame	SK - 2
KJ		July 28, 2020 at 2:28 PM
20118		20118 - Costco Generator Exhaust...



Loads: BLC 3, SEIS-Z

Fortress Structural Engine...	Rigid Frame	SK - 3
KJ		July 28, 2020 at 2:28 PM
20118		20118 - Costco Generator Exhaust...

A Ya VYf'Gi [[YghY'G UdYg

	Ú^&ã} Á^••{ à^!	Ó•ã}^! Á^••{ à^!	Ú~**^•••c^áÁ^••{ à^!	Ó{ }d[[ã* Á^••{ à^!	Ó{ }d[[ã* Á^••{ à^!	V^••Á^••**^••c^áN
F	Ó^æ	ÓFGcHE	PÚUIÉ çl É çl	TF	Úd^} * @	Y^•
G	Új •c	ÓFGcHE	ÓJcFHÉ	TI	Úd^} * @	Y^•

9bj YcdY5-G7 % h fl * \$!%\$L'@F: 8 'GhY'7cXY7\ YWg

	T^••{ à^!	Ú^••{ à^!	Ó{ }á^••Á^••@&	Š &žcáSÓ Ú@æ^Á^••@#É	Š &žcá	Óã	ÞÉ @ÚÞÉ @ÚÞÉ @É ÞÉ @É ÞÉ ÞÉ Ó)
F	TF	ÓFGcHE	É I I	FFÉ J	É I I	^	J I é I H G I I I I F é I H G I I I I P F é a
G	TH	ÓFGcHE	É € G	FFÉ J	É I I	^	J I é I H G I I I I F é I H G I I I I P F é a
H	TI	ÓFGcHE	É G	I J	É FH	I	J F G H I I I I I I F é I H G I I I I P F é a
I	TÍ	ÓFGcHE	É I G	FFÉ J	É H	I	J I é I H G I I I I F é I H G I I I I P F é a
Í	TÍ	ÓFGcHE	É € H	€ I	É FI	I	I F G H I I I I I I F é I H G I I I I P F é a
Î	TÍœ	ÓFGcHE	É I H	I J	É H	I	J F G H I I I I I I F é I H G I I I I P F é a
Ï	TÌ	ÓFGcHE	É I J	I J	É I	HÉ JG	J G H I I I I I I I I F é I H G I I I I P F é a
Ì	TÌ	ÓFGcHE	É UH	€ J	É I	É	J G H I I I I I I I I F é I H G I I I I P F é a

9bj YcdY'A Ya VYf'GYWcb': cfWYg

	T^••{ à^!	Ú^••{ à^!	Ó{ }ã^••á SÓ ^Á^••@æÞÉ SÓ : Á^••@æÞÉ SÓ v{ }~^•••ÞÉ SÓ ^É Á^••{ }^••{ }ã^••á SÓ : É Á^••{ }ÞÉ SÓ
F	TF	F	{ æ } JÉJÍ FF Í I HÉI I Í I I HÉI FH F é I É G J I F J I É JF J G € G
G			{ ã } É I J É J J J É I I HÉI FH É I I HÉI I € G G € G
H		G	{ æ } FGHÉI F F € € G Í F I É J F F é I É G J I I G É I H FH I H I F é J
I			{ ã } É I J I É É J É H I É É J É é É I J F € G É I J É G H I € G
Í		H	{ æ } G I I É J I F € € G Í F I É J F F é I É G J G F I I É H J F é F é É J
Î			{ ã } É J H I É É J É F é É J É é É I J € G É J J é É I H FF € G
Ï		I	{ æ } G I I É J I F € F é é é F J I é É I F F F é I J G é I I FH F é H I É J
Ì			{ ã } É J H I É É J € G É I G é F I J É I I F F É I H G é I I € G
J		Í	{ æ } H é É J I F € € G F I H é I F F F é I J I G I I É F F F F I J J É I
F€			{ ã } É G I I É É J É H G é É J É J F I É É J É I I F F É I F J I É € G J € G
FF	TH	F	{ æ } € G F I H é I J F I É H J I J I É J H FH H é H FF I é J I É J
FG			{ ã } É F é H J € G É I I I F F É H é F H I É J J É H G J € G
FH		G	{ æ } € G F I G é F J F I É H J I J I É J H FH I é F é I J € G
FI			{ ã } É F é H J € G É I I I F F É H é F H I É G I G é I G FF É é I I É J
FÍ		H	{ æ } I I J é F F € G I I I É U F F I J I É J H FH G I J I É € G J € G
FÌ			{ ã } É I é É É J É G F é É J É J J é I J É H é F H I É H I I FF É I J € É J
FÌ		I	{ æ } I I J é F F € G I I I É U F F € G G H I É I I I H I I É é J
FÌ			{ ã } É I é É É J É J I É É J É J J é I J É G é J É F I É H FH € G
FJ		Í	{ æ } I I J é F F € G I I I É U F F € G G F I I É U I FF I I é F é J
G€			{ ã } É I é É É J É F é É J É J J é I J É G é J É H F H é I G J € G
GF	TI	F	{ æ } € G € G I I É I I F F G J é H G J I I J I É é J J € G
GG			{ ã } É J J I É É J É F é É J É F é é G J É H é H FF € G É é J I É J
GH		G	{ æ } € G € G I I É I I F F G J é H G J I H é H I I € G
G			{ ã } É é I é É J É F é É J É F é é G J É H é H FF É G é J I FH É é I É J
G		H	{ æ } € G € G I I É I I F F G J é H G J I I I F é I H I € G
G			{ ã } É F I é É J É F é É J É F é é G J É H é H FF É H F é é FH É F G I É J
G		I	{ æ } € G € G I I É I I F F G J é H G J I J I H é I I H I H é F I
G			{ ã } É G I é É J É F é É J É F é é G J É H é H FF É I F I é F I FH € G
GJ		Í	{ æ } € G € G I I É I I F F G J é H G J I I I J é I G FF F I H U É J
H€			{ ã } É F H é É J É F é É J É F é é G J É H é H FF É J I I é I I J € G
HF	TÍ	F	{ æ } € G F I G é J I I É G H FF I I é I J F é I H é J I F é I É J
HG			{ ã } É I I é G I € G É é é J J € G É I I G é J FF € G

Hilti PROFIS Engineering 3.0.62

www.hilti.com

Company:	Fortress Structural Engineering	Page:	1
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	07-28-20_20118_ steel support at level 1_support 4_	Date:	7/28/2020
Fastening point:			


Specifier's comments:

1 Input data

Anchor type and diameter:	HIT-HY 200 + HAS-V-36 (ASTM F1554 Gr.36) 7/8	
Item number:	not available (element) / 2022793 HIT-HY 200-R (adhesive)	
Effective embedment depth:	$h_{ef,act} = 8.000$ in. ($h_{ef,limit} = -$ in.)	
Material:	ASTM A 1554 Grade 36	
Evaluation Service Report:	ESR-3187	
Issued Valid:	4/1/2020 3/1/2022	
Proof:	Design Method ACI 318-14 / Chem	
Stand-off installation:	$e_b = 0.000$ in. (no stand-off); $t = 0.750$ in.	
Anchor plate ^R :	$l_x \times l_y \times t = 24.000$ in. x 24.000 in. x 0.750 in.; (Recommended plate thickness: not calculated)	
Profile:	no profile	
Base material:	cracked concrete, 5000, $f'_c = 5,000$ psi; $h = 10.000$ in., Temp. short/long: 32/32 °F	
Installation:	hammer drilled hole, Installation condition: Dry	
Reinforcement:	tension: condition B, shear: condition B; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar	
Seismic loads (cat. C, D, E, or F)	Tension load: yes (17.2.3.4.3 (d)) Shear load: yes (17.2.3.5.3 (c))	

^R - The anchor calculation is based on a rigid anchor plate assumption.

Geometry [in.] & Loading [lb, in.lb]





Hilti PROFIS Engineering 3.0.62

www.hilti.com

Company:	Fortress Structural Engineering	Page:	2
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	07-28-20_20118_ steel support at level 1_support 4_	Date:	7/28/2020
Fastening point:			

1.1 Design results

Case	Description	Forces [lb] / Moments [in.lb]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 10,232; V _x = 3,002; V _y = 4,721; M _x = 112,288; M _y = 116,263; M _z = 0; N _{sus} = 0; M _{x,sus} = 0; M _{y,sus} = 0;	yes	56

Hilti PROFIS Engineering 3.0.62
www.hilti.com

Company:	Fortress Structural Engineering	Page:	3
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjjivani@fortressse.com
Design:	07-28-20_20118_ steel support at level 1_support 4_	Date:	7/28/2020
Fastening point:			

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [lb]		Utilization	Status
		Load	Capacity	β_N / β_V [%]	
Tension	Concrete Breakout Failure	15,121	27,120	56 / -	OK
Shear	Concrete edge failure in direction x+	5,595	17,253	- / 33	OK

Loading	β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads	0.558	0.324	5/3	54	OK

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!

Hilti PROFIS Engineering 3.0.62**www.hilti.com**

Company:	Fortress Structural Engineering	Page:	4
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	07-28-20_20118_ steel support at level 1_support 4_	Date:	7/28/2020
Fastening point:			

4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

Hilti PROFIS Engineering 3.0.62

www.hilti.com

Company:	Fortress Structural Engineering	Page:	1
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	07-28-20_20118_ steel support at level 1_support 4_	Date:	7/28/2020
Fastening point:			


Specifier's comments:

1 Input data

Anchor type and diameter:	AWS D1.1 GR. B 3/4
Item number:	not available
Effective embedment depth:	$h_{ef} = 6.000$ in.
Material:	
Proof:	Design Method ACI 318-14 / CIP
Stand-off installation:	$e_b = 0.000$ in. (no stand-off); $t = 0.750$ in.
Anchor plate ^R :	$l_x \times l_y \times t = 24.000$ in. x 24.000 in. x 0.750 in.; (Recommended plate thickness: not calculated)
Profile:	no profile
Base material:	cracked concrete, 5000, $f'_c = 5,000$ psi; $h = 10.000$ in.
Reinforcement:	tension: condition B, shear: condition B; edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)	Tension load: yes (17.2.3.4.3 (d)) Shear load: yes (17.2.3.5.3 (c))

^R - The anchor calculation is based on a rigid anchor plate assumption.

Geometry [in.] & Loading [lb, in.lb]



Input data and results must be checked for conformity with the existing conditions and for plausibility!
 PROFIS Engineering (c) 2003-2020 Hilti AG, FL-9494 Schaan Hilti is a registered Trademark of Hilti AG, Schaan



Hilti PROFIS Engineering 3.0.62

www.hilti.com

Company:	Fortress Structural Engineering	Page:	2
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	07-28-20_20118_ steel support at level 1_support 4_	Date:	7/28/2020
Fastening point:			

1.1 Design results

Case	Description	Forces [lb] / Moments [in.lb]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 3,096; V _x = 1,119; V _y = 738; M _x = 23,241; M _y = 68,384; M _z = 505;	yes	17

Hilti PROFIS Engineering 3.0.62**www.hilti.com**

Company:	Fortress Structural Engineering	Page:	3
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	07-28-20_20118_ steel support at level 1_support 4_	Date:	7/28/2020
Fastening point:			

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [lb]		Utilization	Status
		Load	Capacity	β_N / β_V [%]	
Tension	Concrete Breakout Failure	5,913	34,806	17 / -	OK
Shear	Pryout Strength	1,340	146,981	- / 1	OK

Loading	β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads	0.170	0.009	5/3	6	OK

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!

Hilti PROFIS Engineering 3.0.62**www.hilti.com**

Company:	Fortress Structural Engineering	Page:	4
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	07-28-20_20118_ steel support at level 1_support 4_	Date:	7/28/2020
Fastening point:			

4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

1. Check 1/4" Weld (C 12x30) to embeded plate-see forces at member(worst case Member M1-Support1)

$$t_w := 0.707 \cdot \frac{1}{4} \text{ in} \quad (\text{Thickness of weld})$$

$$M_{dz} := 69414 \text{ in} \cdot \text{lb} \quad (\text{Moment at z Dir.-M1})$$

$$M_{dy} := 28820 \text{ in} \cdot \text{lb} \quad (\text{Moment at y Dir.})$$

$$V_{dx} := 831 \cdot \text{lb} = 831 \text{ lb} \quad (\text{shear at M1})$$

$$V_{dy} := 2793 \cdot \text{lb} = 2793 \text{ lb} \quad (\text{shear at M1})$$

$$V_{dz} := 782 \cdot \text{lb} = 782 \text{ lb} \quad (\text{shear at M1})$$

$$M_d := M_{dz} + M_{dy} = 98234 \text{ in} \cdot \text{lb} \quad (\text{Total Moment})$$

$$V_d := V_{dx} + V_{dy} + V_{dz} = 4406 \text{ lb} \quad (\text{Total shear})$$

$$b := 2.34 \text{ in} \quad d := 8 \text{ in} \quad (\text{Dimensions of weld})$$

$$S_w := \left(b \cdot d + \frac{d^2}{3} \right) \cdot t_w = 7.1 \text{ in}^3 \quad (\text{Section modulus of weld})$$

$$A_w := t_w \cdot (2 \cdot b + 2 \cdot d) = 3.7 \text{ in}^2 \quad (\text{Area of weld})$$

Stress due to Moment:

$$D_w := \frac{M_d}{S_w} = 14 \text{ ksi}$$

$$C_w := 0.75 \cdot 0.6 \cdot 70 \text{ ksi} = 32 \text{ ksi}$$

$$\frac{D_{wt}}{C_w} = 0.44$$

Stress due to Shear:

$$D_v := \frac{V_d}{A_w} = 1 \text{ ksi}$$

(Weld)

(<1.0 OK, D/C Ratio)

Total stress:

$$D_{wt} := \sqrt{D_w^2 + D_v^2} = 14 \text{ ksi}$$

RISER SUPPORT (DETAIL A)

BY **KJ** DATE 5/26/20**Fortress**JOB NO. 20118**Costco Bolding-5 Garage****Support Riser****Holiday-Parks, Inc****GOVERNING CODES & DESIGN CRITERIA****International Building Code, 2015 edition**

ASCE 7-10 Minimum Design Loads for Buildings and Other Structures

Seismic Coefficients

Elements of Structures and Nonstructural Components and Equipment

Seismic Design Category	E	(Per Plans, S0.01)
Site Class	F	
Importance Factor	1.50	

	Vib.	Stl/Cu	--
Component Importance Factor: $I_p =$	1.50	1.50	(Per Plans, S0.01)
Component Amplification Factor: $a_p =$	2.50	2.50	(Table 13.6-1)
Component Amplification Factor: $R_p =$	2.50	6.00	(Table 13.6-1)
SDS =	0.634		(Eq 11.4-3)

Lateral Force (Section 13.3): **Strength Design**

	$I_p = 1.0$	$I_p = 1.5$	
Horizontal Lower Limit: $F_{ph} = (0.3 SDS I_p) * W_p$	0.190	0.285	Eq. 13.3-3
Upper Limit: $F_{ph} = (1.6 SDS I_p) * W_p$	1.014	1.522	Eq. 13.3-2
Vertical $F_{pv} = +/- 0.2 * SDS * W_p$	0.127	0.127	Eq. 12.4-4
$F_{ph} = (0.4 a_p SDS) * (1 + 2z / h) / (R_p / I_p) W_p$			Eq. 13.3-1

	z	h	Vib.		Stl/Cu		--	
			Eq. 13.3-1	Fph	Eq. 13.3-1	Fph	Eq. 13.3-1	Fph
Level 1	0.0	104.0	0.380	0.380	0.159	0.190		
Level 2	18.0	104.0	0.512	0.512	0.213	0.213		
Level 3	27.0	104.0	0.578	0.578	0.241	0.241		
Level 4	36.0	104.0	0.644	0.644	0.268	0.268		
Level 5	45.0	104.0	0.710	0.710	0.296	0.296		
Level 6	54.0	104.0	0.775	0.775	0.323	0.323		
Level 7	63.0	104.0	0.841	0.841	0.351	0.351		
Level 8	72.0	104.0	0.907	0.907	0.378	0.378		
Level 9	81.0	104.0	0.973	0.973	0.405	0.405		
Level 10	90.0	104.0	1.039	1.014	0.433	0.433		
Roof	104.0	104.0	1.141	1.014	0.476	0.476		

BY **KJ** DATE 7/28/20 **Fortress** JOB NO. **20118**

Costco Bolding-5 Garage **Bracing Riser** **Holiday-Parks,Inc**

20" Steel Pipe **Case 2** **Level 10**

Wp = 123.0 plf **6" Min. Concrete Slab**
Fph = 1.014 *Wp
Fpv = 0.127 *Wp (Worst case)

Tr = 20 ft (Max tributary load For 10th Floor)
P = Fph = 2495 lbs (Total load per angle: Seismic)
P₂ = Fph/2 = **1248 lbs** (Seismic force on one side-per pipe)
T (Dead and Thermal)= **2852 lbs** **(5703 lbs/2, For themal and dead load see Thermal)**

(latest Forces as Per thermal is 5284 lbs at level 8, which is less then original design)



See Risa calculation.

Check Welding

tw = 0.25 in (Weld size)
lw = 3.0 in (Weld length)
Aw = tw*lw = 0.75 in² (Area of weld)
Vc = 0.75*0.6*70ksi*Aw = 23625 lbs (Weld capacity)
V Dead= 5703 lbs (thermal and dead load at 10th floor)
Vd = Fph = 2495 lbs (Shear demand)
D/C = (V_d/V_c) = **0.35 <=1.0 OK**

Check Riser Clamp Capacity



Pd = 5703 lbs (Point load From Thermal calculation-Worst case whole load)
Pc = 8100 lbs (See cutsheet in Appendix)
D/C = (P_d/P_c) = **0.70 <=1.0 OK**



Fortress Structural Engine...
KJ
20118

Rigid Frame



SK - 4
Apr 29, 2020 at 3:56 PM
20118 - Costco Generator Exhaust...



Fortress Structural Engine...
KJ
20118

Rigid Frame

SK - 5
Apr 29, 2020 at 4:01 PM
20118 - Costco Generator Exhaust...





Loads: BLC 1, DL

Fortress Structural Engine...
KJ
20118



Rigid Frame

SK - 1
May 26, 2020 at 11:11 AM
20118 - Costco Generator Exhaust...



Loads: BLC 2, SEIS-X

Fortress Structural Engine...	Rigid Frame	SK - 2
KJ		May 26, 2020 at 11:12 AM
20118		20118 - Costco Generator Exhaust...



Loads: BLC 3, SEIS-Z

Fortress Structural Engine...	Rigid Frame	SK - 3
KJ		May 26, 2020 at 11:12 AM
20118		20118 - Costco Generator Exhaust...

fl `cVUL'A cXY`GYH]b[g

Óã æ Á ^ & cã } • Á Á T ^ { à ^ Á Ó æ & •	I Á
T æ Á Q c } æ Á ^ & cã } • Á Á T ^ { à ^ Á Ó æ & •	J I Á
Q & ^ á ^ Á U @ æ Á ^ & cã } { } æ ð } N	Y ^ •
Q & ^ á ^ Á U @ æ Á ^ & cã } * Á Ó æ æ ð Á Á Y ð á N	Y ^ •
Q & ^ á ^ Á Y æ } ð * N	Y ^ •
V æ • Á æ Á Q c } Q c ^ • Á & cã } * Á Y [[á Á Y æ] N	Y ^ •
Q E ^ á æ S æ Á T ^ • @ Á G á G D	F I I
T ^ Á * ^ Á V ^ á æ } & ^ Á G D	E G
U E D ^ c æ Á Q æ } • á Á V ^ á æ } &	E E € Á
Q & ^ á ^ Á U E D ^ c æ Á Á Y æ } • N	Y ^ •
C E { { æ ð æ ð Á Q ^ á æ Á U cã } ^ • • Á Á Y æ } • N	Y ^ •
T æ Á Q ^ á æ ð } • Á Á Y æ } Á U cã } ^ • •	H
Ó æ æ á Á Q B & ^ ^ á æ } Á G D ^ á G D	H G G
Y æ Á T ^ • @ Ú á ^ Á G D	F G
Ó á ^ } • { } cã } Á Q } ç ^ * ^ } & ^ Á V E G E D E D	I
X ^ c æ Á Q æ á	Y
Ó á æ Á T ^ { à ^ Á U á } c æ ð } Á U æ ^	Y Z
U c æ Á U ç ^	U æ ^ • Á Q B & ^ ^ á æ á
Ó ^ } æ æ Á U ç ^	Q B & ^ ^ á æ á U ç ^

P [á U á Á U c ^ Á Q á ^	Q E U Á F I c @ H I E F E D M S U Z O
Q á b ^ • Á U cã } ^ • • N	Y ^ • Q ^ æ ð ^ Á D
U Q U E D } } ^ & cã } Á Q á ^	Q E U Á F I c @ H I E F E D M S U Z O
Ó á Á Q { } ^ á Á U c ^ Á Q á ^	Q E U Á Q U E F E I K Q U E O
Y [[á Á Q á ^	C E Y Ó Á Q U E F G K Q U E O
Y [[á Á V ^ { } ^ á æ ^	L Á F E E O
Ó } & ^ á c Á Q á ^	Q E Q Á F I E F
T æ [] ^ Á Q á ^	Q E Q Á H E E F F K Q U E O
Q E { } ð ^ { } Á Q á ^	Q E Q Á Q T F I E F K Q U E O Á Q ^ á æ * Q E U Á F I c @ H I E F E D M S U Z O

P ^ { à ^ Á Á U @ æ Á ^ * ð } •	I
U ^ * ð } Á U æ ð * Á Q & ^ { ^ } cã } D	I
Ó æ cã Á Q { } Á T ^ c @ á	Q c æ c Á Q c ^ æ ð }
U æ { ^ Á Q ^ c æ Á c æ ç Á Q U O E D	E I
Ó } & ^ á c Á U c ^ • • Á Q &	U ^ & cã } * ^ æ
W ^ Á Q æ ð ^ á Á U ^ & cã } • N	Y ^ •
W ^ Á Q æ ð ^ á Á U ^ & cã } • Á U æ ð N	P [
Ó æ Á Q æ ð ð * Á Y æ } ð * • N	P [
W ^ • á Á Q & ^ Á Y æ } ð * • N	Y ^ •
T ð Á Á Q æ Á Q æ ð Á U æ ð * N	P [
Ó } & ^ á c Á U ^ á æ Á U c	U Ó O C E U ' U Ó V ' C E U V T Q E F I
T ð Á Á U c ^ Á Á Q { } }	F
T æ Á Á U c ^ Á Á Q { } }	I

www.hilti.com

Company:	Fortress Structural Engineering	Page:	1
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortresse.com
Design:	end support_N1 - Option 2- EMBEDDED PLATE FOR	Date:	5/26/2020
Fastening point:			

Specifier's comments:


1 Input data

Anchor type and diameter:	AWS D1.1 GR. B 3/4
Item number:	not available
Effective embedment depth:	$h_{ef} = 4.500$ in.
Material:	
Proof:	Design Method ACI 318-14 / CIP
Stand-off installation:	$e_b = 0.000$ in. (no stand-off); $t = 0.500$ in.
Anchor plate ^R :	$l_x \times l_y \times t = 12.000$ in. x 12.000 in. x 0.500 in.; (Recommended plate thickness: not calculated)
Profile:	no profile
Base material:	cracked concrete, 5000, $f'_c = 5,000$ psi; $h = 6.000$ in.
Reinforcement:	tension: condition B, shear: condition B; edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)	Tension load: yes (17.2.3.4.3 (d)) Shear load: yes (17.2.3.5.3 (c))



^R - The anchor calculation is based on a rigid anchor plate assumption.

Geometry [in.] & Loading [lb, in.lb]



Input data and results must be checked for conformity with the existing conditions and for plausibility!
 PROFIS Engineering (c) 2003-2019 Hilti AG, FL-9494 Schaan Hilti is a registered Trademark of Hilti AG, Schaan



Hilti PROFIS Engineering 3.0.60

www.hilti.com

Company:	Fortress Structural Engineering	Page:	2
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	end support_N1 - Option 2- EMBEDDED PLATE FOR	Date:	5/26/2020
Fastening point:			

1.1 Design results

Case	Description	Forces [lb] / Moments [in.lb]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 1,971; V _x = 1,560; V _y = 1,560; M _x = 0; M _y = 23,340; M _z = 18,720;	yes	91

Hilti PROFIS Engineering 3.0.60**www.hilti.com**

Company:	Fortress Structural Engineering	Page:	3
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	end support_N1 - Option 2- EMBEDDED PLATE FOR	Date:	5/26/2020
Fastening point:			

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [lb]		Utilization	Status
		Load	Capacity	β_N / β_V [%]	
Tension	Concrete Breakout Failure	4,042	12,300	33 / -	OK
Shear	Concrete edge failure in direction x+	2,942	3,502	- / 84	OK

Loading	β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads	0.329	0.840	5/3	91	OK

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!

Hilti PROFIS Engineering 3.0.60**www.hilti.com**

Company:	Fortress Structural Engineering	Page:	4
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	end support _N1 - Option 2- EMBEDDED PLATE FOR	Date:	5/26/2020
Fastening point:			

4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

Hilti PROFIS Engineering 3.0.60

www.hilti.com

Company:	Fortress Structural Engineering	Page:	1
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortresse.com
Design:	Riser_end support_N2-N3 - Option 2- EMBEDDED PL	Date:	5/26/2020
Fastening point:			

Specifier's comments:


1 Input data

Anchor type and diameter:	AWS D1.1 GR. B 3/4
Item number:	not available
Effective embedment depth:	$h_{ef} = 4.500$ in.
Material:	
Proof:	Design Method ACI 318-14 / CIP
Stand-off installation:	$e_b = 0.000$ in. (no stand-off); $t = 0.500$ in.
Anchor plate ^R :	$l_x \times l_y \times t = 12.000$ in. x 12.000 in. x 0.500 in.; (Recommended plate thickness: not calculated)
Profile:	no profile
Base material:	cracked concrete, 5000, $f'_c = 5,000$ psi; $h = 6.000$ in.
Reinforcement:	tension: condition B, shear: condition B; edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)	Tension load: yes (17.2.3.4.3 (d)) Shear load: yes (17.2.3.5.3 (c))



^R - The anchor calculation is based on a rigid anchor plate assumption.

Geometry [in.] & Loading [lb, in.lb]



Input data and results must be checked for conformity with the existing conditions and for plausibility!
PROFIS Engineering (c) 2003-2019 Hilti AG, FL-9494 Schaan Hilti is a registered Trademark of Hilti AG, Schaan



Hilti PROFIS Engineering 3.0.60

www.hilti.com

Company:	Fortress Structural Engineering	Page:	2
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	Riser_end support _N2-N3 - Option 2- EMBEDDED PL	Date:	5/26/2020
Fastening point:			

1.1 Design results

Case	Description	Forces [lb] / Moments [in.lb]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 3,943; V _x = 3,120; V _y = 3,120; M _x = 0; M _y = 0; M _z = 0;	yes	93

Hilti PROFIS Engineering 3.0.60**www.hilti.com**

Company:	Fortress Structural Engineering	Page:	3
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	Riser_end support _N2-N3 - Option 2- EMBEDDED PL	Date:	5/26/2020
Fastening point:			

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [lb]		Utilization	Status
		Load	Capacity	β_N / β_V [%]	
Tension	Concrete Breakout Failure	3,943	17,512	23 / -	OK
Shear	Concrete edge failure in direction x+	4,412	4,895	- / 91	OK

Loading	β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads	0.225	0.901	5/3	93	OK

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!

Hilti PROFIS Engineering 3.0.60**www.hilti.com**

Company:	Fortress Structural Engineering	Page:	4
Address:		Specifier:	Kavita Jivani
Phone Fax:	408-841-4848	E-Mail:	kjivani@fortressse.com
Design:	Riser_end support _N2-N3 - Option 2- EMBEDDED PL	Date:	5/26/2020
Fastening point:			

4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

STANCHION SUPPORT (DETAIL B)

Support B, 20" Pipe -Stanchion

1. Seismic Design Criteria

Governing Code IBC 2015/ ASCE 7-10

$$a_p := 2.5 \quad R_p := 2.5 \quad (\text{Table 13.6-1, High Deform. Piping})$$

$$I_p := 1.5 \quad (\text{See Appendix})$$

$$S_{DS} := 0.634 = 0.63 \quad (\text{See Appendix})$$

$$z := 18 \cdot \text{ft} \quad (\text{Location: Level 1})$$

$$h := 104 \cdot \text{ft} \quad (\text{Height of structure above ground})$$

Horizontal Seismic Design Coefficients: Strength Design

$$F_{phc} := \left(\frac{0.4 \cdot a_p \cdot S_{DS}}{\left(\frac{R_p}{I_p} \right)} \right) \cdot \left(1 + 2 \cdot \frac{z}{h} \right) = 0.512 \quad (\text{Eq: 13.3-1}) \quad \text{Controls}$$

$$F_{phUc} := 1.6 \cdot S_{DS} \cdot I_p = 1.522 \quad (\text{Eq: 13.3-2, Upper Limit})$$

$$F_{phLc} := 0.3 \cdot S_{DS} \cdot I_p = 0.285 \quad (\text{Eq: 13.3-3, Lower Limit})$$

Vertical Seismic Design Coefficients: Strength Design

$$F_{pvc} := 0.2 \cdot S_{DS} = 0.127 \quad (\text{Eq: 12.4-4})$$

2A. Design Loads

$$OD_1 := 20 \text{ in} \quad (\text{Outside diameter of pipe})$$

$$W := 123 \text{ plf} \quad (\text{See Appendix})$$

$$b_1 := 13 \text{ ft} \quad (\text{Max tributary spacing of supports})$$

$$W_2 := W \cdot b_1 = 1599 \text{ lbf} \quad (\text{Weight on support})$$

$$F_{ph} := F_{phc} \cdot W_2 = 819 \text{ lbf} \quad (\text{Horizontal seismic load})$$

$$F_{pv} := F_{pvc} \cdot W_2 = 203 \text{ lbf} \quad (\text{Vertical seismic load})$$

$$W_p := 2081 \cdot \text{lbf} = 2081 \text{ lbf} \quad (\text{See -thermal and dead load Calc})$$

2B. Wind Loads

(No wind load, Support indoor)

3. Check 4 in Dia Stl Post

$$d_1 := 36 \text{ in} \quad F_y := 35 \text{ ksi} \quad z := 4.05 \text{ in}^3 \quad (\text{See diagram / Yield Strength / Section Modulus})$$

$$M_{d1} := F_{ph} \cdot d_1 = 29477 \text{ lbf} \cdot \text{in} \quad (\text{Moment Demand})$$

$$M_c := 0.9 \cdot z \cdot F_y = 127575 \text{ lbf} \cdot \text{in} \quad (\text{Moment Capacity})$$

$$DC := \frac{M_{d1}}{M_c} = 0.23 \quad (<1.0 \text{ OK, D/C Ratio})$$

Compression:

$$P_{ad} := 1.2 \cdot W_p + F_{pv} = 2700 \text{ lbf} \quad (\text{Axial load on brace})$$

$$K := 2.0 \quad r := 1.51 \text{ in} \quad A_g := 2.97 \text{ in}^2 \quad E := 29000 \cdot \text{ksi} \quad (\text{Effective length factor / Radius of gyration / Cross sectional area / Modulus of elasticity})$$

$$KL_r := \frac{K \cdot d_1}{r} = 48 \quad (< 200 \text{ OK}) \quad F_e := \frac{\pi^2 \cdot E}{(KL_r)^2} = 126 \text{ ksi} \quad EF_y := \frac{E}{F_y} \quad F_y F_e := \frac{F_y}{F_e}$$

$$KL_r \leq 4.71 \cdot \sqrt{EF_y} = 1 \quad \text{or} \quad F_e > 0.44 \cdot F_y = 1 \quad F_{cr1} := (0.658^{F_y/F_e}) \cdot F_y = 31 \text{ ksi}$$


$$KL_r > 4.71 \cdot \sqrt{EF_y} = 0 \quad \text{or} \quad F_e < 0.44 \cdot F_y = 0 \quad F_{cr2} := 0.877 F_e = 110 \text{ ksi} \quad (\text{Equation: 0=Doesnt control, 1=controls})$$

$$P_{ac} := 0.9 \cdot F_{cr1} \cdot A_g = 83 \text{ kip} \quad (\text{Pipe support axial capacity})$$

$$DC := \frac{P_{ad}}{P_{ac}} = 0.03 \quad (<1.0 \text{ OK, D/C Ratio})$$

Combined loading:

$$DC := \frac{P_{ad}}{2 \cdot P_{ac}} + \left(\frac{M_{d1}}{M_c} \right) = 0.25 \quad (<1.0 \text{ OK, D/C Ratio, 14th AISC, Eq. H1-1b})$$



4. Check 1/4" Weld at Baseplate

$$t_w := 0.707 \cdot \frac{1}{4} \text{ in}$$

(Thickness of weld)

$$OD := 4.5 \text{ in}$$

(Outside diameter of post)

$$S_w := \pi \cdot \left(\frac{OD}{2}\right)^2 \cdot t_w = 2.8 \text{ in}^3$$

(Section modulus of weld)

$$S_p := 3.03 \text{ in}^3$$

(Section modulus of post: 14th AISC, P. 1-101)

$$A_w := t_w \cdot OD = 0.8 \text{ in}^2$$

(Area of weld)

$$A_p := 2.97 \text{ in}^2$$

(Area of post: 14th AISC, P. 1-101)

Stress due to Moment:

$$D_w := \frac{M_{d1}}{S_w} = 10 \text{ ksi}$$

Stress due to Shear:

$$D_v := \frac{F_{ph} + P_{ad}}{A_w} = 4 \text{ ksi}$$

Total stress:

$$D_{wt} := \sqrt{D_w^2 + D_v^2} = 11 \text{ ksi}$$

$$D_p := \frac{M_{d1}}{S_p} = 10 \text{ ksi}$$

$$D_v := \frac{F_{ph} + P_{ad}}{A_p} = 1 \text{ ksi}$$

$$D_{pt} := \sqrt{D_p^2 + D_v^2} = 10 \text{ ksi}$$

$$C_w := 0.75 \cdot 0.6 \cdot 70 \text{ ksi} = 32 \text{ ksi} \quad (\text{Weld})$$

$$C_p := 0.75 \cdot 35 \text{ ksi} = 26 \text{ ksi} \quad (\text{post})$$

$$\frac{D_{wt}}{C_w} = 0.36 \quad (<1.0 \text{ OK, D/C Ratio})$$

$$\frac{D_{pt}}{C_p} = 0.37 \quad (<1.0 \text{ OK, D/C Ratio})$$

5. Base Plate Design

$$F_y := 36 \text{ ksi}$$

(Yield strength of plate)

$$t_p := 0.5 \text{ in}$$

(Baseplate thickness)

$$l_p := 8 \text{ in}$$

(Baseplate length)

$$OD := OD = 4.5 \text{ in}$$

(Outside diameter of post)

$$d_1 := 1.125 \text{ in}$$

(Distance from edge of plate to C.L. of bolt holes)

$$z := \frac{1}{4} \cdot l_p \cdot (t_p)^2 = 0.5 \text{ in}^3$$

(Section modulus of plate)

$$T_d := P_{ad} = 2700 \text{ lbf}$$

(Tension demand: From package 1)

$$d := \frac{l_p - OD}{2} - d_1 = 0.625 \text{ in}$$

(Lever arm distance: C.L. of bolt hole to face of post)

$$M_d := T_d \cdot d = 1687 \text{ in} \cdot \text{lbf}$$




(Moment demand)

$$M_c := 0.9 \cdot z \cdot F_y = 16200 \text{ in} \cdot \text{lbf}$$

(Moment capacity)

$$DC := \frac{M_d}{M_c} = 0.10$$

<1.0 OK, D/C Ratio)





999 Lake Dr, Issaquah,
WA 98027

COSTCO BLDG-5 GARAGE

LEVEL 1 SOUTH SUBMITTAL EXHAUST ROUTING SUPPORT

STRUCTURAL CALCULATION NOTE FOR THE Thermal Expansion of the Generators' Exhaust Pipe

Ver.	Date	Description	Designed by	Verified by	Approved by
D6	7/16/2020	Changes the design temperature to 1000 degrees	Amin Ghafooripour, PhD		Marcus Oden
D5	4/30/2020	Adding new bellows to the muffler	Amin Ghafooripour, PhD		Marcus Oden
D4	4/26/2020	Issue for comment	Amin Ghafooripour, PhD		Marcus Oden
D3	4/14/2020	Issue for comment	Amin Ghafooripour, PhD		Marcus Oden
D2	4/8/2020	Issue for comment	Amin Ghafooripour, PhD		Marcus Oden
D1	4/6/2020	Issue for comment	Amin Ghafooripour, PhD		
D0	3/28/2020	Interim Report/ not completed yet Only for the review of the criteria	Amin Ghafooripour, PhD		



CONTENTS

.1	BACKGROUND AND PURPOSE OF DOCUMENT.....	3
2.	CRITERIA OF THE THERMAL EXPANSION EVALUATION	9
2.1	THERMAL ANALYSIS OF PIPES FOR THE FEASIBILITY OF A PIPE SYSTEM WITHOUT THERMAL EXPANSIONS	9
2.2	DESIGN OF THE THERMAL EXPANSION SYSTEM	13
3.	ESTIMATION OF THE THERMAL FORCES ON THE STRUCTURAL SUPPORTS (HORIZONTAL PIPES).....	17
3.1	ESTIMATION OF THE LATERAL LOAD ON SUPPORT A	17
3.2	ESTIMATION OF THE LATERAL LOAD ON SUPPORT B & C	21
3.3	ESTIMATION OF THE SUPPORT REACTION IN THE VERTICAL RISERS	24
4.	CHECK THE REQUIREMENTS FOR THE MINIMUM SPACING BETWEEN VERTICAL RISERS	27
5.	CONCLUSION	28


1. BACKGROUND AND PURPOSE OF DOCUMENT

This calculation note presents the statutorily required design calculations for the “thermal analysis of Generator Exhaust pipe.”

Fortress Structural Engineering Inc. is in charge of this design. The contractor delivered all required dimensions, and the design calculations are conducted following the proposed drawings and given information.

Pipe materials and design temperature:

Temperature variation= 1000F



Pipe diameter= 20"
Schedule 40

Application & Performance Warranty Data

Project Information

Site Location:	Washington
Project Name:	Costco Bldg 5 - 3500KW's
Application:	Standby Power
Number Of Engines:	3
Operating Hours per Year:	50

Engine Specifications

Engine Manufacturer:	Cummins
Model Number:	QSK95-G9
EPA Engine Family:	JCEXL95.0AAA-006
Rated Speed:	1800 RPM
Type of Fuel:	Ultra-Low Sulfur Diesel (ULSD)
Type of Lube Oil:	1 wt% sulfated ash or less
Lube Oil Consumption:	0.1 % Fuel Consumption
Number of Exhaust Manifolds:	1

DOC/DPF System Specifications (LTR81-81-20-XR2)

Design Exhaust Flow Rate:	24,975 acfm (cfm)
Design Exhaust Temperature ¹ :	914°F
System Pressure Loss:	15.0 inches of WC (Clean) (34.9 mBar)
Sound Attenuation:	Critical Grade
Minimum Regeneration Temperature ² :	500°F (260°C)

As per the given information:

SUBMITTAL REVIEW COVERSHEET



- Structural engineer to verify basis for Temperature Variation = 200°F (shown on page 104 of 145 and page 116 of 145) that is utilized for thermal expansion calculations. Per generator submittal design exhaust temperature is equal to 914°F (see cutsheet from generator submittal on next page). Generator system is designed for continuous operations with onsite fuel storage for 24+ hours. Rushing would anticipate a temperature differential of approximately 1000°F based on calculations submitted for past projects.

EXHAUST TERMINATION NOTES:

1. OUTLET TO BE DIRECTED TOWARD NE AND ANGLED UP AT 45
2. EXHAUST TERMINATION TO BE LOCATED TO MAINTAIN MINIMUM CLEARANCES PER CODE SUMMARY - NOTE #9 AT RIGHT.




Table I-1 Allowable Stresses

Material	Spec. No.	Type or Grade	Class	P-No.	Notes	Factor E or F	Strengths		Max. Allowable Stress Value in Tension SE, ksi, for Metal Temperature, °F, Not Exceeding										
							Min. Tensile, ksi	Min. Yield, ksi	0 to 100	150	200	250	300	350	400				
Carbon Steel																			
Seamless Pipe and Tube																			
...	ASTM A53	A	S	1	...	1.00	48.0	30.0	13.7	13.7	13.7	13.7	13.7	13.7	13.7				
...	ASTM A53	B	S	1	...	1.00	60.0	35.0	17.1	17.1	17.1	17.1	17.1	17.1	17.1				
...	ASTM A106	A	...	1	...	1.00	48.0	30.0	13.7	13.7	13.7	13.7	13.7	13.7	13.7				
...	ASTM A106	B	...	1	...	1.00	60.0	35.0	17.1	17.1	17.1	17.1	17.1	17.1	17.1				
...	API 5L	A	...	1	(1)	1.00	48.0	30.0	13.7	13.7	13.7	13.7	13.7	13.7	13.7				
...	API 5L	B	...	1	(1)	1.00	60.0	35.0	17.1	17.1	17.1	17.1	17.1	17.1	17.1				
Butt Welded Pipe and Tube																			
...	ASTM A53	...	F	1	(2)	0.60	48.0	30.0	8.2	8.2	8.2	8.2	8.2	8.2	8.2				
...	API 5L	A25	...	1	(1)	0.60	45.0	25.0	7.7	7.7	7.7	7.7	7.7	7.7	7.7				
Electric Resistance Welded Pipe and Tube																			
...	ASTM A53	A	E	1	...	0.85	48.0	30.0	11.7	11.7	11.7	11.7	11.7	11.7	11.7				
...	ASTM A53	B	E	1	...	0.85	60.0	35.0	14.6	14.6	14.6	14.6	14.6	14.6	14.6				
...	ASTM A135	A	...	1	...	0.85	48.0	30.0	11.7	11.7	11.7	11.7	11.7	11.7	11.7				

Capacity of the pipe at the temperature of 1000 F:

The material is A53 with $F_y=35000$ psi. The relation between the temperature and modulus of elasticity and yield point is shown in the following reference:





X.6 STEEL PROPERTIES AT ELEVATED TEMPERATURES


Steel properties, like those of other conventional construction materials, degrade with increases in temperature. The influence of elevated temperatures on the modulus of elasticity (E_m) and the yield strength (F_{ym}) of steel is presented in Table X.1 as a ratio of the value at the elevated temperature to the value at 68 °F (20 °C)⁷.

Steel Temperature °F [°C]	E_m/E	F_{ym}/F_y
68 [20]	1.00	1.00
200 [93]	1.00	1.00
400 [204]	0.90	1.00
600 [316]	0.78	1.00
750 [399]	0.70	1.00
800 [427]	0.67	0.94
1,000 [538]	0.49	0.66
1,200 [649]	0.22	0.35
1,400 [760]	0.11	0.16
1,600 [871]	0.07	0.07
1,800 [982]	0.05	0.04
2,000 [1,090]	0.02	0.02
2,200 [1,200]	0.00	0.00

For the maximum temperature of 1000F (538 C) a reduction factor of 0.66 is expected.
So, $F_y@1000F = 0.66 * 14600 = 9636$ psi







Schedule 40 Pipe Dimensions											
Size Inches	Diameters			Transverse Areas			Length of Pipe per Sq. Foot of		Cubic Feet per Foot of Pipe	Weight per Foot Pounds	Number Threads per Inch of Screw
	External Inches	Internal Inches	Nominal Thickness	External Sq. Ins.	Internal Sq. Ins.	Metal Sq. Ins.	External Surface Feet	Internal Surface Feet			
1/8	.405	.269	.068	.129	.057	.072	9.431	14.199	.00039	.244	27
1/4	.540	.364	.088	.229	.104	.125	7.073	10.493	.00072	.424	18
3/8	.675	.493	.091	.358	.191	.167	5.658	7.747	.00133	.567	18
1/2	.840	.622	.109	.554	.304	.250	4.547	6.141	.00211	.850	14
3/4	1.050	.824	.113	.866	.533	.333	3.637	4.635	.00370	1.130	14
1	1.315	1.049	.133	1.358	.864	.494	2.904	3.641	.00600	1.678	11 1/2
1 1/4	1.660	1.380	.140	2.164	1.495	.669	2.301	2.767	.01039	2.272	11 1/2
1 1/2	1.900	1.610	.145	2.835	2.036	.799	2.010	2.372	.01414	2.717	11 1/2
2	2.375	2.067	.154	4.430	3.355	1.075	1.608	1.847	.02330	3.652	11 1/2
2 1/4	2.875	2.469	.203	6.492	4.788	1.704	1.326	1.547	.03325	5.793	8
3	3.500	3.068	.216	9.621	7.393	2.228	1.091	1.245	.05134	7.575	8
3 1/2	4.000	3.548	.226	12.56	9.886	2.680	.954	1.076	.08866	9.109	8
4	4.500	4.026	.237	15.90	12.73	3.174	.848	.948	.08840	10.790	8
5	5.563	5.047	.256	24.30	20.00	4.300	.686	.756	.1389	14.61	8
6	6.625	6.065	.280	34.47	28.89	5.581	.576	.629	.2006	18.97	8
8	8.625	7.981	.322	58.42	50.02	8.399	.442	.478	.3552	28.55	8
10	10.750	10.020	.365	90.76	78.85	11.90	.355	.381	.5476	40.48	8
12	12.750	11.938	.406	127.64	111.9	15.74	.299	.318	.7763	53.6	
14	14.000	13.125	.437	153.94	135.3	18.64	.272	.280	.9354	63.0	
16	16.000	15.000	.500	201.05	176.7	24.35	.238	.254	1.223	78.0	
18	18.000	16.874	.563	254.85	224.0	30.85	.212	.226	1.555	105.0	
20	20.000	18.814	.593	314.15	278.0	36.15	.191	.203	1.926	123.0	
24	24.000	22.626	.687	452.40	402.1	50.30	.159	.169	2.793	171.0	

2. CRITERIA OF THE THERMAL EXPANSION EVALUATION



As per the given information, the following criteria shall be considered:

- 1- The lateral force on the pipe support is estimated based on the pipe expansion.
- 2- Thermal expansion is considered shall be estimated for the vertical riser.
- 3- The maximum expansion of each line is related to the amount of the bending moment of the perpendicular line. The excess bending moment in the perpendicular line should not exceed the capacity of the pipe.
- 4- In the straight lines, where the pipe clamps were considered, the amount of expansion shall be less than the threshold of the excess stresses in the pipe hangers.
- 5- Seismic braces are not in the scope of work.
- 6- Design temperature variation is given equal to 1000F (according to Rushing company suggestion and experiences)
- 7- Thermal expansion coefficient= 0.0000065

EXPANSION CALCULATIONS AND LOOP SIZING


In a bonded system, the carrier pipe, foam insulation, and outer protective jacket are joined together forming one cohesive unit that expands and contracts together. Thermal expansion of the carrier pipe during operation is therefore transferred to the polyurethane foam and outer jacket. These movements are naturally restricted to a certain extent by the friction between the soil and jacket. In extreme cases, the force of friction can become so great that free expansion cannot occur and the unit becomes "fixed" into place. In such a case, the opposing force from thermal expansion can place impermissibly high stresses in the carrier pipe. Therefore, free expansion must be allowed to occur, but expansion must ultimately be compensated for through system design. The most common method is the inclusion of expansion elbows, loops, or z-bends.

Thermal expansion will occur between all fixed points in the piping system. If the system has the same covering height, natural fixed points will occur in the center of a line section between two expansion elbows. Unequal covering will cause the fixed point to be displaced due to varying frictional forces, and if there is any doubt, the fixed point should be set with an anchor. In all cases, this fixed point should be considered when calculating expansion.



2.1 THERMAL ANALYSIS OF PIPES FOR THE FEASIBILITY OF A PIPE SYSTEM WITHOUT THERMAL EXPANSIONS

To find the maximum allowable length of each line between loops and the bends, we need to find the moment capacity of the pipes and then relate it to the amount of the expansion.



Calculator for Moment of Inertia of Hollow circular section

This calculator gives the values of moment of inertia as well as the values of section modulus about x-axis and y-axis of the section. Section modulus helps in determining the strength of the beam. Please enter the "Input Values" in the form given below and click "Calculate". You should enter all the values in same units and this calculator will provide the "Output Results" in the corresponding units (unit² , unit³ , unit⁴ etc.). You can also visit [Instructions for Moment of Inertia Calculator](#)

Input Values

Outer Diameter of section (unit):

Inner Diameter of section (unit):

Please make sure that all the values are positive and the outer diameter is bigger than the inner diameter

Output Results


Area of section (unit ²):	36.2727502384
Position of centroid - Xc (unit):	10
Position of centroid - Yc (unit):	10
Moment of Inertia Ixx (unit ⁴):	1708.93644506
Moment of Inertia Iyy (unit ⁴):	1708.93644506
Section Modulus Zxx (unit ³):	170.893644506
Section Modulus Zyy (unit ³):	170.893644506
Radius of gyration rxx (unit):	6.86392790245
Radius of gyration ryy (unit):	6.86392790245

Resistive bending moment of the pipe at 1000F with Fy= 9636 psi= Mr=9636*170.89/12=137.2 kip-ft

Check the effect of the elbow and the side of the loop.

The connection at an elbow is similar to the model of a cantilever beam,

Figure 13 Cantilever Beam – Concentrated Load at Free End



$$R = V \dots \dots \dots = P$$

$$M_{max} \text{ (at fixed end)} \dots \dots \dots = P\ell$$

$$M_x \dots \dots \dots = Px$$


$$\Delta_{max} \text{ (at free end)} \dots \dots \dots = \frac{P\ell^3}{3EI}$$

$$\Delta_x \dots \dots \dots = \frac{P}{6EI} (2\ell^3 - 3\ell^2x + x^3)$$

The goal is to find the relation between the maximum possible of the straight length to the maximum reasonable length of the perpendicular pipe.




To find this relation, we analyzed different models of the exhaust pipes with a computer to understand the internal forces:

Case 1, short exhaust length






The length of the elbow is short, and because of the high moment of Inertia that increases the stiffness, the moment at the elbow and thus the lateral force of the support is more than the standard thresholds, so we need use thermal expansion.

The computer model shows the forces:



$M = 14022537 \text{ lb-ft}$, $F_b = M / 170.89 * 12 = 984671.09 \gg 9636 = \text{capacity @ } 1000 \text{ F}$

Case 2, the longest exhaust length




$M = 657109 \text{ lb-ft}$, $F_b = M / 170.89 * 12 = 46142 \gg 9636 = \text{capacity @ } 1000F$

Conclusion: As per the above analysis, it is not feasible to use the elbows to release the thermal stresses, and based on this investigation, we need to use the thermal expansion.

2.2 DESIGN OF THE THERMAL EXPANSION SYSTEM

Every emergency generator application includes an exhaust system designed to route exhaust gases out of the engine room. These exhaust systems consist of piping, elbows, and, very importantly, flexible sections that must be used to account for the engine's vibration, and also for the pipe growth experienced as the engine runs and the exhaust gases quickly rise to 800°F and more. If the exhaust piping were to be installed rigidly, you can be sure that cracks will develop at the weakest point, usually at the engine's outlet flanges, or at silencer inlet/outlet connections. Having a flexible connector between the engine and the silencer seems to be well understood.

A typical generator system shall be designed with the following features:



Assumptions:


- 1- The silencer is not rigidly mounted to the engine
- 2- Between the silencer and the engine, exhaust flex shall be used in accordance with the generator guidelines.
- 3- The design of the flexible connection is not in the scope of work and contractor to follow the vendors specs. To install the flex between engine and silencer. See also the note below:

Note on the Flex:

In most cases, the exhaust piping seems to rely on the flexible connector to absorb all movements in the piping system. The flexible connector is not designed for this, and the consequences are almost always evident in premature gas leaks due to cracked flanges in the flexible connector. Flexible connectors are intended to absorb or isolate high frequency, low amplitude engine vibration (fast but small movements) from the rest of the exhaust piping. They are NOT designed to compensate for or absorb pipe expansion, nor are they designed to “make up” for major mis-alignments in the exhaust piping. If the flexible connector between the engine and the silencer seems compressed or “[s-shaped](#)” in its idle state, it is not installed correctly. Flexible connectors are made up of flexible hose, which is typically constructed of a single ply of relatively small corrugations that allow the material to move with vibration. The corrugations aren't designed to compress; over time the flex will fail if it is operated under compression.

Conclusion on the Thermal system:

Therefore as per the standard design procedure, we need to design the Bellows (Expansion joint after the silencer for both horizontal and vertical directions as shown below:



Note on the Bellows:

Bellows, or expansion joints, are much more flexible than flexible connectors. Bellows are designed to absorb pipe expansion. The corrugations are larger and, therefore, able to compress more. They are generally better able to handle lateral movement as well, so they can better tolerate pipe misalignment. Because they are more flexible, they can provide expansion absorption and vibration isolation in a shorter length than a flexible connector.




Thermal, Vibration, Noise & Seismic Solutions For Pipes

[About Us](#) [En Español](#) [Rep Login](#) 800-621-4347



Exhaust Piping Expansion Joints for engine exhaust systems up to 1,200°F



PART NO	PIPE SIZE	ID (IN)	OAL (IN)	AXIAL COMP (IN)	LATERAL OFFSET (IN)	AXIAL SPRING RATE (LB/IN)	LATERAL SPRING RATE (LB/IN)	WEIGHT (LB)
EX300400	4	4.50	12.00	3	1	46	22	17
EX300500	5	5.56	12.00	3	1	66	47	20
EX300600	6	6.63	12.00	3	1	82	80	23
EX300800	8	8.61	12.00	3	1	103	165	31
EX301000	10	10.75	12.00	3	1	103	248	39
EX301200	12	12.75	12.00	3	0.875	121	405	55
EX301400	14	14.00	12.00	3	0.750	132	530	66
EX301600	16	16.00	12.00	3	0.625	150	777	77
EX301800	18	18.00	12.00	3	0.500	168	1092	80
EX302000	20	20.00	12.00	3	0.500	186	1480	93
EX302200	22	22.00	12.00	3	0.500	204	1952	97
EX302400	24	24.00	12.00	3	0.500	222	2513	124

For the EX302000 (20" pipe), the axial spring stiffness = 186 lb/in


Also the maximum expansion rate= 3"

Lateral stiffness= 1480 lb/in

Lateral offset=0.5"

Maximum horizontal length= 39'

Maximum vertical length = 150.5'-70.5'=80'



The direction of the thermal expansion is shown in the picture.

The maximum expected expansion in the horizontal lines= 3.04” > 3”, so we need to use (2) Bellows

Online Thermal Linear Expansion Calculator

L_0 - initial length of object (m, inches)

α - linear expansion coefficient (m/m°C, in/in°F)

t_0 - initial temperature (°C, °F)

t_1 - final temperature (°C, °F)

www.engineeringtoolbox.com says
 Change in Length of object - dL (m, inches) : 3.042
 Final length of object - L1 (m, inches) : 471.042

The maximum expected expansion in the vertical riser= 6.24” > 3”, so we need (3) Bellows for the vertical riser

Online Thermal Linear Expansion Calculator

L_0 - initial length of object (m, inches)

α - linear expansion coefficient (m/m°C, in/in°F)

t_0 - initial temperature (°C, °F)


t_1 - final temperature (°C, °F)

www.engineeringtoolbox.com says
 Change in Length of object - dL (m, inches) : 6.24
 Final length of object - L1 (m, inches) : 966.24

So, the maximum thermal expansion of one bellow= 3” so we will use model EX302000.

3. ESTIMATION OF THE THERMAL FORCES ON THE STRUCTURAL SUPPORTS (HORIZONTAL PIPES)

As per the below picture and the computer model results, we need to add thermal expansion between the vertical riser and the silencer for all three lines.



Therefore, the thermal expansion forces will be reduced, and thus the lateral pressure on the pipe supports A, B, and C.

3.1 ESTIMATION OF THE LATERAL LOAD ON SUPPORT A

By adding a bellow (expansion joint), we can analyze the pipeline by adding the equivalent stiffness of the bellow to the pipeline. To simulate the stiffness, we can add an element with the unit length and create the equivalent stiffness of the expansion, as shown below:

$$F=K.D$$

$$D=PL/AE,$$

K for the axial element = AE/L , assuming 1' for the element, then $K= A.E= 186 \text{ lb/in}= 2232 \text{ lb/ft}$

Assuming the same E in the program= 4176000000, then the equivalent $A= 0.00000053$

Equivalent moment of Inertia can be estimated like a beam:


$$K=12EI/L^3, L=1' = 12EI = \text{Lateral stiffness}= 1480 \text{ lb/in}= 17760 \text{ lb/ft}$$

Assuming the same E in the program= 4176000000, then $I= 0.000000354$




The corner support should be a free node, and the expansion should be installed between the elbow and the roller support.

For 1000F of temperature variation, we need to use (2) Bellows as per the previous calculations:



Thermal expansion= Element #10 and #12




Lateral displacement (y direction) = $0.06' = 0.72'' < 3''$ OK to use one bellow in vertical direction


Node 13 longitudinal expansion (x-direction (node 12 & 13)) = $0.094' + 0.025' = 1.43'' < 3''$ for each bellows OK

Lateral offset of the Bellow (node #13) = $0.008 - 0.000012 = 0.0081' = 0.09'' < 0.5''$ (maximum allowed lateral offset of the Bellows) OK

So, the model is confirmed.



M_{max} = 641.22 lb-ft < 137.2 kip-ft @ 1000F OK



Vmax.= 145.73 lbs < capacity @ 1000F




Axial load= 145.73 lbs < capacity @ 1000F




Reaction forces

3.2 ESTIMATION OF THE LATERAL LOAD ON SUPPORT B & C

Using the same criteria for the support A, the below pictures shows the analysis results for the pipe with the thermal expansion:




Thermal expansion was modeled as element #2




Node 5 lateral displacement (y direction)= $0.026' = 0.3'' < 0.5''$ OK

Node 6 longitudinal expansion (x-direction)= $(\text{node 5 \& 6})0.022 + 0.0084 = 0.03' = 0.36'' < 3''$ OK




Mmax.=135.77 lb-ft < capacity @1000F OK



Vmax.= 141 lbs < capacity @1000F OK




Axial= 141 lbs < capacity @ 1000F OK




Reactions

3.3 ESTIMATION OF THE SUPPORT REACTION IN THE VERTICAL RISERS


With the same criteria, the vertical riser is analyzed




Bellow #1=Node 13&13 longirudinal expansion (y-direction)=0.077'+0.084'=0.161'=1.93'' <3'' OK




Bellow #2=Node 13&14 longirudinal expansion (y-direction)=0.097'+0.129'=0.226'=2.71'' <3'' OK





Axial load




Reactions

Weight of the pipe=(47)*123 = 5781 @ node 8
 Support Reaction on the top (node #8)= 503.48 lbs + 5781 (Weight of the pipe.)= 5284.48 lbs
 Weight of the pipe=(32)*123 = 3936 @ node 4
 Support Reaction on the top (node #4)= 143.84 lbs + 3936 (Weight of the pipe.)= 4079.84 lbs
 Weight of the pipe=(14)*123 = 1722 @ node 1
 Support Reaction on the top (node #1)= 359.64 lbs + 1722 (Weight of the pipe.)= 2081.64 lbs

4. CHECK THE REQUIREMENTS FOR THE MINIMUM SPACING BETWEEN VERTICAL RISERS

The exhaust pipes penetrate and pass through the slabs. The thickness of the slab is equal to 6.5”.



There is no vertical load on the slab at any level except at levels 4 and 8.

So, at all other levels, only the lateral seismic force and thermal load shall be applied on the slab as the bearing force. So, assuming 18” spacing between pipes, the maximum bearing capacity of the slab is equal to:

$$\text{Area} = 1.5 \times 0.5 = 0.75 \text{ sf}$$

$$\text{Stress} = 0.35f'c = 0.35 \times 3000 = 1050 \text{ psi}$$


$$P = 1050 \times 0.75 \times 144 / 1000 = 113.4 \text{ kips}$$

$$\text{Check Shear force} = 0.29\sqrt{f'c} = 15.88 \text{ psi}$$

$$\text{Shear area} = 18 \times 6 \times 2 = 108 \times 2 = 216 \text{ in}^2$$

$$V_{\text{max}} = 3430 \text{ lbs}$$

Based on the size of the sleeve and assuming the spacing of 18” between pipes:




Then, use 18” clear distance between pipes or 48” O.C.

Any lateral load from the pipe acting on the slab should be smaller than 3430 lbs.


5. CONCLUSION

1- Location of the Bellows and the lateral support reaction is shown below:




Expansion Joint (Bellows) Note:


Type of Bellows:

Thermal Expansion
 EX302000 (20" pipe), 
 The axial spring stiffness = 186 lb/in; Lateral stiffness= 1480 lb/in
 The maximum expansion rate= 3"

Bellows type between muffler and pipe

Thermal Expansion
 EX402000 (20" pipe), 
 The axial spring stiffness = 186 lb/in; Lateral stiffness= 1480 lb/in
 The maximum expansion rate= 3"


Spacing between exhaust pipes in the concrete slab:



Use 18" clear distance between pipes or 48" O.C.

Maximum possible lateral support reaction fore on each pipe: $P_{max.} = 3430$ lbs.

SEOR should confirm the capacity of the slab. We did not evaluate the capacity of the superstructure.



Application & Performance Warranty Data

Project Information

Site Location: Washington
 Project Name: Costco Bldg 5 - 3500KW's
 Application: Standby Power
 Number Of Engines: 3
 Operating Hours per Year: 50

Engine Specifications

Engine Manufacturer: Cummins
 Model Number: QSK95-G9
 EPA Engine Family: JCEXL95.0AAA-006
 Rated Speed: 1800 RPM
 Type of Fuel: Ultra-Low Sulfur Diesel (ULSD)
 Type of Lube Oil: 1 wt% sulfated ash or less
 Lube Oil Consumption: 0.1 % Fuel Consumption
 Number of Exhaust Manifolds: 1

Engine Cycle Data

Load	Speed	Power	Exhaust Flow	Exhaust Temp.	Fuel Cons.	PM10	O2	H2O
%		bhp	acfm (cfm)	F		g/bhp-hr	%	%
100	Rated	5,051	24,975	914		0.11	10	12

Emission Data (100% Load)

Emission	Raw Engine Emissions						Target Outlet Emissions						Calculated Reduction
	g/bhp-hr	g/kW-hr	tons/yr	ppmvd @ 15% O2	ppmvd	lb/MW-hr	g/bhp-hr	g/kW-hr	tons/yr	ppmvd @ 15% O2	ppmvd	lb/MW-hr	
PM10	0.11	0.148	0.03	42	78	0.33	0.02	0.022	0	6	12	0.05	85%

System Specifications

DOC/DPF System Specifications (LTR81-81-20-XR2)

Design Exhaust Flow Rate: 24,975 acfm (cfm)
 Design Exhaust Temperature¹: 914°F
 System Pressure Loss: 15.0 inches of WC (Clean) (34.9 mBar)
 Sound Attenuation: Critical Grade
 Minimum Regeneration Temperature²: 500°F (260°C)

COSTCO BLDG-5 GARAGE

DESIGNED BY: Designer
DRAWN BY: Author
APPROVED BY: Approver
JOB NUMBER:
FILENAME:

REGISTRATION

NOT APPROVED FOR CONSTRUCTION
ISSUE NAME/DATE
SUBMITTAL


3/6/2020 3:41:05 PM

No.	Date	By	Description
A	3/6/20	MH	SUBMITTAL

REGISTERED PROFESSIONAL ENGINEER
DR. AMIN GHAFOR POUR
C84986
Exp. 3/31/22
CIVIL
STATE OF CALIFORNIA


LEVEL 1 SOUTH SUBMITTAL EXHAUST ROUTING SUPPORT

SMP4.01EXH





Note:
Expansion Bellows only shown on View 3 for horizontal pipe.
Bellows shown on View 4 for vertical pipe

Expansion Joint Bellow Legend
 Metraflex EX402000
 Metraflex EX302000



Flexible Connection as Per the Vendor Specification.
If using the MetraFlex EX30 or 40 (20\"/>



1/4\"/>

1/8\"/>


ONLY THERMAL ANALYSIS INCLUDING EXPANSION JOINTS (BELLOWS) TYPE, LOCATION, AND THE SUPPORT REACTIONS ARE COVERED IN THIS DRAWINGS UNDER THIS SIGNATURE.

MIRATECH Scope of Supply & Equipment Details

	Model Number	Quantity
DPF Housing & Catalyst	LTR81-81-20-XR2	1 / engine
DPF Housing Kit	LTR81-20-HSG-0	1 / engine
DPF Housing	LTR81-20-HSG	1 / engine
• Material	Carbon Steel	
• Paint	Standard High Temperature Black Paint	
• Inlet Pipe Size & Connection	20 inch FF Flange, 150# ANSI standard bolt pattern	
• Outlet Pipe Size & Connection	20 inch FF Flange, 150# ANSI standard bolt pattern	
• Door Location	Right	
• Dimensions	63.875" H x 63.625" W x 100" L	
• Weight Without Catalyst	1,911 lbs	
• Weight Including Catalyst	3,348 lbs	
Tray Set	Tray Set-LTR81-300mm	1 / engine
Gasket	1303.0026	2 / engine
Gasket	LTR Expansion Mat	18 / engine
DPF Block	LTR-DPF-Filter-Block	81 / engine
Oxidation Catalyst	LTR81-RE-303-S2400x3250XR	2 / engine
Data Logger	DPF-DataLogger-Assembly	1 / engine
Nut, Bolt, and Gasket Set	NBG-LTR81	1 / engine

Customer Scope Of Supply


- Support Structure
- Attachment to Support Structure (Bolts, Nuts, Levels, etc.)
- Expansion Joints
- Exhaust Piping
- Inlet Pipe Bolts, Nuts, & Gasket
- Outlet Pipe Bolts, Nuts, & Gasket
- Insulation for Exhaust Piping
- Insulation for Housing
- Installation, Fabrication, and Installation of Mounting Frame for Particulate Filters



NOTES:

1. STAINLESS STEEL TUBING REQUIRED FOR PRESSURE LINES UNTIL TEMPERATURE IS ACCEPTABLE FOR POLY TUBING
2. ALL SHIELDED CABLE SHOULD BE TWISTED TYPE-MINIMUM 6 TURNS/FOOT
3. TO COMPLY WITH CARB VERIFICATION AND WARRANTY REQUIREMENTS, THE LTR MONITOR MUST BE INSTALLED AND FUNCTIONAL PRIOR TO INITIAL DIESEL PARTICULATE FILTER OPERATION ENSURE PRESSURE TUBING IS ALWAYS RISING AWAY FROM MOISTURE SEPARATOR.
4. PRESSURE TUBING SHOULD BE RUN SO NO LOOPS ARE IN TUBING. KEEP WIRES AND TUBING AWAY FROM HOUSING AND EXHAUST PIPING AS THEY CAN BE DAMAGED BY HEAT.





PROJECT NAME	PROPRIETARY AND CONFIDENTIAL THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MIRATECH CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MIRATECH CORPORATION IS PROHIBITED.	DIMENSIONS ARE APPROXIMATE IN INCHES UNLESS OTHERWISE SPECIFIED	
PROPOSAL NUMBER		DO NOT SCALE DRAWING	
SALES ORDER NO.		DRAWN CLV	DATE 03/31/2014
CUSTOMER P.O.		REVIEWED BY CDT	DATE 03/31/2014



**LTR-DPF DATALOGGER
System Interconnect**

DRAWING		LTR-DPF DATALOGGER SI	REV 0
SIZE A	NOT TO SCALE	SHEET 1 OF 1	

WEIGHTS (APPROXIMATE)	
EMPTY HOUSING	1911 lb
ONE (1) FULL DPF CATALYST LAYER	1437 lb
ONE (1) OXIDATION ELEMENT	152 lb
<ul style="list-style-type: none"> HOUSING HAS CAPACITY FOR ONE(1) FULL DPF CATALYST LAYERS HOUSING HAS CAPACITY FOR TWO(2) OXIDATION ELEMENT 	



NOTES:

- ONLY USE LIFTING LUGS TO LIFT HOUSING
- ALLOW MINIMUM 50" CLEARANCE FROM DOOR FOR LOADING AND MAINTENANCE
- NO FORCES OR MOMENTS MAY BE APPLIED TO THE FLANGES
- MUST BE MOUNTED HORIZONTALLY (CUSTOM HOUSING REQUIRED TO MOUNT VERTICALLY)

MATERIAL CONSTRUCTION:

- CARBON STEEL

PAINT:

- HIGH TEMPERATURE BLACK (MIRATECH COATING SYSTEM 1)

PROJECT NAME	<p>PROPRIETARY AND CONFIDENTIAL</p> <p>THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MIRATECH CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MIRATECH CORPORATION IS PROHIBITED.</p>	<p>DIMENSIONS ARE APPROXIMATE IN INCHES UNLESS OTHERWISE SPECIFIED</p>							
PROPOSAL NUMBER									
SALES ORDER NO.		DO NOT SCALE DRAWING							
CUSTOMER P.O.		<table border="1"> <tr> <td>DRAWN</td> <td>CDT</td> <td>DATE</td> <td>03/31/2014</td> </tr> <tr> <td>REVIEWED BY</td> <td>EQJ</td> <td>DATE</td> <td>03/31/2014</td> </tr> </table>	DRAWN	CDT	DATE	03/31/2014	REVIEWED BY	EQJ	DATE
DRAWN	CDT	DATE	03/31/2014						
REVIEWED BY	EQJ	DATE	03/31/2014						



**LTR81-20
Sales Drawing**

DRAWING		LTR81-20 SD		REV	0
SIZE	A	SCALE	1:42	SHEET 1 OF 1	

REFERENCES

GENERAL NOTE

S0.1

GENERAL NOTE

THE FOLLOWING NOTES APPLY UNLESS NOTED OTHERWISE - ASTM'S NOTED ARE TO BE LATEST EDITION.

1. DESCRIPTION
Building Name & Site Location - Costco Corporate Headquarters – (Issaquah, WA) Building 5
Building Dept. – City of Issaquah
2. DESIGN CODE AND STANDARDS
Applicable Code (Edition/Name) – 2015 International Building Code (IBC)
Other documents referenced by these notes shall be the specific edition referenced by the building code specified above, or if not specified, shall be the latest edition.
Code supplement & Date – ASCE 7-10
3. DESIGN LOADS
 - a. I. Roof Live Load See snow load / 20 psf (reducible per code)
II. Parking Live Load 40 psf (Unreducible)
 - b. Snow Load
Basic ground snow load – $P_g = 25$ psf
Basic roof snow load – $P_f = 25$ psf
Importance factor – $I_s = 1.0$, snow exposure factor – $C_e = 1.0$
Drifting snow is not required in the design.
 - c. Seismic
Risk Category II
 $S_s = 0.951$, $S_1 = 0.951$, $I_e = 1.0$, Site Class “F”,
 $S_{DS} = 0.634$, $S_{D1} = 0.634$
Seismic Design Category = E
Resisting System(s) = Special Reinforced Concrete Shear Walls
 $CS = 0.127$, $R = 5$. Equivalent lateral force procedure was used.
Mech. & Refrigeration unit loads will be picked up at the point of the units and transferred into the lateral system.
Sprinkler lines will be braced to top of beam or slats by the sprinkler contractor.
 - d. Wind Load
Risk Category II
Basic wind speed (3 sec. gust) $V_{ULT} = 110$ mph, $V_{ASD} = 85$ mph
Exposure B.
 $K_{zt} = 1.0$
IBC Load Cases per sec. 1605.2 or 1605.3.1 only $K_d = 0.85$
Importance factor 1.0.
2 psf of collateral loads was used in uplift design.
 - f. Dead loads
Weight of structure. 113 PSF each floor approx.
 - g. Special Loads
The following special loads are to be considered:
Mechanical equipment on roof.
Sprinkler lines, canopy & other reactions as noted on structural drawings.
 - h. Future Rooftop
Solar Panels
Included in design.
 - i. Load Combinations
All Code required load combinations are to be used in the building design.
Column reactions from these load combinations are to be given to the foundation engineer.

DEFERRED SUBMITTALS STRUCTURAL COMPONENTS

ITEM	REVIEWED BY		
	AOR	EOR	CITY OF ISSAQUAH DEVELOPMENT SERVICES DEPARTMENT (BUILDING)
a. STEEL STAIRS (NOT DETAILED ON STRUCTURAL DRAWINGS)		X	X
b. NON-STRUCTURAL LIGHT GAGE FRAMING	X		
c. ANCHORAGE FOR M.E.P. AND F.P. EQUIPMENT (HUNG OR FLOOR/WALL MOUNTED)		X	X
d. VENEER / FACADE / CLADDING SUPPORT SYSTEMS AND BRACING (NON-DETAILED ON STRUCTURAL DRAWINGS)	X	X	X
e. ELEVATORS AND ELEVATOR SUPPORT FRAMING		X	X
f. MECHANICAL ENCLOSURES AND THEIR ANCHORAGE (NON-DETAILED ON STRUCTURAL DRAWINGS)		X	X
h. ELEMENTS THAT ARE PART OF THE DESIGNATED SEISMIC SYSTEM (p = 1.5) INCLUDING ANCHORAGE, BRACING REQUIREMENTS AND SHAKE TABLE CERTIFICATIONS OF ACTIVE MECHANICAL & ELECTRICAL EQUIPMENTS. THE FOLLOWING COMPONENTS ARE PART OF THE DESIGNATED SEISMIC SYSTEM: -EGRESS STAIRS -SMOKE CONTROL EQUIPMENT -GENERATORS AND OTHER ELECTRICAL EQUIPMENT SUCH AS SWITCH GEAR THAT IS REQUIRED FOR ENERGIZING ELEMENTS THAT ARE ON STAND-BY POWER OR EMERGENCY POWER. -DIESEL TANKS PROVIDING FUEL FOR GENERATORS -FIRE PUMPS -AUTOMATIC FIRE SPRINKLER SYSTEM	X	X	X


NOTES:

1. ALL CALCULATIONS PROVIDED SHALL BEAR THE SEAL & SIGNATURE OF A REGISTERED ENGINEER LICENSED IN THE PROJECT STATE.
2. DEFERRED SUBMITTAL ITEMS SHALL NOT BE OTHERWISE CONSTRUCTED IN PLACE WITHOUT HAVING THE PLANS OR SHOP DRAWINGS REVIEWED AND APPROVED BY THE EOR AND THE BUILDING OFFICIAL.
3. DEFERRED SUBMITTAL DOCUMENTS (CALCULATIONS, DESIGN, DETAILING) ARE REQUIRED TO BE SUBMITTED TO THE REGISTERED DESIGN PROFESSIONAL(S) WHO ARE REQUIRED TO REVIEW THEM AND FORWARD THEM TO THE BUILDING OFFICIAL, NOTING THAT THE DEFERRED SUBMITTAL DOCUMENTS HAVE BEEN REVIEWED AND HAVE BEEN FOUND TO BE IN GENERAL CONFORMANCE TO THE DESIGN OF THE BUILDING.
4. DEFERRED SUBMITTAL ITEMS ARE REQUIRED TO BE REVIEWED /APPROVED BY THE REGISTERED DESIGN PROFESSIONAL(S) PRIOR TO SUBMITTAL TO THE CITY FOR REVIEW.
5. DEFERRED SUBMITTAL ITEMS ARE NOT PERMITTED TO BE INSTALLED UNTIL THE DESIGN AND SUBMITTAL DOCUMENTS HAVE BEEN APPROVED BY THE BUILDING OFFICIAL.
6. AOR DENOTES ARCHITECT OF RECORD.
7. EOR DENOTES ENGINEER OF RECORD.
8. ACTIVE MECHANICAL AND ELECTRICAL EQUIPMENT THAT MUST REMAIN OPERABLE FOLLOWING THE DESIGN EARTHQUAKE GROUND MOTION ARE REQUIRED TO BE CERTIFIED BY THE MANUFACTURER AS OPERABLE WHEREBY ACTIVE PARTS OR ENERGIZED COMPONENTS SHALL BE CERTIFIED EXCLUSIVELY ON THE BASIS OF APPROVED SHAKE TABLE TESTING (13.2.5) OR EXPERIENCE DATA (13.2.6). EVIDENCE DEMONSTRATING COMPLIANCE WITH THIS REQUIREMENT IS REQUIRED TO BE SUBMITTED TO THE BUILDING OFFICIAL AFTER REVIEW AND ACCEPTANCE BY THE REGISTERED DESIGN PROFESSIONAL. THIS REQUIREMENT NEEDS TO BE CLEARLY STATED WITHIN THE DRAWING SET.

CONCRETE


CONCRETE										
STRUCTURAL ELEMENT	EXPOSURE CATEGORY / CLASS				CONCRETE F _c	MAX AGGREGATE ASTM C33	MAX W.C RATIO	SLUMP	MAX AIR CONTENT	NOTE
	(F)	(S)	(W)	(C)						
PILES	F0	S0	W1	C1	4000	3/4"	0.5	6"-10" MAX	2%	c
PILE CAPS AND GRADE BEAMS	F1	S0	W0	C0	4000	1"	0.55	6" MAX	2%	c
SLAB ON GRADE	F0	S0	W0	C0	4000	1 1/2"	0.49	5" ± 1"	2%	c
COLUMNS	F1	S0	W0	C1	5000	3/4"	0.52	5" MAX	2%	c
PT SLABS & BEAMS	F1	S0	W0	C0	5000	2.5 (1")	0.43	4" ± 1"	4%	a, b & d
SHEAR WALLS	F1	S0	W0	C1	5000	3/4"	0.52	5" MAX	2%	c
SLABS OVER STEEL DECK	F0	S0	W0	C0	3000	2.5 (1")	0.45	6" MAX	6%	c


FOR REFERENCE ONLY



SOUTH BUILDING ELEVATION
ALONG GRID 'E'

11 1/8" = 1'-0"






- NOTES: (TYPICAL FOR PT SLAB AT THIS LEVEL)
- SEE DWG S0.1 FOR GENERAL NOTES.
 - TOP OF SLAB ELEVATION & SLAB EDGE PER ARCH.
 - SLAB LIVE LOAD: 40 PSF
 - ALL S REIN. MARKED "TOP" HOLD 1/2" CLR TO TOP OF SLAB. PLACE E-W REIN. DIRECTLY ABOVE U.N.O. PER PLAN.
 - ALL S REIN. MARKED "BOT" HOLD 3/4" CLR TO BOTTOM OF SLAB. PLACE E-W REIN. DIRECTLY BELOW U.N.O. PER PLAN.
 - REFER TO ALL APPLICABLE DETAILS AND SCHEDULE SHEET S0.4 FOR ADDITIONAL REIN. REQUIREMENT.
 - REFER TO P.T. PLANS FOR POST TENSIONING & ADDITIONAL REQUIREMENTS.
 - BEAMS TIES MARKED THIS: T1 REFER TO SCHEDULE ON SHEET S1.04.

DATE	DESCRIPTION
05-21-19	BID
05-31-19	PR-02 EARLY FDN
05-31-19	BID SET ADDENDA "B"
06-07-19	BID SET ADDENDA "C"
06-15-19	BID SET ADDENDA "D"
06-17-19	PR-04 EARLY FDN
06-17-19	PR-05 EARLY FDN
07-01-19	SKYBRIDGE COMMENTS #01
07-03-19	PR-05 EARLY FDN
07-15-19	PERMIT COMMENTS #02
07-26-19	POST BID ADDENDUM
08-02-19	ASB CLASH DETECTION COORD.
09-24-19	SKYBRIDGE COMMENTS #02
09-24-19	PR-06 EARLY FDN
09-24-19	PR-06 EARLY FDN
09-27-19	PR-03
09-27-19	PR-03
09-27-19	PR-03

16038004
PM: C. RUIZ
DRAWN BY: C. HUIH

REINFORCEMENT
PLAN - LEVEL 2 -
SOUTH
S1.2S

10/9/2019 2:53:07 PM C:\Users\cbeam\Desktop\REV\15-16038_PARKING GARAGE 5_R\16_CESARR.dwg




- NOTES:** (TYPICAL FOR PT SLAB AT THIS LEVEL)
- SEE DWG S0.1 FOR GENERAL NOTES.
 - TOP OF SLAB ELEVATION & SLAB EDGE - PER ARCH.
 - SLAB LIVE LOAD: 40 PSF.
 - ALL N-S REINF. MARKED "BOT" HOLD 3/4" CLR TO BOTTOM OF SLAB. PLACE E-W REINF. DIRECTLY ABOVE U.N.O. PER PLAN.
 - ALL N-S REINF. MARKED "TOP" HOLD 1 1/2" CLR TO TOP OF SLAB. PLACE E-W REINF. DIRECTLY BELOW U.N.O. PER PLAN.
 - REFER TO ALL APPLICABLE DETAILS AND SCHEDULE SHEET S0.4 FOR ADDITIONAL REINF. REQUIREMENT.
 - REFER TO P.T. PLANS FOR POST TENSIONING & ADDITIONAL REQUIREMENTS.
 - BEAMS TIES MARKED THUS: T1 REFER TO SCHEDULE ON SHEET S.04.

DATE	DESCRIPTION
05-13-19	FDN CON PERMIT COMMENTS #2
05-13-19	BID
05-21-19	PR-02 EARLY FDN
05-31-19	BID SET ADDENDA "B"
06-03-19	BID SET ADDENDA "C"
06-17-19	BID SET ADDENDA "D"
06-17-19	PR-04 EARLY FDN
06-17-19	FILE PERMIT COMMENTS #05
06-24-19	PERMIT COMMENTS #03
07-01-19	SKYBRIDGE COMMENTS #01
07-03-19	PR-05 EARLY FDN
07-15-19	PERMIT COMMENTS #05
07-26-19	POST BID ADDENDUM
08-02-19	ADD CLASH DETECTION COORD
08-28-19	SKYBRIDGE COMMENTS #02
09-06-19	SKYBRIDGE COMMENTS #03
09-06-19	PR-06 EARLY FDN
09-27-19	PR-B3

16038004
PM: C. RUIZ
DRAWN BY: C. HUH

10/9/2019 2:53:57 PM C:\Users\cesam\Desktop\REV\15-16038_PARKING GARAGE 5_R\16_CESAR.RVT

1 LEVEL 4-9 - SOUTH
1/8" = 1'-0"



NOTES:

1. STAINLESS STEEL TUBING REQUIRED FOR PRESSURE LINES UNTIL TEMPERATURE IS ACCEPTABLE FOR POLY TUBING
2. ALL SHIELDED CABLE SHOULD BE TWISTED TYPE-MINIMUM 6 TURNS/FOOT
3. TO COMPLY WITH CARB VERIFICATION AND WARRANTY REQUIREMENTS, THE LTR MONITOR MUST BE INSTALLED AND FUNCTIONAL PRIOR TO INITIAL DIESEL PARTICULATE FILTER OPERATION ENSURE PRESSURE TUBING IS ALWAYS RISING AWAY FROM MOISTURE SEPARATOR.
4. PRESSURE TUBING SHOULD BE RUN SO NO LOOPS ARE IN TUBING.
5. KEEP WIRES AND TUBING AWAY FROM HOUSING AND EXHAUST PIPING AS THEY CAN BE DAMAGED BY HEAT.

FOR REFERENCE ONLY

PROJECT NAME	PROPRIETARY AND CONFIDENTIAL THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MIRATECH CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MIRATECH CORPORATION IS PROHIBITED.	DIMENSIONS ARE APPROXIMATE IN INCHES UNLESS OTHERWISE SPECIFIED	
PROPOSAL NUMBER			
SALES ORDER NO.		DO NOT SCALE DRAWING	
CUSTOMER P.O.		DRAWN CLV	DATE 03/31/2014
	REVIEWED BY CDT	DATE 03/31/2014	







LTR-DPF DATALOGGER System Interconnect

DRAWING		LTR-DPF DATALOGGER SI		REV 0
SIZE A	NOT TO SCALE			SHEET 1 OF 1

WEIGHTS (APPROXIMATE)	
EMPTY HOUSING	1911 lb
ONE (1) FULL DPF CATALYST LAYER	1437 lb
ONE (1) OXIDATION ELEMENT	152 lb

• HOUSING HAS CAPACITY FOR ONE(1) FULL DPF CATALYST LAYERS
 • HOUSING HAS CAPACITY FOR TWO(2) OXIDATION ELEMENT

3652lbs max with (2) oxidation element



NOTES:

- ONLY USE LIFTING LUGS TO LIFT HOUSING
- ALLOW MINIMUM 50" CLEARANCE FROM DOOR FOR LOADING AND MAINTENANCE
- NO FORCES OR MOMENTS MAY BE APPLIED TO THE FLANGES
- MUST BE MOUNTED HORIZONTALLY (CUSTOM HOUSING REQUIRED TO MOUNT VERTICALLY)

MATERIAL CONSTRUCTION:

- CARBON STEEL

PAINT:



- HIGH TEMPERATURE BLACK (MIRATECH COATING SYSTEM 1)

PROJECT NAME	<p>PROPRIETARY AND CONFIDENTIAL</p> <p>THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MIRATECH CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MIRATECH CORPORATION IS PROHIBITED.</p>	<p>DIMENSIONS ARE APPROXIMATE IN INCHES UNLESS OTHERWISE SPECIFIED</p>	
PROPOSAL NUMBER			
SALES ORDER NO.		DO NOT SCALE DRAWING	
CUSTOMER P.O.		DRAWN CDT	DATE 03/31/2014
	REVIEWED BY EQJ	DATE 03/31/2014	



LTR81-20
Sales Drawing

DRAWING		LTR81-20 SD		REV	0
SIZE	A	SCALE	1:42	SHEET 1 OF 1	



- a) If thrust plate thickness "B" is greater than pipe wall thickness, consult factory.
- b) One pair thrust plates supplied loose for field welding, top only.

Note: For higher load ratings, see: E2200. Available in all insulation thickness.

Pipe Size	Load lbs	A	B	C	D	E	Insul. Thk. = 1"			Insul. Thk. = 2"			Insul. Thk. = 3"			Insul. Thk. = 4"		
							F	G	H	F	G	H	F	G	H	F	G	H
2	750	0.63	0.38	0.38 x 3.00	1.50	0.625	3.94	6.19	5.38	5.00	7.25	7.5	6.00	8.25	9.5	7.06	9.31	11.63
2 1/2	900	0.63	0.38	0.38 x 3.00	1.50	0.625	4.19	6.44	5.88	5.50	7.75	8.5	6.50	8.75	10.5	7.56	9.81	12.63
3	1200	0.63	0.38	0.38 x 3.00	1.50	0.625	4.47	6.72	6.44	5.50	7.75	8.5	6.50	8.75	10.5	7.56	9.81	12.63
4	1800	0.63	0.38	0.38 x 3.00	1.50	0.625	5.00	7.25	7.5	6.00	8.25	9.5	7.06	9.31	11.63	8.06	10.31	13.63
5	2400	0.63	0.38	0.38 x 4.00	2.00	0.625	5.50	7.75	8.5	6.50	8.75	10.5	7.56	9.81	12.63	8.69	10.94	14.88
6	3000	0.63	0.38	0.38 x 4.00	2.00	0.625	6.00	8.25	9.5	7.06	9.31	11.63	8.06	10.31	13.63	9.19	11.44	15.88
8	3900	0.63	0.50	0.50 x 4.00	2.00	0.625	7.31	9.81	11.88	8.31	10.81	13.88	9.44	11.94	16.13	10.44	12.94	18.13
10	4800	0.88	0.50	0.50 x 5.00	3.00	0.625	8.31	10.81	13.88	9.44	11.94	16.13	10.44	12.94	18.13	11.44	13.94	20.13
12	5100	0.88	0.50	0.50 x 5.00	3.00	0.625	9.44	11.94	16.13	10.44	12.94	18.13	11.44	13.94	20.13	12.44	14.94	22.13
14	6000	0.88	0.50	0.50 x 5.00	3.00	0.75	10.06	12.69	17.13	11.06	13.69	19.13	12.06	14.69	21.13	13.06	15.69	23.13
16	6900	0.88	0.50	0.50 x 6.00	4.00	0.75	11.06	13.69	19.13	12.06	14.69	21.13	13.06	15.69	23.13	14.06	16.69	25.13
18	7500	0.88	0.50	0.50 x 6.00	4.00	0.75	12.06	14.69	21.13	13.06	15.69	23.13	14.06	16.69	25.13	15.06	17.69	27.13
20	8100	0.88	0.50	0.50 x 6.00	4.00	0.75	13.06	15.69	23.13	14.06	16.69	25.13	15.06	17.69	27.13	16.06	18.69	29.13
24	8400	0.88	0.50	0.50 x 6.00	4.00	0.75	15.06	17.69	27.13	16.06	18.69	29.13	17.06	19.69	31.13	18.06	20.69	33.13

Application:

Model E2200 through E2230 is designed for use on:

- Hot water
- Cold water
- Chilled water
- Dual temperature
- Steam
- Air
- Gas
- Vacuum

Intended for installation on:

- Vertical runs of insulated pipe with upward and/or downward load.

Other:

- For handling downward loads only, see E1200

Temperature Range: +40°F to +1200°F

Note: Up to 1800°F available upon request.

Features:

- All pipe sizes
- Easy installation
- Positive stop - axially upward or downward
- May be supported from below or above
- Overlapping galvanized sheet metal jacket
- Insulating structural inserts for load transfer
- Other I.D.'s and/or O.D.'s Available on Request
- Eliminates condensation sweating on chilled water risers

Performance Test Results on File:

Available upon request.

Material Data:

- **E2200 - E2230:** specification document: No. 209.

Steel Inner Thrust Plates:

Model	ASTM	For Pipe Material
E2200	A36	Carbon-Steel
E2210	A387GR.11	Chrome-Moly
E2220	A515GR.70	Carbon Silicon
E2230	A304L	Stainless Steel

- Insulation: Calcium silicate asbestos-free, treated with water repellent.
- Jackets: Galvanized steel ASTM A-653.
- Glue: Industrial contact adhesive
- Structural Inserts: High-density calcium silicate asbestos free, treated with water repellent.
- Steel Straps/Base: Carbon steel ASTM A-36.
- Fasteners: ASTM A-307 plated.
- Coating: Primer coated or hot dipped galvanized
- Other coatings available upon request.

Formal submittal sheets available

Schedule 40 Pipe Dimensions

Size Inches	Diameters			Transverse Area			Length of Pipe per Sq. Foot of		Cubic Feet per Foot of Pipe	Weight per Foot Pounds	Number Threads per Inch of Screw
	External Inches	Internal Inches	Nominal Thickness Inches	External Sq. Ins.	Internal Sq. Ins.	Metal Sq. Ins.	External Surface Feet	Internal Surface Feet			
1/8	.405	.369	.068	129	.057	.072	9.431	14.199	.00039	244	27
1/4	.540	.504	.068	229	.104	.125	7.073	10.493	.00072	424	18
3/8	.675	.639	.091	359	.191	.187	5.059	7.747	.00133	567	18
1/2	.840	.802	.109	554	.304	.250	4.547	6.141	.00211	850	14
3/4	1.050	.924	.113	869	.533	.333	3.637	4.835	.00370	1,130	14
1	1.315	1.049	.133	1,359	.864	.494	2.904	3.841	.00600	1,678	11 1/2
1 1/4	1.660	1.380	.140	2,164	1,465	.689	2.301	2.767	.01039	2,272	11 1/2
1 1/2	1.900	1.610	.145	2,835	2,036	.799	2.010	2.372	.01414	2,717	11 1/2
2	2.375	2.067	.154	4,430	3,355	1.075	1.608	1.847	.02330	3,652	11 1/2
2 1/2	2.875	2.489	.203	6,492	4,788	1.704	1.328	1.547	.03325	5,793	8
3	3.500	3.068	.216	9,621	7,093	2,528	1.091	1.245	.05134	7,575	8
3 1/2	4.000	3.548	.226	12,56	9,888	2,680	.954	1.076	.06866	9,109	8
4	4.500	4.026	.237	16,90	12,73	3,174	.848	.948	.08840	10,790	8
5	5.583	5.047	.258	24,30	20.00	4,300	.688	.756	.1389	14.61	8
6	6.625	6.065	.280	34.47	28.89	5,581	.578	.629	.2006	18.97	8
8	8.625	7.981	.322	58.42	50.02	8,399	.442	.478	.3552	28.55	8
10	10.750	10.020	.365	90.76	78.88	11.90	.358	.381	.5476	40.48	8
12	12.750	12.008	.406	127.64	111.9	15.74	.299	.318	.7783	53.6	8
14	14.000	13.125	.437	153.64	135.3	18.64	.272	.280	.9354	63.0	8
16	16.000	15.000	.500	291.05	176.7	24.35	.238	.254	1.223	78.0	8
18	18.000	18.874	.563	354.85	224.0	30.85	.212	.226	1.555	105.0	8
20	20.000	18.814	.593	314.15	278.0	36.15	.191	.203	1.926	123.0	8
24	24.000	22.826	.687	452.40	402.1	50.30	.159	.169	2.793	171.0	8

B3188 - Standard U-Bolt with 4 Hex Nuts (TOLCO Fig. 110) B3188C - Standard Plastic Coated U-Bolt

Size Range: Size 1/2" (15mm) thru 30" (900mm) pipe

Material: Steel

Function: Recommended for support, anchor or guide of pipe.

Approvals: Underwriters Laboratories Listed 3/4" (20mm) thru 12" (300mm).
Conforms to Federal Specification WW-H-171E & A-A-1192A, Type 24
and Manufacturers Standardization Society ANSI/MSS SP-69 & SP-58,
Type 24.


Maximum Temperature: 750°F (399°C)

Finish: Plain. Contact B-Line for alternative finishes and materials.

Order By: Part number and finish. U-bolt can be furnished with longer tangents "D" or with longer threads "E". Consult factory.

Note: When furnished in Hot-Dip Galvanized finish, oversize tapped hex nuts must be used.

B3188NS - Non-standard (NS) U-bolts are available upon request. Specify dimensions other than standard. B3188DI - For ductile iron pipe.



B3188C
Plastic Coated

Part No.	Pipe Size		Thread Size	Thread Length TL		B	
	in.	(mm)		in.	(mm)	in.	(mm)
B3188-1/2	1/2"	(15)	1/4"-20	2 1/8"	(54.0)	15/16"	(23.8)
B3188-3/4	3/4"	(20)	1/4"-20	2 1/8"	(54.0)	1 1/8"	(28.6)
B3188-1	1"	(25)	1/4"-20	2 1/8"	(54.0)	1 3/8"	(34.9)
B3188-1 1/4	1 1/4"	(32)	3/8"-16	2 1/8"	(54.0)	1 11/16"	(42.9)
B3188-1 1/2	1 1/2"	(40)	3/8"-16	2 1/2"	(63.5)	2"	(50.8)
B3188-2	2"	(50)	3/8"-16	2 1/2"	(63.5)	2 7/16"	(61.9)
B3188-2 1/2	2 1/2"	(65)	1/2"-13	3"	(76.2)	2 15/16"	(74.6)
B3188-3	3"	(80)	1/2"-13	3"	(76.2)	3 9/16"	(90.5)
B3188-3 1/2	3 1/2"	(90)	1/2"-13	3"	(76.2)	4 1/16"	(103.2)
B3188-4	4"	(100)	1/2"-13	3"	(76.2)	4 9/16"	(115.9)
B3188-5	5"	(125)	1/2"-13	3"	(76.2)	5 21/32"	(143.6)
B3188-6	6"	(150)	5/8"-11	3 3/4"	(95.2)	6 3/4"	(171.4)
B3188-8	8"	(200)	5/8"-11	3 3/4"	(95.2)	8 3/4"	(222.2)
B3188-10	10"	(250)	3/4"-10	4"	(101.6)	10 7/8"	(276.2)
B3188-12	12"	(300)	7/8"-9	4 1/4"	(107.9)	12 7/8"	(327.0)
B3188-14	14"	(350)	7/8"-9	4 1/4"	(107.9)	14 1/8"	(358.8)
B3188-16	16"	(400)	7/8"-9	4 1/4"	(107.9)	16 1/8"	(409.6)
B3188-18	18"	(450)	1"-8	4 3/4"	(120.6)	18 1/8"	(460.4)
B3188-20	20"	(500)	1"-8	4 3/4"	(120.6)	20 1/8"	(511.2)
B3188-24	24"	(600)	1"-8	4 3/4"	(120.6)	24 1/8"	(612.8)
B3188-30	30"	(750)	1"-8	4 3/4"	(120.6)	30 1/8"	(765.2)

All dimensions in charts and on drawings are in inches. Dimensions shown in parentheses are in millimeters unless otherwise specified.

B3188 - Standard U-Bolt with 4 Hex Nuts (TOLCO Fig. 110) cont.

Part No.	C		Tangent D		E		Approx. Wt./100	
	in.	(mm)	in.	(mm)	in.	(mm)	Lbs.	(kg)
B3188-1/2	1 ³ / ₁₆ "	(30.2)	2 ³ / ₄ "	(69.8)	2 ⁵ / ₁₆ "	(58.7)	10	(4.5)
B3188-3/4	1 ³ / ₈ "	(34.9)	2 ³ / ₄ "	(69.8)	2 ⁷ / ₃₂ "	(56.3)	11	(5.0)
B3188-1	1 ⁵ / ₈ "	(41.3)	2 ³ / ₄ "	(69.8)	2 ³ / ₃₂ "	(53.2)	11	(5.0)
B3188-1 ¹ / ₄	2 ³ / ₃₂ "	(53.2)	2 ⁷ / ₈ "	(73.0)	2 ¹ / ₃₂ "	(51.6)	28	(12.7)
B3188-1 ¹ / ₂	2 ³ / ₈ "	(60.3)	3"	(76.2)	2 ¹ / ₁₆ "	(52.4)	29	(13.1)
B3188-2	2 ¹³ / ₁₆ "	(71.4)	3 ¹ / ₄ "	(82.5)	2 ¹ / ₁₆ "	(52.4)	31	(14.0)
B3188-2 ¹ / ₂	3 ⁷ / ₁₆ "	(87.3)	3 ³ / ₄ "	(95.2)	2 ⁵ / ₁₆ "	(58.7)	72	(32.6)
B3188-3	4 ¹ / ₁₆ "	(103.2)	4"	(101.6)	2 ¹ / ₄ "	(57.1)	79	(35.8)
B3188-3 ¹ / ₂	4 ⁹ / ₁₆ "	(115.9)	4 ¹ / ₄ "	(107.9)	2 ¹ / ₄ "	(57.1)	84	(38.1)
B3188-4	5 ¹ / ₁₆ "	(128.6)	4 ¹ / ₂ "	(114.3)	2 ¹ / ₄ "	(57.1)	94	(42.6)
B3188-5	6 ⁵ / ₃₂ "	(156.3)	5"	(127.0)	2 ⁷ / ₃₂ "	(56.3)	104	(47.2)
B3188-6	7 ³ / ₈ "	(187.3)	6 ¹ / ₈ "	(155.6)	2 ¹³ / ₁₆ "	(71.4)	203	(92.1)
B3188-8	9 ³ / ₈ "	(238.1)	7 ¹ / ₈ "	(181.0)	2 ¹³ / ₁₆ "	(71.4)	241	(109.3)
B3188-10	11 ⁵ / ₈ "	(295.3)	8 ³ / ₈ "	(212.7)	3"	(76.2)	412	(186.9)
B3188-12	13 ³ / ₄ "	(349.2)	9 ⁵ / ₈ "	(244.5)	3 ¹ / ₄ "	(82.5)	661	(299.8)
B3188-14	15"	(381.0)	10 ¹ / ₄ "	(260.3)	3 ¹ / ₄ "	(82.5)	707	(320.7)
B3188-16	17"	(431.8)	11 ¹ / ₄ "	(285.7)	3 ¹ / ₄ "	(82.5)	782	(354.7)
B3188-18	19 ¹ / ₈ "	(485.8)	12 ⁵ / ₈ "	(320.7)	3 ⁵ / ₈ "	(92.1)	1344	(609.6)
B3188-20	21 ¹ / ₈ "	(536.6)	13 ⁵ / ₈ "	(346.1)	3 ⁵ / ₈ "	(92.1)	1458	(661.3)
B3188-24	25 ¹ / ₈ "	(638.2)	15 ⁵ / ₈ "	(396.9)	3 ⁵ / ₈ "	(92.1)	1687	(765.2)
B3188-30	31 ¹ / ₈ "	(790.6)	18 ⁵ / ₈ "	(473.1)	3 ⁵ / ₈ "	(92.1)	2030	(920.8)

Part No.	Design Load 1				Design Load 2		Design Load 3	
	650°F (343°C)		750°F (399°C)		650°F (343°C)		650°F (343°C)	
	Lbs.	(kN)	Lbs.	(kN)	Lbs.	(kN)	Lbs.	(kN)
B3188-1/2	580	(2.58)	454	(2.02)	145	(0.64)	180	(0.80)
B3188-3/4	580	(2.58)	454	(2.02)	145	(0.64)	300	(1.33)
B3188-1	580	(2.58)	454	(2.02)	145	(0.64)	480	(2.13)
B3188-1 ¹ / ₄	1460	(6.49)	1144	(5.09)	365	(1.62)	600	(2.67)
B3188-1 ¹ / ₂	1460	(6.49)	1144	(5.09)	365	(1.62)	600	(2.67)
B3188-2	1460	(6.49)	1144	(5.09)	365	(1.62)	720	(3.20)
B3188-2 ¹ / ₂	2700	(12.01)	2114	(9.40)	675	(3.00)	720	(3.20)
B3188-3	2700	(12.01)	2114	(9.40)	675	(3.00)	900	(4.00)
B3188-3 ¹ / ₂	2700	(12.01)	2114	(9.40)	675	(3.00)	900	(4.00)
B3188-4	2700	(12.01)	2114	(9.40)	675	(3.00)	900	(4.00)
B3188-5	2700	(12.01)	2114	(9.40)	675	(3.00)	1080	(4.80)
B3188-6	4320	(19.21)	3382	(15.04)	1080	(4.80)	1080	(4.80)
B3188-8	4320	(19.21)	3382	(15.04)	1080	(4.80)	--	--
B3188-10	6460	(28.73)	5060	(22.50)	1615	(7.18)	--	--
B3188-12	9960	(44.30)	7016	(31.21)	2490	(11.07)	--	--
B3188-14	9960	(44.30)	7016	(31.21)	2490	(11.07)	--	--
B3188-16	9960	(44.30)	7016	(31.21)	2490	(11.07)	--	--
B3188-18	11800	(52.48)	9240	(41.10)	--	--	--	--
B3188-20	11800	(52.48)	9240	(41.10)	--	--	--	--
B3188-24	11800	(52.48)	9240	(41.10)	--	--	--	--
B3188-30	11800	(52.48)	9240	(41.10)	--	--	--	--

All dimensions in charts and on drawings are in inches. Dimensions shown in parentheses are in millimeters unless otherwise specified.



Thermal, Vibration, Noise & Seismic Solutions For Pipes

About Us En Español Rep Login 800-621-4347

- Products
- Resources
- Find A Representative
- Support
- Fire Products
- Search..

Products > Pipes Guides and Anchors

Custom Fabricated Guides



- [Download Submittal](#)
- [Install/O&M](#)
- [Catalog](#)

Quick Links	
Metal Expansion Joints	
Rubber Expansion Joints	
Metraloop® Seismic/Thermal	
Seismic BreakAway Hanger	
Energy-Saving Pump Connectors	
Flexible Couplings	
Flexible Metal Hose	
Valves	
Compensators	
Strainers	

FOR REFERENCE ONLY