



KERN COUNTY
Public Health Services
DEPARTMENT

**ENVIRONMENTAL HEALTH DIVISION
CERTIFIED UNIFIED PROGRAM AGENCY (CUPA)**

MATTHEW CONSTANTINE
DIRECTOR

2700 M STREET, SUITE 300 BAKERSFIELD, CALIFORNIA 93301-2370 VOICE: 661-862-8740 FAX: 661-862-8701 WWW.CO.KERN.CA.US/EH

January 23, 2014

KULJIT SINGH GHUMAN
2126 TAFT HWY
BAKERSFIELD, CA 93313

Annual UST Monitoring System Compliance Inspection

Facility: JOHNNY QUIK #143, CR# 003201
2126 TAFT HWY
BAKERSFIELD

California state law requires that all underground storage tank (UST) leak monitoring equipment be calibrated, operated and maintained in accordance with manufacturer's instructions, and certified every 12 months for proper operability and calibration. All UST facilities require the following annual inspections:

1. Annual Certification of the Leak Monitoring System - performed by a certified technician employed by a licensed contractor on behalf of the UST owner/operator.
2. Annual Routine UST Inspection - performed by the Kern County Environmental Health Services Department.

Based on this department's records, the annual monitor certification was last completed on 02/14/2013. Please have your certified contractor schedule the monitor certification with this department. We will make every effort to complete our routine inspection at the same time. During the inspection, the following documents must be available for review:

Facility and Tank Registration Forms
Monitoring Procedure Plan
Site Plot Plan
Employee Training Records by Designated Operator

Financial Responsibility Forms
Emergency Response Plan
Monitoring records

The monitor certification is to be scheduled by 03/02/2014 to avoid future enforcement action. Please contact the undersigned at (661) 862-8719 for further information and/or to schedule the inspection.

Sincerely,

MARTY A BROWNFIELD
WASTE MANAGEMENT TECHNICIAN II
Unified Hazardous Materials/Waste Program



HAZARDOUS MATERIALS BUSINESS PLAN INSPECTION REPORT

Facility Name: JOHNNY QUIK #143		Facility ID: FA0002691
		File #: 003201
Site Address: 2126 TAFT HWY BAKERSFIELD, CA 93313		CERS ID: 10233775
Phone: (661) 834-9113	Consent Granted By: JOSSI & KULJIT GHUMAN	Inspection Date: 02/21/2014
Inspection Type: <input type="checkbox"/> Routine <input type="checkbox"/> Reinspection	Reinspection required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Inspection Element: BUS PLAN MED LOW RISK 1 UNIT		

File/CERS Review Violations

V	Viol #	Summary	Code
	H335	FAILURE TO SUBMIT A HAZARDOUS MATERIALS BUSINESS PLAN	19 CCR 4 2729.2(a); HSC 6.95 25505(a)
	H344	FAILURE TO COMPLETE THE BUSINESS ACTIVITIES PAGE AND OR OWNER/OPERATOR IDENTIFICATION PAGE	19 CCR 4 2729.2(a)(1)
✓	H342	FAILURE TO COMPLETE/SUBMIT HAZARDOUS MATERIALS INVENTORY FORMS FOR ALL REPORTABLE HAZARDOUS MATERIALS	19 CCR 4 2729.2(a)(2); HSC 6.95 25504(a)
	H341	FAILURE TO COMPLETE THE HAZARDOUS MATERIALS INVENTORY RE-CERTIFICATION OR RE-SUBMITTAL	19 CCR 4 2729.4(b), 2729.5
	H337	FAILURE TO COMPLETE THE TRIENNIAL HAZARDOUS MATERIALS BUSINESS PLAN REVIEW AND RE-CERTIFICATION	HSC 6.95 25505(c)
	H346	INCOMPLETE ANNOTATED SITE MAP	19 CCR 4 2729.2(a)(3); HSC 25504
	H347	EMERGENCY RESPONSE PLAN AND PROCEDURES NOT INCLUDED OR NOT ADEQUATE	19 CCR 4 2731; HSC 6.95 25504(b)
	H353	TRAINING PROGRAM NOT INCLUDED OR IS NOT ADEQUATE	19 CCR 4 2732(a); HSC 6.95 25504(c)
	H340	PROPERTY OWNER WAS NOT NOTIFIED IN WRITING THAT A HAZARDOUS MATERIALS BUSINESS PLAN IS REQUIRED	HSC 6.95 25503.6
	H336	PROPERTY OWNER WAS NOT PROVIDED A COPY OF THE HAZARDOUS MATERIALS BUSINESS PLAN	HSC 6.95 25503.6

Onsite Inspection Violations

V	Viol #	Summary	Code
	H334	FAILURE TO ESTABLISH AND IMPLEMENT A HAZARDOUS MATERIALS BUSINESS PLAN	19 CCR 4 2729.1(a); HSC 6.95 25503.5(a)
	H343	FAILURE TO REVISE HAZARDOUS MATERIALS BUSINESS PLAN UPON A SUBSTANTIAL CHANGE	HSC 6.95 25505(b)
	H345	FAILURE TO UPDATE HAZARDOUS MATERIALS INVENTORY UPON A SIGNIFICANT CHANGE	19 CCR 4 2729.4(d); HSC 6.95 25505(b), 25510
	H348	TRAINING PROGRAM NOT IMPLEMENTED	19 CCR 4 2732(b); HSC 6.95 25504(c)
	H338	FAILURE TO REPORT A RELEASE OF A HAZARDOUS MATERIAL	19 CCR 4 2703; HSC 6.95 25507

Inspector: MARTY A BROWNFIELD

Inspection Date: 02/21/2014

SUMMARY OF OBSERVATIONS/VIOLATIONS

- No violations of hazardous waste laws/regulations were discovered. KERN CUPA greatly appreciates your efforts to comply with all the laws and regulations applicable to your facility.
- Violations were observed/discovered as listed below. All violations must be corrected by implementing the corrective action listed by each violation. If you disagree with any of the violations or corrective actions required, please inform the CUPA in writing.

ALL VIOLATIONS MUST BE CORRECTED WITHIN 30 DAYS OR AS SPECIFIED. CUPA must be informed in writing with a certification that compliance has been achieved. A false statement that compliance has been achieved is a violation of the law and punishable by a fine of not less than \$2,000 or more than \$25,000 for each violation. Your facility may be reinspected any time during normal business hours. If a second reinspection becomes necessary due to non compliance, a reinspection charge of \$100.00 per hour may be charged to the facility.

You may request a meeting with the Program Manager to discuss the inspection findings and/or the proposed corrective actions. The issuance of this Summary of Violations does not preclude the CUPA from taking administrative, civil, or criminal action.

Facility Name: JOHNNY QUIK #143

Facility ID: FA0002691
File #: 003201

VIOLATIONS

Violation Number	Violation Text	Violation Degree	Comply by
H342	Failure to complete and/or submit hazardous material inventory forms for all reportable hazardous materials on site. 19 CCR 4 2729.2(a)(2); HSC 6.95 25504(a)	CLASS II VIOLATION	03/23/2014
Violation Details & Corrective Action Required:	<p><i>THE FACILITY OWNER/OPERATOR NEEDS TO AMEND THEIR HAZARDOUS MATERIALS INVENTORY IN CERS TO REFLECT THE FOLLOWING ADDITIONAL HAZARDOUS MATERIALS BEING STORED ON SITE.</i></p> <p>1.) PROPANE 2.) CARBON DIOXIDE</p>		

INSPECTION COMMENTS:

COMMENTS: Go to <http://www.co.kern.ca.us/eh/> (Hazardous Materials) for forms and information.

Inspector: MARTY A BROWNFIELD
Inspection Date: 02/21/2014

Signature of Facility Representative:

Certification: I certify under penalty of perjury that this facility has complied with the corrective actions listed on this inspection form.

Printed Name of Owner/Operator

Title

Signature of Owner/Operator

Date



UNDERGROUND STORAGE TANK INSPECTION REPORT

Facility Name: JOHNNY QUIK #143		Facility ID: FA0002691
		File #: 003201
Site Address: 2126 TAFT HWY BAKERSFIELD, CA 93313		CERS ID: 10233775
		BOE #:
Phone: (661) 834-9113	Consent Granted By: JOSSI & KULJIT GHUMAN	Inspection Date: 02/21/2014
Inspection Type: <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Reinspection		Reinspection required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

File/CERS Review Violations

V	Viol #	Summary	Code
	H650	FAILURE TO OBTAIN/MAINTAIN A VALID OPERATING PERMIT	23 CCR 16 2712(i); HSC 6.7 25284
	H651	FAILURE TO SUBMIT ACCURATE UST FACILITY/TANK INFORMATION	23 CCR 16 2711; HSC 6.7 25286(a)
	H653	FAILURE TO SUBMIT STATEMENT OF DESIGNATED OPERATOR/UST COMPLIANCE	23 CCR 16 2715(a), 2715(b)
	H654	FAILURE TO SUBMIT/MAINTAIN AN ACCURATE RESPONSE PLAN	23 CCR 16 2632, 2634(e), 2641(h), 2712(i)
	H655	FAILURE TO SUBMIT/MAINTAIN AN ACCURATE PLOT PLAN	23 CCR 16 2632(d)(1)(C), 2711(a)(8)
	H660	MAKING FALSE STATEMENTS/REPRESENTATION ON ANY DOCUMENT	HSC 6.7 25299
	H662	FAILURE TO COMPLETE/SUBMIT ANNUAL MONITORING CERTIFICATION	23 CCR 16 2638
	H663	FAILURE TO COMPLETE SECONDARY CONTAINMENT TESTING	23 CCR 16 2637
	H664	FAILURE TO ANNUALLY TEST SPILL CONTAINMENT	HSC 6.7 25284.2
	H665	FAILURE TO SUBMIT SECONDARY CONTAINMENT TEST RESULTS	23 CCR 16 2637(e)

General Violations

V	Viol #	Summary	Code
	H741	FAILURE TO COMPLY WITH ALL OPERATING PERMIT CONDITIONS	23 CCR 16 2712
✓	H680	IMPROPER PROGRAMING/OPERATION OF LEAK DETECTION EQUIPMENT	23 CCR 16 2632, 2634, 2636, 2666
	H681	FAILURE OF LEAK DETECTION EQUIPMENT TO HAVE AUDIBLE/VISUAL ALARMS	23 CCR 16 2632, 2634, 2636, 2666
	H683	FAILURE TO INSTALL CORRECT LEAK DETECTION SYSTEM	23 CCR 16 2638; HSC 6.7 25290.1, 25290.2, 2529122 CCR 12 66262.34(d)(2);
	H684	FAILURE TO PROPERLY LABEL CERTIFIED MONITORING EQUIPMENT	23 CCR 16 2638(f)
	H690	FAILURE TO PROPERLY MONITOR UNDER DISPENSER CONTAINMENT	23 CCR 16 2636(f)(1)
✓	H694	FAILURE OF SENSOR TO BE LOCATED IN THE PROPER POSITION	23 CCR 16 2630(d), 2641(a)
✓	H695	TAMPERING WITH LEAK DETECTION EQUIPMENT	HSC 6.7 25299(a)(9)
	H704	FAILURE TO INSTALL LINE LEAK DETECTORS ON PRESSURIZED PIPING	HSC 6.7 25290.1(h), 25290.2(g), 25291(f), 25292(e)
	H708	FAILURE OF LINE LEAK DETECTOR TO FUNCTION AS REQUIRED	23 CCR 16 2636(f)(2)
	H711	FAILURE TO KEEP SECONDARY CONTAINMENT FREE OF DEBRIS/ LIQUID AND IN GOOD CONDITION	HSC 6.7 25290.1, 25290.2, 25291
✓	H717	FAILURE TO KEEP SPILL BUCKET FREE OF DEBRIS/LIQUID AND IN GOOD CONDITION	23 CCR 16 2635(b), 2715(c)(2)
	H676	FAILURE TO OBTAIN PERMITS TO INSTALL, REPLACE, REPAIR OR MODIFY PART OF THE UST SYSTEM	23 CCR 16 2712

Inspector: MARTY A BROWNFIELD

Inspection Date: 02/21/2014

General Violations - continued

V	Viol #	Summary	Code
	H719	FAILURE TO OPERATE THE UST SYSTEM TO PREVENT SPILLS/ OVERFILLS	HSC 6.7 25292.1(a)
	H720	FAILURE OF THE OVERFILL PREVENTION SYSTEM TO FUNCTION AS REQUIRED	23 CCR 16 2635(b)(2), 2665
	H721	FAILURE OF INDIVIDUALS WORKING ON/MAINTAINING THE UST SYSTEM TO HAVE A PROPER/CURRENT ICC CERTIFICATION	23 CCR 16 2715
	H747	FAILURE TO COMPLY WITH TEMPORARY CLOSURE REQUIREMENTS	23 CCR 16 2670, 2671; HSC 6.7 25298
	H748	FAILURE TO COMPLY WITH ALL PERMANENT CLOSURE REQUIREMENTS	23 CCR 16 2670, 2672; HSC 6.7 25298

Double Walled Tank Violations

V	Viol #	Summary	Code
	H682	FAILURE TO CONTINUOUSLY MONITOR SECONDARY CONTAINMENT THAT ACTIVATES AN AUDIBLE/VISUAL ALARM	23 CCR 16 2631(g), 2632(c)(2)(A)&(B), 2633(c), 2636(f)
	H699	FAILURE TO CONTINUOUSLY MONITOR SECONDARY CONTAINMENT USING VACUUM/PRESSURE/HYDROSTATIC	HSC 6.7 25290.1(e)
	H714	FAILURE TO MAINTAIN PRODUCT TIGHT SECONDARY CONTAINMENT	23 CCR 16 2662; HSC 6.7 25290.1(c)(2), 25290.2(c)(2), 25291(a), 25292(e)

Double Walled Piping Violations

V	Viol #	Summary	Code
	H666	FAILURE TO COMPLY WITH ANNUAL LINE INTEGRITY TESTING	23 CCR 16 2636(f)(4)
	H686	FAILURE OF SECONDARY CONTAINMENT MONITORING TO PROVIDE FAIL SAFE AND POSITIVE SHUT DOWN	23 CCR 16 2636(f)(5)
	H687	FAILURE TO CONTINUOUSLY MONITOR SECONDARY CONTAINMENT THAT ACTIVATES AN AUDIBLE/VISUAL ALARM	23 CCR 16 2636(f)(1)
	H705	FAILURE TO CHECK MONITORING SYSTEM DAILY TO MAINTAIN EMERGENCY GENERATOR LINE LEAK DETECTOR EXEMPTION	23 CCR 16 2636(f)(2), 2666(c)
	H712	FAILURE TO MAINTAIN SECONDARY CONTAINMENT TO ALLOW PRODUCT TO BE DETECTED AT THE EARLIEST POSSIBLE OPPORTUNITY	23 CCR 16 2630(d), 2641(a)

Single Walled Tank Violations

V	Viol #	Summary	Code
	H685	FAILURE TO USE THE AUTOMATIC TANK GAUGE AND MANUAL INVENTORY RECONCILIATION FOR LOW VOLUME TANK TESTING	23 CCR 16 2643(b)(2)
	H688	FAILURE TO CONDUCT 0.2 GALLON/HOUR CONTINUOUS IN TANK LEAK DETECTION TEST MONTHLY AND DOCUMENT	23 CCR 16 2643(b)(5)
	H689	FAILURE TO CONDUCT 0.2 GALLON/HOUR IN TANK LEAK DETECTION TEST MONTHLY AND DOCUMENT	23 CCR 16 2643(b)(1)
	H692	FAILURE TO INSTALL AUTOMATIC TANK GAUGING/LEAK DETECTION	23 CCR 16 2643; HSC 6.7 25292(a)
	H701	FAILURE TO MAINTAIN/INSPECT CORROSION PROTECTION SYSTEM AS REQUIRED	23 CCR 16 2635(a)(2), 2662(c)(1)(B)
	H755	FAILURE TO INSTALL A FUNCTIONAL CORROSION PROTECTION SYSTEM	23 CCR 16 2635(a)(2)(A)
	H669	FAILURE TO RECERTIFY INTERIOR LINED TANKS AS REQUIRED	23 CCR 16 2663
	H671	FAILURE TO CONDUCT ENHANCED LEAK DETECTION TESTING AS REQUIRED	23 CCR 16 2644.1(a)(3)
	H672	FAILURE TO SUBMIT ENHANCED LEAK DETECTION TEST RESULTS AS REQUIRED	23 CCR 16 2644.1(a)(5)
	H749	FAILURE TO CORRECT ANY FAILURES DETECTED DURING ENHANCED LEAK DETECTION TESTING	HSC 6.7 25292.4(d), 25292.5(c)

Inspector: MARTY A BROWNFIELD

Inspection Date: 02/21/2014

Single Walled Piping Violations

V	Viol #	Summary	Code
	H703	FAILURE TO PERFORM MONTHLY 0.2 GALLON/HOUR OR ANNUAL 0.1 GALLON/HOUR LINE INTEGRITY TESTS	23 CCR 16 2641(a), 2643(c)
	H707	FAILURE OF THE LINE LEAK DETECTOR TO PROVIDE FAIL SAFE AND POSITIVE SHUT DOWN	23 CCR 16 2666(c)

On Site Records Violations

V	Viol #	Summary	Code
	H652	FAILURE TO OBTAIN/MAINTAIN A VALID BOARD OF EQUALIZATION ACCOUNT NUMBER	HSC 6.7 25286(c)
	H661	FAILURE TO NOTIFY THE CUPA OF A CHANGE IN DESIGNATED OPERATOR	23 CCR 16 2715(a)
	H724	FAILURE TO SUBMIT/MAINTAIN A CURRENT CERTIFICATION OF FINANCIAL RESPONSIBILITY	23 CCR 16 2711; 23 CCR 18 2808.1, 2809-2809.2; HSC 6.7 25292.2; HSC 6.75 25299.30-25299.34
	H726	FAILURE TO MAINTAIN COPIES OF DESIGNATED OPERATOR'S INSPECTION REPORTS AND LIST OF TRAINED EMPLOYEES	23 CCR 16 2715
	H727	FAILURE OF DESIGNATED OPERATOR TO COMPLY WITH ALL MONTHLY INSPECTION REQUIREMENTS	23 CCR 16 2715
	H729	FAILURE TO MAINTAIN ALARM LOGS AND FOLLOW-UP DOCUMENTATION	23 CCR 16 2632, 2634, 2712(b)
	H731	FAILURE OF DESIGNATED OPERATOR TO PROVIDE APPROPRIATE EMPLOYEE TRAINING	23 CCR 16 2715(c)(6), 2715(f)
	H736	FAILURE TO MAINTAIN MONITORING, MAINTENANCE, AND REPAIR RECORDS	23 CCR 16 2712(b)
	H737	FAILURE TO MAINTAIN CORROSION PROTECTION RECORDS	23 CCR 16 2635, 2712(b)
	H738	FAILURE TO MAINTAIN AN APPROVED MONITORING PLAN ON SITE	23 CCR 16 2632, 2634, 2711, 2712(i)
	H739	FAILURE TO SUBMIT/MAINTAIN A WRITTEN OWNER/OPERATOR AGREEMENT	23 CCR 16 2620(b); HSC 6.7 25284(a)(3)
	H740	FAILURE TO RECORD AND/OR REPORTSUSPECTED OR ACTUAL UNAUTHORIZED RELEASE CORRECTLY	HSC 6.7 29294, 29295

Inspector: MARTY A BROWNFIELD

Inspection Date: 02/21/2014

SUMMARY OF OBSERVATIONS/VIOLATIONS

- No violations of hazardous waste laws/regulations were discovered. KERN CUPA greatly appreciates your efforts to comply with all the laws and regulations applicable to your facility.
- Violations were observed/discovered as listed below. All violations must be corrected by implementing the corrective action listed by each violation. If you disagree with any of the violations or corrective actions required, please inform the CUPA in writing.

ALL VIOLATIONS MUST BE CORRECTED WITHIN 30 DAYS OR AS SPECIFIED. CUPA must be informed in writing with a certification that compliance has been achieved. A false statement that compliance has been achieved is a violation of the law and punishable by a fine of not less than \$2,000 or more than \$25,000 for each violation. Your facility may be reinspected any time during normal business hours. If a second reinspection becomes necessary due to non compliance, a reinspection charge of \$100.00 per hour may be charged to the facility.

You may request a meeting with the Program Manager to discuss the inspection findings and/or the proposed corrective actions. The issuance of this Summary of Violations does not preclude the CUPA from taking administrative, civil, or criminal action.

VIOLATIONS

Violation Number	Violation Text	Violation Degree	Comply by
H680	Failure of the leak detection equipment to be properly programmed or properly operated. 23 CCR 16 2632, 2634, 2636, 2666	CLASS II VIOLATION	03/23/2014
Violation Details & Corrective Action Required:	<p><i>THE LIQUID SENSOR LOCATED IN THE PREMIUM (91 OCTANE) TURBINE SUMP FAILED TO SHUTDOWN THE TURBINE OF CAUSE THE SYSTEM TO GO INTO ALARM AS REQUIRED.</i></p> <p><i>THE UST FACILITY OWNER/OPERATOR MUST REPLACE AND RETEST THE SENSOR LOCATED IN THE PREMIUM (91 OCTANE) TURBINE SUMP WITHIN THIRTY (30) DAYS OF THE INITIAL FAILURE.</i></p>		
H694	Failure of sensor to be located in the proper position/location. 23 CCR 16 2630(d), 2641(a)	CLASS I VIOLATION	03/23/2014
Violation Details & Corrective Action Required:	<p><i>DURING THE COURSE OF THE INSPECTION IT WAS DISCOVERED THAT THE LIQUID SENSOR IN THE TURBINE SUMP WAS NOT PROPERLY PLACED IN THE LOWEST PORTION OF THE SUMP.</i></p> <p><i>THE SENSOR WAS FOUND HANGING FROM THE TOP RIM OF THE SUMP BY A SECTION OF METAL PLUMBER'S TAPE.</i></p> <p><i>THE SERVICE TECHNICIAN FROM RICH ENVIRONMENTAL REPLACED THE SENSOR IN ITS HOLDER AFTER TESTING WAS COMPLETED. VIOLATION CORRECTED ON SITE AT THE TIME OF THE INSPECTION.</i></p> <p><i>IT WAS DETERMINED THAT A SEPERATE 3RD PARTY UST CONTRACTOR HAD FAILED TO REPLACE THE SENSOR IN ITS PROPER LOCATION AFTER THEY HAD COMPLETED REPAIR WORK ON THE DIESEL TURBINE.</i></p> <p>*****</p> <p>**</p> <p><i>IT IS THE UST SYSTEM OWNER/OPERATOR'S RESPONSIBILITY TO ENSURE THEIR CONTRACTORS RETURN/REPLACE ALL SENSORS AND MONITORING EQUIPMENT TO THEIR CORRECT LOCATION AFTER THEY WORK ON ANY PORTIONS OF THE UST SYSTEM.</i></p> <p>*****</p> <p>**</p>		

Inspector: MARTY A BROWNFIELD

Inspection Date: 02/21/2014

H695 **Leak detection equipment disabled or tampered with in a manner that would prevent the monitoring system from detecting and/or alerting the owner/operator of a leak. HSC 6.7 25299(a)(9)** **CLASS I VIOLATION** **03/23/2014**

Violation Details & Corrective Action Required: *DURING THE COURSE OF THE INSPECTION IT WAS DISCOVERED THAT THE LIQUID SENSOR IN THE TURBINE SUMP WAS NOT PROPERLY PLACED IN THE LOWEST PORTION OF THE SUMP.*

THE SENSOR WAS FOUND HANGING FROM THE TOP RIM OF THE SUMP BY A SECTION OF METAL PLUMBER'S TAPE.

THE SERVICE TECHNICIAN FROM RICH ENVIRONMENTAL REPLACED THE SENSOR IN ITS HOLDER AFTER TESTING WAS COMPLETED. VIOLATION CORRECTED ON SITE AT THE TIME OF THE INSPECTION.

IT WAS DETERMINED THAT A SEPERATE 3RD PARTY UST CONTRACTOR HAD FAILED TO REPLACE THE SENSOR IN ITS PROPER LOCATION AFTER THEY HAD COMPLETED REPAIR WORK ON THE DIESEL TURBINE.

**

IT IS THE UST SYSTEM OWNER/OPERATOR'S RESPONSIBILITY TO ENSURE THEIR CONTRACTORS RETURN/REPLACE ALL SENSORS AND MONITORING EQUIPMENT TO THEIR CORRECT LOCATION AFTER THEY WORK ON ANY PORTIONS OF THE UST SYSTEM.

**

H717 **Failure to comply with one or more of the following: maintain the spill bucket in good condition, containment free of debris/liquid, and/or to remove the contents of the spill bucket when a release/leak/spill was observed. 23 CCR 16 2635(b), 2715(c)(2)** **CLASS II VIOLATION** **03/23/2014**

Violation Details & Corrective Action Required: *DURING THE COURSE OF THE INSPECTION THE REGULAR (87 OCTANE) OVERFILL/SPILL BUCKET WAS FOUND TO CONTAIN AN ACCUMULATION OF GASOLINE.*

THE SERVICE TECHNICIAN FROM RICH ENVIRONMENTAL REMOVED THE ACCUMULATED FUEL FROM THE SPILL BUCKET PRIOR TO FILLING IT WITH WATER FOR IT'S ANNUAL TIGHNESS TESTING.

**

THE FACILITY OWNER OPERATOR NEEDS TO CONTACT HIS FUEL PROVIDER/TRUCKING COMPANY AND REMIND THEM TO REMIND THEIR DRIVERS TO MAKE SURE THEY DRAIN ANY FUEL SPILLED IN THE BUCKETS AS A RESULT OF DELIVERING FUEL.

**

H753 **Failure of non integral secondary containment to be designed and constructed to an engineering specification approved by a registered professional engineer or in accordance with a nationally recognized industry core or engineering standard. 23 CCR 16 2631(d)** **CLASS II VIOLATION** **03/23/2014**

Violation Details & Corrective Action Required: *DURING THE INSPECTION IT WAS DISCOVERED THE TWO (2) GILBARCO ADVANTAGE FUEL DISPENSERS (5/6 & 7/8) LOCATED NEAREST TO TAFT HIGHWAY ARE NOT INSTALLED ON PROPERLY SIZED UDC'S. THE METERS FOR THESE TWO DISPENSERS ARE NOT PROTECTED FROM SPILLS BY THE UDC.*

THE UST FACILITY OWNER/OPERATOR MUST INSTALL A CALIFORNIA WATERBOARD LISTED AND APPROVED SPILL DIVERTER DEVICE IN THESE TWO DISPENSERS.

INSPECTION COMMENTS:

ADDITIONAL NOTES:

EXCEPTIONAL AMOUNTS OF AIR WERE OBSERVED IN THE DIESEL PRODUCT LINE DURING THE TESTING OF THE DIESEL MECHANICAL LINE LEAK DETECTOR. THIS LARGE ACCUMULATION OF AIR TRAPPED IN THE PRODUCT LINE SEVERELY COMPROMISES THE LINE LEAK DETECTORS ABILITY TO DETECT A MINIMUM OF A 3 GALLON PER HOUR LEAK. THIS MAY ALSO CAUSE A FALSE ACTITVATION OF THE LINE LEAK DETECTOR.

THE UST FACILITY OWNER/OPERATOR NEEDS TO WORK WITH A CALIFORNIA STATE LICENSED AND ICC CERTIFIED UST CONTRACTOR TO COME UP WITH AN ACCEPTABLE METHOD TO REMOVE/REDUCE THE ACCUMULATION OF AIR IN THE DIESEL PRODUCT LINE.

COMMENTS: Go to <http://www.co.kern.ca.us/eh/> (Hazardous Materials) for forms and information.

Inspector: MARTY A BROWNFIELD

Signature of Facility Representative:

Inspection Date: 02/21/2014

Certification: I certify under penalty of perjury that this facility has complied with the corrective actions listed on this inspection form.

Printed Name of Owner/Operator

Title

Signature of Owner/Operator

Date

MONITORING SYSTEM CERTIFICATION

For Use By All Jurisdictions Within the State of California

Authority Cited: Chapter 6.7, Health and Safety Code; Chapter 16, Division 3, Title 23, California Code of Regulations

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

A. General Information

Facility Name: JOHNNY QUICK Bldg. No.: _____
Site Address: 2126 TAFT HWY. City: BAKERSFIELD Zip: 93313
Facility Contact Person: MR. KOOL Contact Phone No.: (661) 834-9113
Make/Model of Monitoring System: TLS-350 Date of Testing/Servicing: 2/21/2014


B. Inventory of Equipment Tested/Certified

Check the appropriate boxes to indicate specific equipment inspected/serviced:

Tank ID: REG87 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: PREM91 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Tank ID: DIESEL <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: _____ <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input type="checkbox"/> Annular Space or Vault Sensor. Model: _____ <input type="checkbox"/> Piping Sump / Trench Sensor(s). Model: _____ <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Dispenser ID: 1/2 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 3/4 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: 5/6 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 7/8 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply): System set-up Alarm history report

Technician Name (print): RICHARD MASON Signature: 
Certification No.: 5927857-UT / B36880 License No.: C61/ D40 A HAZ 809850
Testing Company Name: RICH ENVIRONMENTAL Phone No.: (661) 392-8687
Testing Company Address: 5643 BROOKS CT. BAKERSFIELD, CA. 93308 Date of Testing/Servicing: 2/21/2014

D. Results of Testing/Serviceing

Software Version Installed: 332.00

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the audible alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the visual alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors visually inspected, functionally tested, and confirmed operational?
<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No*	Were all sensors installed at lowest point of secondary containment and positioned so that other equipment will not interfere with their proper operation?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	If alarms are relayed to a remote monitoring station, is all communications equipment (e.g., modem) operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected? If yes: which sensors initiate positive shut-down? <i>(Check all that apply)</i> <input checked="" type="checkbox"/> Sump/Trench Sensors; <input type="checkbox"/> Dispenser Containment Sensors. Did you confirm positive shut-down due to leaks <u>and</u> sensor failure/disconnection? <input checked="" type="checkbox"/> Yes; <input type="checkbox"/> No.
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For tank systems that utilize the monitoring system as the primary tank overfill warning device (i.e., no mechanical overfill prevention valve is installed), is the overfill warning alarm visible and audible at the tank fill point(s) and operating properly? If so, at what percent of tank capacity does the alarm trigger? %
<input checked="" type="checkbox"/> Yes*	<input type="checkbox"/> No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes, or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E, below.
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was liquid found inside any secondary containment systems designed as dry systems? <i>(Check all that apply)</i> <input type="checkbox"/> Product; <input type="checkbox"/> Water. If yes, describe causes in Section E, below.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was monitoring system set-up reviewed to ensure proper settings? Attach set up reports, if applicable
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is all monitoring equipment operational per manufacturer's specifications?

* In Section E below, describe how and when these deficiencies were or will be corrected.

E. Comments: 1) DIESEL SUMP SENSOR WAS RAISED AND HANGING ON TOP. NO LIQUID IN SUMP. I PLACED SENSOR AT LOWEST POINT. 2) 91 SUMP SENSOR (L:5) WAS BAD. I REPLACED ON 3/11/14 AND RE-TESTED - PASSED

F. In-Tank Gauging / SIR Equipment:

- Check this box if tank gauging is used only for inventory control.
- Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all tank gauging probes visually inspected for damage and residue buildup?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system product level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system water level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all probes reinstalled properly?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

G. Line Leak Detectors (LLD):


- Check this box if LLDs are not installed.

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For equipment start-up or annual equipment certification, was a leak simulated to verify LLD performance? (Check all that apply) Simulated leak rate: <input checked="" type="checkbox"/> 3 g.p.h.; <input type="checkbox"/> 0.1 g.p.h; <input type="checkbox"/> 0.2 g.p.h.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all LLDs confirmed operational and accurate within regulatory requirements?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was the testing apparatus properly calibrated?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

H. Comments:

53510 

I. Results of Vacuum/Pressure Monitoring Equipment Testing

This page should be used to document testing and servicing of vacuum and pressure interstitial sensors. A copy of this form must be included with the Monitoring System Certification Form, which must be provided to the tank system owner/operator. The owner/operator must submit a copy of the Monitoring System Certification Form to the local agency regulating UST systems within 30 days of test date.


Manufacturer: N/A		Model:		System Type: <input type="checkbox"/> Pressure; <input type="checkbox"/> Vacuum	
Sensor ID					
	Component(s) Monitored by this Sensor:				
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		
	Component(s) Monitored by this Sensor:				
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		
	Component(s) Monitored by this Sensor:				
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		
	Component(s) Monitored by this Sensor:				
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		
	Component(s) Monitored by this Sensor:				
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		
	Component(s) Monitored by this Sensor:				
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		
	Component(s) Monitored by this Sensor:				
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		
How was interstitial communication verified?					
<input type="checkbox"/> Leak Introduced at Far End of Interstitial Space; ¹ <input type="checkbox"/> Gauge; <input type="checkbox"/> Visual Inspection; <input type="checkbox"/> Other (Describe in Sec. J, below)					
Was vacuum/pressure restored to operating levels in all interstitial spaces? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no, describe in Sec. J, below)					

J. Comments: N/A

¹ If the sensor successfully detects a simulated vacuum/pressure leak introduced in the interstitial space at the furthest point from the sensor, vacuum/pressure has been demonstrated to be communicating throughout the interstice.

UST Monitoring Site Plan

Site Address: 2126 TAFT HWY. BAKERSFIELD, CA.



Date map was drawn: 2/14/2013.

Instructions

If you already have a diagram that shows all required information, you may include it, rather than this page, with your Monitoring System Certification. On your site plan, show the general layout of tanks and piping. Clearly identify locations of the following equipment, if installed: monitoring system control panels; sensors monitoring tank annular spaces, sumps, dispenser pans, spill containers, or other secondary containment areas; mechanical or electronic line leak detectors; and in-tank liquid level probes (if used for leak detection). In the space provided, note the date this Site Plan was prepared.

3310
M

RICH ENVIRONMENTAL
5643 BROOKS CT. BAKERSFIELD, CA. 93308
OFFICE (661)392-8687 FAX (661)392-0621
PRODUCT LINE LEAK DETECTOR TEST

WORK SHEET

W/O#: _____

FACILITY NAME: JOHNNY QUICK

FACILITY ADDRESS: 2126 TAFT HWY. BAKERSFIELD

PRODUCT LINE TYPE: PRESSURE

PRODUCT	LEAK DETECTOR TYPE SERIAL NUMBER	TEST BELOW 3 G.P.H.	TRIP P.S.I.	PASS OR FAIL
REG87	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>2347</u>	YES	10	PASS
PREM91	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>1262</u>	YES	10	PASS
DIESEL	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>3246</u>	YES	10	PASS
	L/D TYPE : <u> </u> SERIAL # <u> </u>	YES NO		PASS FAIL

I CERTIFY THE ABOVE TESTS WERE CONDUCTED ON THIS DATE ACCORDING TO RED JACKET PUMPS FIELD TEST APPARATUS TESTING PROCEDURE AND LIMITATIONS. THE MECHANICAL LEAK DETECTOR TEST PASS / FAIL IS DETERMINED BY USING A LOW FLOW THRESHOLD TRIP RATE OF 3 GALLONS PER HOUR OR LESS AT 10 P.S.I. I ACKNOWLEDGE THAT ALL DATA COLLECTED IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE.

TECHNICIAN: RICHARD MASON

SIGNATURE: _____


DATE: 2/21/14

Spill Bucket Testing Report Form

This form is intended for use by contractors performing annual testing of UST spill containment structures. The completed form and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: JOHNNY QUICK	Date of Testing: 2/21/14
Facility Address: 2126 TAFT HWY. BAKERSFIELD	
Facility Contact: MR. KOOL	Phone: (661) 834-9113
Date Local Agency Was Notified of Testing : 2/3/14	
Name of Local Agency Inspector (if present during testing): MARTY	

2. TESTING CONTRACTOR INFORMATION

Company Name: RICH ENVIRONMENTAL	
Technician Conducting Test: RICHARD MASON	
Credentials ¹ : <input type="checkbox"/> CSLB Contractor <input checked="" type="checkbox"/> ICC Service Tech. <input type="checkbox"/> SWRCB Tank Tester <input type="checkbox"/> Other (Specify) _____	
License Number(s): 5297857-UT	

3. SPILL BUCKET TESTING INFORMATION

Test Method Used: <input checked="" type="checkbox"/> Hydrostatic <input type="checkbox"/> Vacuum <input type="checkbox"/> Other				
Test Equipment Used: VISUAL	Equipment Resolution: 0.00			
Identify Spill Bucket (By Tank Number, Stored Product, etc.)	1 REG87-FILL	2 PREM91-FILL	3 DIESEL	4
Bucket Installation Type:	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump
Bucket Diameter:	12"	12"	12"	
Bucket Depth:	12"	12"	12"	
Wait time between applying vacuum/water and start of test:	30MIN	30MIN	30MIN	
Test Start Time (T _I):	9:00	9:00	9:00	
Initial Reading (R _I):	10"	10"	10"	
Test End Time (T _F):	10:00	10:00	10:00	
Final Reading (R _F):	10"	10"	10"	
Test Duration (T _F - T _I):	60MIN	60MIN	60MIN	
Change in Reading (R _F - R _I):	0	0	0	
Pass/Fail Threshold or Criteria:	0	0	0	
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

I hereby certify that all the information contained in this report is true, accurate, and in full compliance with legal requirements.

Technician's Signature: _____

Date: 2/21/14

¹ State laws and regulations do not currently require testing to be performed by a qualified contractor. However, local requirements may be more stringent.

h

SYSTEM SETUP

FEB 21, 2014 8:37 AM

IN-TANK SETUP

T 1:UNL87
 PRODUCT CODE : 1
 THERMAL COEFF : .000700
 TANK DIAMETER : 96.00
 TANK PROFILE : 4 PTS
 FULL VOL : 10000
 72.0 INCH VOL : 8192
 48.0 INCH VOL : 5091
 24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
 HIGH WATER LIMIT: 3.0
 WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10000
 OVERFILL LIMIT : 90%
 HIGH PRODUCT : 9000
 : 95%
 : 9500
 DELIVERY LIMIT : 10%
 : 1000

LOW PRODUCT : 1000
 LEAK ALARM LIMIT: 99
 SUDDEN LOSS LIMIT: 99
 TANK TILT : 0.00
 PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
 T#: NONE
 LINE MANIFOLDED TANKS
 T#: NONE

LEAK MIN PERIODIC: 10%
 : 1000

LEAK MIN ANNUAL : 10%
 : 1000

PERIODIC TEST TYPE
 STANDARD

ANNUAL TEST FAIL
 ALARM DISABLED

PERIODIC TEST FAIL
 ALARM DISABLED

GROSS TEST FAIL
 ALARM DISABLED

ANN TEST AVERAGING: OFF
 PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
 PUMP THRESHOLD : 10.00%

COMMUNICATIONS SETUP

PORT SETTINGS:

COMM BOARD : 1 (EDIM)
 RS-232 SECURITY
 CODE : DISABLED

COMM BOARD : 2 (RS-232)
 BAUD RATE : 9600
 PARITY : NONE
 STOP BIT : 1 STOP
 DATA LENGTH: 8 DATA
 RS-232 SECURITY
 CODE : DISABLED

COMM BOARD : 3 (RS-232)
 BAUD RATE : 1200
 PARITY : ODD
 STOP BIT : 1 STOP
 DATA LENGTH: 7 DATA
 RS-232 SECURITY
 CODE : DISABLED

AUTO TRANSMIT SETTINGS:

AUTO LEAK ALARM LIMIT
 DISABLED
 AUTO HIGH WATER LIMIT
 DISABLED
 AUTO OVERFILL LIMIT
 DISABLED
 AUTO LOW PRODUCT
 DISABLED
 AUTO THEFT LIMIT
 DISABLED
 AUTO DELIVERY START
 DISABLED
 AUTO DELIVERY END
 DISABLED
 AUTO EXTERNAL INPUT ON
 DISABLED
 AUTO EXTERNAL INPUT OFF
 DISABLED
 AUTO SENSOR FUEL ALARM
 DISABLED
 AUTO SENSOR WATER ALARM
 DISABLED
 AUTO SENSOR OUT ALARM
 DISABLED

RS-232 END OF MESSAGE
 DISABLED

SYSTEM UNITS

U.S.
 SYSTEM LANGUAGE
 ENGLISH
 SYSTEM DATE/TIME FORMAT
 MON DD YYYY HH:MM:SS xM

JOHNNY QUICK 143
 2126 TAFT HWY
 BAKERSFIELD CA 93313
 661-834-9113

SHIFT TIME 1 : 8:00 AM
 SHIFT TIME 2 : DISABLED
 SHIFT TIME 3 : DISABLED
 SHIFT TIME 4 : DISABLED

TANK PER TST NEEDED WRN
 DISABLED
 TANK ANN TST NEEDED WRN
 DISABLED

LINE RE-ENABLE METHOD
 PASS LINE TEST

LINE PER TST NEEDED WRN
 DISABLED
 LINE ANN TST NEEDED WRN
 DISABLED

PRINT TC VOLUMES
 ENABLED

TEMP COMPENSATION
 VALUE (DEG F): 60.0
 STICK HEIGHT OFFSET
 DISABLED
 ULLAGE: 90%

H-PROTOCOL DATA FORMAT
 HEIGHT
 DAYLIGHT SAVING TIME
 ENABLED
 START DATE
 MAR WEEK 2 SUN
 START TIME
 2:00 AM
 END DATE
 NOV WEEK 1 SUN
 END TIME
 2:00 AM

RE-DIRECT LOCAL PRINTOUT
 DISABLED

EURO PROTOCOL PREFIX
 S

SYSTEM SECURITY
 CODE : 000000

MAINTENANCE HISTORY
 DISABLED

LEAK TEST METHOD

TEST ON DATE : ALL TANK
MAY 27, 2011
START TIME : DISABLED
TEST RATE : 0.20 GAL/HR
DURATION : 2 HOURS

TST EARLY STOP:DISABLED

LEAK TEST REPORT FORMAT
NORMAL

LIQUID SENSOR SETUP

L 1:87 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 2:91 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 3:DSL ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 4:87 STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 5:91 STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 6:DSL STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

T 3:DIESEL
PRODUCT CODE : 3
THERMAL COEFF : .000450
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
: 9000
HIGH PRODUCT : 95%
: 9500
DELIVERY LIMIT : 10%
: 1000

LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
: 1000
LEAK MIN ANNUAL : 10%
: 1000

PERIODIC TEST TYPE
STANDARD
ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED
GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF
TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF
DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

T 2:PREM91
PRODUCT CODE : 2
THERMAL COEFF : .000700
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
: 9000
HIGH PRODUCT : 95%
: 9500
DELIVERY LIMIT : 10%
: 1000

LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
: 1000
LEAK MIN ANNUAL : 10%
: 1000

PERIODIC TEST TYPE
STANDARD
ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED
GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF
TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF
DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

EVR/ISD SETUP

EVR TYPE: BALANCE

BALANCE NOZZLE TYPE
VST

VAPOR PROCESSOR TYPE
WEEDER-ROOT POLISHER

ANALYSIS TIMES
TIME: 10:00 AM
DELAY MINUTES: 1

ACCEPT HIGH ORVR:
DISABLED

ISD HOSE TABLE

ID	FP	FL	HL	AA	RR
01	01	01	02	01	02
02	02	02	02	01	02
03	03	03	02	02	02
04	04	04	02	02	02
05	05	05	02	03	02
06	06	06	02	03	02
07	07	07	02	04	02
08	08	08	02	04	02

ISD AIRFLOW METER MAP

ID	SERIAL NUM	LABEL
1	54188	DISP 1-2 A
2	54184	DISP 3-4 A
3	54186	DISP 5-6 A
4	54207	DISP 7-8 A

ISD FUEL GRADE HOSE MAP

FP	MHH	MHH	MHH	MHH	AA
01	201	101	901	3	U 1
02	202	102	902	3	U 1
03	203	103	903	3	U 2
04	204	104	904	3	U 2
05	305	105	205	U	U 3
06	306	106	206	U	U 3
07	307	107	207	U	U 4
08	308	108	208	U	U 4

LABEL TABLE

- 1: UNASSIGNED
- 2: BLENDS
- 3: REGULAR
- 4: MID GRADE
- 5: PREMIUM
- 6: GOLD
- 7: BRONZE
- 8: SILVER
- 9: BLEND2
- 10: BLEND4

OUTPUT RELAY SETUP

R 1:87
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 1

LIQUID SENSOR ALMS
L 1:FUEL ALARM
L 4:FUEL ALARM
L 1:SENSOR OUT ALARM
L 4:SENSOR OUT ALARM

ISD SITE ALARMS
ISD GROSS PRES FAIL
ISD DEGRD PRES FAIL
ISD VAPOR LEAK FAIL
ISD VP PRES FAIL
ISD VP STATUS FAIL

ISD HOSE ALARMS
ALL:FLOW COLLECT FAIL

R 2:91
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 2

LIQUID SENSOR ALMS
L 2:FUEL ALARM
L 5:FUEL ALARM
L 2:SENSOR OUT ALARM
L 5:SENSOR OUT ALARM

ISD SITE ALARMS
ISD GROSS PRES FAIL
ISD VAPOR LEAK FAIL
ISD VP PRES FAIL
ISD VP STATUS FAIL

ISD HOSE ALARMS
ALL:FLOW COLLECT FAIL

R 3:DSL
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 3

LIQUID SENSOR ALMS
L 3:FUEL ALARM
L 6:FUEL ALARM
L 3:SENSOR OUT ALARM
L 6:SENSOR OUT ALARM

SMARTSENSOR SETUP

s 1:CARBON CANISTOR
CATEGORY VAPOR VALVE

s 2:VAPOR PRESSURE
CATEGORY VAPOR PRESSURE

s 3:DISP 1-2 AFM
CATEGORY AIR FLOW METER

s 4:DISP 3-4 AFM
CATEGORY AIR FLOW METER

s 5:DISP 5-6 AFM
CATEGORY AIR FLOW METER

s 6:DISP 7-8 AFM
CATEGORY AIR FLOW METER

s 8:ATM
CATEGORY ATM P SENSOR

M

----- SENSOR ALARM -----
L 4:87 STP
STP SUMP
SENSOR OUT ALARM
FEB 21. 2014 10:24 AM

FUEL ALARM
FEB 21. 2014 10:16 AM

SENSOR OUT ALARM
MAY 11. 2013 9:50 AM

----- SENSOR ALARM -----
L 11:87 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 21. 2014 10:24 AM

FUEL ALARM
FEB 21. 2014 10:20 AM

FUEL ALARM
MAY 11. 2013 9:50 AM

* * * * * END * * * * *

* * * * * END * * * * *

ALARM HISTORY REPORT

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 5:91 STP
STP SUMP
FUEL ALARM
FEB 21. 2014 10:03 AM

SENSOR OUT ALARM
FEB 21. 2014 10:00 AM

SENSOR OUT ALARM
MAY 29. 2013 1:11 PM

----- SENSOR ALARM -----
L 2:91 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 21. 2014 10:24 AM

FUEL ALARM
FEB 21. 2014 10:15 AM

SENSOR OUT ALARM
JUN 8. 2013 12:21 AM

* * * * * END * * * * *

* * * * * END * * * * *

ALARM HISTORY REPORT

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 6:DSL STP
STP SUMP
SENSOR OUT ALARM
FEB 21. 2014 10:24 AM

FUEL ALARM
FEB 21. 2014 9:25 AM

FUEL ALARM
MAY 16. 2013 2:06 PM

----- SENSOR ALARM -----
L 9:DSL ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 21. 2014 10:24 AM

FUEL ALARM
FEB 21. 2014 9:29 AM

FUEL ALARM
MAY 11. 2013 8:32 AM

M

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 5:91 STP
STP SUMP
FUEL ALARM
MAR 11, 2014 3:24 PM

SENSOR OUT ALARM
MAR 11, 2014 3:19 PM

FUEL ALARM
FEB 21, 2014 10:03 AM

----- SENSOR ALARM -----
L 5:91 STP
STP SUMP
SENSOR OUT ALARM
MAR 11, 2014 3:19 PM

----- SENSOR ALARM -----
L 5:91 STP
STP SUMP
FUEL ALARM
MAR 11, 2014 3:24 PM

Handwritten mark

* * * * * END * * * * *

JOHNNY QUICK 143
2126 TAFT HWY
BAKERSFIELD CA 93313
661-834-9113

MAR 11, 2014 3:34 PM

SYSTEM STATUS REPORT

ALL FUNCTIONS NORMAL

M

MONITOR CERT. FAILURE REPORT

SITE NAME: JOHNNY QUICK DATE: 2/21/14 / 3/11/14

ADDRESS: 2126 TAFT HWY. TECHNICIAN: RICHARD MASON

CITY: BAKERSFIELD SIGNATURE:

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS: 1) DIESEL STP SUMP SENSOR WAS RAISED, I LOWERED. 2) 91 SUMP SENSOR FAILED, I REPLACED ON 3/11/14 AND RE-TESTED.

LABOR: 1 HOUR

PARTS INSTALLED: 1- VEEDER-ROOT 208 SENSOR

NAME: TITLE:

SIGNATURE:

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENENCE.

ENVIRONMENTAL HEALTH PERMIT

KERN COUNTY PUBLIC HEALTH SERVICES DEPARTMENT
ENVIRONMENTAL HEALTH SERVICES DIVISION

2700 M ST SUITE 300 BAKERSFIELD CA 93301

(661) 862-8740 www.co.kern.ca.us/eh e-mail: eh@co.kern.ca.us

REGULATED FACILITY:

JOHNNY QUIK #143
126 TAFT HWY
BAKERSFIELD CA 93313

IDENTIFICATION NUMBERS:

FACILITY ID: FA0002691
CERS ID: 10233775
FILE ID: 003201

OWNER(S) OF RECORD:

KULJIT SINGH GHUMAN

General Health Program

BUS PLAN MED LOW RISK 1 UNIT
UNDERGROUND STORAGE TANK PROGRAM

Permit #

0000313
0013545

Additional Information

Effective Thru

06/30/2017
02/28/2017

(See tank information on back)

Permit Issued: 03/01/2013

Matthew Constantine
Public Health Services Director

This ENVIRONMENTAL HEALTH PERMIT is issued to the owner(s) and establishment shown above subject to compliance with all applicable laws and regulations. Permit is valid unless revoked or suspended for violation of applicable laws and regulations.

The underground storage tank portion of this permit is valid for one year after the Permit Issued date

PERMIT IS NON-TRANSFERABLE AND MUST BE PROMINENTLY DISPLAYED IN THE PLACE OF BUSINESS

Underground Storage Tank Facilities:

1. The permit holder shall comply with the monitoring, response, and plot plans approved by this Department. The underground storage tanks must also be monitored according to the applicable requirements in the California Code of Regulations, Title 23, Division 3, Chapter 16.
2. A copy of the facility's underground storage tank leak prevention monitoring program (including facility form, tank form, monitoring plan, response plan, and plot plan), as approved by this Department, must be maintained on site.
3. Monitoring of the tank system(s) shall be according to the Monitoring Plan(s) attached and approved by this Department.
4. Monitor panel shall be inspected daily. Inspections shall be documented and maintained on site.
5. The underground storage tank system shall be operated and maintained in accordance with the manufacturer's instructions, including routine maintenance and service checks (at least once per year) for operability or running condition.
6. A report documenting the maintenance, testing, monitoring, and any changes to the underground storage tanks shall be submitted to this Department each year.
7. The facility owner and operator shall ensure that the facility has adequate financial responsibility insurance coverage, as mandated for all underground storage tanks containing petroleum, and supply proof of such coverage to this Department.
8. The owner and/or operator must report any significant unauthorized release from underground storage tanks within 24 hours of discovery.

KULJIT SINGH GHUMAN
2126 TAFT HWY
BAKERSFIELD, CA 93313

STATE REQUIRED SUPPLEMENTAL INFORMATION

<u>STATE UST ID#</u>	<u>SIZE(GAL)</u>	<u>CONTENTS</u>
15-010-002691-0001	10,000	REGULAR UNLEADED
15-010-002691-0002	10,000	PREMIUM UNLEADED
15-010-002691-0003	10,000	DIESEL

MONITORING PLAN

Kern County Environmental Health Services Department
2700 M Street, Suite 300
Bakersfield, CA 93301
(661) 862-8740 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
UNDERGROUND STORAGE TANK

(Page 1 of 2)

TYPE OF ACTION [] 1. NEW PLAN [] 2. CHANGE OF INFORMATION 490-1

PLAN TYPE [] 1. MONITORING IS IDENTICAL FOR ALL USTs AT THIS FACILITY 490-2
(Check one item only) [X] 2. THIS PLAN COVERS ONLY THE FOLLOWING UST SYSTEM(S) 1 - REGULAR UNLEADED

I. FACILITY INFORMATION

FACILITY ID# (Agency Use Only) FA0002691
BUSINESS NAME (Same as FACILITY NAME) JOHNNY QUIK #143
BUSINESS SITE ADDRESS 2126 TAFT HWY 103 CITY BAKERSFIELD 104

II. EQUIPMENT TESTING AND PREVENTIVE MAINTENANCE

Testing, preventive maintenance, and calibration of monitoring equipment (e.g., sensors, probes, line leak detectors, etc.) must be performed at the frequency specified by the equipment manufacturers' instructions, or annually, whichever is more frequent, and that such work must be performed by qualified personnel. (23 CCR 2632, 2634, 2638, 2641)

MONITORING EQUIPMENT IS SERVICED [X] 1. ANNUALLY [] 99. OTHER (Specify) 490-3a-b

III. MONITORING LOCATIONS

[] 1. NEW SITE PLOT PLAN/MAP SUBMITTED WITH THIS PLAN. [X] 2. SITE PLOT PLAN/MAP PREVIOUSLY SUBMITTED. 490-4
(23 CCR 2632, 2634)

IV. TANK MONITORING IS PERFORMED USING THE FOLLOWING METHOD(S):

[X] 1. CONTINUOUS ELECTRONIC TANK MONITORING OF ANNULAR (INTERSTITIAL) SPACE(S) OR SECONDARY CONTAINMENT 490-5
VAULT(S) WITH AUDIBLE AND VISUAL ALARMS. (23 CCR 2632, 2634)

SECONDARY CONTAINMENT IS: [X] a. DRY [] b. LIQUID FILLED [] c. PRESSURIZED [] d. UNDER VACUUM 490-6

PANEL MANUFACTURER: VEEDER ROOT 490-7 MODEL #: TLS 350 490-8

LEAK SENSOR MANUFACTURER: VEEDER ROOT 490-9 MODEL #(S): 420 490-10

[] 2. AUTOMATIC TANK GAUGING (ATG) SYSTEM USED TO MONITOR SINGLE WALL TANK(S). (23 CCR 2643) 490-11

PANEL MANUFACTURER: 490-12 MODEL #: 490-13

IN-TANK PROBE MANUFACTURER: 490-14 MODEL #(S): 490-15

LEAK TEST FREQUENCY: [] a. CONTINUOUS [] b. DAILY/NIGHTLY [] c. WEEKLY 490-16

[] d. MONTHLY [] e. OTHER (Specify): 490-17

PROGRAMMED TESTS: [] a. 0.1 g.p.h. [] b. 0.2 g.p.h. [] c. OTHER (Specify): 490-18-19

[] 3. MONTHLY STATISTICAL INVENTORY RECONCILIATION (23 CCR 2646.1): 490-20

[] 4. WEEKLY MANUAL TANK GAUGING (MTG) (23 CCR 2645). TESTING PERIOD: [] a. 36 HOURS [] b. 60 HOURS 490-21-22

[] 5. TANK INTEGRITY TESTING (23 CCR 2643.1): 490-23

TEST FREQUENCY: [] a. ANNUALLY [] b. BIENNIALY [] c. OTHER (Specify): 490-24-25

[] 99. OTHER (Specify): 490-26-27

V. PIPE MONITORING IS PERFORMED USING THE FOLLOWING METHOD(S) (Check all that apply)

[X] 1. CONTINUOUS MONITORING OF PIPE/PIPING SUMP(S) AND OTHER SECONDARY CONTAINMENT WITH AUDIBLE AND VISUAL 490-28
ALARMS. (23 CCR 2636)

SECONDARY CONTAINMENT IS: [X] a. DRY [] b. LIQUID FILLED [] c. PRESSURIZED [] d. UNDER VACUUM 490-29

PANEL MANUFACTURER: VEEDER ROOT 490-30 MODEL #: TLS 350 490-31

LEAK SENSOR MANUFACTURER: VEEDER ROOT 490-32 MODEL #(S): 208 490-33

PIPING LEAK ALARM TRIGGERS AUTOMATIC PUMP (i.e., TURBINE) SHUTDOWN [X] a. YES [] b. NO 490-34

FAILURE/DISCONNECTION OF THE MONITORING SYSTEM TRIGGERS AUTOMATIC PUMP SHUTDOWN [X] a. YES [] b. NO 490-35

[X] 2. MECHANICAL LINE LEAK DETECTOR (MLLD) THAT ROUTINELY PERFORMS 3.0 g.p.h. LEAK TESTS AND RESTRICTS OR SHUTS 490-36
OFF PRODUCT FLOW WHEN A LEAK IS DETECTED (23 CCR 2636)

MLLD MANUFACTURER(S): RED JACKET 490-37 MODEL #(S): FX 1V 490-38

[] 3. ELECTRONIC LINE LEAK DETECTOR (ELLD) THAT ROUTINELY PERFORMS 3.0 g.p.h. LEAK TESTS (23 CRRR 2636) 490-39

ELLD MANUFACTURER(S): 490-40 MODEL #(S): 490-41

PROGRAMMED IN LINE LEAK TEST: [] 1. MINIMUM MONTHLY 0.2 g.p.h. [] 2. MINIMUM ANNUAL 0.1 g.p.h. 490-42

ELLD DETECTION OF A PIPING LEAK TRIGGERS AUTOMATIC PUMP SHUTDOWN [] a. YES [X] b. NO 490-43

ELLD FAILURE/DISCONNECTION TRIGGERS AUTOMATIC PUMP SHUTDOWN [] a. YES [X] b. NO 490-44

[] 4. PIPE INTEGRITY TESTING 490-45

TEST FREQUENCY [] a. ANNUALLY [] b. EVERY 3 YEARS [] c. OTHER (Specify) 490-46 490-47

[] 5. VISUAL PIPE MONITORING 490-48

TEST FREQUENCY [] a. DAILY [] b. WEEKLY [] c. MIN.MONTHLY & EACH TIME SYSTEM OPERATED* 490-49

* Allowed for monitoring of unburied emergency generator fuel piping only per HSC 25281.5 (b)(3)

[] 6. SUCTION PIPING MEETS EXEMPTION CRITERIA [23 CCR 2636(a)(3)]. 490-50

[] 7. NO REGULATED PIPING PER HEALTH AND SAFETY CODE, DIVISION 20, CHAPTER 6.7 IS CONNECTED TO THE TANK SYSTEM 490-51

[] 99. OTHER (Specify) 490-52-53

MONITORING PLAN

VI. UNDER DISPENSER CONTAINMENT (UDC) MONITORING

1. UDC MONITORING IS PERFORMED USING THE FOLLOWING METHOD

490-54a

1. CONTINUOUS ELECTRONIC MONITORING
 2. FLOAT AND CHAIN ASSEMBLY
 3. ELECTRONIC STAND-ALONE
 490-54b
 4. NO DISPENSERS
 99. OTHER (Specify)

PANEL MANUFACTURER: _____ 490-55 MODEL #: _____ 490-56
 LEAK SENSOR MANUFACTURER: **BEAUDREAU** 490-57 MODEL #(S): **406** 490-58

- DETECTION OF A LEAK INTO THE UDC TRIGGERS AUDIBLE AND VISUAL ALARMS
 a. YES b. NO 490-59
 UDC LEAK ALARM TRIGGERS AUTOMATIC PUMP SHUTDOWN
 a. YES b. NO 490-60
 FAILURE/DISCONNECTION OF UDC MONITORING SYSTEM TRIGGERS AUTOMATIC PUMP SHUTDOWN
 a. YES b. NO 490-61
 LEAK SENSOR MANUFACTURER: _____
 a. YES b. NO 490-62

2. UDC CONSTRUCTION IS 1. SINGLE-WALLED 2. DOUBLE-WALLED 490-63

IF DOUBLE WALLED: 490-64a

- UDC INTERSTITIAL SPACE IS MONITORED BY:
 1. LIQUID 2. PRESSURE 3. VACCUM
 A LEAK WITHIN THE SECONDARY CONTAINMENT OF THE UDC TRIGGERS AUDIBLE AND VISUAL ALARMS
 a. YES b. NO 490-64b

VII. PERIODIC SYSTEM TESTING

1. **ELD TESTING:** THIS FACILITY HAS BEEN NOTIFIED BY THE STATE WATER RESOURCES CONTROL BOARD THAT **ENHANCED LEAK DETECTION DETECTION (ELD)** MUST BE PERFORMED. PERIODIC ELD IS PERFORMED EVERY 36 MONTHS AS REQUIRED. (23 CCR 2644.1) 490-65
 2. **SECONDARY CONTAINMENT COMPONENTS ARE TESTED EVERY 36 MONTHS.** 490-66
 3. **SPILL BUCKETS ARE TESTED ANNUALLY.** 490-67

VIII. RECORDKEEPING

- The following monitoring/maintenance records are kept for this facility:
- Alarm logs 490-68a Visual inspection records 490-68b Tank integrity testing results 490-68c
 SIR testing results (and supporting documentation records) 490-68d Tank gauging results (and supporting documentation records) 490-68e
 ATG Testing results (and supporting documentation records) 490-68f Corrosion protection 60-day logs 490-68g
 Equipment maintenance and calibration records 490-68h

IX. TRAINING

- Personnel with UST monitoring responsibilities are familiar with all of the following documents relevant to their job duties. 490-69a
REFERENCE DOCUMENTS MAINTAINED AT FACILITY (Check all that apply)
 THIS UNDERGROUND STORAGE TANK MONITORING PLAN (Required) 490-69b
 OPERATING MANUALS FOR ELECTRONIC MONITORING EQUIPMENT (Required) 490-69c
 CALIFORNIA UNDERGROUND STORAGE TANK REGULATIONS 490-69d
 CALIFORNIA UNDERGROUND STORAGE TANK LAW 490-69e
 STATE WATER RESOURCES CONTROL BOARD (SWRCB) PUBLICATION: "HANDBOOK FOR TANK OWNERS-MANUAL AND STATISTICAL INVENTORY RECONCILIATION" 490-69f
 SWRCB PUBLICATION: "UNDERSTANDING AUTOMATIC TANK GAUGING SYSTEMS" 490-69g
 OTHER (Specify): _____ 490-69h-69i
 This facility has a "Designated UST Operator" who has passed the California UST System Operator Exam administered by the International Code Council (ICC). 490-70
 The "Designated UST Operator" will train facility employees in the proper operation and maintenance of the UST systems annually, and within 30 days of hire.
 This training will include, but is not limited to, the following:
 - Operation of the UST systems in a manner consistent with the facility's best management practices
 - The facility employee's role with regard to the monitoring equipment as specified in this UST Monitoring Plan
 - The facility employee's role with regard to spills and overfills as specified in the UST Response Plan
 - Names of contact person(s) for emergencies and monitoring alarms.

X. COMMENTS/ADDITIONAL INFORMATION

Provide additional comments here or indicate how many pages with additional information on specific monitoring procedures are attached to this plan. 490-71

XI. PERSONNEL RESPONSIBILITIES

The UST Owner/Operator is responsible for ensuring that: 1) the daily/routine UST monitoring activities and maintenance of UST leak detection equipment covered by this plan occurs, 2) all conditions that indicate a possible release are investigated, and 3) all monitoring records are maintained properly.
 The following person(s) are responsible for performing the monitoring and equipment maintenance:

NAME	490-72	TITLE	490-73
NAME	490-74	TITLE	490-75

The Designated Operator shall perform a monthly visual inspection of the facility, provide a report to the owner/operator, and inform the owner/operator of any conditions that need follow-up action.

XII. OWNER/OPERATOR SIGNATURE

CERTIFICATION: I certify that the informatino provided herein is true and accurate to the best of my knowledge.

APPLICANT SIGNATURE	490-76	DATE:	490-77
REPRESENTING: <input type="checkbox"/> 1. Tank Owner/Operator <input type="checkbox"/> 2. Facility Owner/Operator <input type="checkbox"/> 3. Authorized Representative of Owner			
APPLICANT NAME (print):	490-78	APPLICANT TITLE:	490-79

(Agency Use Only) This plan has been reviewed and: Approved Approved With Conditions

Local Agency Signature: _____ Date: _____

Comments or Special Conditions: _____

MONITORING PLAN

Kern County Environmental Health Services Department
 2700 M Street, Suite 300
 Bakersfield, CA 93301
 (661) 862-8740 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
 UNDERGROUND STORAGE TANK

(Page 1 of 2)

TYPE OF ACTION	<input type="checkbox"/> 1. NEW PLAN <input type="checkbox"/> 2. CHANGE OF INFORMATION	490-1
PLAN TYPE	<input type="checkbox"/> 1. MONITORING IS IDENTICAL FOR ALL USTs AT THIS FACILITY (Check one item only) <input checked="" type="checkbox"/> 2. THIS PLAN COVERS ONLY THE FOLLOWING UST SYSTEM(S)	490-2
I. FACILITY INFORMATION		
FACILITY ID# (Agency Use Only)	FA0002691	1
BUSINESS NAME (Same as FACILITY NAME)	JOHNNY QUIK #143	3
BUSINESS SITE ADDRESS	2126 TAFT HWY 103 CITY BAKERSFIELD	104
II. EQUIPMENT TESTING AND PREVENTIVE MAINTENANCE		
Testing, preventive maintenance, and calibration of monitoring equipment (e.g., sensors, probes, line leak detectors, etc.) must be performed at the frequency specified by the equipment manufacturers' instructions, or annually, whichever is more frequent, and that such work must be performed by qualified personnel. (23 CCR 2632, 2634, 2638, 2641)		
MONITORING EQUIPMENT IS SERVICED	<input checked="" type="checkbox"/> 1. ANNUALLY <input type="checkbox"/> 99. OTHER (Specify)	490-3a-b
III. MONITORING LOCATIONS		
<input type="checkbox"/> 1. NEW SITE PLOT PLAN/MAP SUBMITTED WITH THIS PLAN.	<input checked="" type="checkbox"/> 2. SITE PLOT PLAN/MAP PREVIOUSLY SUBMITTED. (23 CCR 2632, 2634)	490-4
IV. TANK MONITORING IS PERFORMED USING THE FOLLOWING METHOD(S):		
<input checked="" type="checkbox"/> 1. CONTINUOUS ELECTRONIC TANK MONITORING OF ANNULAR (INTERSTITIAL) SPACE(S) OR SECONDARY CONTAINMENT VAULT(S) WITH AUDIBLE AND VISUAL ALARMS. (23 CCR 2632, 2634)		490-5
SECONDARY CONTAINMENT IS: <input checked="" type="checkbox"/> a. DRY <input type="checkbox"/> b. LIQUID FILLED <input type="checkbox"/> c. PRESSURIZED <input type="checkbox"/> d. UNDER VACUUM		490-6
PANEL MANUFACTURER: VEEDER ROOT	490-7 MODEL #: TLS 350	490-8
LEAK SENSOR MANUFACTURER: VEEDER ROOT	490-9 MODEL #(S): 420	490-10
<input type="checkbox"/> 2. AUTOMATIC TANK GAUGING (ATG) SYSTEM USED TO MONITOR SINGLE WALL TANK(S). (23 CCR 2643)		490-11
PANEL MANUFACTURER:	490-12 MODEL #:	490-13
IN-TANK PROBE MANUFACTURER:	490-14 MODEL #(S):	490-15
LEAK TEST FREQUENCY: <input type="checkbox"/> a. CONTINUOUS <input type="checkbox"/> b. DAILY/NIGHTLY <input type="checkbox"/> c. WEEKLY <input type="checkbox"/> d. MONTHLY <input type="checkbox"/> e. OTHER (Specify):		490-16 490-17
PROGRAMMED TESTS:	<input type="checkbox"/> a. 0.1 g.p.h. <input type="checkbox"/> b. 0.2 g.p.h. <input type="checkbox"/> c. OTHER (Specify):	490-18-19
<input type="checkbox"/> 3. MONTHLY STATISTICAL INVENTORY RECONCILIATION (23 CCR 2646.1):		490-20
<input type="checkbox"/> 4. WEEKLY MANUAL TANK GAUGING (MTG) (23 CCR 2645). TESTING PERIOD:	<input type="checkbox"/> a. 36 HOURS <input type="checkbox"/> b. 60 HOURS	490-21-22
<input type="checkbox"/> 5. TANK INTEGRITY TESTING (23 CCR 2643.1): TEST FREQUENCY:	<input type="checkbox"/> a. ANNUALLY <input type="checkbox"/> b. BIENNIALY <input type="checkbox"/> c. OTHER (Specify):	490-23 490-24-25
<input type="checkbox"/> 99. OTHER (Specify):		490-26-27
V. PIPE MONITORING IS PERFORMED USING THE FOLLOWING METHOD(S) (Check all that apply)		
<input checked="" type="checkbox"/> 1. CONTINUOUS MONITORING OF PIPE/PIPING SUMP(S) AND OTHER SECONDARY CONTAINMENT WITH AUDIBLE AND VISUAL ALARMS. (23 CCR 2636)		490-28
SECONDARY CONTAINMENT IS: <input checked="" type="checkbox"/> a. DRY <input type="checkbox"/> b. LIQUID FILLED <input type="checkbox"/> c. PRESSURIZED <input type="checkbox"/> d. UNDER VACUUM		490-29
PANEL MANUFACTURER: VEEDER ROOT	490-30 MODEL #: TLS 350	490-31
LEAK SENSOR MANUFACTURER: VEEDER ROOT	490-32 MODEL #(S): 208	490-33
PIPING LEAK ALARM TRIGGERS AUTOMATIC PUMP (i.e., TURBINE) SHUTDOWN	<input checked="" type="checkbox"/> a. YES <input type="checkbox"/> b. NO	490-34
FAILURE/DISCONNECTION OF THE MONITORING SYSTEM TRIGGERS AUTOMATIC PUMP SHUTDOWN	<input checked="" type="checkbox"/> a. YES <input type="checkbox"/> b. NO	490-35
<input checked="" type="checkbox"/> 2. MECHANICAL LINE LEAK DETECTOR (MLLD) THAT ROUTINELY PERFORMS 3.0 g.p.h. LEAK TESTS AND RESTRICTS OR SHUTS OFF PRODUCT FLOW WHEN A LEAK IS DETECTED (23 CCR 2636)		490-36
MLLD MANUFACTURER(S): RED JACKET	490-37 MODEL #(S): FX IV	490-38
<input type="checkbox"/> 3. ELECTRONIC LINE LEAK DETECTOR (ELLD) THAT ROUTINELY PERFORMS 3.0 g.p.h. LEAK TESTS (23 CCR 2636)		490-39
ELLD MANUFACTURER(S):	490-40 MODEL #(S):	490-41
PROGRAMMED IN LINE LEAK TEST:	<input type="checkbox"/> 1. MINIMUM MONTHLY 0.2 g.p.h. <input type="checkbox"/> 2. MINIMUM ANNUAL 0.1 g.p.h.	490-42
ELLD DETECTION OF A PIPING LEAK TRIGGERS AUTOMATIC PUMP SHUTDOWN	<input type="checkbox"/> a. YES <input checked="" type="checkbox"/> b. NO	490-43
ELLD FAILURE/DISCONNECTION TRIGGERS AUTOMATIC PUMP SHUTDOWN	<input type="checkbox"/> a. YES <input checked="" type="checkbox"/> b. NO	490-44
<input type="checkbox"/> 4. PIPE INTEGRITY TESTING TEST FREQUENCY	<input type="checkbox"/> a. ANNUALLY <input type="checkbox"/> b. EVERY 3 YEARS <input type="checkbox"/> c. OTHER (Specify)	490-45 490-46 490-47
<input type="checkbox"/> 5. VISUAL PIPE MONITORING TEST FREQUENCY	<input type="checkbox"/> a. DAILY <input type="checkbox"/> b. WEEKLY <input type="checkbox"/> c. MIN. MONTHLY & EACH TIME SYSTEM OPERATED*	490-48 490-49
* Allowed for monitoring of unburied emergency generator fuel piping only per HSC 25281.5 (b)(3)		
<input type="checkbox"/> 6. SUCTION PIPING MEETS EXEMPTION CRITERIA [23 CCR 2636(a)(3)].		490-50
<input type="checkbox"/> 7. NO REGULATED PIPING PER HEALTH AND SAFETY CODE, DIVISION 20, CHAPTER 6.7 IS CONNECTED TO THE TANK SYSTEM		490-51
<input type="checkbox"/> 99. OTHER (Specify)		490-52-53

MONITORING PLAN

(Page 2 of 2)

VI. UNDER DISPENSER CONTAINMENT (UDC) MONITORING

1. UDC MONITORING IS PERFORMED USING THE FOLLOWING METHOD

490-54a

1. CONTINUOUS ELECTRONIC MONITORING 2. FLOAT AND CHAIN ASSEMBLY 3. ELECTRONIC STAND-ALONE 490-54b
 4. NO DISPENSERS 99. OTHER (Specify)

PANEL MANUFACTURER: 490-55 MODEL #: 490-56

LEAK SENSOR MANUFACTURER: **BEAUDREAU** 490-57 MODEL #(S): **406** 490-58

DETECTION OF A LEAK INTO THE UDC TRIGGERS AUDIBLE AND VISUAL ALARMS a. YES b. NO 490-59

UDC LEAK ALARM TRIGGERS AUTOMATIC PUMP SHUTDOWN a. YES b. NO 490-60

FAILURE/DISCONNECTION OF UDC MONITORING SYSTEM TRIGGERS AUTOMATIC PUMP SHUTDOWN a. YES b. NO 490-61

LEAK SENSOR MANUFACTURER: a. YES b. NO 490-62

2. UDC CONSTRUCTION IS 1. SINGLE-WALLED 2. DOUBLE-WALLED 490-63

IF DOUBLE WALLED: 490-64a

UDC INTERSTITIAL SPACE IS MONITORED BY: 1. LIQUID 2. PRESSURE 3. VACCUM

A LEAK WITHIN THE SECONDARY CONTAINMENT OF THE UDC TRIGGERS AUDIBLE AND VISUAL ALARMS a. YES b. NO 490-64b

VII. PERIODIC SYSTEM TESTING

1. **ELD TESTING:** THIS FACILITY HAS BEEN NOTIFIED BY THE STATE WATER RESOURCES CONTROL BOARD THAT ENHANCED LEAK DETECTION DETECTION (ELD) MUST BE PERFORMED. PERIODIC ELD IS PERFORMED EVERY 36 MONTHS AS REQUIRED. (23 CCR 2644.1) 490-65

2. **SECONDARY CONTAINMENT COMPONENTS ARE TESTED EVERY 36 MONTHS.** 490-66

3. **SPILL BUCKETS ARE TESTED ANNUALLY.** 490-67

VIII. RECORDKEEPING

The following monitoring/maintenance records are kept for this facility:

- Alarm logs 490-68a Visual inspection records 490-68b Tank integrity testing results 490-68c
 SIR testing results (and supporting documentation records) 490-68d Tank gauging results (and supporting documentation records) 490-68e
 ATG Testing results (and supporting documentation records) 490-68f Corrosion protection 60-day logs 490-68g
 Equipment maintenance and calibration records 490-68h

IX. TRAINING

Personnel with UST monitoring responsibilities are familiar with all of the following documents relevant to their job duties. 490-69a

REFERENCE DOCUMENTS MAINTAINED AT FACILITY (Check all that apply)

- THIS UNDERGROUND STORAGE TANK MONITORING PLAN (Required) 490-69b
 OPERATING MANUALS FOR ELECTRONIC MONITORING EQUIPMENT (Required) 490-69c
 CALIFORNIA UNDERGROUND STORAGE TANK REGULATIONS 490-69d
 CALIFORNIA UNDERGROUND STORAGE TANK LAW 490-69e
 STATE WATER RESOURCES CONTROL BOARD (SWRCB) PUBLICATION: "HANDBOOK FOR TANK OWNERS-MANUAL AND STATISTICAL INVENTORY RECONCILLIATION" 490-69f
 SWRCB PUBLICATION: "UNDERSTANDING AUTOMATIC TANK GAUGING SYSTEMS" 490-69g
 OTHER (Specify): 490-69h-69i

This facility has a "Designated UST Operator" who has passed the California UST System Operator Exam administered by the International Code Council (ICC). 490-70
The "Designated UST Operator" will train facility employees in the proper operation and maintenance of the UST systems annually, and within 30 days of hire.
This training will include, but is not limited to, the following:

- Operation of the UST systems in a manner consistent with the facility's best management practices
- The facility employee's role with regard to the monitoring equipment as specified in this UST Monitoring Plan
- The facility employee's role with regard to spills and overfills as specified in the UST Response Plan
- Names of contact person(s) for emergencies and monitoring alarms.

X. COMMENTS/ADDITIONAL INFORMATION

Provide additional comments here or indicate how many pages with additional information on specific monitoring procedures are attached to this plan. 490-71

XI. PERSONNEL RESPONSIBILITIES

The UST Owner/Operator is responsible for ensuring that: 1) the daily/routine UST monitoring activities and maintenance of UST leak detection equipment covered by this plan occurs, 2) all conditions that indicate a possible release are investigated, and 3) all monitoring records are maintained properly.

The following person(s) are responsible for performing the monitoring and equipment maintenance:

NAME 490-72 TITLE 490-73

NAME 490-74 TITLE 490-75

The Designated Operator shall perform a monthly visual inspection of the facility, provide a report to the owner/operator, and inform the owner/operator of any conditions that need follow-up action.

XII. OWNER/OPERATOR SIGNATURE

CERTIFICATION: I certify that the informatino provided herein is true and accurate to the best of my knowledge.

APPLICANT SIGNATURE 490-76 DATE: 490-77

REPRESENTING: 1. Tank Owner/Operator 2. Facilitv Owner/Operator 3. Authorized Representative of Owner

APPLICANT NAME (print): 490-78 APPLICANT TITLE: 490-79

(Agency Use Only) This plan has been reviewed and: Approved Approved With Conditions

Local Agency Signature: _____ Date: _____

Comments or Special Conditions:

MONITORING PLAN

Kern County Environmental Health Services Department
 2700 M Street, Suite 300
 Bakersfield, CA 93301
 (661) 862-8740 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
 UNDERGROUND STORAGE TANK

TYPE OF ACTION	<input type="checkbox"/> 1. NEW PLAN	<input type="checkbox"/> 2. CHANGE OF INFORMATION	490-1
PLAN TYPE	<input type="checkbox"/> 1. MONITORING IS IDENTICAL FOR ALL USTs AT THIS FACILITY		490-2
(Check one item only)	<input checked="" type="checkbox"/> 2. THIS PLAN COVERS ONLY THE FOLLOWING UST SYSTEM(S) 3 - DIESEL		
I. FACILITY INFORMATION			
FACILITY ID# (Agency Use Only)	FA0002691	-	1
BUSINESS NAME (Same as FACILITY NAME)	JOHNNY QUIK #143		3
BUSINESS SITE ADDRESS	2126 TAFT HWY	103	CITY BAKERSFIELD 104
II. EQUIPMENT TESTING AND PREVENTIVE MAINTENANCE			
Testing, preventive maintenance, and calibration of monitoring equipment (e.g., sensors, probes, line leak detectors, etc.) must be performed at the frequency specified by the equipment manufacturers' instructions, or annually, whichever is more frequent, and that such work must be performed by qualified personnel. (23 CCR 2632, 2634, 2638, 2641)			
MONITORING EQUIPMENT IS SERVICED	<input checked="" type="checkbox"/> 1. ANNUALLY	<input type="checkbox"/> 99. OTHER (Specify)	490-3a-b
III. MONITORING LOCATIONS			
<input type="checkbox"/> 1. NEW SITE PLOT PLAN/MAP SUBMITTED WITH THIS PLAN.	<input checked="" type="checkbox"/> 2. SITE PLOT PLAN/MAP PREVIOUSLY SUBMITTED.		490-4
(23 CCR 2632, 2634)			
IV. TANK MONITORING IS PERFORMED USING THE FOLLOWING METHOD(S):			
<input checked="" type="checkbox"/> 1. CONTINUOUS ELECTRONIC TANK MONITORING OF ANNULAR (INTERSTITIAL) SPACE(S) OR SECONDARY CONTAINMENT VAULT(S) WITH AUDIBLE AND VISUAL ALARMS. (23 CCR 2632, 2634)			490-5
SECONDARY CONTAINMENT IS:	<input checked="" type="checkbox"/> a. DRY	<input type="checkbox"/> b. LIQUID FILLED	490-6
	<input type="checkbox"/> c. PRESSURIZED	<input type="checkbox"/> d. UNDER VACUUM	
PANEL MANUFACTURER:	VEEDER ROOT	490-7	MODEL #: TLS 350 490-8
LEAK SENSOR MANUFACTURER:	VEEDER ROOT	490-9	MODEL #(S): 420 490-10
<input type="checkbox"/> 2. AUTOMATIC TANK GAUGING (ATG) SYSTEM USED TO MONITOR SINGLE WALL TANK(S). (23 CCR 2643)			490-11
PANEL MANUFACTURER:		490-12	MODEL #: 490-13
IN-TANK PROBE MANUFACTURER:		490-14	MODEL #(S): 490-15
LEAK TEST FREQUENCY:	<input type="checkbox"/> a. CONTINUOUS	<input type="checkbox"/> b. DAILY/NIGHTLY	490-16
	<input type="checkbox"/> d. MONTHLY	<input type="checkbox"/> e. OTHER (Specify):	490-17
PROGRAMMED TESTS:	<input type="checkbox"/> a. 0.1 g.p.h.	<input type="checkbox"/> b. 0.2 g.p.h.	490-18-19
	<input type="checkbox"/> c. OTHER (Specify):		
<input type="checkbox"/> 3. MONTHLY STATISTICAL INVENTORY RECONCILIATION (23 CCR 2646.1):			490-20
<input type="checkbox"/> 4. WEEKLY MANUAL TANK GAUGING (MTG) (23 CCR 2645).	TESTING PERIOD:	<input type="checkbox"/> a. 36 HOURS	490-21-22
		<input type="checkbox"/> b. 60 HOURS	
<input type="checkbox"/> 5. TANK INTEGRITY TESTING (23 CCR 2643.1):			490-23
TEST FREQUENCY:	<input type="checkbox"/> a. ANNUALLY	<input type="checkbox"/> b. BIENNIALY	490-24-25
	<input type="checkbox"/> c. OTHER (Specify):		
<input type="checkbox"/> 99. OTHER (Specify):			490-26-27
V. PIPE MONITORING IS PERFORMED USING THE FOLLOWING METHOD(S) (Check all that apply)			
<input checked="" type="checkbox"/> 1. CONTINUOUS MONITORING OF PIPE/PIPING SUMP(S) AND OTHER SECONDARY CONTAINMENT WITH AUDIBLE AND VISUAL ALARMS. (23 CCR 2636)			490-28
SECONDARY CONTAINMENT IS:	<input checked="" type="checkbox"/> a. DRY	<input type="checkbox"/> b. LIQUID FILLED	490-29
	<input type="checkbox"/> c. PRESSURIZED	<input type="checkbox"/> d. UNDER VACUUM	
PANEL MANUFACTURER:	VEEDER ROOT	490-30	MODEL #: TLS 350 490-31
LEAK SENSOR MANUFACTURER:	VEEDER ROOT	490-32	MODEL #(S): 208 490-33
PIPING LEAK ALARM TRIGGERS AUTOMATIC PUMP (i.e., TURBINE) SHUTDOWN			490-34
FAILURE/DISCONNECTION OF THE MONITORING SYSTEM TRIGGERS AUTOMATIC PUMP SHUTDOWN	<input checked="" type="checkbox"/> a. YES	<input type="checkbox"/> b. NO	490-35
	<input checked="" type="checkbox"/> a. YES	<input type="checkbox"/> b. NO	
<input checked="" type="checkbox"/> 2. MECHANICAL LINE LEAK DETECTOR (MLLD) THAT ROUTINELY PERFORMS 3.0 g.p.h. LEAK TESTS AND RESTRICTS OR SHUTS OFF PRODUCT FLOW WHEN A LEAK IS DETECTED (23 CCR 2636)			490-36
MLLD MANUFACTURER(S):	RED JACKET	490-37	MODEL #(S): FX 1DV 490-38
<input type="checkbox"/> 3. ELECTRONIC LINE LEAK DETECTOR (ELLD) THAT ROUTINELY PERFORMS 3.0 g.p.h. LEAK TESTS (23 CCR 2636)			490-39
ELLD MANUFACTURER(S):		490-40	MODEL #(S): 490-41
PROGRAMMED IN LINE LEAK TEST:	<input type="checkbox"/> 1. MINIMUM MONTHLY 0.2 g.p.h.	<input type="checkbox"/> 2. MINIMUM ANNUAL 0.1 g.p.h.	490-42
ELLD DETECTION OF A PIPING LEAK TRIGGERS AUTOMATIC PUMP SHUTDOWN			490-43
	<input type="checkbox"/> a. YES	<input checked="" type="checkbox"/> b. NO	
ELLD FAILURE/DISCONNECTION TRIGGERS AUTOMATIC PUMP SHUTDOWN			490-44
	<input type="checkbox"/> a. YES	<input checked="" type="checkbox"/> b. NO	
<input type="checkbox"/> 4. PIPE INTEGRITY TESTING			490-45
TEST FREQUENCY	<input type="checkbox"/> a. ANNUALLY	<input type="checkbox"/> b. EVERY 3 YEARS	490-46 490-47
	<input type="checkbox"/> c. OTHER (Specify)		
<input type="checkbox"/> 5. VISUAL PIPE MONITORING			490-48
TEST FREQUENCY	<input type="checkbox"/> a. DAILY	<input type="checkbox"/> b. WEEKLY	490-49
	<input type="checkbox"/> c. MIN. MONTHLY & EACH TIME SYSTEM OPERATED*		
* Allowed for monitoring of unburied emergency generator fuel piping only per HSC 25281.5 (b)(3)			
<input type="checkbox"/> 6. SUCTION PIPING MEETS EXEMPTION CRITERIA [23 CCR 2636(a)(3)].			490-50
<input type="checkbox"/> 7. NO REGULATED PIPING PER HEALTH AND SAFETY CODE, DIVISION 20, CHAPTER 6.7 IS CONNECTED TO THE TANK SYSTEM			490-51
<input type="checkbox"/> 99. OTHER (Specify)			490-52-53

MONITORING PLAN

VI. UNDER DISPENSER CONTAINMENT (UDC) MONITORING

1. UDC MONITORING IS PERFORMED USING THE FOLLOWING METHOD

490-54a

1. CONTINUOUS ELECTRONIC MONITORING 2. FLOAT AND CHAIN ASSEMBLY 3. ELECTRONIC STAND-ALONE
 4. NO DISPENSERS 99. OTHER (Specify)

490-54b

PANEL MANUFACTURER: 490-55 MODEL #: 490-56
 LEAK SENSOR MANUFACTURER: **BEAUDREAU** 490-57 MODEL #(S): **406** 490-58

- DETECTION OF A LEAK INTO THE UDC TRIGGERS AUDIBLE AND VISUAL ALARMS a. YES b. NO 490-59
 UDC LEAK ALARM TRIGGERS AUTOMATIC PUMP SHUTDOWN a. YES b. NO 490-60
 FAILURE/DISCONNECTION OF UDC MONITORING SYSTEM TRIGGERS AUTOMATIC PUMP SHUTDOWN a. YES b. NO 490-61
 LEAK SENSOR MANUFACTURER: a. YES b. NO 490-62

2. UDC CONSTRUCTION IS 1. SINGLE-WALLED 2. DOUBLE-WALLED 490-63

IF DOUBLE WALLED: 490-64a

- UDC INTERSTITIAL SPACE IS MONITORED BY: 1. LIQUID 2. PRESSURE 3. VACCUM
 A LEAK WITHIN THE SECONDARY CONTAINMENT OF THE UDC TRIGGERS AUDIBLE AND VISUAL ALARMS a. YES b. NO 490-64b

VII. PERIODIC SYSTEM TESTING

1. **ELD TESTING:** THIS FACILITY HAS BEEN NOTIFIED BY THE STATE WATER RESOURCES CONTROL BOARD THAT ENHANCED LEAK DETECTION DETECTION (ELD) MUST BE PERFORMED. PERIODIC ELD IS PERFORMED EVERY 36 MONTHS AS REQUIRED. (23 CCR 2644.1) 490-65
 2. **SECONDARY CONTAINMENT COMPONENTS ARE TESTED EVERY 36 MONTHS.** 490-66
 3. **SPILL BUCKETS ARE TESTED ANNUALLY.** 490-67

VIII. RECORDKEEPING

- The following monitoring/maintenance records are kept for this facility:
- Alarm logs 490-68a Visual inspection records 490-68b Tank integrity testing results 490-68c
 SIR testing results (and supporting documentation records) 490-68d Tank gauging results (and supporting documentation records) 490-68e
 ATG Testing results (and supporting documentation records) 490-68f Corrosion protection 60-day logs 490-68g
 Equipment maintenance and calibration records 490-68h

IX. TRAINING

- Personnel with UST monitoring responsibilities are familiar with all of the following documents relevant to their job duties. 490-69a
REFERENCE DOCUMENTS MAINTAINED AT FACILITY (Check all that apply)
 THIS UNDERGROUND STORAGE TANK MONITORING PLAN (Required) 490-69b
 OPERATING MANUALS FOR ELECTRONIC MONITORING EQUIPMENT (Required) 490-69c
 CALIFORNIA UNDERGROUND STORAGE TANK REGULATIONS 490-69d
 CALIFORNIA UNDERGROUND STORAGE TANK LAW 490-69e
 STATE WATER RESOURCES CONTROL BOARD (SWRCB) PUBLICATION: "HANDBOOK FOR TANK OWNERS-MANUAL AND STATISTICAL INVENTORY RECONCILLIATION" 490-69f
 SWRCB PUBLICATION: "UNDERSTANDING AUTOMATIC TANK GAUGING SYSTEMS" 490-69g
 OTHER (Specify): 490-69h-69i
- This facility has a "Designated UST Operator" who has passed the California UST System Operator Exam administered by the International Code Council (ICC). 490-70
 The "Designated UST Operator" will train facility employees in the proper operation and maintenance of the UST systems annually, and within 30 days of hire.
 This training will include, but is not limited to, the following:
 - Operation of the UST systems in a manner consistent with the facility's best management practices
 - The facility employee's role with regard to the monitoring equipment as specified in this UST Monitoring Plan
 - The facility employee's role with regard to spills and overfills as specified in the UST Response Plan
 - Names of contact person(s) for emergencies and monitoring alarms.

X. COMMENTS/ADDITIONAL INFORMATION

Provide additional comments here or indicate how many pages with additional information on specific monitoring procedures are attached to this plan. 490-71

XI. PERSONNEL RESPONSIBILITIES

The UST Owner/Operator is responsible for ensuring that: 1) the daily/routine UST monitoring activities and maintenance of UST leak detection equipment covered by this plan occurs, 2) all conditions that indicate a possible release are investigated, and 3) all monitoring records are maintained properly.
 The following person(s) are responsible for performing the monitoring and equipment maintenance:

NAME	490-72	TITLE	490-73
NAME	490-74	TITLE	490-75

The Designated Operator shall perform a monthly visual inspection of the facility, provide a report to the owner/operator, and inform the owner/operator of any conditions that need follow-up action.

XII. OWNER/OPERATOR SIGNATURE

CERTIFICATION: I certify that the informatino provided herein is true and accurate to the best of my knowledge.

APPLICANT SIGNATURE	490-76	DATE:	490-77
REPRESENTING: <input type="checkbox"/> 1. Tank Owner/Operator <input type="checkbox"/> 2. Facility Owner/Operator <input type="checkbox"/> 3. Authorized Representative of Owner			
APPLICANT NAME (print):	490-78	APPLICANT TITLE:	490-79

(Agency Use Only) This plan has been reviewed and: Approved Approved With Conditions

Local Agency Signature: _____ Date: _____
 Comments or Special Conditions: _____

KERN COUNTY ENVIRONMENTAL HEALTH DEPARTMENT

INVESTIGATION RECORD

DBA _____
 OWNER _____ ADDRESS _____
 ADDRESS _____
 ASSESSORS' PARCEL # _____ CT _____

CHRONOLOGICAL RECORD OF INVESTIGATION

DATE	
8-11-99	Called and spoke to Cyndi of Bed Properties re. the incident at this site. She requested a copy of the ER report + orders to repair. Johnny Quick is having an owners meeting today. She stated that it is the operators responsibility to maintain the equipment. - faxed info if
8-13-99	Rec'd a call from Kujit Ghuman. BSSR is working on the system but that the wiring is needing to be replaced. I explained that the monitoring system needs to be inspected when installed. if
8-13-99	Called BSSR & explained that this department is to be called for an inspection upon completion of the work. if

Narration for a Complaint Investigation (emergency response)

Johnny Quick #143

Work Order: 11,432

Date of Incident: 7-12-99

Date of Narration: Updated as needed

Narration By: Laurel Funk

Complaint: Compliance problems with UST's

RP: Ghuman Singh Kuljit, Business Owner
P.O. Box 137
Pumpkin Center, CA 93383

Site: 2126 Taft Hwy.

Narration:

July 12, 1999 Amy Green and Wesley Nicks responded to a gasoline spill at the above site. At that time, it was noted that the emergency shut off switch was not functional. The piping sumps also contained product and the monitoring system was not detecting it.

July 13, 1999 Green returned to the site all product had been removed from the dispenser pans and the piping sumps. The emergency switch had been repaired. Approval was given to operate the UST system. Instructions were given to repair the monitoring system.

July 19, 1999 Laurel Funk reviewed ER report and files. WAM had conducted a routine inspection on 2/20/98 according to Envision. The inspection report is not in any facility file. According to the computer, no violations were found on the UST system. The previous inspection was conducted in 1992 and indicated that they were not checking the monitoring system as required and the line leak detector need to be certified annually.


The permits issued in 1991 and 1997 both required that the product lines be tested and the monitoring system be inspected and certified annually. The file indicates that this has not been done.

The tax records indicate that Beal Properties, Inc. is the land owner. George Beal was the owner that installed the tanks. The phone number for the property owner is not available.

12/9/88
Performed second, and passed backfill, spark test and an propane test with "soaping" of joints. Made agreement to return Monday at 3:30 to inspect electrical, secondary containment and wrap-ups of all metal piping.

12/12/88
Performed second inspection which included the sec. containment for piping and electrical. Tom Stanley accompanied me on the inspection to perform the electrical which was passed by him. The secondary containment on the piping was also passed after requiring taping of metal connections.

2/27/89
Performed third inspection of leak detection system, fill boxes, and sumps. After several adjustments on the leak detection system it was determined to be operating correctly. The fill boxes and sumps were passed.



9/16/88

Received a call from George Beale advising me that MP Vacuum will be cleaning the tanks and that it will be performed on 9/28/88.

9/8/88

Upon arrival on-site Jack Cash of MP Vacuum advised me that the tanks were not ready to be removed. I informed Doyle Sumrall that he will be charged for an extra inspection. He advised that he will call the office to schedule another inspection depending on Cash's schedule to get the tanks clean.

9/12/88


Sam performed inspection and found one of the 1000gal tanks proposed to be used for fire water storage had an LEL of 25%. The tank was cleaned to be removed because the tank had an O₂ conc. of 0. The tank will have to be re-cleaned if still proposed for storage of water.

9/21/88

Called George Beale to remind him that the tank still had to be cleaned to obtain a 0-LEL. He advised that it will be performed soon and that he will call the department.

10/7/88

Informed G. Beale that I needed manifest before abandonment can be deemed completed




SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

JOHNNY QUIK
 ATTN KULJIT SINGH GHUMAN
 2126 TAFT HWY
 BAKERSFIELD CA 93313

 2. Article Number
 (Transfer from service label)
**COMPLETE THIS SECTION ON DELIVERY**

A. Signature

-
- Agent
-
-
- Addressee

B. Received by (Printed Name)

C. Date of Delivery

D. Is delivery address different from item 1? YesIf YES, enter delivery address below: No


3. Service Type

-
- Certified Mail
-
- Express Mail
-
-
- Registered
-
- Return Receipt for Merchandise
-
-
- Insured Mail
-
- C.O.D.

4. Restricted Delivery? (Extra Fee)

 Yes

UNITED STATES POSTAL SERVICE
BAKERSFIELD CA



J. MARSHALL
BAKERSFIELD CA 93301

First-Class Mail
Postage & Fees Paid
USPS
Permit No. G-10

- Sender: Please print your name, address, and ZIP+4 in this box •

KERN COUNTY ENVIRONMENTAL
HEALTH DIVISION
2700 M STREET, SUITE 300
BAKERSFIELD, CA 93301





ENVIRONMENTAL HEALTH DIVISION

2700 M STREET, SUITE 300, BAKERSFIELD, CA 93301-2370

VOICE: (661) 321-3000 FAX: (661) 862-8701

Web: www.co.kern.ca.us/eh E-mail: eh@co.kern.ca.us

"ONE VOICE"



MATTHEW CONSTANTINE, DIRECTOR
PUBLIC HEALTH SERVICES

CLAUDIA JONAH, MD
PUBLIC HEALTH OFFICER

September 28, 2012

Johnny Quik #143
2126 Taft Hwy
Bakersfield, CA 93313
Attn: Kuljit Singh Ghuman

This Is a Legal Notice

SUBJECT: NOTICE OF VIOLATION (NOV)
Johnny Quik #143
2126 Taft Hwy, Bakersfield, CA 93313
Facility #: FA0002691

Dear Kuljit Singh Ghuman:

This NOV is in reference to the Secondary Containment Test conducted on June 19, 2012 at Johnny Quik #143 (2126 Taft Hwy, Bakersfield, CA 93313). The following violations from the California Code of Regulations (CCR) were observed and are detailed in the following section.

VIOLATION

1. Violation of the CCR 23, Section 2637(a):

(a) Secondary containment systems installed on or after January 1, 2001 shall be tested upon installation, 6 months after installation, and every 36 months thereafter. Secondary containment systems installed prior to January 1, 2001 shall be tested by January 1, 2003 and at least every 36 months thereafter.

(b) By December 31, 2002, the owner or operator of any secondary containment system that the owner or operator determines cannot be tested in accordance with this section shall replace the secondary containment system with a system that can be tested in accordance with this section. As an alternative, the owner or operator may submit a proposal and workplan for enhanced leak detection to the local agency in accordance with subdivisions 2644.1(a)(1), (2), (4), and (5) by July 1, 2002; complete the program of enhanced leak detection by December 31, 2002; and replace the secondary containment system with a system that can be tested in accordance with this section by July 1, 2005. The local agency shall review the proposed program of enhanced leak detection within 45 days of submittal or re-submittal.



PS Form 3800, August 2006

**U.S. Postal Service™
CERTIFIED MAIL™ RECEIPT**
(Domestic Mail Only; No Insurance Coverage Provided)
For delivery information visit our website at www.usps.com

OFFICIAL USE

Postage \$ JM
 Certified Fee
 Return Receipt Fee (Endorsement Required)
 Restricted Delivery Fee (Endorsement Required)
 Total P. _____

Postmark Here *JM*
 10/12/12

JOHNNY QUIK
 ATTN KULJIT SINGH GHUMAN
 2126 TAFT HWY
 BAKERSFIELD CA 93313

Sent To _____
 Street, Apt. or PO Box _____
 City, State _____

2011 0470 0002 9943 1646

(c) Periodic testing of secondary containment systems shall be conducted using a test procedure that demonstrates that the system performs at least as well as it did upon installation. For example, if the secondary containment system was tested upon installation by using a test method that applied a pressure of 5 psi, then the periodic test must be conducted using a method that tests the system at an equivalent pressure. These tests shall be performed in accordance with manufacturer's guidelines or standards. If there are no manufacturer's guidelines or standards, secondary containment systems must be tested using an applicable method specified in an industry code or engineering standard. If there are no applicable manufacturers guidelines, industry codes, or engineering standards a test method approved by a state registered professional engineer shall be used.

- a. During the Secondary Containment Test conducted on June 19, 2012, Rich Environmental determined that the following equipment failed the test. These included:
- i. 87 Octane (Regular) Secondary Piping;
 - ii. 91 Octane (Supreme) Secondary Piping;
 - iii. Diesel Secondary Piping;
 - iv. 87 Octane (Regular) Turbine Sump;
 - v. 91 Octane (Supreme) Turbine Sump;
 - vi. Diesel Turbine Sump; and
 - vii. Under Dispenser Containment (UDC) #3/4.

CORRECTIVE ACTION

The following corrective actions shall be completed by **October 12, 2012**.


1. The owner/operator shall repair or replace the secondary piping, turbine sumps and UDCs described above.
2. The owner/operator shall have a licensed technician re-test all repaired or replaced secondary piping, turbine sumps and UDCs once all repairs have been made. A copy of these test results shall be submitted to the Kern County Environmental Health Division.

Johnny Quik #143
Subject: Notice of Violation
September 28, 2012.

Failure to bring your facility into compliance by October 12, 2012, may result in enforcement action, including maximum penalties of up to \$25,000 per violation. You may also be responsible for re-inspection fees of \$100.00 per hour for time spent by Division staff. You are strongly advised to abate the violations within the timeline provided in order to minimize future oversight costs by this Division and additional fines and penalties.

If you have any questions, please contact my office at (661) 862-8775.

Sincerely,



Jeffrey S. Marshall
Registered Environmental Health Specialist II
Unified Hazardous Materials/Waste Program

cc:
Rich Phillips, Rich Environmental



ENVIRONMENTAL HEALTH SERVICES DEPARTMENT

MATTHEW CONSTANTINE, R.E.H.S., Director

2700 "M" STREET, SUITE 300
BAKERSFIELD, CA 93301-2370
Voice: (661) 862-8700
Fax: (661) 862-8701
TTY Relay: (800) 735-2929
Web: www.co.kern.ca.us/eh
E-Mail: eh@co.kern.ca.us



RESOURCE MANAGEMENT AGENCY

ELISSA D. LADD, ACTING RMA DIRECTOR

Animal Control Department
Community and Economic Development Department
Engineering and Survey Services Department
Environmental Health Services Department
Planning Department
Roads Department

August 26, 2009

Johnny Quik #143
2126 Taft Hwy
Bakersfield, CA 93313
Attn: Ghuman Singh Kuljit

SUBJECT: SECONDARY CONTAINMENT TESTING REPORT FOR METTLER
RENEGADE, 2023 METTLER FRONTAGE RD., BAKERSFIELD, CA
Facility ID: FA0002691

Dear Mr. Ghuman Singh Kuljit:

This Department has received the report for the secondary containment testing of the underground storage tank system at the Johnny Quik #143 which took place on July 7, 2009. The report indicates that several components of the system failed the test or could not be tested. To date, we have not received any information that the repairs to the system have been made and the re-test completed.

Therefore, the repairs of the secondary containment system and re-test of the failed components must be completed within 30 days of receipt of this letter. Failure to bring this facility into compliance could result in civil and administrative penalties.

As always, we are available to assist you. If you have any questions or concerns, please contact (661) 862-8700.

Sincerely,

A handwritten signature in black ink, appearing to read "Lydia V. von Sydow".

Lydia V. von Sydow
Waste Management Technician II
Unified Hazardous Materials/Waste Program



VST601

From: "Laurel Funk" <LAURELF@co.kern.ca.us>
To: <MChristofferson@waterboards.ca.gov>
Date: 7/28/05 4:04PM
Subject: Re: Johnny Quick, 2126 Taft Highway, Bakersfield, CA

003201

The well on the site, #1503091-001, has been destroyed. I am not aware of any other public drinking water wells with in 1000 feet.

Three other sites also received ELD notification because of this well.

ARCO #81774/JAI Mini Mart, 2051 Taft Hwy, Bakersfield 000243

S and W Chevron, 1999 Taft Hwy, Bakersfield 003290

E-Z Mart Mobil, 2106 Taft Hwy, Bakersfield 001792

If you have any questions, please give me a call.

Laurel Funk
Kern County Environmental Health
Certified Unified Program Agency (CUPA)
2700 "M" Street, Suite 300
Bakersfield, CA 93301
Ph# (661) 862-8763
Fax (661) 862-8701



State Water Resources Control Board



Alan C. Lloyd, Ph.D.
Agency Secretary

Division of Water Quality

1001 I Street, Sacramento, California 95814 ♦ (916) 341-5594
Mailing Address: P.O. Box 2231, Sacramento, California 95812
FAX (916) 341-5808 ♦ Internet Address: <http://www.waterboards.ca.gov>

Arnold Schwarzenegger
Governor

AUG 5 2005

CERTIFIED MAIL NO. 7002 2410 0002 6857 9991

Mr. Kuljit Ghuman
Johnny Quik #143
2126 Taft Highway
Bakersfield, CA 93313

Dear Mr. Ghuman:

APPROVAL OF REQUEST FOR RECONSIDERATION OF ENHANCED LEAK
DETECTION (ELD) TESTING: JOHNNY QUIK #143, 2126 TAFT HIGHWAY,
BAKERSFIELD, CA 93313

This letter is in response to your request for reconsideration of the requirement to perform ELD testing. We have reviewed your request and the supporting documents you provided, and we have consulted with the local permitting agency. Based on the enclosed information, your request has been approved for the reason(s) indicated below.

↓ UST system is not located within 1,000 feet of a public drinking water well.

If you have any questions, please contact Marci Christofferson at (916) 341-5594.


Sincerely,

Elizabeth L. Haven, Manager
Underground Storage Tank Program

Enclosures (Basis for Decision)

cc: Mr. Joe Canas
Kern County Environmental Health
2700 M Street, Suite 300
Bakersfield, CA 93301

California Environmental Protection Agency



5516 E. Shields Ave., Suite #101 • Fresno, California 93727-2010 • (559) 291-9672 • Fax (559) 291-1656

Fax Transmittal Form

To *Amad*

Name:

From:

GEORGE BEAL

Phone number:

Fax number: *916-341-5808*

Phone: 559-291-9672

Fax: 559-291-1656

- Urgent
- For Review
- Please Comment
- Please Reply

Date sent: *8/8/03*

Time sent:

Number of pages including cover page:

Message:

As per our conversations

we are now working with
the pumpin center water dist
to ~~we~~ hook up to city water
at our location 2126 Taft Hwy
Bolsfield Calif

Thanks

Geo Beal

AUG 28 2003

STEVE McCALLEY, R.E.H.S., Director
2700 "M" STREET, SUITE 300
BAKERSFIELD, CA 93301-2370
Voice: (661) 862-8700
Fax: (661) 862-8701
TTY Relay: (800) 735-2929
e-mail: eh@co.kern.ca.us



DAVID PRICE III, RMA DIRECTOR
Community Development Program Department
Engineering & Survey Services Department
Environmental Health Services Department
Planning Department
Roads Department

F A X

TRANSMITTAL SHEET

DATE: 8-29-03

FROM: Laurel Funk (661) 862-8763

TO: George Beal
Name

Beal Properties
Company/Department

FAX # (559) 291-1656

TOTAL # PAGES 2 (including this cover sheet)

COMMENTS: a couple of comments 1. There is no Pumpkin Center Water District.
2. California water service provides water in that area
3. Will your well remain active? (this is the
state's interpretation) You will then
have to use ELD testing, water testing and Backflow
prevention.

Any problems questions, please call us at (661) 862-8700

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT

STEVE McCALLEY, R.E.H.S., Director

2700 "M" STREET, SUITE 300
BAKERSFIELD, CA 93301-2370
Voice: (661) 862-8700
Fax: (661) 862-8701
TTY Relay: (800) 735-2929
e-mail: eh@co.kern.ca.us



320028
RESOURCE MANAGEMENT AGENCY

DAVID PRICE III, RMA DIRECTOR

Community and Economic Development Department
Engineering & Survey Services Department
Environmental Health Services Department
Planning Department
Roads Department

June 24, 2005

Beal Properties
5816 East Shields, #101
Fresno, CA 93727

SUBJECT: Johnny Quick Store #143


Ladies and Gentlemen:

This is to advise you that your domestic well located on APN 514-060-21, under Permit EH-2955, was properly destroyed on June 21, 2005.

This is provided for your records. If you have any further questions, please contact me at (661) 862-8768.

Sincerely,

Steve McCalley, Director


By: Thomas Hardy, R.E.H.S.
Environmental Health Specialist III
Water Quality Program

TH:jrw

(water\hardy\eh2599-w10)

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT

STEVE McCALLEY, R.E.H.S., Director

2700 AM@ STREET, SUITE 300
BAKERSFIELD, CA 93301-2370
Voice: (661) 862-8700
Fax: (661) 862-8701
TTY Relay: (800) 735-2929
e-mail: eh@co.kern.ca.us



RESOURCE MANAGEMENT AGENCY

DAVID PRICE III, RMA DIRECTOR

Community and Economic Development Department
Engineering & Survey Services Department
Environmental Health Services Department
Planning Department
Roads Department

May 5, 2005

Ghuman Singh Kuljit
Johnny Quik #143
P O Box 137
Pumpkin Center, CA 93383

Subject: Monitoring System Certification
Johnny Quik #143
2126 Taft Hwy

This Department received the Monitoring System Certification for the above-mentioned facility. The Certification indicates that the sensors are not installed in the Under-Dispenser Containment (UDC). State Regulations require that the UDC be equipped with a continuous monitoring system that either activates an audible and visual alarm or stops the flow of product at the dispenser if a leak is detected.

A flow chart is included to explain this requirement. Please provide documentation to this Department that the sensors have been installed. This documentation must be provided by June 10, 2005.

Thank you for your cooperation in this matter. If you have any questions, please contact this Department at (661) 862-8700.

Sincerely,

Steve McCalley, Director

A handwritten signature in cursive script that reads "Laurel Funk".

By: Laurel Funk
Hazardous Materials Specialist
Unified Hazardous Materials/Waste Program

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT

STEVE McCALLEY, R.E.H.S., Director

2700 "M" STREET, SUITE 300
BAKERSFIELD, CA 93301-2370
Voice: (661) 862-8700
Fax: (661) 862-8701
TTY Relay: (800) 735-2929
e-mail: eh@co.kern.ca.us



RESOURCE MANAGEMENT AGENCY

DAVID PRICE III, RMA DIRECTOR

Community and Economic Development Department
Engineering & Survey Services Department
Environmental Health Services Department
Planning Department
Roads Department

October 15, 2004

320028
GHUMAN SINGH KULJIT
P O BOX 137
BAKERSFIELD, CA 93383

Subject: . Underground Storage Tank Designated Operator Requirements
SECOND NOTICE

All Underground Storage Tank (UST) facilities must notify this Department of the person who will serve as their Designated Operator. This requirement may be found in the California Code of Regulations, Title 23, Chapter 16, Section 2715. The notification is required to be submitted by January 1, 2005. The State is offering an UST Owner/Operator Outreach Session to provide information and answer questions about this new requirement. This session date and location is:

Tuesday, November 2, 2004
9:00 A.M. – 12:00 P.M.
City of Bakersfield, Council Chambers
1501 Truxtun Avenue
Bakersfield, CA 93301

Included with this notice is the form to notify this Department of each facility's Designated Operator. This form is to be completed and returned by January 1, 2005.

Thank you for your cooperation in this matter. If you have any questions, please contact this Department at (661) 862-8700.

Sincerely,

Steve McCalley, Director

A handwritten signature in black ink that reads "Joe Canas".

By: Joe Canas, REHS
Hazardous Materials Specialist IV
Unified Hazardous Materials/Waste Program

Encl.

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT

STEVE McCALLEY, R.E.H.S., Director

2700 "M" STREET, SUITE 300
BAKERSFIELD, CA 93301-2370
Voice: (661) 862-8700
Fax: (661) 862-8701
TTY Relay: (800) 735-2929
e-mail: eh@co.kern.ca.us



RESOURCE MANAGEMENT AGENCY

DAVID PRICE III, RMA DIRECTOR

Community and Economic Development Department
Engineering & Survey Services Department
Environmental Health Services Department
Planning Department
Roads Department

August 26, 2004

GHUMAN SINGH KULJIT
GHUMAN SINGH KULJIT
P O BOX 137
PUMPKIN CENTER, CA 93383

320028

Subject: Underground Storage Tank Requirements

The State of California has established new regulations for Underground Storage Tanks (UST). UST facilities must meet the following requirements to maintain compliance with current regulations.

- 1. Designated Operator:** All UST facilities must notify this Department of the person who will serve as their Designated Operator. This notification is required by January 1, 2005. Enclosed is a flyer explaining these requirements. The State is offering several UST Owner/Operator Outreach Sessions to provide information and answer questions about this new requirement. Also included is a notice about those sessions.
- 2. Double Walled Pressurized Piping Leak Detection:** The State is requiring line leak detectors that detect a 3.0 gallon per hour release from the primary containment be installed by November 9, 2004. A mechanical or electronic line leak detector may be used to fulfill this requirement. This requirement is in addition to the continuous monitors (sensors) in the piping sumps and under dispenser containments. *This requirement is only for double walled pressurized piping.* A flow chart is included to further explain these requirements.


Thank you for your cooperation in this matter. If you have any questions, please contact this Department at (661) 862-8700.

Sincerely,

Steve McCalley, Director

A handwritten signature in black ink that reads "Joe Canas".

By: Joe Canas, REHS
Hazardous Materials Specialist IV
Unified Hazardous Materials/Waste Program





State Water Resources Control Board



Gray Davis
Governor

Winston H. Hickox
Secretary for
Environmental
Protection

Division of Water Quality
1001 I Street • Sacramento, California 95814 • (916) 341-5752
Mailing Address: P.O. Box 2231 • Sacramento, California • 95812
FAX (916) 341-5808 • Internet Address: <http://www.swrcb.ca.gov>

The energy challenge facing California is real. Every Californian needs to take immediate action to reduce energy consumption. For a list of simple ways you can reduce demand and cut your energy costs, see our website at <http://www.swrcb.ca.gov>.

AUG 22 2003

CERTIFIED MAIL
7002 2410 0001 6010 3591

Mr. Jagdish Patel
Manager/Partner
ARCO #1774 / Jai Mini Mart
7012 Frog Meadow Street
Bakersfield, CA 93313

Dear Mr. Patel:

DENIAL OF REQUEST FOR RECONSIDERATION OF ENHANCED LEAK DETECTION (ELD) TESTING: ARCO #1774 / JAI MINI MART, 2051 TAFT HIGHWAY, BAKERSFIELD, CA

This letter is in response to your Request for Reconsideration of the requirement to perform ELD testing. We have consulted with the Kern County Environmental Health and George Beal (water purveyor) who has confirmed that your facility is within 1,000 feet of a Beal Properties' public drinking water well. This well will be connected to the Pumpkin Center Water District system and thus will remain active. As explained to you by my staff on June 12, 2003, based on this information, we have determined that your underground storage tank (UST) facility is subject to the ELD testing requirement. Your request has been denied for the reason(s) indicated below.

UST system(s) is within 1,000 feet of a public drinking water well.

If you have any questions, please contact Mr. Ahmad Kashkoli at (916) 341-5855.

Sincerely,

Elizabeth L. Haven, Manager
Underground Storage Tank Program

Enclosure(s): (basis for the decision)

cc: Ms. Laurel Funk
Kern County Environmental Health
2700 M Street, Suite 300
Bakersfield, CA 93301

California Environmental Protection Agency

Recycled Paper





5316 E. Shields Ave., Suite #101 • Fresno, California 93727-8010 • (559) 291-9672 • Fax (559) 291-1656

Fax Transmittal Form

To *Amad*

Name:

From

GEORGE BEAL

320028

Phone number:

Fax number: *916-341-5808*

Phone: 559-291-9672

Fax: 559-291-1656

- Urgent
- For Review
- Please Comment
- Please Reply

Date sent: *8/8/03*

Time sent:

Number of pages including cover page:

Message:

*As per our conversations
 we are now working with
 the pumpkin center water dist
 to ~~be~~ hook up to city water
 at our location 2126 Taft Hwy
 Bolingfield Calif*

*Thanks
 Geo Beal*

11/20
AUG 29 2003
11/20

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT

STEVE McCALLEY, R.E.H.S., Director

2700 "M" STREET, SUITE 300
BAKERSFIELD, CA 93301-2370
Voice: (661) 862-8700
Fax: (661) 862-8701
TTY Relay: (800) 735-2929
e-mail: eh@co.kern.ca.us



RESOURCE MANAGEMENT AGENCY

DAVID PRICE III, RMA DIRECTOR

Community and Economic Development Department
Engineering & Survey Services Department
Environmental Health Services Department
Planning Department
Roads Department

April 25, 2003

GHUMAN SINGH KULJIT
P O BOX 137
PUMPKIN CENTER, CA 93383

Subject: Underground Storage Tank (UST) System Requirements

Facility: JOHNNY QUICK #143, 320028
2126 TAFT HWY
BAKERSFIELD

Dear Mr. Kuljit:

This department received the secondary containment test report dated December 3, 2003. This report indicates that the product lines, sumps and Under Dispenser Containment (UDC) failed the testing. The components that failed need to be repaired and retested.

If the repairs can be completed without breaking concrete a modification permit may not be required. If a modification permit is required, the current fee is \$650. Once all repairs are completed, the secondary containment system is to be tested and the results submitted to this Department.

This facility is currently out of compliance with the UST regulations. Failure to respond within the required time frame may result in enforcement actions by this Department.

Please respond to this department in writing as to the status of the site testing by May 31, 2003. The system must be tested within 60 days of your response. If you wish to discuss these options, please contact Laurel Funk at (661) 862-8763. Thank you for your cooperation in this matter.

Sincerely,

Steve McCalley, Director

A handwritten signature in cursive script that reads "Joe Canas".

By: Joe Canas
Hazardous Materials Specialist IV
Unified Hazardous Materials/Waste Program

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT

RESOURCE MANAGEMENT AGENCY

STEVE McCALLEY, R.E.H.S., Director
2700 "M" STREET, SUITE 300
BAKERSFIELD, CA 93301-2370
Voice: (661) 862-8700
Fax: (661) 862-8701
TTY Relay: (800) 735-2929
e-mail: eh@co.kern.ca.us



DAVID PRICE III, RMA DIRECTOR
Community Development Program Department
Engineering & Survey Services Department
Environmental Health Services Department
Planning Department
Roads Department

October 25, 2002

GHUMAN SINGH KULJIT
GHUMAN SINGH KULJIT
P O BOX 137
PUMPKIN CENTER, CA 93383

Subject: Secondary Containment Testing for Underground Storage Tank (UST) Systems

Facility: JOHNNY QUICK #143, 320028
2126 TAFT HWY
BAKERSFIELD

Dear Sir or Madam,

This Department has determined that the above mentioned facility is subject to the Secondary Containment Testing Requirements. The deadline for completing the testing is January 1, 2003. As of this date, the results have not been submitted to this Department. Enclosed is information from the State Water Resources Control Board reminding tank owners of this requirement.

If for some reason you feel that this information is incorrect, please contact this Department. The Hazardous Materials staff is available at (661) 862-8700 to answer any questions you may have. Thank you for your prompt attention to this matter.

Sincerely,

Steve McCalley, Director

A handwritten signature in black ink that reads "Joe Canas".

By: Joe Canas
Hazardous Materials Specialist IV
Unified Hazardous Materials/Waste Program

Enclosures

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT

RESOURCE MANAGEMENT AGENCY

STEVE McCALLEY, R.E.H.S., Director
2700 "M" STREET, SUITE 300
BAKERSFIELD, CA 93301-2370
Voice: (661) 862-8700
Fax: (661) 862-8701
TTY Relay: (800) 735-2929
e-mail: eh@co.kern.ca.us



DAVID PRICE III, RMA DIRECTOR
Community Development Program Department
Engineering & Survey Services Department
Environmental Health Services Department
Planning Department
Roads Department

July 15, 2002

320028

GHUMAN SINGH KULJIT
GHUMAN SINGH KULJIT
P O BOX 137
PUMPKIN CENTER, CA 93383

Subject: Updated Underground Storage Tank (UST) Monitoring and Response Plans

Facility: JOHNNY QUICK #143, FA0002691
2126 TAFT HWY
BAKERSFIELD

Dear Sir or Madam:

The Kern County Environmental Health Services Department has recently reviewed the underground storage tank (UST) files. Many facilities do not have current and/or approved monitoring plans, response plans, and plot plans on file with this Department. These plans are to be submitted to and approved by this Department for each facility. Copies of the plans are to be kept at each facility site with the Unified Hazardous Materials/Waste Facility Permit.

If you feel that you have already submitted these plans, please contact this Department to have your file reviewed. The submitted plans will be reviewed for completeness and you will be notified if updated plans are required.

To assist you in completing these plans, the following forms have been enclosed:

- **Monitoring Plan Cover Sheet***: This form is to be completed for each facility and attached to the monitoring plan developed for the facility.
- **Monitoring Requirement Options***: This is a list of various options that facilities can use to monitor most UST systems. You may develop your monitoring plan(s) by picking and choosing the options that apply to the site. Specific site information is necessary to complete the monitoring plan.
- **Samples of Log Forms**: Most monitoring plans require the logging of inspections and test results. These forms may be used for that purpose.
- **Emergency Response Plan Form***: This form is to be completed for each facility.

In addition to the above information, a plot plan for the facility is to be submitted which shows the location of the tanks, monitoring sensors, buildings, alarm panels, and rectifiers. The plot plan is to be on an 8 1/2 x 11 sheet of paper.

The forms noted with a * are available in Word and Word Perfect format. If you would like to receive the forms electronically, please e-mail your request to laurelf@co.kern.ca.us and the forms will be sent to you.

Copies of the Monitoring, Response, and Plot Plans are to be submitted to this Department within 30 days of the date of this letter. If the facility owner is not contacted within 30 days of submittal, the plans are considered approved by this Department. The permit holder must notify this Department within 30 days of any changes to the monitoring, response, and plot plans.

Thank you for your cooperation in this matter. If you have any questions, please contact the Hazardous Materials staff at (661) 862-8700

Sincerely,

Steve McCalley, Director

A handwritten signature in black ink, appearing to read "Joe Canas". The signature is written in a cursive style with a long, sweeping underline.

By: Joe Canas, REHS
Hazardous Material Specialist IV
Unified Hazardous Materials/Waste Program

JC:lf
Enclosures

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT

320028
RESOURCE MANAGEMENT AGENCY

STEVE McCALLEY, R.E.H.S., Director
2700 "M" STREET, SUITE 300
BAKERSFIELD, CA 93301-2370
Voice: (661) 862-8700
Fax: (661) 862-8701
TTY Relay: (800) 735-2929
e-mail: eh@co.kern.ca.us



DAVID PRICE III, RMA DIRECTOR
Community Development Program Department
Engineering & Survey Services Department
Environmental Health Services Department
Planning Department
Roads Department

November 30, 2001

GHUMAN SINGH KULJIT
GHUMAN SINGH KULJIT
P O BOX 137
PUMPKIN CENTER, CA 93383

Subject: Underground Storage Tank (UST) Requirements and Deadlines
Facility: JOHNNY QUICK #143, FA0002691
2126 TAFT HWY
BAKERSFIELD

The State of California has established new regulations for underground storage tanks. All UST files have been reviewed by this Department for compliance with both existing and these new regulations. The facility listed above must meet the following requirements to maintain compliance with current regulations.

Secondary Containment Testing

The following systems have at least one component which is secondarily contained (i.e., tank, piping, sump, or dispenser containment). Any tank using hydrostatic or vacuum monitoring is not required to be tested, however; piping, sumps, and dispenser containment still require testing. The secondary containment system is to be tested by the date listed below and every 36 months thereafter. If the date has already passed, the test must be completed within 60 days of this letter. If the system is untestable by an approved method, the system shall be tested by Enhanced Leak Detection (ELD). The facility shall have an ELD program reviewed and approved by this Department by July 1, 2002; implemented by December 31, 2002; and the secondary containment system replaced by July 1, 2005. The testing and ELD requirements are enclosed.

Tank #	Tank Size	Product Stored	Test Due Date
1	10,000	PREMIUM	01/01/2003
2	10,000	UNLEADED	01/01/2003
3	10,000	UNLEADED PLUS	01/01/2003

In addition to the above-mentioned requirements, all monitoring equipment shall be calibrated, operated and maintained in accordance with the manufacturers' instructions. The equipment shall also be certified for proper operating condition and calibration every 12 months.

All testing is to be completed by a licensed or approved tester. Permits may be required for some of the tests. This Department shall be notified at least 48 hours prior to conducting any tests or inspections. The results of the test are to be submitted to this Department within 30 days of completion.

If for some reason the owner or operator of this facility believes that the above information is incorrect, please contact this Department. An inspection and file review can be completed to clarify and/or correct the information.

GHUMAN SINGH KULJIT
JOHNNY QUICK #143, FA0002691
November 30, 2001
Page #: 2

California Air Resources Board (CARB) has implemented additional requirements for Enhanced Vapor Recovery. While the CARB requirements are separate from the UST requirements, modifications to comply with these requirements may activate the CARB requirements. Please contact the local Air District for assistance prior to making any modifications to this facility.

Please contact the Hazardous Materials staff at (661) 862-8700 if you need any assistance.


Sincerely,

Steve McCalley, Director

A handwritten signature in black ink, appearing to read "Joe Canas", written in a cursive style.

By: Joe Canas, REHS
Hazardous Material Specialist IV
Unified Hazardous Materials/Waste Program

CA Cert. No. 06292



Kern County Environmental
Health Services Department
Steve McCalley, R.E.H.S., Director
2700 M Street, Suite 300
Bakersfield, CA 93301-2370

Voice (805) 862-8700
FAX (805) 862-8701

E-Mail: eh@co.kern.ca.us

An upgrade compliance certificate has been issued in connection with the operating permit for the facility indicated below. The certificate number on this facsimile matches the number on the certificate displayed at the facility.

Instructions to the issuing agency: Use the space below to enter the following information in the format of your choice: name of owner; name of operator; name of facility; street address, city, and zip code of facility; facility identification number (from Form A); name of issuing agency; and date of issue. Other identifying information may be added as deemed necessary by the local agency.

Facility: JOHNNY QUICK #143, 002691

Location: 2126 TAFT HWY
BAKERSFIELD, CA 93313

Owner: GHUMAN SINGH KULJIT
c/o GHUMAN SINGH KULJIT
P O BOX 137
PUMPKIN CENTER, CA 93383

UST Site ID: 320028

BP Site ID: 003201

Issue Date: September 1, 1998

98C-3

10-5-98

GHuman

Kern County Environmental
Health Services Department
Certified Unified Program Agency
2700 "M" Street, Suite 300, Bakersfield, CA

UNIFIED HAZARDOUS MATERIALS / WASTE FACILITY PERMIT

Phone: (805) 862-8700

FAX: (805) 862-8701

FACILITY NAME: JOHNNY QUICK #143, 002691

OWNER'S NAME: GHUMAN SINGH KULJIT

LOCATION: 2126 TAFT HWY
BAKERSFIELD, CA

P O BOX 137
PUMPKIN CENTER, CA
93383

Key Map No.: 123-36D

ISSUED FOR THE FOLLOWING ACTIVITIES:

Underground Storage
Tanks (Permitted)

Haz Material Business
Plan/RMPP (Authorized)

Hazardous Waste
Generator

Above-Ground
Storage Tanks

320028C
10000 GAL., DOUBLE WALLED, PREM UNL/SUPER, PRESSURE
10000 GAL., DOUBLE WALLED, GASOLINE, PRESSURE
10000 GAL., DOUBLE WALLED, GASOLINE, PRESSURE

Site ID #: 003201

NOT AUTHORIZED

NOT AUTHORIZED

**THIS PERMIT IS GRANTED SUBJECT TO THE CONDITIONS
LISTED ON THE BACK**

Issue Date: November 1, 1997

Expiration Date: November 1, 2000

**-- POST ON PREMISES --
NONTRANSFERABLE**

**HAZARDOUS MATERIALS / WASTE
FACILITY PERMIT
SUMMARY OF CONDITIONS**

CONDITIONS:

1. The facility owner and operator must be familiar with all conditions specified by this permit and must meet any additional requirements imposed by the permitting authority.
2. The facility owner and operator shall ensure that the facility has adequate financial responsibility insurance coverage, as mandated for all underground storage tanks containing petroleum, and supply proof of such coverage to the permitting authority.

The facility will be considered in violation and operating without a permit if annual fees are not received within 30 days of the invoice date.
4. The monitoring/operational requirements shall be implemented within 30 days of the permit issue date.
5. Any inactive underground storage tank which is not being monitored, as approved by the permitting authority, is considered improperly closed. Proper closure is required and must be completed under a permit issued by the permitting authority.
6. The facility owner/operator must obtain a modification permit before:
 - a. Uncovering any underground storage tank after failure of a tank integrity test.
 - b. Replacement of piping.
 - c. Lining the interior of the underground storage tank.
7. The facility owner must advise the Environmental Health Services Department within 30 days of transfer of ownership.
8. The owner and/or operator shall keep a copy of all tank monitoring records at the facility for a minimum of three years, or as specified by the permitting authority. They may be kept off site if they can be obtained within 24 hours of a request made by the local authority.
9. The owner/operator must report any significant unauthorized release from permitted tanks within 24 hours of discovery.
10. The owner and operator must meet all applicable requirements of Chapters 6.5, 6.67, 6.7, 6.75, and 6.95 of the Health and Safety Code and applicable sections of the California Code of Regulations and the Kern County Ordinance Code.
11. A hazardous materials inventory plan must be prepared and kept current by the owner or the operator of this facility.
12. An annual report shall be submitted to the Kern County Environmental Health Services Department each year after the monitoring has been initiated. The owner or operator shall use the form provided along with the permit or another approved by the Kern County Environmental Health Services Department.
13. All underground storage tanks shall be equipped with a continuous monitoring device within the interstitial space which must be connected to an audible and visual alarm system. All piping sumps shall be monitored manually or by utilizing an electronic monitoring device.
14. All pressurized piping systems shall be equipped with pressurized piping leak detectors. The piping systems shall be tested annually unless the facility has installed a continuous monitoring/automatic shutoff system within the secondary containment.
15. All equipment installed for leak detection shall be operated and maintained in accordance with manufacturer's instructions, including routine maintenance and service checks (at least once per year) for operability or running condition.
16. An underground storage tank monitoring response plan shall be developed, if not currently on file, and submitted to the Department for review and approval within 30 days of the issuance date of this permit.

RMA ACCOUNTS RECEIVABLE INSTRUCTIONS
ADVISORY FORM

PERMIT # 32-00286

DATE 04-11-95

WORK ORDER # _____

INVOICE # 0110860-FC

CUSTOMER # 20-Johnny I

CUSTOMER NAME Johnny Quick Food Store

ACTION TO BE TAKEN

- Waive Permit Fee (State Reason Below)
- Waive Service Fee (State Reason Below)
- Waive Late Charges (State Reason Below)
- Waive Surcharge Fee (State Reason Below)
- Send to Collections
- Payment Schedule Requested (See Details Below)
- Other (Explain Below)

EXPLANATION/COMMENTS

See attached letter from customer - original invoice never received - payment in full on 1995 UST permit

APPROVED BY
SPECIALIST James M Warren DATE 4-13-95
CHIEF [Signature] DATE 4-13-95
DIRECTOR [Signature] DATE 4-17-95

RMA ACCOUNTING
ACCOUNTANT _____ DATE _____

Spreek

Comments: _____

ACCTG-POSTED BY _____ DATE _____
Acct Clerk Sharon/Tweil 4/20/95

Dir,

Your invoice #0109464 in original was not received for reasons best known to the Postal Authorities. I haven't about the payment on receipt of your invoice # 0110860-FC dated Mar 14, 95 indicating the penalty.

I had spoken to Ms Beverly last week and requested her to forward a copy of the same so that I could make the payment.

3. You are requested to waive the penalty of \$ 225.00 (USD) and please find a check (#5206) for \$225 in respect of the permit fee.

Mr Steve McCalley
Director
Financial Group
Gary

Apr 04, 95

Dear Sir,
Please refer to my letter dated Apr 0495 addressed to Mr. Glave. We call for clearing of the property. Enclosed herewith are the check # 5209 of \$225.00 towards the AUST Permit with a view to make a total of \$450.00. By mistake I had remitted a check for \$225.00 instead of \$450.00. The inconvenience caused is regretted.

Thanking you,

Sincerely yours,
Gandhi
Apr 05, 95

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT

STEVE McCALLEY, R.E.H.S.
DIRECTOR



2700 "M" Street, Suite 300
Bakersfield, CA 93301
(805) 861-3636
(805) 861-3429 FAX

February 24, 1994

JOHNNY QUICK FOOD STORE
P. O. BOX 49408
BAKERSFIELD, CA 93382

SUBJECT: 2126 TAFT HIGHWAY, BAKERSFIELD, CA

PERMIT #: 320028C

Dear Sir/Madam:

The permit issued to the facility cited above provided one page of conditions/prohibitions for operation of the underground storage tank system. One of the conditions provided on that page specified that "the owner and operator ensure that the facility have adequate financial responsibility coverage, as mandated for all underground storage tanks containing petroleum, and supply proof of such coverage when requested by the permitting agency." Federal regulations which went into effect in December 1988 required that all underground storage tank facilities obtain financial responsibility coverage, using an approved mechanism to pay for the costs of cleanup and any third party liability, in case of a leak from the tank system, and provide evidence of that coverage to the local implementing agency by deadlines established in law. The amount of coverage required and the mechanisms which could be utilized were also specified in law.

In an attempt to assist underground storage tank facilities comply with the financial responsibility requirements, the state developed a clean up fund, which was approved by the Federal EPA as a mechanism for meeting a portion of the Federal financial responsibility requirements. The state has prepared a summary of the clean up fund, how you pay into the fund, and the financial responsibility requirements. That summary has been enclosed with this letter.

The Certificate of Financial Responsibility enclosed is the proof that this Department needs for the underground storage facility cited above. As shown by the example provided, you can utilize one statement for all underground storage tanks that you own or operate.

Please review all information provided, complete the Certificate of Financial Responsibility enclosed, and return it by March 31, 1994. If you have any questions, feel free to call the Underground Storage Tank Program at (805) 861-3636.

Sincerely,

Steve McCalley, Director

A handwritten signature in cursive script, reading "Amy E. Green".

By: Amy E. Green, R.E.H.S.
Hazardous Materials Specialist IV
Hazardous Materials Management Program

AEG:jrw
Enclosures
(block2a)

RESOURCE MANAGEMENT AGENCY

RANDALL L. ABBOTT
DIRECTOR

DAVID PRICE III
ASSISTANT DIRECTOR



Environmental Health Services Department
STEVE McCALLEY, REHS, DIRECTOR

Air Pollution Control District
WILLIAM J. RODDY, APCO

Planning & Development Services Department
TED JAMES, AICP, DIRECTOR

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT PERMIT TO OPERATE UNDERGROUND HAZARDOUS STORAGE FACILITY

Permit No.: 320028C

State ID No.: 320028

Issued to: JOHNNY QUICK FOOD STORE

No. of Tanks: 3

Location: 2126 TAFT HIGHWAY
BAKERSFIELD, CA

Owner: JOHNNY QUICK FOOD STORE
P. O. BOX 49408
BAKERSFIELD, CA 93382

Operator: BALBIR SHERGILL
2126 TAFT HIGHWAY
BAKERSFIELD, CA 93313

Facility Profile:

<u>Tank No.</u>	<u>Substance Code</u>	<u>Tank Contents</u>	<u>Tank Capacity</u>	<u>Year Installed</u>	<u>Is piping Pressurized?</u>
1	MVF 6	PREMIUM	10,000	1988	YES
2	MVF 6	UNLEADED	10,000	1988	YES
3	MVF 6	REGULAR	10,000	1988	YES

This permit is granted subject to the conditions and prohibitions listed on the attached summary of conditions/prohibitions

By: Steve McCalley
Steve McCalley

Issue Date: September 23, 1991

Title: Director, Environmental Health Services Department

Expiration Date: September 23, 1996

-- POST ON PREMISES --
NONTRANSFERABLE

2700 "M" STREET, SUITE 300

BAKERSFIELD, CALIFORNIA 93301

(805) 861-3636
FAX: (805) 861-3429

**HAZARDOUS UNDERGROUND STORAGE FACILITY PERMIT
SUMMARY OF CONDITIONS/PROHIBITIONS**

CONDITIONS/PROHIBITIONS:

1. The facility owner and operator must be familiar with all conditions specified within this permit and must meet any additional requirements to monitor, upgrade, or close the tanks and associated piping imposed by the permitting authority.
2. If the operator of the underground storage tank is not the owner, then the owner shall enter into a written contract with the operator, requiring the operator to monitor the underground storage tank; maintain appropriate records; and implement reporting procedures as required by the Department.
3. The facility owner and operator shall ensure that the facility has adequate financial responsibility insurance coverage, as mandated for all underground storage tanks containing petroleum, and supply proof of such coverage when requested by the permitting authority.
4. The facility owner must ensure that the annual permit fee is paid within 30 days of the invoice date.
5. The facility will be considered in violation and operating without a permit if annual permit fees are not received within 60 days of the invoice date.
6. The facility owner and/or operator shall review the leak detection requirements provided within this permit. The monitoring alternative shall be implemented within 60 days of the permit issue date.
7. The facility underground storage tanks must be monitored, utilizing the option approved by the permitting authority, until the tank is closed under a valid, unexpired permit for closure.
8. Any inactive underground storage tank which is not being monitored, as approved by the permitting authority, is considered improperly closed. Proper closure is required and must be completed under a permit issued by the permitting authority.
9. The facility owner/operator must obtain a modification permit before:
 - a. Uncovering any underground storage tank after failure of a tank integrity test.
 - b. Replacement of piping.
 - c. Lining the interior of the underground storage tank.
10. The tank owner must advise the Environmental Health Services Department within 10 days of transfer of ownership.
11. Any change in state law or local ordinance may necessitate a change in permit conditions. The owner/operator will be required to meet new conditions within 60 days of notification.
12. The owner and/or operator shall keep a copy of all monitoring records at the facility for a minimum of three years, or as specified by the permitting authority. They may be kept off site if they can be obtained within 24 hours of a request made by the local authority.
13. The owner/operator must report any unauthorized release which escapes from the secondary containment, or from the primary containment if no secondary containment exists, which increases the hazard of fire or explosion or causes any deterioration of the secondary containment within 24 hours of discovery.

MONITORING REQUIREMENTS: (MVF6 pr)

1. All underground storage tanks designated as MVF 6 on the first page of this permit shall be monitored utilizing the following method:
 - a. Each tank shall be equipped with a continuous monitoring device within the interstitial space, which must be connected to an audible and visual alarm system within 60 days of the issue date on page 1 of this permit.
 - b. All piping sumps shall be monitored manually or by utilizing an electronic monitoring device.
 - c. All pressurized piping systems shall install pressurized piping leak detection systems and ensure that they are capable of functioning as specified by the manufacturer. The mechanical leak detection systems must be capable of alerting the owner/operator of a leak by restricting or shutting off the flow of hazardous substances through the piping, or by triggering an audible or visual alarm, detecting three gallons or more per hour per square inch line pressure within one hour.
 - d. All pressurized piping systems shall be tested annually unless the facility has installed the following:
 1. A continuous monitoring system within secondary containment.
 2. The continuous monitor is connected to an audible and visual alarm system and the pumping system.
 3. The continuous monitor shuts down the pump and activates the alarm system when a release is detected.
 4. The pumping system shuts down automatically if the continuous monitor fails or is disconnected.

The first test shall be completed before December 31, 1991, and subsequent tests completed each calendar year thereafter.

2. All equipment installed for leak detection shall be operated and maintained in accordance with manufacturer's instructions, including routine maintenance and service checks (at least once per year) for operability or running condition.
3. A monitoring response plan shall be developed, and submitted to the department for review and approval within 90 days of the issuance date of this permit.
4. An annual report shall be submitted to the Kern County Environmental Health Services Department each year after monitoring has been initiated. The owner or operator shall use the form provided along with the permit, unless another has received prior approval.

Attn: Alexandra. ⁸ page 2

UNIFIED PROGRAM CONSOLIDATED FORM
UNDERGROUND STORAGE TANK
OPERATING PERMIT APPLICATION - FACILITY INFORMATION
(One form per facility)

TYPE OF ACTION 1. NEW PERMIT 5. CHANGE OF INFORMATION 7. PERMANENT FACILITY CLOSURE
(Check one item only) 3. RENEWAL PERMIT 6. TEMPORARY FACILITY CLOSURE 9. TRANSFER PERMIT

I. FACILITY INFORMATION

TOTAL NUMBER OF USTs AT FACILITY ⁴⁰⁴ 3 FACILITY ID # (Agency Use Only) FA-000-2691

BUSINESS NAME (Same as Facility Name or DBA - Doing Business As) JOHNNY QUIK #143

BUSINESS SITE ADDRESS ¹⁰³ 2126 TAFT HWY CITY ¹⁰⁴ BAKERSFIELD

FACILITY TYPE 1. MOTOR VEHICLE FUELING 2. FUEL DISTRIBUTION ⁴⁰³
 3. FARM 4. PROCESSOR 6. OTHER Is the facility located on Indian Reservation or Trust lands? 1. Yes 2. No ⁴⁰⁵

II. PROPERTY OWNER INFORMATION

PROPERTY OWNER NAME ⁴⁰⁷ KULWIT S. GHUMAN PHONE ⁴⁰⁸ (661) 834-9113

MAILING ADDRESS ⁴⁰⁹ 1001 NICKI CT.

CITY ⁴¹⁰ BAKERSFIELD STATE ⁴¹¹ CA ZIP CODE ⁴¹² 93307

III. TANK OPERATOR INFORMATION

TANK OPERATOR NAME ⁴²⁸⁻¹ Rich Environmental Services PHONE ⁴²⁸⁻² (661) 326-8402

MAILING ADDRESS ⁴²⁸⁻³ 5643 Baobab Ct. BAKERSFIELD CA-93308

CITY ⁴²⁸⁻⁴ Bakersfield STATE ⁴²⁸⁻⁵ CA ZIP CODE ⁴²⁸⁻⁶ 93308

IV. TANK OWNER INFORMATION

TANK OWNER NAME ⁴¹⁴ KULWIT S. GHUMAN PHONE ⁴¹⁵ (661) 834-9113

MAILING ADDRESS ⁴¹⁶ 2126 TAFT HWY

CITY ⁴¹⁷ BAKERSFIELD STATE ⁴¹⁸ CA ZIP CODE ⁴¹⁹ 93313

OWNER TYPE: 4. LOCAL AGENCY/DISTRICT 5. COUNTY AGENCY 6. STATE AGENCY ⁴²⁰
 7. FEDERAL AGENCY 8. NON-GOVERNMENT

V. BOARD OF EQUALIZATION UST STORAGE FEE ACCOUNT NUMBER

TY (TK) HQ 44- 005589 Call the State Board of Equalization, Fuel Tax Division, if there are questions. ⁴²¹

VI. PERMIT HOLDER INFORMATION

Issue permit and send legal notifications and mailings to: 1. FACILITY OWNER 4. TANK OPERATOR ⁴²³
 3. TANK OWNER 5. FACILITY OPERATOR

SUPERVISOR OF DIVISION, SECTION, OR OFFICE (Required for Public Agencies Only) ⁴⁰⁶

VII. APPLICANT SIGNATURE

CERTIFICATION: I certify that the information provided herein is true, accurate, and in full compliance with legal requirements.

APPLICANT SIGNATURE ⁴²⁴ K Ghuman DATE 02/13/12 PHONE ⁴²⁵ (661) 834-9113

APPLICANT NAME (pnnr) ⁴²⁶ KULWIT S. GHUMAN APPLICANT TITLE ⁴²⁷ OWNER

OPERATING PERMIT APPLICATION - TANK INFORMATION (One form per UST)

**KERN COUNTY ENVIRONMENTAL HEALTH SERVICES
DEPARTMENT**
2700 M STREET, SUITE 300
BAKERSFIELD, CA 93301
(661) 862-8700 Fax (661) 862-8701

**Unified Program Consolidated Form (UPCF)
UNDERGROUND STORAGE TANKS**

(one page per tank) Page of

TYPE OF ACTION (Check one item only. For an UST permanent closure or removal, complete only this section and Sections I, II, III, IV, and IX below)		430
<input type="checkbox"/> 1. NEW PERMIT	<input checked="" type="checkbox"/> 3. RENEWAL PERMIT	
<input type="checkbox"/> 6. TEMPORARY UST CLOSURE	<input type="checkbox"/> 7. UST PERMANENT CLOSURE ON SITE	
	<input type="checkbox"/> 5. CHANGE OF INFORMATION	
	<input type="checkbox"/> 8. UST REMOVAL	

DATE UST PERMANENTLY CLOSED: 430a	DATE EXISTING UST DISCOVERED: 430b
-----------------------------------	------------------------------------

I. FACILITY INFORMATION

FACILITY ID # (Agency Use Only)	FA - 000 - 26 91
BUSINESS NAME (Same as FACILITY NAME or DBA-Doing Business As)	JOHNNY QUIK #143
BUSINESS SITE ADDRESS 103	2126 Taft Hwy
CITY 104	Bakersfield, CA - 93313

II. TANK DESCRIPTION

TANK ID # 432	TANK MANUFACTURER 433	TANK CONFIGURATION: THIS TANK IS 434
		<input checked="" type="checkbox"/> 1. A STAND-ALONE TANK
		<input type="checkbox"/> 2. A COMPARTMENTED UNIT
DATE UST SYSTEM INSTALLED 435	TANK CAPACITY IN GALLONS 436	NUMBER OF COMPARTMENTS IN THE UNIT 437
1988	10,000	ONE

III. TANK USE AND CONTENTS

TANK USE 439	<input checked="" type="checkbox"/> 1a. MOTOR VEHICLE FUELING	<input type="checkbox"/> 1b. MARINA FUELING	<input type="checkbox"/> 1c. AVIATION FUELING
	<input type="checkbox"/> 3. CHEMICAL PRODUCT STORAGE	<input type="checkbox"/> 4. HAZARDOUS WASTE (Includes Used Oil)	<input type="checkbox"/> 5. EMERGENCY GENERATOR FUEL (HSC §25281.5(e))
	<input type="checkbox"/> 6. OTHER GENERATOR FUEL	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):
CONTENTS 439a	PETROLEUM: <input checked="" type="checkbox"/> 1a. REGULAR UNLEADED	<input type="checkbox"/> 1c. MIDGRADE UNLEADED	<input type="checkbox"/> 1b. PREMIUM UNLEADED
	<input type="checkbox"/> 3. DIESEL	<input type="checkbox"/> 5. JET FUEL	<input type="checkbox"/> 6. AVIATION GAS
	<input type="checkbox"/> 8. PETROLEUM BLEND FUEL	<input type="checkbox"/> 9. OTHER PETROLEUM (Specify):	
	NON-PETROLEUM: <input type="checkbox"/> 7. USED OIL	<input type="checkbox"/> 10. ETHANOL	
	<input type="checkbox"/> 11. OTHER NON-PETROLEUM (Specify):		

IV. TANK CONSTRUCTION

TYPE OF TANK 443	<input type="checkbox"/> 1. SINGLE WALL	<input checked="" type="checkbox"/> 2. DOUBLE WALL	<input type="checkbox"/> 95. UNKNOWN
PRIMARY CONTAINMENT 444	<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 3. FIBERGLASS	<input type="checkbox"/> 6. INTERNAL BLADDER
	<input type="checkbox"/> 7. STEEL + INTERNAL LINING	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):
SECONDARY CONTAINMENT 444a	<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 3. FIBERGLASS	<input type="checkbox"/> 6. EXTERIOR MEMBRANE LINER
	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 7. JACKETED
OVERFILL PREVENTION 445	<input checked="" type="checkbox"/> 1. AUDIBLE & VISUAL ALARMS	<input type="checkbox"/> 2. BALL FLOAT	<input type="checkbox"/> 3. FILL TUBE SHUT-OFF VALVE
	<input type="checkbox"/> 4. TANK MEETS REQUIREMENTS FOR EXEMPTION FROM OVERFILL PREVENTION EQUIPMENT		

V. PRODUCT / WASTE PIPING CONSTRUCTION

PIPING CONSTRUCTION 460	<input type="checkbox"/> 1. SINGLE-WALLED	<input checked="" type="checkbox"/> 2. DOUBLE-WALLED	<input type="checkbox"/> 99. OTHER
SYSTEM TYPE 458	<input checked="" type="checkbox"/> 1. PRESSURE	<input type="checkbox"/> 2. GRAVITY	<input type="checkbox"/> 3. CONVENTIONAL SUCTION
	<input type="checkbox"/> 4. SAFE SUCTION (23 CCR §2636(a)(3))		
PRIMARY CONTAINMENT 464	<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 8. FLEXIBLE
	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):
SECONDARY CONTAINMENT 464a	<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 8. FLEXIBLE
	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):
PIPING/TURBINE CONTAINMENT SUMP TYPE 464d	<input checked="" type="checkbox"/> 1. SINGLE WALL	<input type="checkbox"/> 2. DOUBLE WALL	<input type="checkbox"/> 90. NONE

VI. VENT, VAPOR RECOVERY (VR) AND RISER / FILL PIPE PIPING CONSTRUCTION

VENT PRIMARY CONTAINMENT 464e	<input checked="" type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify):
VENT SECONDARY CONTAINMENT 464f	<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify):
VR PRIMARY CONTAINMENT 464g	<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify):
VR SECONDARY CONTAINMENT 464h	<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify):
VENT PIPING TRANSITION SUMP TYPE 464i	<input type="checkbox"/> 1. SINGLE WALL	<input type="checkbox"/> 2. DOUBLE WALL	<input checked="" type="checkbox"/> 90. NONE		
RISER PRIMARY CONTAINMENT 464j	<input checked="" type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify):
RISER SECONDARY CONTAINMENT 464k	<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify):
FILL COMPONENTS INSTALLED 464l-c	<input checked="" type="checkbox"/> 1. SPILL BUCKET	<input type="checkbox"/> 3. STRIKER PLATE/BOTTOM PROTECTOR	<input type="checkbox"/> 4. CONTAINMENT SUMP		

VII. UNDER DISPENSER CONTAINMENT (UDC)

CONSTRUCTION TYPE 469a	<input checked="" type="checkbox"/> 1. SINGLE WALL	<input type="checkbox"/> 2. DOUBLE WALL	<input type="checkbox"/> 3. NO DISPENSERS	<input type="checkbox"/> 90. NONE
CONSTRUCTION MATERIAL 469b-c	<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 99. OTHER (Specify):

VIII. CORROSION PROTECTION

STEEL COMPONENT PROTECTION 448	<input type="checkbox"/> 2. SACRIFICIAL ANODE(S)	<input type="checkbox"/> 4. IMPRESSED CURRENT	<input type="checkbox"/> 6. ISOLATION
--------------------------------	--	---	---------------------------------------

IX. APPLICANT SIGNATURE

CERTIFICATION: I certify that this UST system is compatible with the hazardous substance stored and that the information provided herein is true, accurate, and in full compliance with legal requirements.

APPLICANT SIGNATURE 470	DATE 02/13/12
APPLICANT NAME (print) 471	APPLICANT TITLE 472
KULJIT S. GHUMAN	OWNER

OPERATING PERMIT APPLICATION - TANK INFORMATION (One form per UST)

KERN COUNTY ENVIRONMENTAL HEALTH SERVICES
 DEPARTMENT
 2700 M STREET, SUITE 300
 BAKERSFIELD, CA 93301
 (661) 862-8700 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
UNDERGROUND STORAGE TANKS

(one page per tank) Page of

TYPE OF ACTION (Check one item only. For an UST permanent closure or removal, complete only this section and Sections I, II, III, IV, and IX below) 430
 1. NEW PERMIT
 6. TEMPORARY UST CLOSURE
 3. RENEWAL PERMIT
 7. UST PERMANENT CLOSURE ON SITE
 5. CHANGE OF INFORMATION
 8. UST REMOVAL

DATE UST PERMANENTLY CLOSED: 430a _____ DATE EXISTING UST DISCOVERED: 430b _____

I. FACILITY INFORMATION

FACILITY ID # (Agency Use Only) _____
 BUSINESS NAME (Same as FACILITY NAME or DBA-Doing Business As) FA - 000 - 2691
 BUSINESS SITE ADDRESS 2126 Taft Hwy CITY Bakersfield, CA - 93313
JOHNNY QUIK #143

II. TANK DESCRIPTION

TANK ID # 432 _____ TANK MANUFACTURER 433 _____ TANK CONFIGURATION: THIS TANK IS 434
 1. A STAND-ALONE TANK
 2. A COMPARTMENTED UNIT
 DATE UST SYSTEM INSTALLED 435 1988 TANK CAPACITY IN GALLONS 436 10,000 NUMBER OF COMPARTMENTS IN THE UNIT 437 ONE

III. TANK USE AND CONTENTS

TANK USE 439
 1a. MOTOR VEHICLE FUEL
 3. CHEMICAL PRODUCT STORAGE
 6. OTHER GENERAL FUEL
 1b. MARINA FUEL
 4. HAZARDOUS WASTE (includes Used Oil)
 9. UNKNOWN
 1c. AVIATION FUELING
 5. EMERGENCY GENERATOR FUEL (HSC §25281.5(c))
 99. OTHER (Specify): _____
 CONTENTS 439a
 PETROLEUM: 1a. REGULAR UNLEADED 1c. MIDGRADE UNLEADED 1b. PREMIUM UNLEADED
 3. DIESEL 5. JET FUEL 6. AVIATION GAS
 8. PETROLEUM BLEND FUEL 9. OTHER PETROLEUM (Specify): _____
 NON-PETROLEUM: 7. USED OIL 10. ETHANOL
 11. OTHER NON-PETROLEUM (Specify): _____ 440b

IV. TANK CONSTRUCTION

TYPE OF TANK 443
 1. SINGLE WALL 2. DOUBLE WALL 9. UNKNOWN
 PRIMARY CONTAINMENT 444
 1. STEEL 3. FIBERGLASS 6. INTERNAL BLADDER
 7. STEEL + INTERNAL LINING 9. UNKNOWN 99. OTHER (Specify): _____ 444a
 SECONDARY CONTAINMENT 445
 1. STEEL 3. FIBERGLASS 6. EXTERIOR MEMBRANE LINER 7. JACKETED
 9. NONE 9. UNKNOWN 99. OTHER (Specify): _____ 445a
 OVERFILL PREVENTION 452
 1. AUDIBLE & VISUAL ALARMS 2. BALL FLOAT 3. FILL TUBE SHUT-OFF VALVE
 4. TANK MEETS REQUIREMENTS FOR EXEMPTION FROM OVERFILL PREVENTION EQUIPMENT

V. PRODUCT / WASTE PIPING CONSTRUCTION

PIPING CONSTRUCTION 460
 1. SINGLE-WALLED 2. DOUBLE-WALLED 99. OTHER
 SYSTEM TYPE 461
 1. PRESSURE 2. GRAVITY 3. CONVENTIONAL SUCTION 4. SAFE SUCTION (23 CCR §26.6(a)(3))
 PRIMARY CONTAINMENT 464
 1. STEEL 4. FIBERGLASS 8. FLEXIBLE 10. RIGID PLASTIC
 9. NONE 9. UNKNOWN 99. OTHER (Specify): _____ 464a
 SECONDARY CONTAINMENT 464b
 1. STEEL 4. FIBERGLASS 8. FLEXIBLE 10. RIGID PLASTIC
 9. NONE 9. UNKNOWN 99. OTHER (Specify): _____ 464c
 PIPING/TURBINE CONTAINMENT SUMP TYPE 464d
 1. SINGLE WALL 2. DOUBLE WALL 9. NONE

VI. VENT, VAPOR RECOVERY (VR) AND RISER / FILL PIPE PIPING CONSTRUCTION

VENT PRIMARY CONTAINMENT 464e
 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 9. NONE 99. OTHER (Specify) _____ 464e
 VENT SECONDARY CONTAINMENT 464f
 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 9. NONE 99. OTHER (Specify) _____ 464f
 VR PRIMARY CONTAINMENT 464g
 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 9. NONE 99. OTHER (Specify) _____ 464g
 VR SECONDARY CONTAINMENT 464h
 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 9. NONE 99. OTHER (Specify) _____ 464h
 VENT PIPING TRANSITION SUMP TYPE 464i
 1. SINGLE WALL 2. DOUBLE WALL 9. NONE
 RISER PRIMARY CONTAINMENT 464j
 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 9. NONE 99. OTHER (Specify) _____ 464j
 RISER SECONDARY CONTAINMENT 464k
 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 9. NONE 99. OTHER (Specify) _____ 464k
 FILL COMPONENTS INSTALLED 464l-c
 1. SPILL BUCKET 3. STRIKER PLATE/BOTTOM PROTECTOR 4. CONTAINMENT SUMP

VII. UNDER DISPENSER CONTAINMENT (UDC)

CONSTRUCTION TYPE 469a
 1. SINGLE WALL 2. DOUBLE WALL 3. NO DISPENSERS 9. NONE
 CONSTRUCTION MATERIAL 469b-c
 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 99. OTHER (Specify) _____

VIII. CORROSION PROTECTION

STEEL COMPONENT PROTECTION 448
 2. SACRIFICIAL ANODE(S) 4. IMPRESSED CURRENT 6. ISOLATION

IX. APPLICANT SIGNATURE

CERTIFICATION: I certify that this UST system is compatible with the hazardous substance stored and that the information provided herein is true, accurate, and in full compliance with legal requirements.
 APPLICANT SIGNATURE K. Ghuman DATE 02/13/12 470
 APPLICANT NAME (print) KULJIT S. GHUMAN APPLICANT TITLE OWNER 472

OPERATING PERMIT APPLICATION - TANK INFORMATION (One form per UST)
KERN COUNTY ENVIRONMENTAL HEALTH SERVICES DEPARTMENT
2700 M STREET, SUITE 300 BAKERSFIELD, CA 93301
(661) 862-8700 Fax (661) 862-8701
Unified Program Consolidated Form (UPCF)
UNDERGROUND STORAGE TANKS

TYPE OF ACTION (Check one item only. For an UST permanent closure or removal, complete only this section and Sections I, II, III, IV, and IX below) 430
 1. NEW PERMIT
 6. TEMPORARY UST CLOSURE
 3. RENEWAL PERMIT
 7. UST PERMANENT CLOSURE ON SITE
 5. CHANGE OF INFORMATION
 8. UST REMOVAL

DATE UST PERMANENTLY CLOSED: 430a DATE EXISTING UST DISCOVERED: 430b

I. FACILITY INFORMATION

FACILITY ID # (Agency Use Only) FA-000-2691
BUSINESS NAME (Same as FACILITY NAME or DBA-Doing Business As) JOHNNY QUIK #143
BUSINESS SITE ADDRESS 2126 Taft Hwy 103 CITY Bakersfield, CA-93313 104

II. TANK DESCRIPTION

TANK ID # 432 TANK MANUFACTURER 433 TANK CONFIGURATION: THIS TANK IS 434
 1. A STAND-ALONE TANK
 2. A COMPARTMENTED UNIT
DATE UST SYSTEM INSTALLED 1988 435 TANK CAPACITY IN GALLONS 10,000 436 NUMBER OF COMPARTMENTS IN THE UNIT ONE 437

III. TANK USE AND CONTENTS

TANK USE 1a. MOTOR VEHICLE FUELING 1b. MARINA FUELING 1c. AVIATION FUELING 439
 3. CHEMICAL PRODUCT STORAGE 4. HAZARDOUS WASTE (Includes Used Oil) 5. EMERGENCY GENERATOR FUEL (HSC §25281.5(c))
 6. OTHER GENERATOR FUEL 95. UNKNOWN 99. OTHER (Specify): 439a
CONTENTS PETROLEUM: 1a. REGULAR UNLEADED 1c. MIDGRADE UNLEADED 1b. PREMIUM UNLEADED 440
 3. DIESEL 5. JET FUEL 6. AVIATION GAS 440a
 8. PETROLEUM BLEND FUEL 9. OTHER PETROLEUM (Specify) 440a
NON-PETROLEUM: 7. USED OIL 10. ETHANOL 440a
 11. OTHER NON-PETROLEUM (Specify): 440b

IV. TANK CONSTRUCTION

TYPE OF TANK 1. SINGLE WALL 2. DOUBLE WALL 95. UNKNOWN 443
PRIMARY CONTAINMENT 1. STEEL 3. FIBERGLASS 6. INTERNAL BLADDER 444
 7. STEEL + INTERNAL LINING 95. UNKNOWN 99. OTHER (Specify): 444a
SECONDARY CONTAINMENT 1. STEEL 3. FIBERGLASS 6. EXTERIOR MEMBRANE LINER 7. JACKETED 445
 90. NONE 95. UNKNOWN 99. OTHER (Specify): 445a
OVERFILL PREVENTION 1. AUDIBLE & VISUAL ALARMS 2. BALL FLOAT 3. FILL TUBE SHUT-OFF VALVE 445a
 4. TANK MEETS REQUIREMENTS FOR EXEMPTION FROM OVERFILL PREVENTION EQUIPMENT 452

V. PRODUCT / WASTE PIPING CONSTRUCTION

PIPING CONSTRUCTION 1. SINGLE-WALLED 2. DOUBLE-WALLED 99. OTHER 460
SYSTEM TYPE 1. PRESSURE 2. GRAVITY 3. CONVENTIONAL SUCTION 4. SAFE SUCTION [23 (CCR §26.6(a)(3))] 460
PRIMARY CONTAINMENT 1. STEEL 4. FIBERGLASS 8. FLEXIBLE 10. RIGID PLASTIC 464
 90. NONE 95. UNKNOWN 99. OTHER (Specify): 464a
SECONDARY CONTAINMENT 1. STEEL 4. FIBERGLASS 8. FLEXIBLE 10. RIGID PLASTIC 464b
 90. NONE 95. UNKNOWN 99. OTHER (Specify): 464c
PIPING/TURBINE CONTAINMENT SUMP TYPE 1. SINGLE WALL 2. DOUBLE WALL 90. NONE 464d

VI. VENT, VAPOR RECOVERY (VR) AND RISER / FILL PIPE PIPING CONSTRUCTION

VENT PRIMARY CONTAINMENT 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464e
VENT SECONDARY CONTAINMENT 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464f
VR PRIMARY CONTAINMENT 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464g
VR SECONDARY CONTAINMENT 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464h
VENT PIPING TRANSITION SUMP TYPE 1. SINGLE WALL 2. DOUBLE WALL 90. NONE 464i
RISER PRIMARY CONTAINMENT 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464j
RISER SECONDARY CONTAINMENT 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464k
FILL COMPONENTS INSTALLED 1. SPILL BUCKET 3. STRIKER PLATE/BOTTOM PROTECTOR 4. CONTAINMENT SUMP 464l
451a-c

VII. UNDER DISPENSER CONTAINMENT (UDC)

CONSTRUCTION TYPE 1. SINGLE WALL 2. DOUBLE WALL 3. NO DISPENSERS 90. NONE 469a
CONSTRUCTION MATERIAL 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 99. OTHER (Specify) 469b-c

VIII. CORROSION PROTECTION

STEEL COMPONENT PROTECTION 2. SACRIFICIAL ANODE(S) 4. IMPRESSED CURRENT 6. ISOLATION 448

IX. APPLICANT SIGNATURE

CERTIFICATION: I certify that this UST system is compatible with the hazardous substance stored and that the information provided herein is true, accurate, and in full compliance with legal requirements.
APPLICANT SIGNATURE *Kuljit S. Ghuman* DATE 02/13/12 470
APPLICANT NAME (print) KULJIT S. GHUMAN 471 APPLICANT TITLE OWNER 472

UNIFIED PROGRAM CONSOLIDATED FORM
UNDERGROUND STORAGE TANK
MONITORING PLAN - (Page 1 of 2)

TYPE OF ACTION 1. NEW PLAN 2. CHANGE OF INFORMATION 490-1
PLAN TYPE 1. MONITORING IS IDENTICAL FOR ALL USTs AT THIS FACILITY. 490-2
(Check one item only) 2. THIS PLAN COVERS ONLY THE FOLLOWING UST SYSTEM(S):

I. FACILITY INFORMATION

FACILITY ID # (Agency Use Only) _____
BUSINESS NAME (Same as Facility Name or DBA) **Johnny DUK #143**
BUSINESS SITE ADDRESS **2126 Taft Hwy** CITY **Bakersfield**

II. EQUIPMENT TESTING AND PREVENTIVE MAINTENANCE

Testing, preventive maintenance, and calibration of monitoring equipment (e.g., sensors, probes, line leak detectors, etc.) must be performed at the frequency specified by the equipment manufacturers' instructions, or annually, whichever is more frequent. Such work must be performed by qualified personnel. [23 CCR §2632, 2634, 2638, 2641]
MONITORING EQUIPMENT IS SERVICED 1. ANNUALLY 99. OTHER (Specify):

III. MONITORING LOCATIONS

1. NEW SITE PLOT PLAN/MAP SUBMITTED WITH THIS PLAN 2. SITE PLOT PLAN/MAP PREVIOUSLY SUBMITTED [23 CCR §2632, 2634] 490-4

IV. TANK MONITORING IS PERFORMED USING THE FOLLOWING METHOD(S) (Check all that apply)

1. CONTINUOUS ELECTRONIC TANK MONITORING OF ANNULAR (INTERSTITIAL) SPACE(S) OR SECONDARY CONTAINMENT VAULT(S) WITH AUDIBLE AND VISUAL ALARMS. [23 CCR §2632, 2634] 490-5
SECONDARY CONTAINMENT IS: a. DRY b. LIQUID FILLED c. PRESSURIZED d. UNDER VACUUM 490-6
PANEL MANUFACTURER: _____ MODEL #: _____ 490-7
LEAK SENSOR MANUFACTURER: _____ MODEL #(S): _____ 490-9
 2. AUTOMATIC TANK GAUGING (ATG) SYSTEM USED TO MONITOR SINGLE WALL TANK(S). [23 CCR §2643] 490-11
PANEL MANUFACTURER: _____ MODEL #: _____ 490-12
IN-TANK PROBE MANUFACTURER: _____ MODEL #(S): _____ 490-14
LEAK TEST FREQUENCY: a. CONTINUOUS b. DAILY/NIGHTLY c. WEEKLY 490-16
 d. MONTHLY e. OTHER (Specify): _____ 490-17
PROGRAMMED TESTS: a. 0.1 g.p.h. b. 0.2 g.p.h. c. OTHER (Specify): _____ 490-18
 3. MONTHLY STATISTICAL INVENTORY RECONCILIATION [23 CCR §2646.1] 490-20
 4. WEEKLY MANUAL TANK GAUGING (MTG) [23 CCR §2645] TESTING PERIOD: a. 36 HOURS b. 60 HOURS 490-21
 5. TANK INTEGRITY TESTING PER [23 CCR §2643.1] 490-23
TEST FREQUENCY: a. ANNUALLY b. BIENNIALY c. OTHER (Specify): _____ 490-25
 99. OTHER (Specify): _____ 490-27

V. PIPE MONITORING IS PERFORMED USING THE FOLLOWING METHOD(S) (Check all that apply)

1. CONTINUOUS MONITORING OF PIPE/PIPING SUMP(S) AND OTHER SECONDARY CONTAINMENT WITH AUDIBLE & VISUAL ALARMS. [23 CCR §2636] 490-28
SECONDARY CONTAINMENT IS: a. DRY b. LIQUID FILLED c. PRESSURIZED d. UNDER VACUUM 490-29
PANEL MANUFACTURER: _____ MODEL #: _____ 490-30
LEAK SENSOR MANUFACTURER: _____ MODEL #(S): _____ 490-32
PIPING LEAK ALARM TRIGGERS AUTOMATIC PUMP (i.e., TURBINE) SHUTDOWN. a. YES b. NO 490-34
FAILURE/DISCONNECTION OF THE MONITORING SYSTEM TRIGGERS AUTOMATIC PUMP SHUTDOWN. a. YES b. NO 490-35
 2. MECHANICAL LINE LEAK DETECTOR (MLLD) THAT ROUTINELY PERFORMS 3.0 g.p.h. LEAK TESTS AND RESTRICTS OR SHUTS OFF PRODUCT FLOW WHEN A LEAK IS DETECTED. [23 CCR §2636] 490-36
MLLD MANUFACTURER(S): **Red Jacket** MODEL #(S): **SX1V, SX1DV** 490-37
 3. ELECTRONIC LINE LEAK DETECTOR (ELLD) THAT ROUTINELY PERFORMS 3.0 g.p.h. LEAK TESTS. [23 CCR §2636] 490-39
ELLD MANUFACTURER(S): _____ MODEL #(S): _____ 490-41
PROGRAMMED IN LINE LEAK TEST: a. MINIMUM MONTHLY 0.2 g.p.h. b. MINIMUM ANNUAL 0.1 g.p.h. 490-42
ELLD DETECTION OF A PIPING LEAK TRIGGERS AUTOMATIC PUMP SHUTDOWN. a. YES b. NO 490-43
ELLD FAILURE/DISCONNECTION TRIGGERS AUTOMATIC PUMP SHUTDOWN. a. YES b. NO 490-44
 4. PIPE INTEGRITY TESTING. 490-45
TEST FREQUENCY: a. ANNUALLY b. EVERY 3 YEARS c. OTHER (Specify) _____ 490-46
 5. VISUAL PIPE MONITORING. 490-47
FREQUENCY: a. DAILY b. WEEKLY c. MIN. MONTHLY & EACH TIME SYSTEM OPERATED* 490-49
* Allowed for monitoring of unburned emergency generator fuel piping only per HSC §25281.5(b)(3) 490-50
 6. SUCTION PIPING MEETS EXEMPTION CRITERIA. [23 CCR §2636(a)(3)] 490-51
 7. NO REGULATED PIPING PER HEALTH AND SAFETY CODE, DIVISION 20, CHAPTER 6.7 IS CONNECTED TO THE TANK SYSTEM. 490-52
 99. OTHER (Specify) _____ 490-53

UNIFIED PROGRAM CONSOLIDATED FORM
UNDERGROUND STORAGE TANK
MONITORING PLAN - (Page 2 of 2)

VI. UNDER DISPENSER CONTAINMENT (UDC) MONITORING

(Check all that apply)

UDC MONITORING IS PERFORMED USING THE FOLLOWING METHOD(S)

- 1. CONTINUOUS ELECTRONIC MONITORING 490-54a
- 2. FLOAT AND CHAIN ASSEMBLY 490-54b
- 3. ELECTRONIC STAND-ALONE 490-54a
- 4. NO DISPENSERS 490-54b
- 99. OTHER (Specify) _____

LEAK MONITOR MANUFACTURER: Beudsen 490-55 MODEL #: 406 490-56

LEAK SENSOR MANUFACTURER: _____ 490-57 MODEL #(S): _____ 490-58

DETECTION OF A LEAK INTO THE UDC TRIGGERS AUDIBLE AND VISUAL ALARMS. a. YES b. NO 490-59

UDC LEAK ALARM TRIGGERS AUTOMATIC PUMP SHUTDOWN. a. YES b. NO 490-60

FAILURE/DISCONNECTION OF UDC MONITORING SYSTEM TRIGGERS AUTOMATIC PUMP SHUTDOWN. a. YES b. NO 490-61

UDC MONITORING STOPS THE FLOW OF PRODUCT AT THE DISPENSER. a. YES b. NO 490-62

UDC CONSTRUCTION IS: 1. SINGLE WALL 2. DOUBLE WALL 490-63

IF DOUBLE WALL: _____ 490-64a

UDC INTERSTITIAL SPACE IS MONITORED BY: a. LIQUID b. PRESSURE c. VACUUM 490-64b

A LEAK WITHIN THE SECONDARY CONTAINMENT OF THE UDC TRIGGERS AUDIBLE AND VISUAL ALARMS. a. YES b. NO 490-64b

VII. PERIODIC SYSTEM TESTING

1. ELD TESTING: THIS FACILITY HAS BEEN NOTIFIED BY THE STATE WATER RESOURCES CONTROL BOARD THAT ENHANCED LEAK DETECTION (ELD) MUST BE PERFORMED. PERIODIC ELD IS PERFORMED EVERY 36 MONTHS AS REQUIRED. (23 CCR 52644.1) 490-65

2. SECONDARY CONTAINMENT COMPONENTS ARE TESTED EVERY 36 MONTHS. 490-66

3. SPILL BUCKETS ARE TESTED ANNUALLY. 490-67

VIII. RECORD KEEPING

The following monitoring/maintenance records are kept for this facility: 490-68

- a. ALARM LOGS b. VISUAL INSPECTION RECORDS c. TANK INTEGRITY TESTING RESULTS
- d. SIR TESTING RESULTS (and supporting documentation records) e. TANK GAUGING RESULTS (and supporting documentation records)
- f. ATG TESTING RESULTS (and supporting documentation records) g. CORROSION PROTECTION 60-DAY LOGS
- h. EQUIPMENT MAINTENANCE AND CALIBRATION RECORDS

IX. TRAINING

Personnel with UST monitoring responsibilities are familiar with all of the following documents relevant to their job duties: 490-69a

REFERENCE DOCUMENTS MAINTAINED AT FACILITY (Check all that apply) 490-69b

THIS UNDERGROUND STORAGE TANK MONITORING PLAN (Required) 490-69c

OPERATING MANUALS FOR ELECTRONIC MONITORING EQUIPMENT (Required) 490-69d

CALIFORNIA UNDERGROUND STORAGE TANK REGULATIONS 490-69e

CALIFORNIA UNDERGROUND STORAGE TANK LAW 490-69f

STATE WATER RESOURCES CONTROL BOARD (SWRCB) PUBLICATION: "HANDBOOK FOR TANK OWNERS - MANUAL AND STATISTICAL INVENTORY RECONCILIATION" 490-69g

SWRCB PUBLICATION: "UNDERSTANDING AUTOMATIC TANK GAUGING SYSTEMS" 490-69h

OTHER (Specify): _____ 490-69i

This facility has a "Designated UST Operator" who has passed the California UST System Operator Exam administered by the International Code Council (ICC). The "Designated UST Operator" will train facility employees in the proper operation and maintenance of the UST systems annually, and within 30 days of hire. This training will include, but is not limited to, the following: 490-70

- > Operation of the UST systems in a manner consistent with the facility's best management practices.
- > The facility employee's role with regard to the monitoring equipment as specified in this UST Monitoring Plan.
- > The facility employee's role with regard to spills and overfills as specified in the facility's UST Response Plan.
- > Name(s) of contact person(s) for emergencies and monitoring alarms.

X. COMMENTS/ADDITIONAL INFORMATION

Provide additional comments here or indicate how many pages with additional information on specific monitoring procedures are attached to this plan. 490-71

XI. PERSONNEL RESPONSIBILITIES

The UST Owner/Operator is responsible for ensuring that: 1.) the daily/routine UST monitoring activities and maintenance of UST leak detection equipment covered by this plan occurs; 2.) all conditions that indicate a possible release are investigated; and 3.) all monitoring records are maintained properly.

THE FOLLOWING PERSON(S) ARE RESPONSIBLE FOR PERFORMING THE MONITORING AND EQUIPMENT MAINTENANCE: 490-73

NAME: KULJIT S. GHUMAN 490-72 TITLE: OWNER 490-73

NAME: _____ 490-74 TITLE: _____ 490-75

The Designated UST Operator shall perform a monthly visual inspection of the facility, provide a report to the owner/operator, and inform the owner/operator of any conditions that need follow-up action.

XII. OWNER/OPERATOR SIGNATURE

CERTIFICATION: I certify that the information provided herein is true and accurate to the best of my knowledge. 490-77

APPLICANT SIGNATURE: KS Ghuman DATE: 02/13/12 490-77

REPRESENTING 1 Tank Owner/Operator 2 Facility Owner/Operator 3 Authorized Representative of Owner 490-76

APPLICANT NAME (print): KULJIT S. GHUMAN 490-78

APPLICANT TITLE: OWNER 490-79

RESPONSE PLAN - PAGE 1

KERN COUNTY ENVIRONMENTAL HEALTH SERVICES
 DEPARTMENT
 2700 M STREET, SUITE 300
 BAKERSFIELD, CA 93301
 (661) 862-8700 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
UNDERGROUND STORAGE TANK
 (One form per facility)

TYPE OF ACTION 1. NEW PLAN 2. CHANGE OF INFORMATION R01

I. FACILITY INFORMATION

FACILITY ID # (Agency Use Only)		-	-	1.	
BUSINESS NAME (Same as FACILITY NAME)		Johnny QUICK #143			3
BUSINESS SITE ADDRESS	2126 Taft Hwy	103.	BUSINESS SITE CITY	104	
		Bakersfield, CA-93313			

II. SPILL CONTROL AND CLEANUP METHODS

This plan addresses unauthorized releases from UST systems and supplements the emergency response plans and procedures in the facility's Hazardous Materials Business Plan (HMBP).

- If safe to do so, facility personnel will take immediate measures to control or stop any release (e.g., activate pump shut-off, etc.) and, if necessary, safely remove remaining hazardous material from the UST system.
- Any release to secondary containment will be pumped or otherwise removed within a time consistent with the ability of the secondary containment system to contain the hazardous material, but not greater than 30 calendar days, or sooner if required by the local agency. Recovered hazardous materials, unless still suitable for their intended use, will be managed as hazardous waste.
- Absorbent material will be used to contain and clean up manageable spills of hazardous materials. Absorbent material which has become too saturated to be effective or which is no longer intended for use will be managed as hazardous waste unless a waste determination in accordance with 22 CCR §66262.11 finds that it is non-hazardous. Used absorbent material, reusable or waste, will be stored in a properly labeled and sealed container. Waste material shall be disposed of appropriately.
- Facility personnel will determine whether any water removed from secondary containment systems, or from clean-up activity, has been in contact with any hazardous material. If the water is contaminated, it will be managed as hazardous waste unless a hazardous waste determination in accordance with 22 CCR §66262.11 finds that it is non-hazardous. If the water has a petroleum sheen (i.e., rainbow colors), it is contaminated. A thick floating petroleum layer may not necessarily display rainbow colors. Water (hazardous or non-hazardous) from sumps, spill containers, etc. will not be disposed to storm water systems.
- We will review secondary containment systems for possible deterioration if any of the following conditions occur:
 1. Hazardous material in contact with secondary containment is not compatible with the material used for secondary containment;
 2. Secondary containment is prone to damage from any equipment used to remove or clean up hazardous material collected in secondary containment;
 3. Hazardous material, other than the product/waste stored in the primary containment system, is placed inside secondary containment to treat or neutralize released product/waste, and the added material or resulting material from such a combination is not compatible with secondary containment.

III. SPILL CONTROL AND CLEAN-UP EQUIPMENT

PERIODIC MAINTENANCE: Spill control and clean-up equipment kept permanently on-site is listed in the facility's Hazardous Materials Business Plan. This equipment is inspected at least monthly, and after each use, supplies are replenished as needed. Defective equipment is repaired or replaced as necessary.

EQUIPMENT NOT PERMANENTLY ON-SITE, BUT AVAILABLE FOR USE IF NEEDED: (Complete only if applicable)

EQUIPMENT	LOCATION	AVAILABILITY	
cat litter to soak	2126 Taft Hwy	All the times.	R30
the gas or diesel fuel.	Hwy		R31
siphon pumps			R32
Call Rich Environmental	661-326-8402		R33
for heavy spill.	5643 Brooks Ct.		R34
	Bakersfield, CA		R35

IV. RESPONSIBLE PERSONS

THE FOLLOWING PERSON(S) IS/ARE RESPONSIBLE FOR AUTHORIZING ANY WORK NECESSARY UNDER THIS RESPONSE PLAN:

NAME	R40	TITLE	R50
KULJIT S. GHUMAN		OWNER	
Rich Environmental		Testing Co.	
NAME	R42	TITLE	R52
NAME	R43	TITLE	R53

V. MONITORING INDICATORS

IF MONITORING INDICATES A POSSIBLE UNAUTHORIZED RELEASE, STEPS TO VERIFY THE RELEASE WILL BE MADE AS FOLLOWS:

1. ADDITIONAL SYSTEM TESTING OR DATA COLLECTION 2. INSPECTION BY QUALIFIED PERSONS 3. RECALIBRATION OF EQUIPMENT R60

99. OTHER (Specify): R61

RESPONSE PLAN - PAGE 2

KERN COUNTY ENVIRONMENTAL HEALTH SERVICES
DEPARTMENT
2700 M STREET, SUITE 300
BAKERSFIELD, CA 93301
(661) 862-8700 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
UNDERGROUND STORAGE TANK
(One form per facility)

VI. REPORTING AND RECORD KEEPING

We will report/record any overfill, spill, or unauthorized release from a UST system as indicated in this plan.

Recordable Releases: Any unauthorized release from primary containment which the UST operator is able to clean up within eight (8) hours after the release was detected or should reasonably have been detected, and which does not escape from secondary containment, does not increase the hazard of fire or explosion, and does not cause any deterioration of secondary containment, must be recorded in the facility's monitoring records. Monitoring records must include:

- The UST operator's name and telephone number;
- A list of the types, quantities, and concentrations of hazardous substances released;
- A description of the actions taken to control and clean up the release;
- The method and location of disposal of the released hazardous substances, and whether a hazardous waste manifest was or will be used;
- A description of actions taken to repair the UST and to prevent future releases;
- A description of the method used to reactivate interstitial monitoring after replacement or repair of primary containment.

Reportable Releases: Any overfill, spill, or unauthorized release which escapes from secondary containment (or primary containment if no secondary containment exists), increases the hazard of fire or explosion, or causes any deterioration of secondary containment, is a reportable release. Reportable releases are also recordable.

Within 24 hours after a reportable release has been detected, or should have been detected, we will notify the local agency administering the UST program of the release, investigate the release, and take immediate measures to stop the release. If necessary, or if required by the local agency, remaining stored product/waste will be removed from the UST to prevent further releases or facilitate corrective action. If an emergency exists, we will notify the State Office of Emergency Services.

Within five (5) working days of a reportable release, we will submit to the local agency a full written report containing all of the following information to the extent that the information is known at the time of filing the report:

- The UST owner's or operator's name and telephone number;
- A list of the types, quantities, and concentrations of hazardous materials released;
- The approximate date of the release;
- The date on which the release was discovered;
- The date on which the release was stopped;
- A description of actions taken to control and/or stop the release;
- A description of corrective and remedial actions, including investigations which were undertaken and will be conducted to determine the nature and extent of soil, ground water or surface water contamination due to the release;
- The method(s) of cleanup implemented to date, proposed cleanup actions, and a schedule for implementing the proposed actions;
- The method(s) and location(s) of disposal of released hazardous materials and any contaminated soils, groundwater, or surface water.
- Copies of any hazardous waste manifests used for off-site transport of hazardous wastes associated with clean-up activity;
- A description of proposed methods for any repair or replacement of UST system primary/secondary containment systems;
- A description of additional actions taken to prevent future releases.

We will follow the reporting procedures described above if any of the following conditions occur:

- A recordable unauthorized release can not be cleaned up or is still under investigation within eight (8) hours of detection;
- Released hazardous substances are discovered at the UST site or in the surrounding area;
- Unusual operating conditions are observed, including erratic behavior of product dispensing equipment, sudden loss of product, or the unexplained presence of water in the tank, unless system equipment is found to be defective and is immediately repaired or replaced, and no leak has occurred;
- Monitoring results from UST system monitoring equipment/methods indicate that a release may have occurred, unless the monitoring equipment is found to be defective and is immediately repaired, recalibrated, or replaced, and additional monitoring does not confirm the initial results.

Record Retention: Monitoring records and written reports of unauthorized releases must be maintained on-site (or off-site at a readily available location, if approved by the local agency) for at least 3 years. Hazardous waste shipping/disposal records (e.g., manifests) must be maintained for at least 3 years from the date of shipment.

VII. OWNER/OPERATOR SIGNATURE

CERTIFICATION: I certify that the information provided herein is true and accurate to the best of my knowledge.

OWNER/OPERATOR SIGNATURE <i>K.S. Ghuman</i>	DATE 02/13/12	R70
OWNER/OPERATOR NAME (print) KULJIT S. GHUMAN	OWNER/OPERATOR TITLE OWNER	R72

(Agency Use Only) This plan has been reviewed and: Approved Approved With Conditions Disapproved

Local Agency Signature: _____ Date: _____



State of California
 State of Water Resources Control Board
 Division of Clean Water Programs
 P.O. Box 944212
 Sacramento, CA 94244-2120

(Instructions on reverse side)

For State Use Only

CERTIFICATION OF FINANCIAL RESPONSIBILITY FOR UNDERGROUND STORAGE TANKS CONTAINING PETROLEUM

A. I am required to demonstrate Financial Responsibility in the Required amounts as specified in Section 2807, Chapter 18, Div. 3, Title 23, CCR:

- 500,000 dollars per occurrence
 or
 1 million dollars per occurrence
- AND
- 1 million dollars annual aggregate
 or
 2 million dollars annual aggregate

B. JOHNNY QUIK #143 hereby certifies that it is in compliance with the requirements of Section 2807,
 (Name of Tank Owner or Operator)
 Article 3, Chapter 18, Division 3, Title 23, California Code of Regulations.
 The mechanisms used to demonstrate financial responsibility as required by Section 2807 are as follows:

C. Mechanism Type	Name and Address of Issuer	Mechanism Number	Coverage Amount	Coverage Period	Corrective Action	Third Party Comp.
State UST Fund	UST Cleanup Fund PO Box 944212 Sacramento, CA 94244	N/A for UST Cleanup Fund	1 million per occurrence and Annual Aggregate	state UST Fund Continuous	Yes	Yes
owner/operator	Johnny Quik #143 2126 Taft Hwy Bakersfield, CA 93313	N/A for this mechanism	\$5000 per occurrence and Annual Aggregate	Annual	Yes	Yes

Note: If you are using the State Fund as any part of your demonstration of financial responsibility, your execution and submission of this certification also certifies that you are in compliance with all conditions for participation in the Fund.

D. Facility Name <u>Johnny Quik #143</u>		Facility Address <u>Bakersfield</u> <u>2126 TAFT HWY CA-93313</u>	
Facility Name		Facility Address	
Facility Name		Facility Address	
E. Signature of Tank Owner or Operator <u>K Ghuman</u>	Date <u>02/25/08</u>	Name and Title of Tank Owner or Operator <u>KULVITS GHUMAN, OWNER</u>	
Signature of Witness or Notary <u>E Ghuman</u>		Name of Witness or Notary <u>EVANGELINE GHUMAN</u>	

INSTRUCTIONS

CERTIFICATION OF FINANCIAL RESPONSIBILITY

Please type or print information clearly. All UST sites owned or operated may be listed on one form, therefore, a separate certification is not required for each site.

DOCUMENT INFORMATION

- A. **Coverage Required** Check the appropriate boxes.
- B. **Name of Tank Owner or Operator** Full name of either the tank owner or the operator.
- C. **Mechanism Type** Indicate which approved mechanism(s) are being used to show financial responsibility either as contained in the federal regulations, 40 CFR Part 280 Subpart H, Sections 280.93 through 280.107, or Section 2808.1 Chapter 18, Div. 3, Title 23, CCR (see Financial Responsibility Guide for more information).
- Name of Issuer** List all names and address of companies and/or individuals issuing coverage.
- Mechanism Number** List identifying number for each mechanism used. Example: insurance policy number, Letter of Credit number, etc., etc. If using the State Cleanup Fund, leave blank.
- Coverage Amount** Indicate amount of coverage for each listed mechanism. If more than one mechanism is indicated, total must equal 100% of financial responsibility for each site.
- Coverage Period** Indicate the effective date(s) of all mechanisms. State Cleanup Fund coverage is continuous as long as you maintain compliance and remain eligible to participate in the Fund.
- Corrective Action** Indicate yes or no. Does the specified financial assurance mechanism provide coverage for corrective action? It is a required coverage. If using the State Cleanup Fund, indicate "yes."
- Third Party Compensation** Indicate yes or no. Does the specified financial assurance mechanism provide coverage for corrective action? It is a required coverage. If using the State Cleanup Fund, indicate "yes."
- D. **Facility Information** Provide all facility and or site names and addresses.
- E. **Signature Block** Provide signature and date signed by tank owner or operator; printed or typed name and title of tank owner or operator; signature of witness or notary and date signed; and printed or typed name of witness or notary. (If notary signs please attach documentation.)

Where to Mail certification:

Please send original to your local agency(ies) [agency(ies) that issues the UST permits]. Keep a copy of the certification at each listed site.

Questions:

If you have questions about financial responsibility requirements or about the Certification of Financial Responsibility form, please contact the State Water Resources Control Board, Underground Storage Tank Cleanup Fund at (916) 341-5648.

Note:

Penalties for Failure to Comply with Financial Responsibility Requirements:

Failure to comply may result in: 1) jeopardizing claimant eligibility for the State Cleanup Fund, and 2) liability for civil penalties of up to \$10,000 per day, per underground storage tank, for each day of violation as stated in Article 7, Section 25299.76(a) of the California Health and Safety Code.

ACORD TM

NOTICE OF INFORMATION PRACTICES (PRIVACY)

AGENCY
 Thomco Assoc. Ins. Services, Inc
 P.O. Box 9307
 4333 North West Avenue
 Fresno, CA 93791

Ph: 1-800-713-6342

CODE: 40407-00 SUBCODE: 0001

AGENCY CUSTOMER ID

APPLICANT'S NAME AND MAILING ADDRESS (include county & ZIP+4)
 Kuljit Ghuman
 DBA Johnny Quik Foodstore #143
 2126 Taft Highway
 Bakersfield, CA 93313

TELEPHONE NUMBER
 (661) 834-9113

COMPANY
 Markel Insurance Company

ACCOUNT NUMBER

POLICY NUMBER	<input checked="" type="checkbox"/>	NEW	EFFECTIVE DATE	EXPIRATION DATE
MSPQUOTE		RNWL	09/22/06	09/22/07

- | | | | |
|-------------|----------|--------------|--------------|
| California | Georgia | New Jersey | Washington |
| Connecticut | Illinois | Rhode Island | Other: _____ |
| Delaware | Nevada | Virginia | |

Privacy Notification.

A credit report or other investigative report about you may be requested in connection with this application for insurance and subsequent amendments and renewals. Credit scoring information may be used to determine either your eligibility for insurance or the premium you will be charged. We may use a third party in connection with the development of your score. Any information which we have or may obtain about you or other individuals listed as policyholders on your policy will be treated confidentially. However, this information, as well as other personal or privileged information subsequently collected, may, under certain circumstances, be disclosed without prior authorization to non-affiliated third parties. We may also share such information with affiliated companies for such purposes as claims handling, servicing, underwriting and insurance marketing.

You have the right to see personal information collected about you, and you have the right to correct any information which may be wrong.

If you are interested in obtaining a description of our information practices, and your rights regarding information we collect, ask your agent, or, if you have been issued a policy, please write us at the address provided with your policy.

* <u>K. Ghuman</u>	* <u>09/20/06</u>
APPLICANT/NAMED INSURED'S SIGNATURE	DATE
_____	_____
APPLICANT/NAMED INSURED'S SIGNATURE	DATE
_____	_____
APPLICANT/NAMED INSURED'S SIGNATURE	DATE
_____	_____
APPLICANT/NAMED INSURED'S SIGNATURE	DATE
_____	_____

EL

No. **MSP610669**

GARAGE COVERAGE PART DECLARATIONS

Effective Date: **09/22/06**

12:01 A.M., Standard Time

ONE - Named Insured and Mailing Address/Policy Period - Shown in Policy Declarations.
Type of Business: Individual Partnership Corporation Limited Liab. Co. Other _____

ITEM TWO - SCHEDULE OF COVERAGES AND COVERED AUTOS This policy provides only those coverages where a charge is shown in the premium column below. Each of these coverages will apply only to those "autos" shown as covered "autos". "Autos" are shown as covered "autos" for a particular coverage by the entry of one or more of the symbols from the COVERED AUTOS Section of the Garage Coverage Form next to the name of the coverage. Entry of a symbol next to **LIABILITY** provides coverage for "garage operations".

COVERAGES	COVERED AUTOS <small>(Entry of one or more of the symbols from the COVERED AUTOS Section of the Garage Coverage Form shows which autos are covered autos)</small>	LIMIT			PREMIUM
		Each "Accident" "Garage Operations"	Aggregate - "Garage Operations"	Other Than "Auto" Only	
LIABILITY	29	"Auto" Only \$ 1,000,000	Other Than "Auto" Only \$ 1,000,000	Other Than "Auto" Only \$ 3,000,000	\$ 890
PERSONAL INJURY PROTECTION (P.I.P.)**		SEPARATELY STATED IN EACH P.I.P. END. MINUS \$ -0- DEDUCTIBLE			\$
ADDED P.I.P. (or equivalent added No-Fault cov.)		SEPARATELY STATED IN EACH ADDED P.I.P. ENDORSEMENT			\$
PROPERTY PROTECTION INS. (P.P.I.) (Michigan only)		SEPARATELY STATED IN THE P.P.I. ENDORSEMENT MINUS DEDUCTIBLE FOR EACH ACCIDENT			\$
AUTO MEDICAL PAYMENTS		\$			\$
MEDICAL PAYMENTS	See CA2505	\$ 5,000			\$ 8
UNINSURED MOTORISTS (UM)		\$			\$
UNDERINSURED MOTORISTS <small>(when not included in UM Cov.)</small>		\$			\$
GARAGEKEEPER'S					
COMPREHENSIVE COVERAGE	30	\$ 20,000 EACH LOCATION MINUS \$ 1,000 DED. FOR EACH COVERED AUTO FOR LOSS CAUSED BY THEFT OR MISCHIEF OR VANDALISM SUBJECT TO \$ 3,000 MAXIMUM DEDUCTIBLE FOR ALL SUCH LOSS IN ANY ONE EVENT			\$ 109
SPECIFIED CAUSES OF LOSS COVERAGE					\$
COLLISION COVERAGE	30	\$ 20,000 EACH LOCATION MINUS \$ 1,000 DED. FOR EACH COVERED AUTO			\$ 99
PHYSICAL DAMAGE					
COMPREHENSIVE COVERAGE		ACTUAL CASH VALUE OR COST OF REPAIR WHICHEVER IS LESS MINUS } SEE SUPPLEMENTARY SCHEDULE FOR LIMITS AND DEDUCTIBLES }			\$
SPECIFIED CAUSES OF LOSS COVERAGE					\$
FIRE AND THEFT COVERAGE					\$
COLLISION COVERAGE					\$
TOWING AND LABOR <small>(Not Available in California)</small>		\$ for each disablement of a private passenger auto			\$
<p>FORMS AND ENDORSEMENTS APPLYING TO THIS COVERAGE PART AND MADE PART OF THIS POLICY AT TIME OF ISSUE: *</p> <p>CA0005 (07/97), CA0040 (02/03), CA0143 (02/97), CA0302 (12/93), CA2384 (01/06) CA2505 (07/97), CA2518 (09/98), CA9917 (07/97), IL0021 (07/02), MCA018 (03/00) MCA023 (03/00), MD028 (03/99), MIL004 (03/00), MIL006 (03/00), MIL127 (03/00) MIL140 (10/01), PN-CA-TERR (05/04)</p>					
PREMIUM FOR ENDORSEMENTS					\$
ESTIMATED TOTAL PREMIUM **					\$ 1106

THIS DECLARATIONS MUST BE COMPLETED BY THE ATTACHMENT OF SUPPLEMENTARY SCHEDULE

* Forms and Endorsements applicable to this Coverage Part omitted if shown elsewhere in the policy.

** This policy may be subject to final audit.

*** (Or equivalent No-fault coverage.)

Owner Statements of Designated Underground Storage Tank (UST) Operator and Understanding of and Compliance with UST Requirements

Facility Name: Johnny Quik #143	Facility ID #: 320028/003201
Facility Address: 2126 Taft Hwy, Bakersfield, Ca 93313	Reason for Submitting this Form (Check One)
Facility Phone #: (661)834-9113	<input checked="" type="checkbox"/> Change of Designated Operator
	<input type="checkbox"/> Update Certificate Expiration Date

Designated UST Operator(s) for this Facility

PRIMARY

Designated Operator's Name: Aaron Koop
 Business Name (If different from above): Rich Environmental
 Designated Operator's Phone #: (661)392-8687
 International Code Council Certification #: 5246167-UC

Relation to UST Facility (Check One)
 Owner Operator Employee
 Service Technician Third-Party
 Expiration Date: 11-12-06

ALTERNATE 1 (OPTIONAL)

Designated Operator's Name: James Rich
 Business Name (If different from above): Rich Environmental
 Designated Operator's Phone #: (661)392-8687
 International Code Council Certification #: 1064166-UC

Relation to UST Facility (Check One)
 Owner Operator Employee
 Service Technician Third-Party
 Expiration Date: 11-12-06

ALTERNATE 2 (OPTIONAL)

Designated Operator's Name:
 Business Name (If different from above):
 Designated Operator's Phone #:
 International Code Council Certification #:

Relation to UST Facility (Check One)
 Owner Operator Employee
 Service Technician Third-Party
 Expiration Date:

NOTE: THE LOCAL REGULATORY AGENCY MUST BE NOTIFIED OF ANY CHANGES TO THIS INFORMATION WITHIN 30 DAYS OF THE CHANGE.

I certify that, for the facility indicated at the top of this page, the individual(s) listed above will serve as Designated UST Operator(s). The individual(s) will conduct and document monthly facility inspections and annual facility employee training, in accordance with California Code of Regulations, title 23, section 2715(c) - (f).

Furthermore, I understand and am in compliance with the requirements (statutes, regulations, and local ordinances) applicable to underground storage tanks.

NAME OF TANK OWNER OR OWNER'S AGENT (Please Print): KULWIT S. GHUMAN

SIGNATURE OF TANK OWNER OR OWNER'S AGENT: *[Signature]*

DATE: 12/27/04 OWNER'S PHONE #: 661-834-9113

Designated UST Operator(s) for Facility

PRIMARY		Designated Operator's Name: JAMES RICH	Business Name (If different from above): RICH ENVIRONMENTAL	Designated Operator's Phone #: (661)392-8687	International Code Council Certification #: 1064166-UC
Relation to UST Facility (Check One)		<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Employee <input type="checkbox"/> Service Technician <input type="checkbox"/> Third-Party	Expiration Date: 11-12-06		
ALTERNATE 1 (Optional)		Designated Operator's Name: AARON KOOP	Business Name (If different from above): RICH ENVIRONMENTAL	Designated Operator's Phone #: (661)392-8687	International Code Council Certification #: 5246167-UC
Relation to UST Facility (Check One)		<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Employee <input type="checkbox"/> Service Technician <input type="checkbox"/> Third-Party	Expiration Date: 11-12-06		
ALTERNATE 2 (Optional)		Designated Operator's Name: RYAN MASON	Business Name (If different from above): RICH ENVIRONMENTAL	Designated Operator's Phone #: (661)392-8687	International Code Council Certification #: 5261213-UC
Relation to UST Facility (Check One)		<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Employee <input type="checkbox"/> Service Technician <input type="checkbox"/> Third-Party	Expiration Date: 6-13-07		
ALTERNATE 1 (Optional)		Designated Operator's Name: STEVEN OBBERT	Business Name (If different from above): RICH ENVIRONMENTAL	Designated Operator's Phone #: (661)392-8687	International Code Council Certification #: 5261246-UC
Relation to UST Facility (Check One)		<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Employee <input type="checkbox"/> Service Technician <input type="checkbox"/> Third-Party	Expiration Date: 9-7-07		
ALTERNATE 2 (Optional)		Designated Operator's Name: KVIN KIRK	Business Name (If different from above): RICH ENVIRONMENTAL	Designated Operator's Phone #: (661)392-8687	International Code Council Certification #: 5261193-UC
Relation to UST Facility (Check One)		<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Employee <input type="checkbox"/> Service Technician <input type="checkbox"/> Third-Party	Expiration Date: 6-18-07		
ALTERNATE 1 (Optional)		Designated Operator's Name: BRIAN SCOTT	Business Name (If different from above): RICH ENVIRONMENTAL	Designated Operator's Phone #: (661)392-8687	International Code Council Certification #: 5268644-UC
Relation to UST Facility (Check One)		<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Employee <input type="checkbox"/> Service Technician <input type="checkbox"/> Third-Party	Expiration Date: 10-10-07		
ALTERNATE 2 (Optional)		Designated Operator's Name:	Business Name (If different from above):	Designated Operator's Phone #:	International Code Council Certification #:
Relation to UST Facility (Check One)		<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Employee <input type="checkbox"/> Service Technician <input type="checkbox"/> Third-Party	Expiration Date:		
ALTERNATE 1 (Optional)		Designated Operator's Name:	Business Name (If different from above):	Designated Operator's Phone #:	International Code Council Certification #:
Relation to UST Facility (Check One)		<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Employee <input type="checkbox"/> Service Technician <input type="checkbox"/> Third-Party	Expiration Date:		
ALTERNATE 2 (Optional)		Designated Operator's Name:	Business Name (If different from above):	Designated Operator's Phone #:	International Code Council Certification #:
Relation to UST Facility (Check One)		<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Employee <input type="checkbox"/> Service Technician <input type="checkbox"/> Third-Party	Expiration Date:		
ALTERNATE 1 (Optional)		Designated Operator's Name:	Business Name (If different from above):	Designated Operator's Phone #:	International Code Council Certification #:
Relation to UST Facility (Check One)		<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Employee <input type="checkbox"/> Service Technician <input type="checkbox"/> Third-Party	Expiration Date:		
ALTERNATE 2 (Optional)		Designated Operator's Name:	Business Name (If different from above):	Designated Operator's Phone #:	International Code Council Certification #:
Relation to UST Facility (Check One)		<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Employee <input type="checkbox"/> Service Technician <input type="checkbox"/> Third-Party	Expiration Date:		

Kern County Environmental Health Services Department
 2700 M Street, Suite 300
 Bakersfield, CA 93301
 (661) 862-8700 Fax (661) 862-8701
 Certified Unified Program Agency – Underground Storage Tank Program

**UST Owner Declaration of Compliance
 and Identification of Designated UST Operator**

Facility and Owner Information

Date:	Facility ID: 320028 / 003201
Tank Owner Name: GHUMAN SINGH KULJIT	Facility Name: JOHNNY QUICK #143
Tank Owner Address: P O BOX 137 PUMPKIN CENTER, CA 93383	Facility Address: 2126 TAFT HWY BAKERSFIELD
Tank Owner Phone: <i>661-831-9316</i>	Facility Phone: <i>661-834-9113</i>

Designated Operator Information

Name of Designated Operator:	<i>Aaron Koop / Rich Environmental</i>
Facility Connection:	<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Employee <input checked="" type="checkbox"/> Service Tech <input type="checkbox"/> Other/Third Party
Business Name / Phone # of Designated Operator (If Service Tech or Third Party)	<i>Rich Environmental Ph: 661-392-8687</i>
California UST Operator Certificate Number, (issued by ICC):	<i>5246167-UC</i>

Declaration of Compliance

Owner Declaration: *I hereby designate the above-named individual as the "Designated UST Operator" for this facility. This operator has completed the required certified training and is in possession of the Operator Certificate noted above. This individual will conduct monthly visual inspections of the UST Facility, provide basic on-the-job- training to facility employees every twelve months, and keep records of these activities. It is understood that these tasks must be performed by the Designated Operator and cannot be delegated.*

Furthermore, As the owner of the underground storage tanks at the above-noted facility, I declare, under penalty of perjury, that I understand and am in compliance with all applicable Underground Storage Tank requirements pursuant to the California Health and Safety Code, Chapter 6.7.

Signature of Tank Owner: *[Signature]* *12/27/04*

Handwritten text at the top of the page, possibly a title or header.

Large block of handwritten text in the upper middle section.

Handwritten text in the middle section, appearing as a list or series of notes.

Two lines of handwritten text in the lower middle section.

Handwritten text at the bottom of the page, possibly a signature or footer.

Owner Statements of Designated Underground Storage Tank (UST) Operator and Understanding of and Compliance with UST Requirements

Facility Name: Johnny Quik #143	Facility ID #: <u>320028/003201</u>
Facility Address: 2126 Taft Hwy. Bakersfield, Ca 93313	Reason for Submitting this Form (Check One) <input checked="" type="checkbox"/> Change of Designated Operator <input type="checkbox"/> Update Certificate Expiration Date
Facility Phone #: (661)834-9113	

Designated UST Operator(s) for this Facility

PRIMARY

Designated Operator's Name: Aaron Koop
 Business Name (If different from above): Rich Environmental
 Designated Operator's Phone #: (661)392-8687
 International Code Council Certification #: 5246167-UC

Relation to UST Facility (Check One)
 Owner Operator Employee
 Service Technician Third-Party
 Expiration Date: 11-12-06

ALTERNATE 1 (Optional)

Designated Operator's Name: James Rich
 Business Name (If different from above): Rich Environmental
 Designated Operator's Phone #: (661)392-8687
 International Code Council Certification #: 1064166-UC

Relation to UST Facility (Check One)
 Owner Operator Employee
 Service Technician Third-Party
 Expiration Date: 11-12-06

ALTERNATE 2 (Optional)

Designated Operator's Name:
 Business Name (If different from above):
 Designated Operator's Phone #:
 International Code Council Certification #:

Relation to UST Facility (Check One)
 Owner Operator Employee
 Service Technician Third-Party
 Expiration Date:

NOTE: THE LOCAL REGULATORY AGENCY MUST BE NOTIFIED OF ANY CHANGES TO THIS INFORMATION WITHIN 30 DAYS OF THE CHANGE.

I certify that, for the facility indicated at the top of this page, the individual(s) listed above will serve as Designated UST Operator(s). The individual(s) will conduct and document monthly facility inspections and annual facility employee training, in accordance with California Code of Regulations, title 23, section 2715(c) - (f).

Furthermore, I understand and am in compliance with the requirements (statutes, regulations, and local ordinances) applicable to underground storage tanks.

NAME OF TANK OWNER OR OWNER'S AGENT (Please Print): KULVIT S. GHUMAN

SIGNATURE OF TANK OWNER OR OWNER'S AGENT: [Signature]

DATE: 12/27/04 OWNER'S PHONE #: 661-834-9113

DEC 29 2004


WORLD LIBRARY

[Illegible text]

[Illegible text]

320028

MONITORING PLAN COVER SHEET



FACILITY INFORMATION

Name: JOHNNY QUIK #143
 Operator: KULJIT S. GHUMAN Facility ID #: FA0002691
 Address: 2126 TAFT HWY
 City: BAKERSFIELD State: CA Zip: 93313

TANK OWNER INFORMATION

Name: KULJIT S. GHUMAN
 Address: 2126 TAFT HWY
 City: BAKERSFIELD State: CA Zip: 93313

** If the tank owner and operator are not the same, an owner/operator agreement form must be completed and submitted to the Kern County Environmental Health Services Department.

PERSON RESPONSIBLE FOR MONITORING

Name: KULJIT S. GHUMAN Title: OWNER

TRAINING

Describe the training necessary for the operation of the UST system, including piping and monitoring equipment:

One or two years College Education.
2 or 3 years work at gas station.
Any technical knowledge will be plus.

SUBMITTED BY

Name: Kuljit S. Ghuman Title: OWNER
 Phone: 661-834-9113 Date: 08/7/02

A copy of the monitoring plan is to be kept on site with the Permit to Operate

INTERNAL USE ONLY

Approved by: _____ Date: _____

1945-1946
1947-1948

1949-1950

1951-1952
1953-1954
1955-1956

1957-1958

1959-1960

1961-1962
1963-1964
1965-1966

1967-1968

1969-1970
1971-1972
1973-1974
1975-1976

1977-1978

1979-1980

1981-1982

1983-1984

1985-1986

MONITORING REQUIREMENT OPTIONS

TANKS

DOUBLE WALLED (JACKETED) TANKS

The double walled (jacketed) tanks have a continuous leak monitoring system in the annular space. The system is a (EMC) Environmental Management Console (make and model) and is located Inside in office corner (panel location). The system is connected to an audible and visual alarm. EMC WITH (BIR) A MAP is attached.

The alarm panel is inspected daily for power and alarm status and is documented on a daily log sheet.

For hydrostatic annular monitoring systems, if monitoring indicates a possible unauthorized release, the presence or absence of hazardous substance in the interstitial space will be determined by _____ (method used).

SINGLE WALLED FIBERGLASS OR CLAD TANKS

The tanks have an automatic tank gauging (ATG) system that is capable of conducting a 0.2 gph leak test. The system is a _____ (make and model) and is located _____ (panel location). The ATG is placed in the test mode at least monthly and after product delivery or when the tank is filled to within 10% of the previous month's highest operating level.

The ATG generates a hard copy (print out) of the test data after each test. The copies are maintained on site or at _____ (an approved location).

SINGLE WALLED INTERIOR LINED AND CATHODICALLY PROTECTED TANKS

The tanks have an automatic tank gauging (ATG) system that is capable of conducting a 0.2 gph leak test. The system is a _____ (make and model) and is located _____ (panel location). The ATG is placed in the test mode at least monthly and after product delivery or when the tank is filled to within 10% of the previous month's highest operating level.

The ATG generates a hard copy (print out) of the test data after each test. The copies are maintained on site or at _____ (an approved location).

The interior lining will be inspected and certified before _____ (ten years from lining date) and every five years thereafter.

The cathodic protection system will be tested and certified every three years. The rectifier (impressed current systems) is located _____ (panel location). The rectifier is inspected every _____ days (at least every 60 days) for setting, power, and operating hours. The results documented on the inspection log. Records pertaining to the cathodic protection system maintenance are kept for 6 ½ years.

PIPING

DOUBLE WALLED PIPING

The double walled piping has a continuous leak monitoring system in the turbine sump. The system is a Gilbarco EMC with (BIR) (make and model) and is located _____ (panel location). The system is connected to an audible and visual alarm.

The alarm panel is inspected daily for power and alarm status and is documented on a daily log sheet.

- AND -

Positive Shut Down Options for Pressurized Piping

1. The monitoring system does not shut down the turbine when a release is detected. An automatic line leak detector is installed that detects a release equivalent to 3.0 gph. An annual piping integrity test is conducted that detects a release from the primary piping equivalent to 0.1 gph. **OR**
- ✓ 2. The monitoring system shuts down the turbine when a release is detected. An annual piping integrity test is conducted that detects a release from the primary piping equivalent to 0.1 gph. **OR**
3. The monitoring system shuts down the turbine when a release is detected and if the continuous monitoring system fails or is disconnected.

SINGLE WALLED FIBERGLASS PRESSURIZED PIPING

The single walled pressurized piping has an automatic line leak detector that shuts off the product flow if a release is detected or if the line leak detector fails or is disconnected. The system is a _____ (make and model). The Panel is located _____ (panel location).

- AND -

1. A piping integrity test that is third party certified to detect a release of 0.2 gph is conducted monthly. **OR**
2. A piping integrity test that is third party certified to detect a release of 0.1 gph defined at 150% of normal operating pressure is conducted annually.

SINGLE WALLED METAL PRESSURIZED PIPING CATHODICALLY PROTECTED

The single walled pressurized piping has an automatic line leak detector that shuts off the product flow if a release is detected or if the line leak detector fails or is disconnected. The system is a _____ (make and model). The Panel is located _____ (panel location).

- AND -

3. A piping integrity test that is third party certified to detect a release of 0.2 gph is conducted monthly. **OR**
4. A piping integrity test that is third party certified to detect a release of 0.1 gph defined at 150% of normal operating pressure is conducted annually.

The cathodic protection system will be tested and certified every three years. The rectifier (impressed current systems) is located _____ (panel location). The rectifier is inspected every _____ days (at least every 60 days) for setting, power, and operating hours. The results documented on the inspection log. Records pertaining to the cathodic protection system maintenance are kept for 6 ½ years.

SINGLE WALLED SUCTION PIPING

The single walled suction piping is monitored daily for the presence of air in the line and is documented by completion of the daily inspection log.

- AND -

All check valves and pumps are installed above grade, and an inspection method is provided to readily demonstrate this. **OR**

A check valve is installed below grade, and a piping integrity test, that is third party certified to detect a release of 0.1 gph defined at 150% of normal operating pressure, is conducted at least once every three years.

(Any metal suction piping must also meet the same cathodic protection requirements as pressurized piping)

SINGLE WALLED GRAVITY PIPING

A piping integrity test that is third party certified to detect a release of 0.1 gph defined at 150% of normal operating pressure is conducted at least once every two years.

(Any metal gravity piping must also meet the same cathodic protection requirements as pressurized piping)

DISPENSER PANS

The dispenser pans are monitored using a continuous leak monitoring system. The system is a Gilbarco (EMC) (make and model) and is connected to an audible and visual alarm. The system is located Inside in the office (panel location).

The alarm panel is inspected daily for power and alarm status and is documented on a daily log sheet. **OR**

The dispenser pans are monitored using a continuous leak monitoring system. The system is a _____ (make and model) and stops the flow of product at the dispenser when a leak is detected.

- AND -

Positive Shut Down Options for Dispenser Pans

4. The monitoring system does not shut down the turbine when a release is detected. An automatic line leak detector is installed that detects a release equivalent to 3.0 gph. An annual piping integrity test is conducted that detects a release from the primary piping equivalent to 0.1 gph. **OR**

✓ 5. The monitoring system shuts down the turbine when a release is detected. An annual piping integrity test is conducted that detects a release from the primary piping equivalent to 0.1 gph. **OR**

6. The monitoring system shuts down the turbine when a release is detected and if the continuous monitoring system fails or is disconnected.

- OR -

Dispenser pans will be installed before December 31, 2003 with an approved monitoring. The monitoring plan will be updated and approved at the time of installation.

OVERFILL AND SPILL PREVENTION

Each tank fill opening is equipped with an approved spill prevention container of minimum five gallon capacity. The container is equipped with a drain valve to permit spilled hazardous material to be drained into the tank primary containment.

- AND -

Each tank fill opening is equipped with an approved overflow prevention device which cannot allow manual override and alerts the transfer operator when the tank is 90% full by restricting the flow into the tank or by triggering an audible and visual alarm. **OR**

Each tank fill opening is equipped with an approved overflow prevention device which cannot allow manual override and restricts the flow to the tank at least 30 minutes prior to tank overflow, the restriction occurs at no more than 95% of the tank capacity and triggers an audible and visual alarm at least five minutes prior to tank overflow. **OR**

Each tank fill opening is equipped with an approved overflow prevention device which cannot allow manual override and provides positive shut-off (100%) of flow to the tank when the tank is no more than 95 % full.

MONITORING EQUIPMENT MAINTENANCE (All facilities)

Equipment and devices used to monitor the UST system will be calibrated, operated, and maintained in accordance with the manufacturer's instructions, including routine maintenance and service checks at least once per calendar year for operability or running condition. The Kern County Environmental Health Services Department will be notified at least two working days prior to the annual certification and the results submitted within 30 days.

SECONDARY CONTAINMENT TESTING

The secondary containment systems (i.e. tanks, piping, turbine (piping) sumps, fill sumps, and dispenser pans) will be tested every 36 months with the first test completed before January 1, 2003.

ENHANCED LEAK DETECTION MONITORING

This facility is located within 1000 feet of a public drinking water well and has at least one component that is single walled (i.e. tank, piping, or no dispenser pan). The tank system will be tested using an approved Enhanced Leak Detection program within 18 months of notification from the State and every 36 months thereafter.

RECORD RETENTION

Written monitoring records will be maintained on site or at 2126 TAFT HWY
(an approved location)
for the following periods of time:

Three years for monitoring and maintenance records

Five years for written performance claims pertaining to release detection systems and calibration/maintenance records for such systems.

6 ½ years for cathodic protection maintenance records.

RECTIFIER - 60 DAY INSPECTION LOG

N/A

Facility Name: _____	Permit #: _____
Address: _____	
Rectifier Make & Model: _____	
Installer: _____	Installation Date: _____

Inspection Schedule	Date	Inspector	Rectifier Settings		D C Outputs		Clock Hour Readings	Remarks
			Coarse	Fine	Volts	Amps		
Initial								
2 Months								
4 Months								
6 Months								
6 month inspection report is required from a Cathodic Protection Tester								
8 Months								
10 Months								
12 Months								
14 Months								
16 Months								
18 Months								
20 Months								
22 Months								
24 Months								
26 Months								
28 Months								
30 Months								
32 Months								
34 Months								
36 Months								
3 year inspection report required from a Cathodic Protection Tester								
Normal Ranges								

If there appears to be a problem with the system, note the problem under remarks and call for assistance.

Records on cathodic protection are to be maintained for 6 1/2 years

1 DAY REPORT 1

Day # 0918 01/07/02 10:15 TO Current

PRINTED: 01/08/02 09:28

TCR-15 JOHNNY QUIK #143
2126 TAFT HWY.
BAKERSFIELD CA 93313

CONSOLE Ver: 30.0.11
SYSTEM Ver: 85.0.19

SALES SUMMARY

Revenue

Sales

Fuel Sales	Volume	%-of-Sales	Sales
UNLEAD	2282.886	81.07%	\$ 2098.04
P-PLUS	195.200	8.29%	\$ 214.53
P-PREM	229.678	10.64%	\$ 275.37

Total Fuel 2707.764 100.00% \$ 2587.94

Net Manual Fuel Sales 0.00

Prepays

Prepays Started	\$ 1022.43
Prepays Completed	1022.43

Net Prepays 0.00

Net Department Sales 1795.29

Net Car Wash Sales 29.84

Total Sales \$ 4413.07

Other Revenue

Taxes Collected on taxable sales \$ 678.63 \$ 48.98

Paid In 0.00

Fees on Debit Sales 0.00

Total Other Revenue 48.98

Total Revenue \$ 4462.05

Expenses

Paid Out	(\$ 236.07)
Refunds to Cash	0.00
Refunds to Credit	0.00
Refunds to Debit	0.00
Refunds to Proprietary Fleet	0.00
Refunds to Local Credit	0.00
Cash Back on Debit	(40.00)

Total Expenses (236.07)

Total Money Due \$ 4225.98

Fuel Adjustments Driveoffs 0.00

**EMERGENCY RESPONSE PLAN FORM
UNDERGROUND STORAGE TANK MONITORING PROGRAM**

Facility Name: JOHNNY QUICK #143

Facility Address: 2126 TAFT HWY BAKERSFIELD, CA -93303

1. If an unauthorized release occurs, how will the hazardous substance be cleaned up?

Note: If released hazardous substances reach the environment, increase the fire or explosion hazard, are not cleaned up from the secondary containment within 8 hours, or deteriorate the secondary containment, the Kern County Environmental Health Services Department must be notified within 24 hours.

For small spills of gas, we use cat litter or soaking sand. After that, we will sweep it off with broom. For major spill, I'll call a company, who does this kind of service.

2. Describe the proposed methods and equipment to be used for removing and properly disposing of any hazardous substances.

suction pumps, sweeping brooms and soaking sand etc.

3. Describe the location and availability of the required cleanup equipment in item 2 above.

2126 TAFT HWY, open 24 hours.

4. Describe the maintenance schedule for the cleanup equipment.

Periodic maintenance is done.

5. List the name(s) and title(s) of the person(s) responsible for authorizing any work necessary under the response plan:

KULWIT S. GHUMAN (OWNER)
SURINDER S. GHUMAN (EMPLOYEE)
JASWINDER SINGH (EMPLOYEE)

Handwritten text at the top of the page, possibly a title or header.

Handwritten text in the upper middle section.


Handwritten text in the middle section.

Handwritten text in the lower middle section.

Large block of handwritten text in the lower section.

Handwritten text at the bottom of the page.

PLOT PLAN



119 TAFT HWY






ENTRANCE

ENTRANCE

PRICE
SIGNS

GRASS

10,000
GALLONS UST
GAS TANKS
WITH SENSORS
IN THE ANNULAR
SPACE



GAS PUMPS

TURBINE SUMPS
& MAN HOLES
WITH MONITORING SENSORS

MAIN
ENTRANCE

PARKING

PARKING

AIR
WATER

PUBLIC
PHONES





WATER
WELL

CAR
WASH

OPEN SPACE

ENVIRONMENTAL
MANAGEMENT
CONSOLE
(EMIC) WITH
ALARM PANEL

STORE BUILDING



ENVIRONMENTAL HEALTH SERVICES DEPARTMENT

RESOURCE MANAGEMENT AGENCY

STEVE McCALLEY, R.E.H.S., Director
2700 "M" STREET, SUITE 300
Bakersfield, CA 93301-2370
Voice: (805) 862-8700
FAX: (805) 862-8701
TTY Relay: 1-800-735-2979



DAVID PRICE III, RMA DIRECTOR
Engineering & Survey Services Department
Environmental Health Services Department
Planning Department
Roads Department

Date: 2/20/98
Time In: 9:30 AM

CERTIFIED UNIFIED PROGRAM AGENCY
INSPECTION FORM

UGP-9-64
Violations
Employee ID: KLD 9

Table with 7 columns: Record ID, Prog/Elc, Svc, Result, Action, Insp Min., Facility Violation. Contains handwritten entries for inspection records.

Legend table with 4 columns: PROGRAM/ELEMENT, SERVICE CODES, RESULT CODES, ACTION CODES. Lists codes for various inspection types and results.

ENVISION FACILITY ID NO.: 603201
FACILITY NAME: Johnny Quirk Texaco
FACILITY LOCATION: 2124 Taft Hwy
TEL. NO.(DAY): 832-9113
(24 HR) 832-9113

TYPE OF INSP.: [X] Routine [] Re-insp. [] Complaint
INSPECTING AGENCY: [] EHSD [] KCFD [] AG [X] WAM

PROGRAMS INSPECTED: [X] Business Plan [] HW Generator [X] UST [] AGT
REINSPECTION REQUIRED: [] NO [] YES [] Business Plan [] HW Generator [] UST [] AGT

CONSENT: Consent to conduct inspection which may involve obtaining photographs, review and copying of records, and determination of compliance with UST, AGT, and hazardous materials/waste handling requirements.
[X] Granted [] Refused By (Name/Title): Owner/UGP Reason (if refused): NOT Available

GENERAL REQUIREMENTS

- YES NO N/A VIOL. # TRAINING
[] [X] [] TR01 Facility has appropriate training program (Title 19 CCR 2732 & 22 CCR 66265.16)
[] [X] [] TR02 Training documentation is maintained on site for current personnel(Title 19 CCR 2732 & 22 CCR 66265.16)
CONTINGENCY/EMERGENCY PLAN
[] [X] ER01 Contingency plan is complete, updated, and maintained on site (HSC 25504, Title 19 CCR 2731 & 22 CCR & 66265.53/54)
[X] [] [] ER02 Facility is operated and maintained to prevent/minimize/mitigate fire, explosion, or release of hazardous materials/waste constituents to the environment. Maintains all required or appropriate equipment including an alarm and communications system (Title 19 CCR 2731 & 22 CCR 66265.31-.34)

BUSINESS PLAN

- YES NO N/A VIOL. #
[] [X] [] BP01 Business plan is current & available during inspection (HSC 25503.5, Title 19 CCR 2729)
[X] [X] [] BP02 Inventory of hazardous materials is complete (HSC 25504, Title 19 CCR 2729)

YES NO N/A VIOL. # Hazardous Waste Generator (continued)

WASTE DISCHARGE

WD01 Facility has a washrack, drain, or sump. Status: active closed
WD02 Arc above activities in compliance. (closed looped system or connected to sewer)

UNDERGROUND STORAGE TANK (UST)

Permit No. 05 3201
PERMITTED TANKS 3
UNPERMITTED TANKS
Owner & operator as indicated on permit: YES NO
If no, new owner name & address:
MONITORING CODES
1. No monitoring
2. Standard Inventory Control
3. Modified Inventory Control
4. Statistical Inventory Rec.
5. Automatic tank gauge (list type)
6. Continuous monitoring in tank annular space/secondary containment
7. Visual monitoring
8. Manual monitoring annular space
9. Temporarily abandoned under permit
10. Another method

YES NO N/A VIOL. #

PERMITTING

UT01 Site has a permit to operate (HSC 25284)
UT02 Permit is kept on the premises (KCOC 8.48.080)
UT03 Change of ownership is reported to the permitting agency within 30 days (HSC 25284(c))
UT04 All UST(s) are properly permitted to operate or properly closed (HSC 25298, KCOC 8.48.270)

MONITORING

UT05 UST(s) monitored using method specified on the permit or approved by the permitting agency (HSC 25293, KCOC 8.48.140) (Designat monitoring code(s) observed 57, ,)
UT06 Monitoring records are provided to regulatory agency upon request (KCOC 8.48.035/140)
UT07 Automatic line leak detection system is installed & kept operational for all pressurized piping (HSC 25292)
UT08 An annual report is submitted to regulatory agency (KCOC 8.48.130)
UT09 Tank tightness test and/or piping test is being performed as required (Title 23 CCR)
UT10 Alarm Response Plan submitted for electronically monitored tank system (Title 23 CCR 2632/34)
UT11 Facility maintains evidence of Financial Responsibility for corrective action and for compensating third parties for bodily injury/ property damage caused by a release from the tank system (HSC 25292, KCOC 8.48.175)

ABOVEGROUND PETROLEUM STORAGE TANK ACT

No. of Tanks: Product Stored: Diesel Gasoline Crude oil
Total Volume: bbls or gals Others

Note: SPCC required for tanks with total storage capacity of > 10,000 gallons - 240 hbls ; for farms, nurseries, construction sites individual storage capacity of >20,000 gal or total storage capacity of >100,000 gallons.

YES NO N/A VIOL. #

AT01 SPCC Plan is prepared and certified by a registered engineer within last 3 yrs.
AT02 SPCC Plan is maintained on site or nearest field office.

*Gilbarco G- Site

SUMMARY OF OBSERVATIONS/VIOLATIONS

No violations of underground tank, hazardous materials inventory, and hazardous waste laws, regulations, and requirements were discovered. KCEHSD greatly appreciates your efforts to comply with all the laws and regulations applicable to your facility.

Violations were observed/discovered as listed below. All violations must be corrected by implementing the corrective action listed by each violation. If you disagree with any of the violations or proposed action, please inform KCEHSD in writing.

All minor violations must be corrected within 30 days or as specified. KCEHSD must be informed in writing certifying that compliance has been achieved. A false statement that compliance has been achieved is a violation of the law and punishable by a fine of not less than \$2,000 or more than \$25,000 for each violation. Your facility may be reinspected at any time.

You may request a meeting with KCEHSD Program Manager to discuss the inspection findings and/or proposed corrective actions. The issuance of this Summary of Violations does not preclude KCEHSD from taking administrative, civil, or criminal action as a result of the violations noted or that have not been corrected within the time specified.

VIOLATIONS.

	NO.	MINOR	MAJOR	CORRECTIVE ACTION REQUIRED
TR0	1	✓	—	Need to document training of employees
ERO	—	—	—	—
BPO	1	—	✓	Not available visit was available at ^{office} worksite
	2	✓	—	No hard copy available on inventory computer
	3	✓	—	Available at proposed office
GTO	—	—	—	—
WDO	—	—	—	—
UTO	—	—	—	—
ATO	—	—	—	—

COMMENTS:

Insp. Agency Rep.: Leo Mendez Facility Rep.: W. Gausman

Date: 2/20/98 Title: owner

of Deal Properties
5790 E. Rte. 100

(209) 291-8672



State of California
State Water Resources Control Board

For Regulatory Agency Use Only

320028

CERTIFICATION OF FINANCIAL RESPONSIBILITY FOR UNDERGROUND STORAGE TANKS CONTAINING PETROLEUM

A. I am required to demonstrate Financial Responsibility in the required amounts as specified in Section 2807, Chapter 18, Div. 3, Title 23, CCR:

500,000 dollars per occurrence

AND

1 million dollars annual aggregate

1 million dollars per occurrence

2 million dollars annual aggregate

6/99M

B. JeeT Saha hereby certifies that it is in compliance with the requirements of Section 2807.

(Name of Tank Owner or Operator)

Article 3, Chapter 18, Division 3, Title 23, California Code of Regulations.

The mechanisms used to demonstrate financial responsibility as required by Section 2807 are as follows:

C. Mechanism Type	Name and Address of Issuer	Mechanism Number	Coverage Amount	Coverage Period	Corrective Action	Third Party Comp.
Kern Co. CALIFORNIA	Allied Group Robert Lynn Co, P.O. Box 1966 Bakersfield, CA 93303	ACPRAS 7800078468	1MM	8-23-93 8-23-94	Yes	Yes

Note: If you are using the State Fund as any part of your demonstration of financial responsibility, your execution and submission of this certification also certifies that you are in compliance with all conditions for participation in the Fund.

D. Facility Name	Facility Address
Johnny Quik Food Store, #143	2126 Taft Hwy. Bakersfield, CA 93383
Facility Name	Facility Address
Facility Name	Facility Address
Facility Name	Facility Address
Facility Name	Facility Address

E. Signature of Tank Owner or Operator	Date	Name and Title of Tank Owner or Operator
<u>MB/Almond</u>	<u>May 04, 94</u>	<u>APSGREWAL</u>
Signature of Witness or Notary	Date	Name of Witness or Notary
<u>Hossam Khiralla</u>	<u>05-04-94</u>	<u>Hossam Khiralla</u>

INSTRUCTIONS

CERTIFICATION OF FINANCIAL RESPONSIBILITY FORM

Please type or print clearly all information on Certification of Financial Responsibility form. All UST facilities and/or sites owned or operated may be listed on one form; therefore a separate certificate is not required for each site.

DOCUMENT INFORMATION

- A. **Amount Required** - Check the appropriate boxes.
- B. **Name of Tank Owner or Operator** - Full name of either the tank owner or the operator.
- C. **Mechanism Type** - Indicate which State approved mechanism(s) are being used to show financial responsibility either as contained in the federal regulations, 40 CFR, Part 280, Subpart H, Sections 280.90 through 280.103 (See Financial Responsibility Guide, for more information), or Section 2808.1, Chapter 18, Division 3, Title 23, CCR.
- Name of Issuer** - List all names and addresses of companies and/or individuals issuing coverage.
- Mechanism Number** - List identifying number for each mechanism used. Example: insurance policy number or file number as indicated on bond or document. (If using State Cleanup Fund (State Fund) leave blank.)
- Coverage Amount** - Indicate amount of coverage for each type of mechanism(s). If more than one mechanism is indicated, total must equal 100% of financial responsibility for each facility.
- Coverage Period** - Indicate the effective date(s) of all financial mechanism(s). (State Fund coverage would be continuous as long as you maintain compliance and remain eligible to continue participation in the Fund.)
- Corrective Action** - Indicate yes or no. Does the specified financial mechanism provide coverage for corrective action? (If using State Fund, indicate "yes".)
- Third Party Compensation** - Indicate yes or no. Does the specified financial mechanism provide coverage for third party compensation? (If using State Fund, indicate "yes".)
- D. **Facility Information** - Provide all facility and/or site names and addresses.
- E. **Signature Block** - Provide signature and date signed by tank owner or operator; printed or typed name and title of tank owner or operator; signature of witness or notary and date signed; and printed or typed name of witness or notary (if notary signs as witness, please place notary seal next to notary's signature).

Where to Mail Certification:

Please send original to your local agency (agency who issues your UST permits). Keep a copy of the certification at each facility or site listed on the form.

Questions:

If you have questions on financial responsibility requirements or on the Certification of Financial Responsibility Form, please contact the State UST Cleanup Fund at (916) 227-4307.

Note: Penalties for Failure to Comply with Financial Responsibility Requirements:

Failure to comply may result in: (1) jeopardizing claimant eligibility for the State UST Cleanup Fund, and (2) liability for civil penalties of up to \$10,000 dollars per day, per underground storage tank, for each day of violation as stated in Article 7, Section 25299.76(a) of the California Health and Safety Code.

KERN COUNTY RESOURCE MANAGEMENT AGENCY

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT
 2700 "M" STREET, SUITE 300, BAKERSFIELD, CA. 93301
 (805)861-3636

UNDERGROUND HAZARDOUS SUBSTANCE STORAGE FACILITY
 * INSPECTION REPORT *

PERMIT# 320028C TIME IN 10:45A TIME OUT _____ NUMBER OF TANKS: 3
 PERMIT POSTED? YES _____ NO _____ INSPECTION DATE: 6-8-92
 TYPE OF INSPECTION: ROUTINE REINSPECTION _____ COMPLAINT _____

FACILITY NAME: JOHNNY QUICK FOOD STORE
 FACILITY ADDRESS: 2126 TAFT HIGHWAY
 BAKERSFIELD, CA
 OWNERS NAME: JOHNNY QUICK FOOD STORE
 OPERATORS NAME: JOHNNY QUICK FOOD STORE
 COMMENTS: _____

ITEM	VIOLATIONS/OBSERVATIONS
1. PRIMARY CONTAINMENT MONITORING: a. Intercepting an directing system b. Standard Inventory Control c. Modified Inventory Control d. In-tank Level Sensing Device e. Groundwater Monitoring f. Vadose Zone Monitoring	N/A
2. SECONDARY CONTAINMENT MONITORING: a. Liner (b) Double-Walled tank c. Vault	Alarm installed - functioning properly - Need to be checking daily - left forms.
3. PIPING MONITORING: a. Pressurized b. Suction c. Gravity	Check line leak detector for compliance annually.
4. OVERFILL PROTECTION:	installed - need to be cleaned out
5. TIGHTNESS TESTING	N/A
6. NEW CONSTRUCTION/MODIFICATIONS	None
7. CLOSURE/ABANDONMENT	None
8. UNAUTHORIZED RELEASE	unknown
9. MAINTENANCE, GENERAL SAFETY, AND OPERATING CONDITION OF FACILITY	OK

COMMENTS/RECOMMENDATIONS _____

REINSPECTION SCHEDULED? yes no _____ APPROXIMATE REINSPECTION DATE: _____
 INSPECTOR: Laurel Funk REPORT RECEIVED BY: [Signature]

KERN COUNTY AIR POLLUTION CONTROL DISTRICT

2700 "M" Street, Suite 275

Bakersfield, CA. 93301

(805) 861-3682

PHASE I VAPOR RECOVERY INSPECTION FORM

Station Name: Johnny Quik Market # 143 Location: 2126 Taft Hwy. P/O #: 8670010-012

Company Mailing Address: P.O. Box 72137 City: Pumkin Center

Date: 6-8-92 Phone: _____ System Type: (Sep. Riser) Coaxial

Inspector: Laurel Funk Notice Rec'd By: Jalson

	TANK #1	TANK #2	TANK #3	TANK #4
1. PRODUCT (UL, PUL, P, or R)	<u>UL</u>	<u>UL</u>	<u>PUL</u>	_____
2. TANK LOCATION REFERENCE	<u>South</u>	<u>Center</u>	<u>North</u>	_____
3. BROKEN OR MISSING VAPOR CAP	_____	<input checked="" type="checkbox"/>	_____	_____
4. BROKEN OR MISSING FILL CAP	_____	_____	_____	_____
5. BROKEN CAM LOCK ON VAPOR CAP	_____	_____	_____	_____
6. FILL CAPS NOT PROPERLY SEATED	_____	_____	_____	_____
7. VAPOR CAPS NOT PROPERLY SEATED	_____	_____	_____	_____
8. GASKET MISSING FROM FILL CAP	<input checked="" type="checkbox"/>	_____	_____	_____
9. GASKET MISSING FROM VAPOR CAP	_____	_____	_____	_____
10. FILL ADAPTOR NOT TIGHT	_____	_____	_____	_____
11. VAPOR ADAPTOR NOT TIGHT	_____	_____	_____	_____
12. GASKET BETWEEN ADAPTOR & FILL TUBE MISSING / IMPROPERLY SEATED	_____	_____	_____	_____
13. DRY BREAK GASKETS DETERIORATED	_____	<input checked="" type="checkbox"/>	_____	_____
14. EXCESSIVE VERTICAL PLAY IN COAXIAL FILL TUBE	_____	_____	_____	_____
15. COAXIAL FILL TUBE SPRING MECHANISM DEFECTIVE	_____	_____	_____	_____
16. TANK DEPTH MEASUREMENT	<u>147"</u>	<u>146"</u>	<u>145"</u>	_____
17. TUBE LENGTH MEASUREMENT	<u>141"</u>	<u>143"</u>	<u>140 1/2"</u>	_____
18. DIFFERENCE (SHOULD BE 6" OR LESS)	<u>6"</u>	<u>3"</u>	<u>4 1/2"</u>	_____
19. OTHER	_____	_____	_____	_____
20. COMMENTS:	_____			

★ **WARNING: SYSTEMS MARKED WITH A CHECK ABOVE ARE IN VIOLATION OF KERN COUNTY AIR POLLUTION CONTROL DISTRICT RULE(S) 209, 412 AND/OR 412.1. THE CALIFORNIA HEALTH & SAFETY CODE SPECIFIES PENALTIES OF UP TO \$1,000.00 PER DAY FOR EACH VIOLATION. TELEPHONE (805) 861-3682 CONCERNING FINAL RESOLUTION OF THE VIOLATION(S)** ★★★

APCD FILE

KERN COUNTY AIR POLLUTION CONTROL DISTRICT

2700 "M" Street, Suite 275

Bakersfield, CA. 93301

(805) 861-3682

PHASE II VAPOR RECOVERY INSPECTION FORM

8670010-012

Station Location 2126 Taft Hwy. P/O # 86
 Company Address P.O. Box 73137 City Pumpkin Center Zip 93383
 Contact Balram Sandhu Phone _____ System Type: BA RJ HI HE GH HA
 Inspector Laurel Funk Date 6-8-92 Notice Rec'd By Dalton

NOZZLE #	1A	1B	1C	2A	2B	2C	3A	3B	3C	4A	4B	4C	5A	5B	5C
GAS GRADE	UL	UL	PUL	UL	UL	PUL	UL	UL	PUL	UL	UL	PUL	UL	UL	PUL
NOZZLE TYPE	OPV HVF	EW 4001	RA 4001	EW 4001	EW 4001	EW 4001	4001	4001	RA 4001	RA 4001	A 4001	A 4001	4001	OPV HVF	OPV HVF

Hold open latch Y Y Y N Y Y Y Y Y Y Y Y Y Y Y Y

N O Z Z L E	1. CERT. NOZZLE															
	2. CHECK VALVE															
	3. FACE SEAL															
	4. RING, RIVET															
	5. BELLOWS															
	6. SWIVEL(S)															
	7. FLOW LIMITER (EW)															
V A P O R H O S E	1. HOSE CONDITION															
	2. LENGTH															
	3. CONFIGURATION															
	4. SWIVEL															
	5. OVERHEAD RETRACTOR															
	6. POWER/PILOT ON															
	7. SIGNS POSTED	M	M	M	OK	OK	OK	M	M	M	OK	OK	OK			

Key to system types: BA=Balance HE=Healey RJ=Red Jacket HI=Hirt GH=Gulf Hasselmann HA=Hasstech
 Key to deficiencies: NC= not certified, M= missing, AD= needs adjustment, S= short TO= torn, L= long, MA= misaligned, F= flat, LO= loose, K= kinked, B= broken, TN= tangled, FR= frayed.

OK OK OK OK OK OK

** INSPECTION RESULTS **	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7
--------------------------	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

Key to inspection results: Blank= OK, 7= Repair within seven days, T= Tagged (nozzle tagged out-of-order until repaired), U= Taggable violation but left in use.

COMMENTS: _____

VIOLATIONS: SYSTEMS MARKED WITH A "T OR U" CODE IN INSPECTION RESULTS, ARE IN VIOLATION OF KERN COUNTY AIR POLLUTION CONTROL DISTRICT RULE(S) 412 AND/OR 412.1. THE CALIFORNIA HEALTH & SAFETY CODE SPECIFIES PENALTIES OF UP TO \$1,000.00 PER DAY FOR EACH DAY OF VIOLATION. TELEPHONE (805) 861-3682 CONCERNING FINAL RESOLUTION OF THE VIOLATION.

NOTE: CALIFORNIA HEALTH & SAFETY CODE SECTION 41960.2, REQUIRES THAT THE ABOVE LISTED 7-DAY DEFICIENCIES BE CORRECTED WITHIN 7 DAYS. FAILURE TO COMPLY MAY RESULT IN LEGAL ACTION

KERN COUNTY AIR POLLUTION CONTROL DISTRICT

2700 "M" Street, Suite 275

Bakersfield, CA. 93301

(805) 861-3682

PHASE II VAPOR RECOVERY INSPECTION FORM

Station Location 2126 Taft Hwy P/O # 8670010-012
 Company Address _____ City _____ Zip _____
 Contact _____ Phone 2 System Type: BA RJ HI HE GH HA
 Inspector Laurel Frank Date _____ Notice Rec'd By [Signature]

NOZZLE #
GAS GRADE
NOZZLE TYPE

6A	6B	6C	7A	7B	7C	8A	8B	8C												
UL	UL	PUL	UL	UL	PUL	UL	UL	PUL												
RF																				

Hold Open Latch

Y Y Y Y Y Y Y Y Y

N O Z Z L E	1. CERT. NOZZLE																				
	2. CHECK VALVE																				
	3. FACE SEAL																				
	4. RING, RIVET																				
	5. BELLOWS																				
	6. SWIVEL(S)																				
	7. FLOW LIMITER (EW)																				
V A P O R H O S E	1. HOSE CONDITION																				
	2. LENGTH																				
	3. CONFIGURATION																				
	4. SWIVEL																				
	5. OVERHEAD RETRACTOR																				
	6. POWER/PILOT ON																				
7. SIGNS POSTED																					

Key to system types: BA=Balance HE=Healey RJ=Red Jacket HI=Hirt GH=Gulf Hasselmann HA=Hasstech
 Key to deficiencies: NC= not certified, M= missing, AD= needs adjustment, S= short TO= torn, MA= misaligned, F= flat, L= long, K= kinked, B= broken, TN= tangled, LO= loose, FR= frayed.

**** INSPECTION RESULTS ****

7	7	7				7	7	7											
---	---	---	--	--	--	---	---	---	--	--	--	--	--	--	--	--	--	--	--

Key to inspection results: Blank= OK, 7= Repair within seven days, T= Tagged (nozzle tagged out-of-order until repaired), U= Taggable violation but left in use.

COMMENTS: _____

VIOLATIONS: SYSTEMS MARKED WITH A "T OR U" CODE IN INSPECTION RESULTS, ARE IN VIOLATION OF KERN COUNTY AIR POLLUTION CONTROL DISTRICT RULE(S) 412 AND/OR 412.1. THE CALIFORNIA HEALTH & SAFETY CODE SPECIFIES PENALTIES OF UP TO \$1,000.00 PER DAY FOR EACH DAY OF VIOLATION. TELEPHONE (805) 861-3682 CONCERNING FINAL RESOLUTION OF THE VIOLATION.

NOTE: CALIFORNIA HEALTH & SAFETY CODE SECTION 41960.2, REQUIRES THAT THE ABOVE LISTED 7-DAY DEFICIENCIES BE CORRECTED WITHIN 7 DAYS. FAILURE TO COMPLY MAY RESULT IN LEGAL ACTION

RESPONSE CHECKLIST

Specialist reviewing the information returned: Laurel Funk

Date questionnaire was returned: 8-14-91

Facility Permit Number: 320028

Tanks located at the facility: 3

Was a reply received for each substance code assigned to the facility?

Yes No

Does the facility need to provide additional information in order for the monitoring alternative to be acceptable? Yes No

Describe what information is required:

The monitoring alternative picked by the facility representative is acceptable for the facility tanks. Yes No

(The monitoring alternative will be viewed as unacceptable if the alternative was not appropriate for the type of tank described on the facility profile or within the facility file. Example: The facility may wish to use the visual alternative for a tank that is not vaulted, or the tank size is not appropriate for the type of inventory monitoring chosen.)


Additional Comments:

Information has been reviewed and placed within the database:

Date entered within the database: 8/20/91

Entered by (name): Jane Warren

ENCLOSURE CHECKLIST



Facility JOHNNY DUNK #143

Permit # 320028 C

This checklist is provided to ensure that all necessary packet enclosures were received. Please complete this form and return it to the Kern County Environmental Health Services Department, along with the Monitoring Alternatives Questionnaire, within 30 days of receipt.

CHECK

- | <u>YES</u> | <u>NO</u> | The packet I received contained: |
|-------------------------------------|--------------------------|---|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | 1. Cover letter. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | 2. Facility Profile Sheet (provides Facility Permit Number and information on the underground storage tanks and piping, as provided on the application). <u>The substance code in Column #2 should be referenced when reviewing the Monitoring Alternatives Fact Sheets and Questionnaires.</u> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | 3. A Monitoring Alternatives and Upgrade Requirements Fact Sheet for each substance code referenced on the Facility Profile Sheet. |
| <input type="checkbox"/> | <input type="checkbox"/> | 4. A Monitoring Alternatives Questionnaire for each substance code referenced on the Facility Profile Fact Sheet. |

Signature of Person Completing the Checklist Steve Carter

Title Reg

Date 8-14-91

**MONITORING ALTERNATIVES
QUESTIONNAIRE
FOR
MVF 6 FACILITY TANKS**

Facility Name: JOHNNY GULIK 143
Facility Address: 2126 TAFT HIGHWAY
Owner's Name: WESTERN CONVENIENCE STORES
Owner's Address: PO BOX 25249 FRESNO CA 93729
Operator's Name: BALBIR SHERGILL
Permit Number (obtained from the facility profile sheet): 320028C
Number of Tanks which have been assigned the MVF6 Code: 3

All information has been received and reviewed and the following summarizes the monitoring alternative which I have picked for the MVF 6 tanks at this facility. I realize that the monitoring alternative must be approved by the local agency before implementation. (Place an X next to the alternative picked).

1. **VISUAL MONITORING** will be utilized. (I can inspect the exterior of all tanks, without using extraordinary personnel protective equipment).
2. **CONTINUOUS MONITORING WITHIN THE INTERSTITIAL SPACE** of each tank. It will be connected to an audible and visual alarm system.
3. **CONTINUOUS MONITORING WITHIN THE INTERSTITIAL SPACE**. The facility has already installed a continuous monitoring device within the annular space, of each tank, which are connected to an audible and visual alarm.

Provide information on the continuous monitoring device:

System Manufacturer: _____

System Model No.: _____

Date Installed: _____

Name of person completing this form: Steve Carter

Title: Bhr Date: 8-14-91

CR 3201

Secondary Containment Testing Report Form

This form is intended for use by contractors performing periodic testing of UST secondary containment systems. Use the appropriate pages of this form to report results for all components tested. The completed form, written test procedures, and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name:	Shell	Date of Testing:	6/7/2013
Facility Address:	2126 Taft Highway, Bakersfield, CA		
Facility Contact:	Jerry Hale	Phone:	661-864-1023
Date Local Agency Was Notified of Testing :	6/4/2013		
Name of Local Agency Inspector (if present during testing):	None		

2. TESTING CONTRACTOR INFORMATION

Company Name:	Confidence UST Services		
Technician Conducting Test:	Bryan A Self		
Credentials:	x CSLB Licensed Contractor	SWRCB Licensed Tank Tester	
License Type:	CSLB	License Number: 804904	
Manufacturer Training			
Manufacturer	Component(s)	Date Training Expires	
UST Installaton/Retrofit		11/22/2013	
UST Service technician	ICC	1/28/2015	
Star. Smith. Fibercast	Fiber Glass Systems	N.A.	

3. SUMMARY OF TEST RESULTS

Component	Pass	Fail	Not Tested	Repairs Made	Component	Pass	Fail	Not Tested	Repairs Made
87 Annular	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	UDC 7-8	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
91 Annular	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	87 Fill Spill Bucket	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Diesel Annular	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	87 Vapor Spill Bucket	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
87 Secondary Line	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	91 Fill Spill Bucket	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
91 Secondary Line	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	91 Vapor Spill Bucket	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Diesel Secondary Line	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Diesel Fill Spill Bucket	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
87 STP	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
91 STP	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Diesel STP	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
UDC 1-2	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
UDC 3-4	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
UDC 5-6	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

If hydrostatic testing was performed, describe what was done with the water after completion of tests:

Water was put back into test trailer and waste drum

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

To the best of my knowledge, the facts stated in this document are accurate and in full compliance with legal requirements

Technician's Signature:

Bryan A Self

Date: 6/7/2013

4. TANK ANNULAR TESTING

Test Method Developed By:	<input type="checkbox"/> Tank Manufacturer x Industry Standard		<input type="checkbox"/> Professional Engineer	
	<input type="checkbox"/> Other (Specify)			
Test Method Used:	<input type="checkbox"/> Pressure x Vacuum		<input type="checkbox"/> Hydrostatic	
	<input type="checkbox"/> Other (Specify)			
Test Equipment Used: Calibrated Gages			Equipment Resolution:0.0625"	
	Tank # 87	Tank # 91	Tank # Diesel	Tank #
Is Tank Exempt From Testing? ¹	<input type="checkbox"/> Yes X No	<input type="checkbox"/> Yes X No	<input type="checkbox"/> Yes X No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Tank Capacity:	10,000	10,000	10,000	
Tank Material:	Steel	Steel	Steel	
Tank Manufacturer:	Modern Welding	Modern Welding	Modern Welding	
Product Stored:	87	91	Diesel	
Wait time between applying pressure/vacuum/water and starting test:	5 min.	5 min.	5 min.	
Test Start Time:	9:00am	9:00am	9:00am	
Initial Reading (R _i):	-10 Hg	-10 Hg	-10 Hg	
Test End Time:	10:00am	10:00am	10:00am	
Final Reading (R _f):	-10 Hg	-10 Hg	-10 Hg	
Test Duration:	1 Hour	1 Hour	1 Hour	
Change in Reading (R _f -R _i):	0.00"	0.00"	0.00"	
Pass/Fail Threshold or Criteria:	0.00"	0.00"	0.00"	
Test Result:	X Pass <input type="checkbox"/> Fail	X Pass <input type="checkbox"/> Fail	X Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	X Yes <input type="checkbox"/> No <input type="checkbox"/> NA	X Yes <input type="checkbox"/> No <input type="checkbox"/> NA	X Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No X NA	<input type="checkbox"/> Yes <input type="checkbox"/> No X NA	<input type="checkbox"/> Yes <input type="checkbox"/> No X NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ Secondary containment systems where the continuous monitoring automatically monitors both the primary and secondary containment, such as systems that are hydrostatically monitored or under constant vacuum, are exempt from periodic containment testing. {California Code of Regulations, Title 23, Section 2637(a)(6)}

6. PIPING SUMP TESTING

Test Method Developed By:	<input type="checkbox"/> Sump Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
	<input type="checkbox"/> Other (Specify)		
Test Method Used:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic
	<input type="checkbox"/> Other (Specify)		
Test Equipment Used: Ts-sts	Equipment Resolution:		
	Sump # 87	Sump # 91	Sump # Diesel
	Sump #		
Sump Diameter:	37.00"	37.00"	37.00"
Sump Depth:	51.00"	55.00"	53.00"
Sump Material:	FRP	FRP	FRP
Height from Tank Top to Top of Highest Piping Penetration:	15.00"	10.00"	10.00"
Height from Tank Top to Lowest Electrical Penetration:	19.00"	17.00"	18.00"
Condition of sump prior to testing:	Clean & Dry	Clean & Dry	Clean & Dry
Portion of Sump Tested ¹	High Penetration	High Penetration	High Penetration
Does turbine shut down when sump sensor detects liquid (both product and water)?*	<input type="checkbox"/> Yes <input type="checkbox"/> No XNA	<input type="checkbox"/> Yes <input type="checkbox"/> No XNA	<input type="checkbox"/> Yes <input type="checkbox"/> No XNA
Turbine shutdown response time	N/A	N/A	N/A
Is system programmed for fail-safe shutdown?*	<input type="checkbox"/> Yes <input type="checkbox"/> No XNA	<input type="checkbox"/> Yes <input type="checkbox"/> No XNA	<input type="checkbox"/> Yes <input type="checkbox"/> No XNA
Was fail-safe verified to be operational?*	<input type="checkbox"/> Yes <input type="checkbox"/> No XNA	<input type="checkbox"/> Yes <input type="checkbox"/> No XNA	<input type="checkbox"/> Yes <input type="checkbox"/> No XNA
Wait time between applying pressure/vacuum/water and starting test:	5 Min	5 Min	5 Min
Test Start Time:			
Initial Reading (R _i):			
Test End Time:			
Final Reading (R _f):			
Test Duration:			
Change in Reading (R _f -R _i):			
Pass/Fail Threshold or Criteria:			
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail
	<input type="checkbox"/> Pass <input type="checkbox"/> Fail		
Was sensor removed for testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No XNA	<input type="checkbox"/> Yes <input type="checkbox"/> No XNA	<input type="checkbox"/> Yes <input type="checkbox"/> No XNA
Was sensor properly replaced and verified functional after testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No XNA	<input type="checkbox"/> Yes <input type="checkbox"/> No XNA	<input type="checkbox"/> Yes <input type="checkbox"/> No XNA

See INCON Results

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ If the entire depth of the sump is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire sump must be tested. (See SWRCB LG-160)

7. UNDER-DISPENSER CONTAINMENT (UDC) TESTING

Test Method Developed By:	<input type="checkbox"/> UDC Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer	
	<input type="checkbox"/> Other (Specify)			
Test Method Used:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic	
	<input type="checkbox"/> Other (Specify)			
Test Equipment Used: Ts-sts	Equipment Resolution:			
	UDC # 1-2	UDC # 3-4	UDC # 5-6	UDC # 7-8
UDC Manufacturer:	Western	Western	Western	Western
UDC Material:	FRP	FRP	FRP	FRP
UDC Depth:	27.00"	27.00"	27.00"	27.00"
Height from UDC Bottom to Top of Highest Piping Penetration:	10.00"	10.00"	10.00"	10.00"
Height from UDC Bottom to Lowest Electrical Penetration:	13.00"	13.00"	13.00"	13.00"
Condition of UDC prior to testing:	Clean & Dry	Clean & Dry	Clean & Dry	Clean & Dry
Portion of UDC Tested ¹	High Penetration	High Penetration	High Penetration	High Penetration
Does turbine shut down when UDC sensor detects liquid (both product and water)?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A
Turbine shutdown response time	N/A	N/A	N/A	N/A
Is system programmed for fail-safe shutdown?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A
Was fail-safe verified to be operational?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A
Wait time between applying pressure/vacuum/water and starting test	5 Min	5 Min	5 Min	5 Min
Test Start Time:				
Initial Reading (R _i):				
Test End Time:				
Final Reading (R _f):				
Test Duration:				
Change in Reading (R _f -R _i):				
Pass/Fail Threshold or Criteria:				
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Was sensor properly replaced and verified functional after testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A

See INCON Results

Comments -- (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ If the entire depth of the UDC is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire UDC must be tested. (See SWRCB LG-160)

8. FILL RISER CONTAINMENT SUMP TESTING

Facility is Not Equipped With Fill Riser Containment Sumps <input checked="" type="checkbox"/>				
Fill Riser Containment Sumps are Present, but were Not Tested <input type="checkbox"/>				
Test Method Developed By: <input type="checkbox"/> Sump Manufacturer <input type="checkbox"/> Industry Standard <input type="checkbox"/> Professional Engineer <input type="checkbox"/> Other (Specify)				
Test Method Used: <input type="checkbox"/> Pressure <input type="checkbox"/> Vacuum <input type="checkbox"/> Hydrostatic <input type="checkbox"/> Other (Specify)				
Test Equipment Used:			Equipment Resolution:	
	Fill Sump #	Fill Sump #	Fill Sump #	Fill Sump #
Sump Diameter:				
Sump Depth:				
Height from Tank Top to Top of Highest Piping Penetration:				
Height from Tank Top to Lowest Electrical Penetration:				
Condition of sump prior to testing:				
Portion of Sump Tested				
Sump Material:				
Wait time between applying pressure/vacuum/water and starting test:				
Test Start Time:				
Initial Reading (R _i):				
Test End Time:				
Final Reading (R _f):				
Test Duration:				
Change in Reading (R _f -R _i):				
Pass/Fail Threshold or Criteria:				
Test Result:	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Is there a sensor in the sump?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Does the sensor alarm when either product or water is detected?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor removed for testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

SHELL
2126 TAFT HWY
BAKERSFIELD CA
661-846-1023
WO-30969

06/07/2013 8:49 AM

SUMP LEVEL REPORT

SUMP DSL-STP 4.764 IN
SUMP 91-STP 3.096 IN
SUMP 87-STP 2.801 IN

SHELL
2126 TAFT HWY
BAKERSFIELD CA
661-846-1023
WO-30969

06/07/2013 9:04 AM

SUMP LEAK TEST REPORT

DSL-STP

TEST STARTED 8:49 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 4.7640 IN
END TIME 9:04 AM
END DATE 06/07/2013
END LEVEL 4.7617 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

91-STP

TEST STARTED 8:49 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 3.0964 IN
END TIME 9:04 AM
END DATE 06/07/2013
END LEVEL 3.0962 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

87-STP

TEST STARTED 8:49 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 2.8014 IN
END TIME 9:04 AM
END DATE 06/07/2013
END LEVEL 2.8013 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

SHELL
2126 TAFT HWY
BAKERSFIELD CA
661-846-1023
WO-30969

06/07/2013 9:21 AM

SUMP LEAK TEST REPORT

DSL-STP

TEST STARTED 9:06 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 4.7616 IN
END TIME 9:21 AM
END DATE 06/07/2013
END LEVEL 4.7603 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

91-STP

TEST STARTED 9:06 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 3.0962 IN
END TIME 9:21 AM
END DATE 06/07/2013
END LEVEL 3.0958 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

87-STP

TEST STARTED 9:06 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 2.8014 IN
END TIME 9:21 AM
END DATE 06/07/2013
END LEVEL 2.8022 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

SHELL
2126 TAFT HWY
BAKERSFIELD CA
661-846-1023
WO-30969

06/07/2013 9:45 AM

SUMP LEAK TEST REPORT

DSL-STP

TEST STARTED 9:30 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 4.7606 IN
END TIME 9:45 AM
END DATE 06/07/2013
END LEVEL 4.7585 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

91-STP

TEST STARTED 9:30 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 3.0961 IN
END TIME 9:45 AM
END DATE 06/07/2013
END LEVEL 3.0955 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

87-STP

TEST STARTED 9:30 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 2.8054 IN
END TIME 9:45 AM
END DATE 06/07/2013
END LEVEL 2.7631 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

SHELL
2126 TAFT HWY
BAKERSFIELD CA
661-846-1023
WO-30969

06/07/2013 10:43 AM

SUMP LEAK TEST REPORT

UDC 1-2

TEST STARTED 10:27 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 3.4849 IN
END TIME 10:43 AM
END DATE 06/07/2013
END LEVEL 3.4845 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC 3-4

TEST STARTED 10:27 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 1.5781 IN
END TIME 10:43 AM
END DATE 06/07/2013
END LEVEL 1.5773 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC 5-6

TEST STARTED 10:27 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 1.9582 IN
END TIME 10:43 AM
END DATE 06/07/2013
END LEVEL 1.9591 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC 7-8

TEST STARTED 10:27 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 3.3804 IN
END TIME 10:43 AM
END DATE 06/07/2013
END LEVEL 3.3804 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

SHELL
2126 TAFT HWY
BAKERSFIELD CA
661-846-1023
WO-30969

06/07/2013 11:02 AM

SUMP LEAK TEST REPORT

UDC 1-2

TEST STARTED 10:47 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 3.4843 IN
END TIME 11:02 AM
END DATE 06/07/2013
END LEVEL 3.4842 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC 3-4

TEST STARTED 10:47 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 1.5774 IN
END TIME 11:02 AM
END DATE 06/07/2013
END LEVEL 1.5774 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC 5-6

TEST STARTED 10:47 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 1.9591 IN
END TIME 11:02 AM
END DATE 06/07/2013
END LEVEL 1.9593 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC 7-8

TEST STARTED 10:47 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 3.3807 IN
END TIME 11:02 AM
END DATE 06/07/2013
END LEVEL 3.3778 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

SHELL
2126 TAFT HWY
BAKERSFIELD CA
661-846-1023
WD-30969

06/07/2013 11:37 AM
SUMP LEAK TEST REPORT

UDC 1-2

TEST STARTED 11:21 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 3.4843 IN
END TIME 11:37 AM
END DATE 06/07/2013
END LEVEL 3.4842 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC 3-4

TEST STARTED 11:21 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 1.5770 IN
END TIME 11:37 AM
END DATE 06/07/2013
END LEVEL 1.5766 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC 5-6

TEST STARTED 11:21 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 1.9587 IN
END TIME 11:37 AM
END DATE 06/07/2013
END LEVEL 1.9591 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC 7-8

TEST STARTED 11:21 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 3.4254 IN
END TIME 11:37 AM
END DATE 06/07/2013
END LEVEL 3.4248 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

SHELL
2126 TAFT HWY
BAKERSFIELD CA
661-846-1023
WD-30969

06/07/2013 11:18 AM
SUMP LEAK TEST REPORT

UDC 1-2

TEST STARTED 11:03 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 3.4842 IN
END TIME 11:18 AM
END DATE 06/07/2013
END LEVEL 3.4845 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC 3-4

TEST STARTED 11:03 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 1.5774 IN
END TIME 11:18 AM
END DATE 06/07/2013
END LEVEL 1.5769 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC 5-6

TEST STARTED 11:03 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 1.9593 IN
END TIME 11:18 AM
END DATE 06/07/2013
END LEVEL 1.9592 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC 7-8

TEST STARTED 11:03 AM
TEST STARTED 06/07/2013
BEGIN LEVEL 3.3786 IN
END TIME 11:18 AM
END DATE 06/07/2013
END LEVEL 3.3710 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

MONITORING SYSTEM CERTIFICATION

49605
K

For Use By All Jurisdictions Within the State of California
Authority Cited: Chapter 6.7, Health and Safety Code; Chapter 16, Division 3, Title 23, California Code of Regulations

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

A. General Information

3201

Facility Name: JOHNNY QUICK Bldg. No.: _____
Site Address: 2126 TAFT HWY. City: BAKERSFIELD Zip: 93313
Facility Contact Person: MR. KOOL Contact Phone No.: (661) 834-9113
Make/Model of Monitoring System: TLS-350 Date of Testing/Servicing: 2/14/2013

B. Inventory of Equipment Tested/Certified

Check the appropriate boxes to indicate specific equipment inspected/serviced:

Tank ID: REGULAR 87 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: PREMIUM 91 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Tank ID: DIESEL <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input type="checkbox"/> Annular Space or Vault Sensor. Model: _____ <input type="checkbox"/> Piping Sump / Trench Sensor(s). Model: _____ <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Dispenser ID: 1/2 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 3/4 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: 5/6 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 7/8 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply):
 System set-up Alarm history report

Technician Name (print): STEVEN OBERT Signature: _____
Certification No.: A28531 / 8029980-UC License No.: C61/ D40 A HAZ 809850
Testing Company Name: RICH ENVIRONMENTAL Phone No.: (661) 392-8687
Testing Company Address: 5643 BROOKS CT. BAKERSFIELD, CA. 93308 Date of Testing/Servicing: 2/14/2013

49605
[Handwritten mark]

D. Results of Testing/Serviceing

Software Version Installed: 332.00

Complete the following checklist:

<input checked="checked" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the audible alarm operational?
<input checked="checked" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the visual alarm operational?
<input checked="checked" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors visually inspected, functionally tested, and confirmed operational?
<input checked="checked" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors installed at lowest point of secondary containment and positioned so that other equipment will not interfere with their proper operation?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="checked" type="checkbox"/> N/A	If alarms are relayed to a remote monitoring station, is all communications equipment (e.g., modem) operational?
<input checked="checked" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected? If yes: which sensors initiate positive shut-down? (Check all that apply) <input checked="checked" type="checkbox"/> Sump/Trench Sensors; <input type="checkbox"/> Dispenser Containment Sensors. Did you confirm positive shut-down due to leaks and sensor failure/disconnection? <input checked="checked" type="checkbox"/> Yes; <input type="checkbox"/> No.
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="checked" type="checkbox"/> N/A	For tank systems that utilize the monitoring system as the primary tank overfill warning device (i.e., no mechanical overfill prevention valve is installed), is the overfill warning alarm visible and audible at the tank fill point(s) and operating properly? If so, at what percent of tank capacity does the alarm trigger? %
<input type="checkbox"/> Yes*	<input checked="checked" type="checkbox"/> No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes, or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E, below.
<input type="checkbox"/> Yes*	<input checked="checked" type="checkbox"/> No	Was liquid found inside any secondary containment systems designed as dry systems? (Check all that apply) <input type="checkbox"/> Product; <input type="checkbox"/> Water. If yes, describe causes in Section E, below.
<input checked="checked" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was monitoring system set-up reviewed to ensure proper settings? Attach set up reports, if applicable
<input checked="checked" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is all monitoring equipment operational per manufacturer's specifications?

* In Section E below, describe how and when these deficiencies were or will be corrected.

E. Comments:

MC

F. In-Tank Gauging / SIR Equipment:

- Check this box if tank gauging is used only for inventory control.
- Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all tank gauging probes visually inspected for damage and residue buildup?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system product level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system water level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all probes reinstalled properly?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

G. Line Leak Detectors (LLD):


- Check this box if LLDs are not installed.

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For equipment start-up or annual equipment certification, was a leak simulated to verify LLD performance? (Check all that apply) Simulated leak rate: <input checked="" type="checkbox"/> 3 g.p.h.; <input type="checkbox"/> 0.1 g.p.h.; <input type="checkbox"/> 0.2 g.p.h.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all LLDs confirmed operational and accurate within regulatory requirements?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was the testing apparatus properly calibrated?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

H. Comments:

49605


I. Results of Vacuum/Pressure Monitoring Equipment Testing

This page should be used to document testing and servicing of vacuum and pressure interstitial sensors. A copy of this form must be included with the Monitoring System Certification Form, which must be provided to the tank system owner/operator. The owner/operator must submit a copy of the Monitoring System Certification Form to the local agency regulating UST systems within 30 days of test date.

Manufacturer: N/A	Model:	System Type: <input type="checkbox"/> Pressure; <input type="checkbox"/> Vacuum
Sensor ID		
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
How was interstitial communication verified?		
<input type="checkbox"/> Leak Introduced at Far End of Interstitial Space; ¹ <input type="checkbox"/> Gauge; <input type="checkbox"/> Visual Inspection; <input type="checkbox"/> Other (Describe in Sec. J, below)		
Was vacuum/pressure restored to operating levels in all interstitial spaces? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no, describe in Sec. J, below)		


J. Comments: N/A

¹ If the sensor successfully detects a simulated vacuum/pressure leak introduced in the interstitial space at the furthest point from the sensor, vacuum/pressure has been demonstrated to be communicating throughout the interstice.

M

UST Monitoring Site Plan

Site Address: 2126 TAFT HWY. BAKERSFIELD, CA.



Date map was drawn: 2/14/2013.

Instructions

If you already have a diagram that shows all required information, you may include it, rather than this page, with your Monitoring System Certification. On your site plan, show the general layout of tanks and piping. Clearly identify locations of the following equipment, if installed: monitoring system control panels; sensors monitoring tank annular spaces, sumps, dispenser pans, spill containers, or other secondary containment areas; mechanical or electronic line leak detectors; and in-tank liquid level probes (if used for leak detection). In the space provided, note the date this Site Plan was prepared.

49605
P

RICH ENVIRONMENTAL
5643 BROOKS CT. BAKERSFIELD, CA. 93308
OFFICE (661)392-8687 FAX (661)392-0621
PRODUCT LINE LEAK DETECTOR TEST

WORK SHEET

W/O#: _____

FACILITY NAME: JOHNNY QUICK

FACILITY ADDRESS: 2126 TAFT HWY. BAKERSFIELD

PRODUCT LINE TYPE: PRESSURE

PRODUCT	LEAK DETECTOR TYPE SERIAL NUMBER	TEST BELOW 3 G.P.H.	TRIP P.S.I.	PASS OR FAIL
REG87	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>2347</u>	YES	10	PASS
PREM91	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>1262</u>	YES	10	PASS
DIESEL	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>3246</u>	YES	10	PASS
	L/D TYPE : <u> </u> SERIAL # <u> </u>	YES NO		PASS FAIL

I CERTIFY THE ABOVE TESTS WERE CONDUCTED ON THIS DATE ACCORDING TO RED JACKET PUMPS FIELD TEST APPARATUS TESTING PROCEDURE AND LIMITATIONS. THE MECHANICAL LEAK DETECTOR TEST PASS / FAIL IS DETERMINED BY USING A LOW FLOW THRESHOLD TRIP RATE OF 3 GALLONS PER HOUR OR LESS AT 10 P.S.I. I ACKNOWLEDGE THAT ALL DATA COLLECTED IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE.

TECHNICIAN: STEVEN OBERT

SIGNATURE: 

DATE: 02/14/13

49605 *[Signature]*

SWRCB, January 2006

Spill Bucket Testing Report Form

This form is intended for use by contractors performing annual testing of UST spill containment structures. The completed form and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: JOHNNY QUICK	Date of Testing: 2/14/13
Facility Address: 2126 TAFT HWY. BAKERSFIELD	
Facility Contact: MR. KOOL	Phone: (661) 834-9113
Date Local Agency Was Notified of Testing: 1/11/13	
Name of Local Agency Inspector (if present during testing): JEFFREY MARSHAL	

2. TESTING CONTRACTOR INFORMATION

Company Name: RICH ENVIRONMENTAL	
Technician Conducting Test: STEVEN OBERT	
Credentials ¹ : <input type="checkbox"/> CSLB Contractor <input checked="" type="checkbox"/> ICC Service Tech. <input type="checkbox"/> SWRCB Tank Tester <input type="checkbox"/> Other (Specify) _____	
License Number(s): 8029980-UT	

3. SPILL BUCKET TESTING INFORMATION

Test Method Used: <input checked="" type="checkbox"/> Hydrostatic <input type="checkbox"/> Vacuum <input type="checkbox"/> Other				
Test Equipment Used: VISUAL	Equipment Resolution: 0.00			
Identify Spill Bucket (By Tank Number, Stored Product, etc.)	1 REG 87-FILL	2 PREM91-FILL	3 DIESEL	4
Bucket Installation Type:	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump
Bucket Diameter:	12"	12"	12"	
Bucket Depth:	12"	12"	12"	
Wait time between applying vacuum/water and start of test:	30 MIN	30 MIN	30 MIN	
Test Start Time (T _I):	0900	0900	0900	
Initial Reading (R _I):	10"	10"	10"	
Test End Time (T _F):	1000	1000	1000	
Final Reading (R _F):	10"	10"	10"	
Test Duration (T _F - T _I):	1-HOUR	1-HOUR	1-HOUR	
Change in Reading (R _F - R _I):	0	0	0	
Pass/Fail Threshold or Criteria:	+/- 0.00	+/- 0.00	+/- 0.00	
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

I hereby certify that all the information contained in this report is true, accurate, and in full compliance with legal requirements.

Technician's Signature: *[Signature]* Date: 02/14/13

¹ State laws and regulations do not currently require testing to be performed by a qualified contractor. However, local requirements may be more stringent.

----- SENSOR ALARM -----
L 1:87 ANNULAR
ANNULAR SPACE

----- SENSOR ALARM -----
L
OTHER SENSORS

----- SENS(L) LARM -----
L 6:DSL STP
STP SUMP
FUEL ALARM
JUN 19, 2012 7:53 AM

49605

----- SENSOR ALARM -----
L 1:87 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 14, 2013 9:18

***** END *****

***** END *****

***** END *****

----- SENSOR ALARM -----
L 2:91 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 14, 2013 9:18

ALARM HISTORY REPORT

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 2:91 ANNULAR
ANNULAR SPACE

----- SENSOR ALARM -----
L 8:
OTHER SENSORS

ARCHIVE UTILITY

SAVE SETUP DATA:
END TIME:
FEB 14, 2013 9:05:49 AM
BYTES : 12160

----- SENSOR ALARM -----
L 3:DSL ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 14, 2013 9:18

***** END *****

***** END *****

JOHNNY QUICK 143
2126 TAFT HWY
BAKERSFIELD CA 93311
661-834-9113

----- SENSOR ALARM -----
L 4:87 STP
STP SUMP
FUEL ALARM
FEB 14, 2013 9:14 AM

FEB 14, 2013 9:18

ALARM HISTORY REPORT

ARCHIVE UTILITY

----- SENSOR ALARM -----
L 3:DSL ANNULAR
ANNULAR SPACE

SAVE SETUP DATA:
START TIME:
FEB 14, 2013 9:04:14 AM

SYSTEM STATUS

L 1:FUEL ALARM
L 2:FUEL ALARM
L 3:FUEL ALARM

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 5:91 STP
STP SUMP
FUEL ALARM
JUN 19, 2012 8:05 AM

----- SENSOR ALARM -----
L 5:91 STP
STP SUMP
FUEL ALARM
FEB 14, 2013 9:15 AM

JOHNNY QUICK 143
2126 TAFT HWY
BAKERSFIELD CA 93311
661-834-9113

FEB 14, 2013 9:18

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 4:87 STP
STP SUMP

----- SENSOR ALARM -----
L 6:DSL STP
STP SUMP
FUEL ALARM
FEB 14, 2013 9:16 AM

SYSTEM STATUS

L 1:FUEL ALARM
L 2:FUEL ALARM

LEAK TEST METHOD

TEST ON DATE : ALL TANK
MAY 27, 2011
START TIME : DISABLED
TEST RATE : 0.20 GAL/HR
DURATION : 2 HOURS

TST EARLY STOP:DISABLED

LEAK TEST REPORT FORMAT
NORMAL

LIQUID SENSOR SETUP

L 1:87 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 2:91 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 3:DSL ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 4:87 STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 5:91 STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 6:DSL STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

:87
TYPE:
STANDARD
NORMALLY CLOSED
TANK #: 1

LIQUID SENSOR ALMS
L 1:FUEL ALARM
L 4:FUEL ALARM
L 1:SENSOR OUT ALARM
L 4:SENSOR OUT ALARM

ISD SITE ALARMS
ISD GROSS PRES FAIL
ISD DEGRD PRES FAIL
ISD VAPOR LEAK FAIL
ISD VP PRES FAIL
ISD VP STATUS FAIL

ISD HOSE ALARMS
ALL:FLOW COLLECT FAIL

R 2:91
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 2

LIQUID SENSOR ALMS
L 2:FUEL ALARM
L 5:FUEL ALARM
L 2:SENSOR OUT ALARM
L 5:SENSOR OUT ALARM

ISD SITE ALARMS
ISD GROSS PRES FAIL
ISD VAPOR LEAK FAIL
ISD VP PRES FAIL
ISD VP STATUS FAIL

ISD HOSE ALARMS
ALL:FLOW COLLECT FAIL

R 3:DSL
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 3

LIQUID SENSOR ALMS
L 3:FUEL ALARM
L 6:FUEL ALARM
L 3:SENSOR OUT ALARM
L 6:SENSOR OUT ALARM

SMARTSENSOR SETUP

s 1:CARBON CANISTOR
CATEGORY VAPOR VALVE

s 2:VAPOR PRESSURE
CATEGORY VAPOR PRESSURE

s 3:DISP 1-2 AFM
CATEGORY AIR FLOW METER

s 4:DISP 3-4 AFM
CATEGORY AIR FLOW METER

s 5:DISP 5-6 AFM
CATEGORY AIR FLOW METER

s 6:DISP 7-8 AFM
CATEGORY AIR FLOW METER

s 8:ATM
CATEGORY

EVR/ISD TUP

EVR TYPE: BALANCE

BALANCE NOZZLE TYPE
VST

VAPOR PROCESSOR TYPE
VEEDER-ROOT POLISHER

ANALYSIS TIMES
TIME: 10:00 AM
DELAY MINUTES: 1

ACCEPT HIGH ORVR:
DISABLED

ISD HOSE TABLE						
ID	FP	FL	HL	AA	RF	
01	01	01	02	01	02	
02	02	02	02	01	02	
03	03	03	02	02	02	
04	04	04	02	02	02	
05	05	05	02	03	02	
06	06	06	02	03	02	
07	07	07	02	04	02	
08	08	08	02	04	02	

ISD AIRFLOW METER MAP

ID	SERIAL	NUM	LABEL	
1	54188		DISP 1-	
2	54184		DISP 3-	
3	54186		DISP 5-	
4	54207		DISP 7-	

ISD FUEL GRADE HOSE M

FP	MHH				U	AA
	1	2	3	4		
01	201	101	901	3	U	1
02	202	102	902	3	U	1
03	203	103	903	3	U	2
04	204	104	904	3	U	2
05	305	105	205	U	U	3
06	306	106	206	U	U	3
07	307	107	207	U	U	4
08	308	108	208	U	U	4

LABEL TABLE

- 1: UNASSIGNED
- 2: BLEND3
- 3: REGULAR
- 4: MID GRADE
- 5: PREMIUM
- 6: GOLD
- 7: BRONZE
- 8: SILVER
- 9: BLEND2
- 10: BLEND4

SOFTWARE REVISION
VERSION 332.00
SOFTWARE# 346332-1
CREATED - 11.05.27

S-MODULE# 330160-0
SYSTEM FEATURES:
PERIODIC IN-TANK
ANNUAL IN-TANK T
ISD/APM

ALARM HISTORY REPO

---- IN-TANK ALARM

T 1:UNL87

OVERFILL ALARM
DEC 24, 2012 5:56
DEC 5, 2012 5:06
OCT 21, 2012 4:44

LOW PRODUCT ALARM
JUN 6, 2012 5:12
JUN 1, 2012 10:07
MAY 29, 2012 4:52

DELIVERY NEEDED

JUN 6, 2012 5:12
JUN 1, 2012 10:07
MAY 29, 2012 4:52

* * * * * END * *

ALARM HISTORY REPO

---- IN-TANK ALARM

T 2:PREM91

LOW PRODUCT ALARM
APR 29, 2012 2:42

DELIVERY NEEDED
APR 29, 2012 2:42

COMMUNICATIONS SETUP

IN-TANK SETUP

PORT SETTINGS:

COMM BOARD : 1 (EDIM)
 RS-232 SECURITY
 CODE : DISABLED

COMM BOARD : 2 (RS-232)
 BAUD RATE : 1200
 PARITY : ODD
 STOP BIT : 1 STOP
 DATA LENGTH: 7 DATA
 RS-232 SECURITY
 CODE : DISABLED

COMM BOARD : 3 (RS-232)
 BAUD RATE : 1200
 PARITY : ODD
 STOP BIT : 1 STOP
 DATA LENGTH: 7 DATA
 RS-232 SECURITY
 CODE : DISABLED

AUTO TRANSMIT SETTINGS:

AUTO LEAK ALARM LIMIT
 DISABLED

AUTO HIGH WATER LIMIT
 DISABLED

AUTO OVERFILL LIMIT
 DISABLED

AUTO LOW PRODUCT
 DISABLED

AUTO THEFT LIMIT
 DISABLED

AUTO DELIVERY START
 DISABLED

AUTO DELIVERY END
 DISABLED

AUTO EXTERNAL INPUT ON
 DISABLED

AUTO EXTERNAL INPUT OFF
 DISABLED

AUTO SENSOR FUEL ALARM
 DISABLED

AUTO SENSOR WATER ALARM
 DISABLED

AUTO SENSOR OUT ALARM
 DISABLED

RS-232 END OF MESSAGE
 DISABLED

T 1:UNL87
 PRODUCT CODE : 1
 THERMAL COEFF : .000700
 TANK DIAMETER : 96.00
 TANK PROFILE : 4 PTS
 FULL VOL : 10000
 72.0 INCH VOL : 8192
 48.0 INCH VOL : 5091
 24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
 HIGH WATER LIMIT: 3.0
 WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10000
 OVERFILL LIMIT : 90%
 HIGH PRODUCT : 95%
 DELIVERY LIMIT : 10%
 9500

LOW PRODUCT : 1000
 LEAK ALARM LIMIT: 99
 SUDDEN LOSS LIMIT: 99
 TANK TILT : 0.00
 PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
 T#: NONE
 LINE MANIFOLDED TANKS
 T#: NONE

LEAK MIN PERIODIC: 10%
 : 1000

LEAK MIN ANNUAL : 10%
 : 1000

PERIODIC TEST TYPE
 STANDARD

ANNUAL TEST FAIL
 ALARM DISABLED

PERIODIC TEST FAIL
 ALARM DISABLED

GROSS TEST FAIL
 ALARM DISABLED

ANN TEST AVERAGING: OFF
 PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
 PUMP THRESHOLD : 10.00%

T 2:PREM91
 PRODUCT COD : 2
 THERMAL COE : .000700
 TANK DIAMETER : 96.00
 TANK PROFILE : 4 PTS
 FULL VOL : 10000
 72.0 INCH VOL : 8192
 48.0 INCH VOL : 5091
 24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
 HIGH WATER LIMIT: 3.0
 WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10000
 OVERFILL LIMIT : 90%
 9000
 HIGH PRODUCT : 95%
 DELIVERY LIMIT : 10%
 1000

LOW PRODUCT : 1000
 LEAK ALARM LIMIT: 99
 SUDDEN LOSS LIMIT: 99
 TANK TILT : 0.00
 PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
 T#: NONE
 LINE MANIFOLDED TANKS
 T#: NONE

LEAK MIN PERIODIC: 10%
 : 1000

LEAK MIN ANNUAL : 10%
 : 1000

PERIODIC TEST TYPE
 STANDARD

ANNUAL TEST FAIL
 ALARM DISABLED

PERIODIC TEST FAIL
 ALARM DISABLED

GROSS TEST FAIL
 ALARM DISABLED

ANN TEST AVERAGING: OFF
 PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
 PUMP THRESHOLD : 10.00%

49605

T 3:DIESEL
 PRODUCT CODE
 THERMAL COEFF
 TANK DIAMETER
 TANK PROFILE
 FULL VOL
 72.0 INCH VOL
 48.0 INCH VOL
 24.0 INCH VOL

FLOAT SIZE: 4

WATER WARNING :
 HIGH WATER LIMIT:
 WATER ALARM FILTER:

MAX OR LABEL VOL:
 OVERFILL LIMIT :
 HIGH PRODUCT :
 DELIVERY LIMIT :
 1000

LOW PRODUCT :
 LEAK ALARM LIMIT:
 SUDDEN LOSS LIMIT:
 TANK TILT :
 PROBE OFFSET :

SIPHON MANIFOLDED
 T#: NONE
 LINE MANIFOLDED T
 T#: NONE

LEAK MIN PERIODIC
 :
 LEAK MIN ANNUAL
 :
 PERIODIC TEST TY
 :
 ANNUAL TEST FAIL
 ALARM
 PERIODIC TEST FA
 ALARM
 GROSS TEST FAIL
 ALARM
 ANN TEST AVERAGI
 PER TEST AVERAGI
 TANK TEST NOTIFY
 TANK TEST NOTIFY
 DELIVERY DELAY
 PUMP THRESHOLD

----- SENSOR ALARM -----
L 4:87 STP
STP SUMP
SENSOR OUT ALARM
FEB 14, 2013 9:30 AM

FUEL ALARM
FEB 14, 2013 9:14 AM

L 1:87 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 14, 2013 9:30 AM

FUEL ALARM
FEB 14, 2013 9:18 AM

SYSTEM SECURITY
CODE : 00000

MAINTENANCE HISTORY
DISABLED

49605
SYSTEM SETUP

FEB 14, 2013 9:02

TANK CHART SECURITY
DISABLED

CUSTOM ALARMS
DISABLED

SYSTEM UNITS
U.S.
SYSTEM LANGUAGE
ENGLISH
SYSTEM DATE/TIME FC
MON DD YYYY HH:MM:SS

SERVICE NOTICE
DISABLED

JOHNNY QUICK 143
2126 TAFT HWY
BAKERSFIELD CA 9331
661-834-9113

ISO 3166 COUNTRY
CODE:

SHIFT TIME 1 : 8:0
SHIFT TIME 2 : DISA
SHIFT TIME 3 : DISA
SHIFT TIME 4 : DISA

VAPOR MONITORING TYPE
CARB ISD

TANK PER TST NEEDED
DISABLED
TANK ANN TST NEEDED
DISABLED

MASS/DENSITY
DISABLED

FISCAL HEIGHT SECURITY
DISABLED

LINE RE-ENABLE METH
PASS LINE TEST

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 5:91 STP
STP SUMP
SENSOR OUT ALARM
FEB 14, 2013 9:29 AM

FUEL ALARM
FEB 14, 2013 9:15 AM

FUEL ALARM
JUN 19, 2012 8:05 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 2:91 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 14, 2013 9:30 AM

FUEL ALARM
FEB 14, 2013 9:18 AM

LINE PER TST NEEDED
DISABLED
LINE ANN TST NEEDED
DISABLED

PRINT TC VOLUMES
ENABLED

TEMP COMPENSATION
VALUE (DEG F) : 6
STICK HEIGHT OFFSET
DISABLED
ULLAGE: 90%

H-PROTOCOL DATA FOR
HEIGHT
DAYLIGHT SAVING TIM
ENABLED
START DATE
MAR WEEK 2 SUN
START TIME
2:00 AM
END DATE
NOV WEEK 1 SUN
END TIME
2:00 AM

***** END *****

RE-DIRECT LOCAL PRI
DISABLED

EURO PROTOCOL PREFI
S

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 6:DSL STP
STP SUMP
SENSOR OUT ALARM
FEB 14, 2013 9:30 AM


FUEL ALARM
FEB 14, 2013 9:16 AM

FUEL ALARM
JUN 19, 2012 7:53 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 3:DSL ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 14, 2013 9:30 AM

FUEL ALARM
FEB 14, 2013 9:19 AM

49605 

MONITOR CERT. FAILURE REPORT

SITE NAME: JOHNNY QUICK **DATE:** 2/14/13

ADDRESS: 2126 TAFT HWY. **TECHNICIAN:** STEVEN OBERT

CITY: BAKERSFIELD **SIGNATURE:** 

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS: NONE

LABOR: NONE

PARTS INSTALLED: NONE

NAME: _____ **TITLE:** _____

SIGNATURE: _____

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENENCE.

48744
3201

RICH ENVIRONMENTAL

5643 BROOKS CT. - BAKERSFIELD, CA 93308
OFF.(661)392-8687 FAX(661)588-7808

ACURITE TM PIPELINE TESTER
PRECISION PRODUCT LINE TEST
TEST RESULTS

DATE: 12/04/12

BILLING: JOHNNY QUICK
2126 TAFT HWY
BAKERSFIELD, CA

SITE: JOHNNY QUICK
2126 TAFT HWY
BAKERSFIELD, CA

<u>PRODUCT PRODUCTS</u>	<u>PRODUCT LINE TEST</u>	<u>MECHANICAL LEAK DETECTORS</u>
UNL-87	-.005-PASS	N/A
PREM-91	-.000-PASS	N/A
DIESEL	-.000-PASS	N/A


COMMENTS

A PRECISION TEST WAS PERFORMED ON PRODUCT LINES AT THE ABOVE LOCATION USING THE ACURITE TM PIPELINE TESTER. I HAVE REVIEWED THE DATA PRODUCED IN CONJUNCTION WITH AES PROTOCOL, AND THEREFORE SATISFIES ALL REQUIREMENTS FOR SUCH TESTING AS SET FORTH BY NFPA-329-92 AND USE 40 CFR PART 280.

THE RESULTS OF TESTING ARE SHOWN ON THE FOLLOWING PAGE. INCLUDED WITH THE REPORT ARE REPRODUCTION OF DATA COMPLIED DURING THE TEST WHICH FORMED THE BASIS FOR THESE CONCLUSION. THIS INFORMATION IS STORED IN A PERMANENT FILE IF FUTURE VERIFICATION OF TEST RESULTS IS NEEDED.

I DECLARE UNDER PENALTY OF PERJURY THAT I AM A LICENSED TANK TESTER IN THE STATE OF CALIFORNIA AND THAT THE INFORMATION CONTAINED IN THIS REPORT IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE.

TEST CERTIFIED BY:


JAMES J. RICH
MFG# LTN-2245
CERT# 90-1072

48144

RICH ENVIRONMENTAL
 5643 BROOKS CT. BAKERSFIELD, CA, 93308
 OFFICE (661)392-8687 FAX (661)392-0621
ACURITE.™ PIPELINE TESTER

TEST RESULTS WORK SHEET

DATE: 12, 4, 12 W/O #: _____

FACILITY NAME: JOHNNY QUICK

FACILITY ADDRESS: 2126 TAFT HWY
BAKERSFIELD, CA

PRODUCT LINE TYPE: FIBERGLASS STEEL PLASTIC (CIRCLE ONE)

SYSTEM TYPE: PRESSURE SUCTION GRAVITY (CIRCLE ONE)

TURBINE MANUFACTURER:

PRODUCT GRADE	START TIME INITIAL READING 00:00/GPH	END TIME FINAL READING 00:00/GPH	TEST PRESSURE (P.S.I.)	VOLUME RATE (G.P.H.)	RESULTS PASS OR FAIL
UNL-87	10:10 AM .085	10:40 AM .080	50	7.005	PASS
PREM-91	11:00 AM .055	11:30 AM .055	50	7.000	PASS
DIESEL	9:30 AM .035	10:00 AM .035	50	7.000	PASS

I CERTIFY THAT THE ABOVE LINE TESTS WERE CONDUCTED ACCORDING TO THE EQUIPMENT MANUFACTURERS PROCEDURES. THE TEST RESULTS AS LISTED IS TRUE AND ACCURATE TO THE BEST OF MY KNOWLEDGE.

THE TEST PASS/FAIL STATUS IS DETERMINED USING A THRESHOLD OF 190 ML PER HOUR, (0.05 G.P.H.), RATE AT 1 1/2 TIMES OPERATING PRESSURE, OR 50 P.S.I. WHICH EVER IS GREATER.

TECHNICIAN: JAMES J RICH STATE LICENSE #: 90-1072

SIGNATURE: [Signature] MFG. CERTIFICATION #: 2245

SWRCB, January 2002

Secondary Containment Testing Report Form *JM*

This form is intended for use by contractors performing periodic testing of UST secondary containment systems. Use the appropriate pages of this form to report results for all components tested. The completed form, written test procedures, and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: JOHNNY QUICK	Date of Testing: 6/19/12
Facility Address: 2126 TAFT HWY, BAKERSFIELD	
Facility Contact: MR. KOOL	Phone: _____
Date Local Agency Was Notified of Testing: 5/1/12	
Name of Local Agency Inspector (if present during testing): _____	

2. TESTING CONTRACTOR INFORMATION

Company Name: Rich Environmental		
Technician Conducting Test: RICH PHILLIPS		
Credentials: <input checked="" type="checkbox"/> CSLB Licensed Contractor		<input type="checkbox"/> SWRCB Licensed Tank Tester
License Type: C61/D40 A HAZ	License Number: 809850	
Manufacturer Training		
Manufacturer	Component(s)	Date Training Expires
INCON	TS-ST5	6/11/2014

3. SUMMARY OF TEST RESULTS

Component	Pass	Fail	Not Tested	Repairs Made	Component	Pass	Fail	Not Tested	Repairs Made
87 ANNULAR	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	UDC #7/8	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
91 ANNULAR	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	87 VAPOR BUCKET	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DIESEL ANNULAR	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	91 VAPOR BUCKET	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
87 SECONDARY PIPE	<input type="checkbox"/>	X	<input type="checkbox"/>	<input type="checkbox"/>	DIESEL EXTRA BUCKET	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
91 SECONDARY PIPE	<input type="checkbox"/>	X	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DIESEL SEC PIPE	<input type="checkbox"/>	X	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
87 STP	<input type="checkbox"/>	X	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
91 STP	<input type="checkbox"/>	X	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DIESEL STP	<input type="checkbox"/>	X	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
UDC #1/2	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
UDC #3/4	<input type="checkbox"/>	X	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
UDC #5/6	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

If hydrostatic testing was performed, describe what was done with the water after completion of tests: _____

AUG 20 2012

KERN COUNTY
HEALTH SERVICES

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

To the best of my knowledge, the facts stated in this document are accurate and in full compliance with legal requirements

Technician's Signature: _____ Date: **6/19/12**

ENTERED

8/9/25/2012

4. TANK ANNULAR TESTING

Test Method Developed By:		<input type="checkbox"/> Tank Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
		<input type="checkbox"/> Other (Specify)		
Test Method Used:		<input type="checkbox"/> Pressure	<input checked="" type="checkbox"/> Vacuum	<input type="checkbox"/> Hydrostatic
		<input type="checkbox"/> Other (Specify)		
Test Equipment Used: 4" DIAL GAUGE			Equipment Resolution:	
	Tank #87	Tank #91	Tank #DSL	Tank #
Is Tank Exempt From Testing? ¹	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Tank Capacity:	10K	10K	10K	
Tank Material:	STEEL	STEEL	STEEL	
Tank Manufacturer:	UNKNOWN	UNKNOWN	UNKNOWN	
Product Stored:	UNL87	UNL91	DIESEL	
Wait time between applying pressure/vacuum/water and starting test:	30MIN	30MIN	30MIN	
Test Start Time:	8:30	8:30	10:00	
Initial Reading (R _i):	10.5	10.4	10.3	
Test End Time:	9:30	9:30	11:00	
Final Reading (R _f):	10.5	10.4	10.3	
Test Duration:	60 MIN	60 MIN	60 MIN	
Change in Reading (R _f -R _i):	0	0	0	
Pass/Fail Threshold or Criteria:	0	0	0	
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ Secondary containment systems where the continuous monitoring automatically monitors both the primary and secondary containment, such as systems that are hydrostatically monitored or under constant vacuum, are exempt from periodic containment testing. {California Code of Regulations, Title 23, Section 2637(a)(6)}

5. SECONDARY PIPE TESTING

Test Method Developed By: <input type="checkbox"/> Piping Manufacturer <input checked="" type="checkbox"/> Industry Standard <input type="checkbox"/> Professional Engineer <input type="checkbox"/> Other (Specify)				
Test Method Used: <input checked="" type="checkbox"/> Pressure <input type="checkbox"/> Vacuum <input type="checkbox"/> Hydrostatic <input type="checkbox"/> Other (Specify)				
Test Equipment Used: 4" DIAL GAUGE			Equipment Resolution: .5%	
	Piping Run # 87	Piping Run # 91	Piping Run # DSL	Piping Run #
Piping Material:	PLASTIC	PLASTIC	PLASTIC	
Piping Manufacturer:	UNKNOWN	UNKNOWN	UNKNOWN	
Piping Diameter:	3"	3"	3"	
Length of Piping Run:	50'	50'	50'	
Product Stored:	UNL87	UNL91	DIESEL	
Method and location of piping-run isolation:	TEST BOOT IN SUMP	TEST BOOT IN SUMP	TEST BOOT IN SUMP	
Wait time between applying pressure/vacuum/water and starting test:	30 MIN	30 MIN	30 MIN	
Test Start Time:	NO	VISUAL	LEAKS	
Initial Reading (R _I):				
Test End Time:				
Final Reading (R _F):				
Test Duration:	60 MIN	60 MIN	60 MIN	60 MIN
Change in Reading (R _F -R _I):				
Pass/Fail Threshold or Criteria:	0 PSI	0 PSI	0 PSI	0 PSI
Test Result:	<input type="checkbox"/> Pass <input checked="" type="checkbox"/> Fail	<input type="checkbox"/> Pass <input checked="" type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

PRESSURE DROPS OFF TO ZERO AS SOON AS YOU STOP FLOWING NITROGEN. UNABLE TO FIND LEAKS. PLASTIC SECONDARY BOOTS UNDERGROUND, THOUGHT TO BE THE PROBLEM ON ALL GRADES

Multiple empty horizontal lines for additional comments or notes.

6. PIPING SUMP TESTING

Test Method Developed By:	<input type="checkbox"/> Sump Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer					
	<input type="checkbox"/> Other (Specify)							
Test Method Used:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic					
	<input type="checkbox"/> Other (Specify)							
Test Equipment Used: INCON TS-STS		Equipment Resolution:						
	Sump #87	Sump #91	Sump #DSL	Sump #				
Sump Diameter:	40"	40"	40"					
Sump Depth:	43"	43"	43"					
Sump Material:	PLASTIC	PLASTIC	PLASTIC					
Height from Tank Top to Top of Highest Piping Penetration:	12"	12"	12"					
Height from Tank Top to Lowest Electrical Penetration:	30"	30"	30"					
Condition of sump prior to testing:	GOOD	GOOD	GOOD					
Portion of Sump Tested ¹	14"	14"	14"					
Does turbine shut down when sump sensor detects liquid (both product and water)?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA				
Turbine shutdown response time								
Is system programmed for fail-safe shutdown?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA				
Was fail-safe verified to be operational?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA				
Wait time between applying pressure/vacuum/water and starting test:	30 MIN	30 MIN	30 MIN					
Test Start Time:	8:46	9:10	9:37	10:00	9:37	10:00		
Initial Reading (R _i):	3.379	3.305	3.416	2.413	3.492	3.437		
Test End Time:	9:01	9:25	9:52	10:15	9:52	10:15		
Final Reading (R _f):	3.338	3.271	2.411	2.407	3.457	3.413		
Test Duration:	15MIN	15MIN	15MIN	15MIN	15MIN	15MIN		
Change in Reading (R _f -R _i):	.041	.037	-.002	.005	-.035	-.024		
Pass/Fail Threshold or Criteria:	.002	-.002	-.002	-.002	-.002	-.002		
Test Result:	<input type="checkbox"/> Pass <input checked="" type="checkbox"/> Fail		<input type="checkbox"/> Pass <input checked="" type="checkbox"/> Fail		<input type="checkbox"/> Pass <input checked="" type="checkbox"/> Fail		<input type="checkbox"/> Pass <input type="checkbox"/> Fail	
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ If the entire depth of the sump is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire sump must be tested. (See SWRCB LG-160)

7. UNDER-DISPENSER CONTAINMENT (UDC) TESTING

Test Method Developed By:		<input type="checkbox"/> UDC Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer				
		<input type="checkbox"/> Other (Specify)						
Test Method Used:		<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic				
		<input type="checkbox"/> Other (Specify)						
Test Equipment Used: INCON TS-ST5			Equipment Resolution:					
	UDC # 1/2	UDC #3/4	UDC #5/6	UDC #7/8				
UDC Manufacturer:	UNKNOWN	UNKNOWN	UNKNOWN	UNKNOWN				
UDC Material:	FIBERGLASS	FIBERGLASS	FIBERGLASS	FIBERGLASS				
UDC Depth:	26"	26"	26"	26"				
Height from UDC Bottom to Top of Highest Piping Penetration:	8"	8"	8"	8"				
Height from UDC Bottom to Lowest Electrical Penetration:	14"	14"	114"	14"				
Condition of UDC prior to testing:	GOOD	GOOD	GOOD	GOOD				
Portion of UDC Tested ¹	10"	10"	10"	10"				
Does turbine shut down when UDC sensor detects liquid (both product and water)?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA				
Turbine shutdown response time								
Is system programmed for fail-safe shutdown?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA				
Was fail-safe verified to be operational?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA				
Wait time between applying pressure/vacuum/water and starting test	30MIN	30MIN	30MIN	30MIN				
Test Start Time:	9:37	10:00	10:42	11:05	1:05	1:26	12:39	1:05
Initial Reading (R _i):	2.062	2.002	2.498	2.479	4.681	4.682	1.911	1.911
Test End Time:	9:52	10:15	10:57	11:20	1:20	1:40	12:54	1:20
Final Reading (R _f):	2.062	2.062	2.489	2.461	4.681	4.682	1.911	1.911
Test Duration:	15MIN	15MIN	15MIN	15MIN	15MIN	15MIN	15MIN	15MIN
Change in Reading (R _f -R _i):	-.000	-.000	-.009	-.018	-.000	-.000	-.000	-.000
Pass/Fail Threshold or Criteria:	-.002	-.002	-.002	-.002	-.002	-.002	-.002	-.002
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail		<input type="checkbox"/> Pass <input checked="" type="checkbox"/> Fail		<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail		<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ If the entire depth of the UDC is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire UDC must be tested. (See SWRCB LG-160)

8. FILL RISER CONTAINMENT SUMP TESTING

Facility is Not Equipped With Fill Riser Containment Sumps <input type="checkbox"/>				
Fill Riser Containment Sumps are Present, but were Not Tested <input type="checkbox"/>				
Test Method Developed By:		<input type="checkbox"/> Sump Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
		<input type="checkbox"/> Other (Specify)		
Test Method Used:		<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic
		<input type="checkbox"/> Other (Specify)		
Test Equipment Used: INCON TS-ST5			Equipment Resolution:	
	Fill Sump #	Fill Sump #	Fill Sump #	Fill Sump #
Sump Diameter:				
Sump Depth:				
Height from Tank Top to Top of Highest Piping Penetration:				
Height from Tank Top to Lowest Electrical Penetration:				
Condition of sump prior to testing:				
Portion of Sump Tested				
Sump Material:				
Wait time between applying pressure/vacuum/water and starting test:	30MIN	30MIN	30MIN	30MIN
Test Start Time:				
Initial Reading (R _i):				
Test End Time:				
Final Reading (R _f):				
Test Duration:	15MIN	15MIN	15MIN	15MIN
Change in Reading (R _f -R _i):				
Pass/Fail Threshold or Criteria:				
Test Result:	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Is there a sensor in the sump?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Does the sensor alarm when either product or water is detected?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor removed for testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

NO FILL SUMPS AT THIS SITE

9. SPILL/OVERFILL CONTAINMENT BOXES

Facility is Not Equipped With Spill/Overfill Containment Boxes <input type="checkbox"/>							
Spill/Overfill Containment Boxes are Present, but were Not Tested <input type="checkbox"/>							
Test Method Developed By:		<input type="checkbox"/> Spill Bucket Manufacturer		<input checked="" type="checkbox"/> Industry Standard		<input type="checkbox"/> Professional Engineer	
		<input type="checkbox"/> Other (<i>Specify</i>)					
Test Method Used:		<input type="checkbox"/> Pressure		<input type="checkbox"/> Vacuum		<input checked="" type="checkbox"/> Hydrostatic	
		<input type="checkbox"/> Other (<i>Specify</i>)					
Test Equipment Used: INCON TS-STS				Equipment Resolution:			
	Spill Box #87 VPR		Spill Box #91 VPR		Spill Box #EX BOX		Spill Box #
Bucket Diameter:	12"		12"		12"		
Bucket Depth:	16"		16"		16"		
Wait time between applying pressure/vacuum/water and starting test:	30MIN		30MIN		30MIN		
Test Start Time:	8:46	9:10	8:46	9:10	8:46	9:10	
Initial Reading (R _i):	2.071	2.071	2.414	2.664	2.414	2.412	
Test End Time:	9:01	9:25	9:01	9:25	9:01	9:25	
Final Reading (R _f):	2.071	2.071	2.413	2.664	2.413	2.412	
Test Duration:	15MIN	15MIN	15MIN	15MIN	15MIN	15MIN	
Change in Reading (R _f -R _i):	-0.000	-0.000	-0.001	-0.000	-0.001	-0.000	
Pass/Fail Threshold or Criteria:	-0.002	-0.002	-0.002	-0.002	-0.002	-0.002	
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail		<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail		<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail		<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

OPW BUCKETS

TEST STARTED 06/19/2012 10:42 AM
TEST STARTED 06/19/2012 2:49:27 IN
END TIME 10:57 AM
END DATE 06/19/2012
LEAK LEVEL 0.002 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT -FAILED

JOHNNY QUICK
2126 TART HWY
BAKERSFIELD CA
06/19/2012
10:57 AM
SUMP LEAK TEST REPORT

TEST STARTED 06/19/2012 11:05 AM
TEST STARTED 06/19/2012 2:47:56 IN
END TIME 11:20 AM
END DATE 06/19/2012
LEAK LEVEL 2.4619 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

06/19/2012 11:20 AM
SUMP LEAK TEST REPORT
UDCS-7

JOHNNY QUICK
2126 TART HWY
BAKERSFIELD CA

TEST STARTED 06/19/2012 1:25 PM
TEST STARTED 06/19/2012 9:68:20 IN
END TIME 1:40 PM
END DATE 06/19/2012
LEAK LEVEL 0.6821 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDCS-6

TEST STARTED 06/19/2012 1:05 PM
TEST STARTED 06/19/2012 4:68:19 IN
END TIME 1:20 PM
END DATE 06/19/2012
LEAK LEVEL 4.6820 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDCS-6

TEST STARTED 06/19/2012 1:05 PM
TEST STARTED 06/19/2012 1:91:17 IN
END TIME 1:20 PM
END DATE 06/19/2012
LEAK LEVEL 1.9118 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDCS-8

TEST STARTED 06/19/2012 10:00 AM
TEST STARTED 06/19/2012 3:20:58 IN
END TIME 10:15 AM
END DATE 06/19/2012
LEAK LEVEL 3.1838 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT -FAILED

09LSTP

TEST STARTED 06/19/2012 10:00 AM
TEST STARTED 06/19/2012 3:43:29 IN
END TIME 10:15 AM
END DATE 06/19/2012
LEAK LEVEL 3.4130 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT -FAILED

09LSTP

TEST STARTED 06/19/2012 10:00 AM
TEST STARTED 06/19/2012 2:41:30 IN
END TIME 10:15 AM
END DATE 06/19/2012
LEAK LEVEL 2.4089 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT -FAILED

91 STP

TEST STARTED 06/19/2012 10:00 AM
TEST STARTED 06/19/2012 2:06:29 IN
END TIME 10:15 AM
END DATE 06/19/2012
LEAK LEVEL 2.0629 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDCS-2

06/19/2012 10:15 AM
SUMP LEAK TEST REPORT
JOHNNY QUICK
2126 TART HWY
BAKERSFIELD CA

TEST STARTED 06/19/2012 12:39 PM
TEST STARTED 06/19/2012 1:61:40 IN
END TIME 12:54 PM
END DATE 06/19/2012
LEAK LEVEL 1.6055 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

UDCS-6

TEST STARTED 06/19/2012 12:39 PM
TEST STARTED 06/19/2012 1:91:12 IN
END TIME 12:54 PM
END DATE 06/19/2012
LEAK LEVEL 1.9118 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDCS-8

46893

46893

JOHNNY QUICK
2126 TAFT HWY
BAKERSFIELD CA

JOHNNY QUICK
2126 TAFT HWY
BAKERSFIELD CA

JOHNNY QUICK
2126 TAFT HWY
BAKERSFIELD CA

06/19/2012 9:02 AM

06/19/2012 9:25 AM

06/19/2012 9:52 AM

SUMP LEAK TEST REPORT

SUMP LEAK TEST REPORT

SUMP LEAK TEST REPORT

87 UPR

87 UPR

UDC1-2

TEST STARTED 8:46 AM
TEST STARTED 06/19/2012
BEGIN LEVEL 2.0713 IN
END TIME 9:01 AM
END DATE 06/19/2012
END LEVEL 2.0716 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

TEST STARTED 9:10 AM
TEST STARTED 06/19/2012
BEGIN LEVEL 2.0717 IN
END TIME 9:25 AM
END DATE 06/19/2012
END LEVEL 2.0711 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

TEST STARTED 9:37 AM
TEST STARTED 06/19/2012
BEGIN LEVEL 2.0623 IN
END TIME 9:52 AM
END DATE 06/19/2012
END LEVEL 2.0629 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

91 UPR

91 UPR

91 STP

TEST STARTED 8:46 AM
TEST STARTED 06/19/2012
BEGIN LEVEL 2.6658 IN
END TIME 9:01 AM
END DATE 06/19/2012
END LEVEL 2.6651 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

TEST STARTED 9:10 AM
TEST STARTED 06/19/2012
BEGIN LEVEL 2.6646 IN
END TIME 9:25 AM
END DATE 06/19/2012
END LEVEL 2.6643 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

TEST STARTED 9:37 AM
TEST STARTED 06/19/2012
BEGIN LEVEL 2.4169 IN
END TIME 9:52 AM
END DATE 06/19/2012
END LEVEL 2.4143 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

EXBX

EXBX

DSLSTP

TEST STARTED 8:46 AM
TEST STARTED 06/19/2012
BEGIN LEVEL 2.4142 IN
END TIME 9:01 AM
END DATE 06/19/2012
END LEVEL 2.4136 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

TEST STARTED 9:10 AM
TEST STARTED 06/19/2012
BEGIN LEVEL 2.4129 IN
END TIME 9:25 AM
END DATE 06/19/2012
END LEVEL 2.4125 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

TEST STARTED 9:37 AM
TEST STARTED 06/19/2012
BEGIN LEVEL 3.4923 IN
END TIME 9:52 AM
END DATE 06/19/2012
END LEVEL 3.4578 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

87STP

87STP

87STP

TEST STARTED 8:46 AM
TEST STARTED 06/19/2012
BEGIN LEVEL 3.3796 IN
END TIME 9:01 AM
END DATE 06/19/2012
END LEVEL 3.3384 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

TEST STARTED 9:10 AM
TEST STARTED 06/19/2012
BEGIN LEVEL 3.3053 IN
END TIME 9:25 AM
END DATE 06/19/2012
END LEVEL 3.2711 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

TEST STARTED 9:37 AM
TEST STARTED 06/19/2012
BEGIN LEVEL 3.2440 IN
END TIME 9:52 AM
END DATE 06/19/2012
END LEVEL 3.2242 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

46893 *pc*

SB989 TESTING FAILURE REPORT

SITE NAME: JOHNNY OLICK DATE: 6-19-17

ADDRESS: 2126 TAFT HWY TECHNICIAN: RICH PHILLIPS

CITY: BAKERSFIELD CA SIGNATURE: *[Signature]*

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS:

All stops failed, Disp 3/4 failed

(3) Sec Piping failed, plastic sec. fiberglass primaries. Pressure Drops off to zero

LABOR: as soon as you stop flowing nitrogen unable to find leak. Plastic Sec. Boots underground throughout to be the problem with all grades

PARTS INSTALLED:

NAME: _____ TITLE: _____

SIGNATURE: _____

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENENCE.

MONITORING SYSTEM CERTIFICATION

For Use By All Jurisdictions Within the State of California

Authority Cited: Chapter 6.7, Health and Safety Code; Chapter 16, Division 3, Title 23, California Code of Regulations

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

A. General Information

Facility Name: JOHNNY QUICK Bldg. No.: _____
Site Address: 2126 TAFT HWY. City: BAKERSFIELD Zip: 93313
Facility Contact Person: MR. KOOL Contact Phone No.: (661) 834-9113
Make/Model of Monitoring System: TLS-350 Date of Testing/Service: 2/13/2012

B. Inventory of Equipment Tested/Certified

Check the appropriate boxes to indicate specific equipment inspected/serviced:

Tank ID: REGULAR 87 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: PREMIUM 91 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Tank ID: DIESEL <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: _____ <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input type="checkbox"/> Annular Space or Vault Sensor. Model: _____ <input type="checkbox"/> Piping Sump / Trench Sensor(s). Model: _____ <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Dispenser ID: 1/2 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 3/4 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: 5/6 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 7/8 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply): System set-up Alarm history report

Technician Name (print): RICH PHILLIPS Signature: _____
Certification No.: A29084 / 1035169-UT License No.: C61/ D40-A-HAZ, 809850
Testing Company Name: RICH ENVIRONMENTAL Phone No.: (661) 392-8687
Testing Company Address: 5643 BROOKS CT. BAKERSFIELD, CA. 93308 Date of Testing/Service: 2/13/2012

MAR - 9 2012

D. Results of Testing/Serviceing

Software Version Installed: 329.01 :

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the audible alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the visual alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors visually inspected, functionally tested, and confirmed operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors installed at lowest point of secondary containment and positioned so that other equipment will not interfere with their proper operation?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	If alarms are relayed to a remote monitoring station, is all communications equipment (e.g., modem) operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected? If yes: which sensors initiate positive shut-down? (Check all that apply) <input checked="" type="checkbox"/> Sump/Trench Sensors; <input type="checkbox"/> Dispenser Containment Sensors. Did you confirm positive shut-down due to leaks <u>and</u> sensor failure/disconnection? <input checked="" type="checkbox"/> Yes; <input type="checkbox"/> No.
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For tank systems that utilize the monitoring system as the primary tank overflow warning device (i.e., no mechanical overflow prevention valve is installed), is the overflow warning alarm visible and audible at the tank fill point(s) and operating properly? If so, at what percent of tank capacity does the alarm trigger? %
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes, or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E, below.
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was liquid found inside any secondary containment systems designed as dry systems? (Check all that apply) <input type="checkbox"/> Product; <input type="checkbox"/> Water. If yes, describe causes in Section E, below.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was monitoring system set-up reviewed to ensure proper settings? Attach set up reports, if applicable
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is all monitoring equipment operational per manufacturer's specifications?

* In Section E below, describe how and when these deficiencies were or will be corrected.

E. Comments:

F. In-Tank Gauging / SIR Equipment:

- Check this box if tank gauging is used only for inventory control.
- Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all tank gauging probes visually inspected for damage and residue buildup?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system product level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system water level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all probes reinstalled properly?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

G. Line Leak Detectors (LLD):

- Check this box if LLDs are not installed.

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For equipment start-up or annual equipment certification, was a leak simulated to verify LLD performance? <i>(Check all that apply)</i> Simulated leak rate: <input checked="" type="checkbox"/> 3 g.p.h.; <input type="checkbox"/> 0.1 g.p.h.; <input type="checkbox"/> 0.2 g.p.h.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all LLDs confirmed operational and accurate within regulatory requirements?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was the testing apparatus properly calibrated?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?


* In Section H, below, describe how and when these deficiencies were or will be corrected.

H. Comments:

If you already have a diagram that shows all required information, you may include it, rather than this page, with your Monitoring System Certification. On your site plan, show the general layout of tanks and piping. Clearly identify locations of the following equipment, if installed: monitoring system control panels; sensors monitoring tank annular spaces, sumps, dispenser pans, spill containers, or other secondary containment areas; mechanical or electronic line leak detectors; and in-tank liquid level probes (if used for leak detection). In the space provided, note the date this Site Plan was prepared.

Instructions

Date map was drawn: 2/23/10



Site Address: 2126 TAFT HWY, BAKERSFIELD, CA 93313
 UST Monitoring Site Plan

45398

V

RICH ENVIRONMENTAL
 5643 BROOKS CT. BAKERSFIELD, CA. 93308
 OFFICE (661)392-8687 FAX (661)392-0621
PRODUCT LINE LEAK DETECTOR TEST

WORK SHEET

W/O#: _____

FACILITY NAME: JOHNNY QUICK

FACILITY ADDRESS: 2126 TAFT HWY. BAKERSFIELD

PRODUCT LINE TYPE: PRESSURE

PRODUCT	LEAK DETECTOR TYPE SERIAL NUMBER	TEST BELOW 3 G.P.H.	TRIP P.S.I.	PASS OR FAIL
REG87	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>MECHANICAL</u>	YES	10	PASS
PREM91	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>MECHANICAL</u>	YES	10	PASS
DIESEL	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>MECHANICAL</u>	YES	10	PASS
	L/D TYPE : <u> </u> SERIAL # <u> </u>	YES NO		PASS FAIL

I CERTIFY THE ABOVE TESTS WERE CONDUCTED ON THIS DATE ACCORDING TO RED JACKET PUMPS FIELD TEST APPARATUS TESTING PROCEDURE AND LIMITATIONS. THE MECHANICAL LEAK DETECTOR TEST PASS / FAIL IS DETERMINED BY USING A LOW FLOW THRESHOLD TRIP RATE OF 3 GALLONS PER HOUR OR LESS AT 10 P.S.I. I ACKNOWLEDGE THAT ALL DATA COLLECTED IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE.

TECHNICIAN: RICH PHILLIPS

SIGNATURE: _____

DATE: 02/13/12

45348

Spill Bucket Testing Report Form

This form is intended for use by contractors performing annual testing of UST spill containment structures. The completed form and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: JOHNNY QUICK	Date of Testing: 2/13/12
Facility Address: 2126 TAFT HWY. BAKERSFIELD	
Facility Contact: MR. KOOL	Phone: (661) 834-9113
Date Local Agency Was Notified of Testing: 2/8/12	
Name of Local Agency Inspector (if present during testing):	

2. TESTING CONTRACTOR INFORMATION

Company Name: RICH ENVIRONMENTAL
Technician Conducting Test: RICH PHILLIPS
Credentials ¹ : <input type="checkbox"/> CSLB Contractor <input checked="" type="checkbox"/> ICC Service Tech. <input type="checkbox"/> SWRCB Tank Tester <input type="checkbox"/> Other (Specify)
License Number(s): 1035169-UT

3. SPILL BUCKET TESTING INFORMATION

Test Method Used:	<input checked="" type="checkbox"/> Hydrostatic	<input type="checkbox"/> Vacuum	<input type="checkbox"/> Other	
Test Equipment Used:	VISUAL		Equipment Resolution: 0.00	
Identify Spill Bucket (By Tank Number, Stored Product, etc.)	1 REG 87-FILL	2 PREM91-FILL	3 DIESEL	4
Bucket Installation Type:	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump
Bucket Diameter:	12"	12"	12"	
Bucket Depth:	12"	12"	12"	
Wait time between applying vacuum/water and start of test:	30 MIN	30 MIN	30 MIN	
Test Start Time (T _i):	0900	0900	0900	
Initial Reading (R _i):	10"	10"	10"	
Test End Time (T _f):	1000	1000	1000	
Final Reading (R _f):	10"	10"	10"	
Test Duration (T _f - T _i):	1-HOUR	1-HOUR	1-HOUR	
Change in Reading (R _f - R _i):	0	0	0	
Pass/Fail Threshold or Criteria:	+/- 0.00	+/- 0.00	+/- 0.00	
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

I hereby certify that all the information contained in this report is true, accurate, and in full compliance with legal requirements.

Technician's Signature: _____

Date: 02/13/12

¹ State laws and regulations do not currently require testing to be performed by a qualified contractor. However, local requirements may be more stringent.

45270 *f*

SOFTWARE REVISION LEVEL
VERSION 329.01
SOFTWARE# 346329-100-B
CREATED - 09.01.29.15.44
NO SOFTWARE MODULE
SYSTEM FEATURES:
PERIODIC IN-TANK TESTS
ANNUAL IN-TANK TESTS

RE-DIRECT LOCAL PRINTOUT
DISABLED
EURO PROTOCOL PREFIX
S
SYSTEM SECURITY
CODE : 000000
MAINTENANCE HISTORY
DISABLED
TANK CHART SECURITY
DISABLED
CUSTOM ALARMS
DISABLED

AUTO TRANSMIT SETTINGS:
AUTO LEAK ALARM LIMIT
DISABLED
AUTO HIGH WATER LIMIT
DISABLED
AUTO OVERFILL LIMIT
DISABLED
AUTO LOW PRODUCT
DISABLED
AUTO THEFT LIMIT
DISABLED
AUTO DELIVERY START
DISABLED
AUTO DELIVERY END
DISABLED
AUTO EXTERNAL INPUT ON
DISABLED
AUTO EXTERNAL INPUT OFF
DISABLED
AUTO SENSOR FUEL ALARM
DISABLED
AUTO SENSOR WATER ALARM
DISABLED
AUTO SENSOR OUT ALARM
DISABLED

SYSTEM SETUP

FEB 13, 2012 8:39 AM

SERVICE NOTICE
DISABLED
ISO 3166 COUNTRY
CODE:

SYSTEM UNITS
U.S.
SYSTEM LANGUAGE
ENGLISH
SYSTEM DATE/TIME FORMAT
MON DD YYYY HH:MM:SS XM

RS-232 END OF MESSAGE
DISABLED

JOHNNY QUIK 143
2126 TAFT HWY
BAKERSFIELD CA 93313
661-834-9113

SHIFT TIME 1 : 8:00 AM
SHIFT TIME 2 : DISABLED
SHIFT TIME 3 : DISABLED
SHIFT TIME 4 : DISABLED

COMMUNICATIONS SETUP

TANK PER TST NEEDED WRN
DISABLED
TANK ANN TST NEEDED WRN
DISABLED

PORT SETTINGS:
COMM BOARD : 1 (RS-232)
BAUD RATE : 9600
PARITY : ODD
STOP BIT : 1 STOP
DATA LENGTH: 7 DATA
RS-232 SECURITY
CODE : DISABLED
COMM BOARD : 3 (RS-232)
BAUD RATE : 1200
PARITY : ODD
STOP BIT : 1 STOP
DATA LENGTH: 7 DATA
RS-232 SECURITY
CODE : DISABLED

LINE RE-ENABLE METHOD
PASS LINE TEST

LINE PER TST NEEDED WRN
DISABLED
LINE ANN TST NEEDED WRN
DISABLED

PRINT TC VOLUMES
ENABLED

TEMP COMPENSATION
VALUE (DEG F) : 60.0
STICK HEIGHT OFFSET
DISABLED
ULLAGE: 90%

H-PROTOCOL DATA FORMAT
HEIGHT
DAYLIGHT SAVING TIME
ENABLED
START DATE
MAR WEEK 2 SUN
START TIME
2:00 AM
END DATE
NOV WEEK 1 SUN
END TIME
2:00 AM

IN-TANK SETUP

T 1:UNLB7
PRODUCT CODE : 1
THERMAL COEFF : .000700
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
HIGH PRODUCT : 9000
DELIVERY LIMIT : 95%
: 9500
LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
: 1000

LEAK MIN ANNUAL : 10%
: 1000

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

2:PREM91
PRODUCT CODE : 2
THERMAL COEFF : .000700
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
HIGH PRODUCT : 95%
DELIVERY LIMIT : 9500
: 10%
: 1000

LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
: 1000

LEAK MIN ANNUAL : 10%
: 1000

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

42298
T DIESEL
PRODUCT CODE : 3
THERMAL COEFF : .000450
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
HIGH PRODUCT : 95%
DELIVERY LIMIT : 9500
: 10%
: 1000

LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
: 1000

LEAK MIN ANNUAL : 10%
: 1000

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

LEAK TEST METHOD

TEST ON DATE : ALL TANK
JAN 29, 2009
START TIME : DISABLED
TEST RATE : 0.20 GAL/HR
DURATION : 2 HOURS

TST EARLY STOP:DISABLED

LEAK TEST REPORT FORMAT
NORMAL

LIQUID SENSOR SETUP

L 1:87 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 2:91 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 3:DIESEL ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 4:87 STP SUMP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 5:91 STP SUMP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 6:DIESEL STP SUMP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 6:DIESEL STP SUMP
STP SUMP
SENSOR OUT ALARM
FEB 13, 2012 9:12 AM

FUEL ALARM
FEB 13, 2012 9:05 AM

SENSOR OUT ALARM
FEB 24, 2011 10:34 AM

OUTPUT RELAY SETUP

R 1:87
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 1:FUEL ALARM
L 4:FUEL ALARM
L 1:SENSOR OUT ALARM
L 4:SENSOR OUT ALARM

R 2:91
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 2:FUEL ALARM
L 5:FUEL ALARM
L 2:SENSOR OUT ALARM
L 5:SENSOR OUT ALARM

R 3:DSL
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 3:FUEL ALARM
L 6:FUEL ALARM
L 3:SENSOR OUT ALARM
L 6:SENSOR OUT ALARM

SMARTSENSOR SETUP

s 1:CARBON CANISTOR
CATEGORY VAPOR VALVE

s 2:VAPOR PRESSURE
CATEGORY VAPOR PRESSURE

s 8:ATM
CATEGORY ATM P SENSOR

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 5:91 STP SUMP
STP SUMP
SENSOR OUT ALARM
FEB 13, 2012 9:12 AM

FUEL ALARM
FEB 13, 2012 9:04 AM

SENSOR OUT ALARM
FEB 24, 2011 10:34 AM

PMC SETUP

PMC VERSION: 01.02
VAPOR PROCESSOR TYPE
VEEDER-ROOT POLISHER

ANALYSIS TIMES
TIME: 10:00 AM
DELAY MINUTES: 1

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 1:87 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 13, 2012 9:12 AM

FUEL ALARM
FEB 13, 2012 9:03 AM

FUEL ALARM
FEB 24, 2011 10:34 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 2:91 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 13, 2012 9:12 AM

FUEL ALARM
FEB 13, 2012 9:02 AM

FUEL ALARM
FEB 24, 2011 10:34 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 3:DIESEL ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 13, 2012 9:12 AM

FUEL ALARM
FEB 13, 2012 9:02 AM

FUEL ALARM
FEB 24, 2011 10:34 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 4:87 STP SUMP
STP SUMP
SENSOR OUT ALARM
FEB 13, 2012 9:12 AM

FUEL ALARM
FEB 13, 2012 9:04 AM

SENSOR OUT ALARM
AUG 26, 2011 3:06 AM

[Handwritten mark]

MONITOR CERT. FAILURE REPORT

SITE NAME: JOHNNY QUICK **DATE:** 2/13/12

ADDRESS: 2126 TAFT HWY. **TECHNICIAN:** RICH PHILLIPS

CITY: BAKERSFIELD **SIGNATURE:** *[Signature]*

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS: NONE

LABOR: NONE

PARTS INSTALLED: NONE

NAME: _____ **TITLE:** _____

SIGNATURE: _____

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENENCE.

MONITORING SYSTEM CERTIFICATION

40232

For Use By All Jurisdictions Within the State of California

Authority Cited: Chapter 6.7, Health and Safety Code; Chapter 16, Division 3, Title 23, California Code of Regulations

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

A. General Information

Facility Name: JOHNNY QUICK Bldg. No.: _____
Site Address: 2126 TAFT HWY. City: BAKERSFIELD Zip: 93313
Facility Contact Person: MR. KOOL Contact Phone No.: (661) 834-9113
Make/Model of Monitoring System: TLS-350 Date of Testing/Service: 2/24/2011

CL-3201

B. Inventory of Equipment Tested/Certified

Check the appropriate boxes to indicate specific equipment inspected/serviced:

Tank ID: REGULAR 87 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: PREMIUM 91 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Tank ID: DIESEL <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input type="checkbox"/> Annular Space or Vault Sensor. Model: _____ <input type="checkbox"/> Piping Sump / Trench Sensor(s). Model: _____ <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Dispenser ID: 1/2 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 3/4 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: 5/6 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 7/8 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply): System set-up Alarm history report

Technician Name (print): RYAN MASON Signature: _____
Certification No.: A27367/ 8029371-UT License No.: CS1/D40 A HAZ 809850
Testing Company Name: RICH ENVIRONMENTAL Phone No.: (661) 392-8687
Testing Company Address: 5643 BROOKS CT. BAKERSFIELD, CA. 93308 Date of Testing/Service: 2/24/2011

402321

F. In-Tank Gauging / SIR Equipment:

- Check this box if tank gauging is used only for inventory control.
- Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all tank gauging probes visually inspected for damage and residue buildup?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system product level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system water level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all probes reinstalled properly?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

G. Line Leak Detectors (LLD):

- Check this box if LLDs are not installed.

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For equipment start-up or annual equipment certification, was a leak simulated to verify LLD performance? (Check all that apply) Simulated leak rate: <input checked="" type="checkbox"/> 3 g.p.h.; <input type="checkbox"/> 0.1 g.p.h.; <input type="checkbox"/> 0.2 g.p.h.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all LLDs confirmed operational and accurate within regulatory requirements?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was the testing apparatus properly calibrated?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?


* In Section H, below, describe how and when these deficiencies were or will be corrected.

H. Comments:

If you already have a diagram that shows all required information, you may include it rather than this page. With your Monitoring System Certification. On your site plan, show the general layout of tanks and piping. Clearly identify locations of the following equipment: if installed, monitoring system control panels, sensors monitoring tanks, transfer spaces, sumps, dispenser pans, spill containers, or other secondary containment areas; mechanical or electronic line leak detectors; and in-tank liquid level probes (if used for leak detection). In the space provided, note the date this Site Plan was prepared.

Instructions

Date map was drawn: 2/3/2008



Site Address: 2126 TAFT HWY, BAKERSFIELD, CA 93313

TST Monitoring Site Plan

Monitoring System Certification

4023

40232

RICH ENVIRONMENTAL
5643 BROOKS CT. BAKERSFIELD, CA. 93308
OFFICE (661)392-8687 FAX (661)392-0621
PRODUCT LINE LEAK DETECTOR TEST

WORK SHEET

W/O#: _____

FACILITY NAME: JOHNNY QUICK

FACILITY ADDRESS: 2126 TAFT HWY. BAKERSFIELD, CA. 93313


PRODUCT LINE TYPE: PRESSURE

PRODUCT	LEAK DETECTOR TYPE SERIAL NUMBER	TEST BELOW 3 G.P.H.	TRIP P.S.I.	PASS OR FAIL
REGULAR 87	L/D TYPE: <u>RED JACKET</u> SERIAL # <u>MECHANICAL</u>	YES	10 PSI	PASS
PREMIUM 91	L/D TYPE: <u>RED JACKET</u> SERIAL # <u>MECHANICAL</u>	YES	10 PSI	PASS
DIESEL	L/D TYPE: <u>RED JACKET</u> SERIAL # <u>MECHANICAL</u>	YES	10 PSI	PASS
	L/D TYPE: <u> </u> SERIAL # <u> </u>	YES NO		PASS FAIL

I CERTIFY THE ABOVE TESTS WERE CONDUCTED ON THIS DATE ACCORDING TO RED JACKET PUMPS FIELD TEST APPARATUS TESTING PROCEDURE AND LIMITATIONS. THE MECHANICAL LEAK DETECTOR TEST PASS / FAIL IS DETERMINED BY USING A LOW FLOW THRESHOLD TRIP RATE OF 3 GALLONS PER HOUR OR LESS AT 10 P.S.I. I ACKNOWLEDGE THAT ALL DATA COLLECTED IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE.

TECHNICIAN: RYAN MASON

SIGNATURE: _____



DATE: 02/24/11

Spill Bucket Testing Report Form

This form is intended for use by contractors performing annual testing of UST spill containment structures. The completed form and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: JOHNNY QUICK	Date of Testing: 02/24/11
Facility Address: 2126 TAFT HWY. BAKERSFIELD, CA. 93313	
Facility Contact: MR. KOOL	Phone: (661) 834-9113
Date Local Agency Was Notified of Testing:	
Name of Local Agency Inspector (if present during testing):	

2. TESTING CONTRACTOR INFORMATION

Company Name: RICH ENVIRONMENTAL
Technician Conducting Test: RYAN MASON
Credentials ¹ : <input type="checkbox"/> CSLB Contractor <input checked="" type="checkbox"/> ICC Service Tech. <input type="checkbox"/> SWRCB Tank Tester <input type="checkbox"/> Other (Specify) _____
License Number(s): 8029371-UT

3. SPILL BUCKET TESTING INFORMATION

Test Method Used: <input checked="" type="checkbox"/> Hydrostatic <input type="checkbox"/> Vacuum <input type="checkbox"/> Other				
Test Equipment Used: VISUAL Equipment Resolution: 0.00				
Identify Spill Bucket (By Tank Number, Stored Product, etc.)	1 REGULAR 87-FILL	2 PREMIUM 91-FILL	3 DIESEL	4
Bucket Installation Type:	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump
Bucket Diameter:	12"	12"	12"	
Bucket Depth:	12"	12"	12"	
Wait time between applying vacuum/water and start of test:	30 MIN	30 MIN	30 MIN	
Test Start Time (T _I):	0900	0900	0900	
Initial Reading (R _I):	10"	10"	10"	
Test End Time (T _F):	1000	1000	1000	
Final Reading (R _F):	10"	10"	10"	
Test Duration (T _F - T _I):	1-HOUR	1-HOUR	1-HOUR	
Change in Reading (R _F - R _I):	0	0	0	
Pass/Fail Threshold or Criteria:	+/- 0.00	+/- 0.00	+/- 0.00	

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

I hereby certify that all the information contained in this report is true, accurate, and in full compliance with legal requirements.

Technician's Signature: _____

Date: 02/24/11

¹ State laws and regulations do not currently require testing to be performed by a qualified contractor. However, local requirements may be more stringent.

SOFTWARE REVISION LEVEL
VERSION 329.01
SOFTWARE# 346329-100-B
CREATED - 09.01.29.15.44

NO SOFTWARE MODULE
SYSTEM FEATURES:
PERIODIC IN-TANK TESTS
ANNUAL IN-TANK TESTS

SYSTEM SETUP

FEB 24, 2011 10:35 AM

SYSTEM UNITS

U.S.
SYSTEM LANGUAGE
ENGLISH
SYSTEM DATE/TIME FORMAT
MON DD YYYY HH:MM:SS XM

JOHNNY QUIK 143
2126 TAFT HWY
BAKERSFIELD CA 93313
661-834-9113

SHIFT TIME 1 : 8:00 AM
SHIFT TIME 2 : DISABLED
SHIFT TIME 3 : DISABLED
SHIFT TIME 4 : DISABLED

TANK PER TST NEEDED WRN
DISABLED
TANK ANN TST NEEDED WRN
DISABLED

LINE RE-ENABLE METHOD
PASS LINE TEST

LINE PER TST NEEDED WRN
DISABLED
LINE ANN TST NEEDED WRN
DISABLED

PRINT TO VOLUMES
ENABLED

TEMP COMPENSATION
VALUE (DEG F) : 60.0
STICK HEIGHT OFFSET
DISABLED
ULLAGE : 90%

H-PROTOCOL DATA FORMAT
HEIGHT
DAYLIGHT SAVING TIME
ENABLED
START DATE
MAR WEEK 2 SUN
START TIME
2:00 AM
END DATE
NOV WEEK 1 SUN
END TIME
2:00 AM

RE-DIRECT LOCAL PRINTOUT
DISABLED

EURO PROTOCOL PREFIX
S

COMMUNICATIONS SETUP

PORT SETTINGS:

COMM BOARD : 1 (RS-232)
BAUD RATE : 9600
PARITY : ODD
STOP BIT : 1 STOP
DATA LENGTH: 7 DATA
RS-232 SECURITY
CODE : DISABLED

COMM BOARD : 3 (RS-232)
BAUD RATE : 1200
PARITY : ODD
STOP BIT : 1 STOP
DATA LENGTH: 7 DATA
RS-232 SECURITY
CODE : DISABLED

AUTO TRANSMIT SETTINGS:

AUTO LEAK ALARM LIMIT
DISABLED
AUTO HIGH WATER LIMIT
DISABLED
AUTO OVERFILL LIMIT
DISABLED
AUTO LOW PRODUCT
DISABLED
AUTO THEFT LIMIT
DISABLED
AUTO DELIVERY START
DISABLED
AUTO DELIVERY END
DISABLED
AUTO EXTERNAL INPUT ON
DISABLED
AUTO EXTERNAL INPUT OFF
DISABLED
AUTO SENSOR FUEL ALARM
DISABLED
AUTO SENSOR WATER ALARM
DISABLED
AUTO SENSOR OUT ALARM
DISABLED

RS-232 END OF MESSAGE
DISABLED

IN-TANK SETUP

T 1:UNL87
PRODUCT CODE : 1
THERMAL COEFF : 000700
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%

HIGH PRODUCT : 95%

DELIVERY LIMIT : 10%

LOW PRODUCT : 1000

LEAK ALARM LIMIT: 99

SUDDEN LOSS LIMIT: 99

TANK TILT : 0.00

PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
1000

LEAK MIN ANNUAL : 10%
1000

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

40232 /

T 2:PREM91
PRODUCT CODE : 2
THERMAL COEFF : .000700
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

T 3:DIESEL
PRODUCT CODE : 3
THERMAL COEFF : .000450
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

LEAK TEST METHOD
TEST ON DATE : ALL TANK
JAN 29, 2009
START TIME : DISABLED
TEST RATE : 0.20 GAL/HR
DURATION : 2 HOURS

FLOAT SIZE: 4.0 IN.
WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
HIGH PRODUCT : 95%
DELIVERY LIMIT : 10%
LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

FLOAT SIZE: 4.0 IN.
WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
HIGH PRODUCT : 95%
DELIVERY LIMIT : 10%
LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

TST EARLY STOP:DISABLED
LEAK TEST REPORT FORMAT
NORMAL

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LIQUID SENSOR SETUP
L 1:87 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

LEAK MIN PERIODIC: 10%
: 1000
LEAK MIN ANNUAL : 10%
: 1000

LEAK MIN PERIODIC: 10%
: 1000
LEAK MIN ANNUAL : 10%
: 1000

L 2:91 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

PERIODIC TEST TYPE
STANDARD

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

L 3:DIESEL ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 4:87 STP SUMP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 5:91 STP SUMP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 6:DIESEL STP SUMP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

OUTPUT RELAY SETUP

R 1:87
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 1:FUEL ALARM
L 4:FUEL ALARM
L 1:SENSOR OUT ALARM
L 4:SENSOR OUT ALARM

R 2:91
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 2:FUEL ALARM
L 5:FUEL ALARM
L 2:SENSOR OUT ALARM
L 5:SENSOR OUT ALARM

R 3:DSL
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 3:FUEL ALARM
L 6:FUEL ALARM
L 3:SENSOR OUT ALARM
L 6:SENSOR OUT ALARM

SMARTSENSOR SETUP

s 1:CARBON CANISTOR
CATEGORY VAPOR VALVE

s 2:VAPOR PRESSURE
CATEGORY VAPOR PRESSURE

s 8:ATM
CATEGORY ATM P SENSOR

PMC SETUP

PMC VERSION: 01.02
VAPOR PROCESSOR TYPE
VEEDER-ROOT POLISHER

ANALYSIS TIMES
TIME: 10:00 AM
DELAY MINUTES: 1

ALARM HISTORY REPORT

----- SYSTEM ALARM -----
PAPER OUT
DEC 28, 2010 2:43 PM
PRINTER ERROR
DEC 28, 2010 2:43 PM

***** END *****

ALARM HISTORY REPORT

----- IN-TANK ALARM -----
T 1:UNL87

OVERFILL ALARM
FEB 10, 2011 7:55 AM
AUG 19, 2010 12:47 PM
JUN 12, 2010 5:57 AM

HIGH PRODUCT ALARM
FEB 10, 2011 7:57 AM

***** END *****

ALARM HISTORY REPORT

----- IN-TANK ALARM -----
T 2:PREM91

***** END *****

ALARM HISTORY REPORT

----- IN-TANK ALARM -----
T 3:DIESEL

LOW PRODUCT ALARM
NOV 5, 2010 2:27 PM
DEC 3, 2009 9:08 AM
NOV 25, 2009 4:53 AM

DELIVERY NEEDED
NOV 5, 2010 2:27 PM
DEC 3, 2009 9:08 AM
NOV 25, 2009 4:53 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 1:87 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 24, 2011 10:34 AM

FUEL ALARM
FEB 24, 2011 9:09 AM

FUEL ALARM
FEB 23, 2010 9:40 AM

40232 /

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 2:91 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 24, 2011 10:34 AM

FUEL ALARM
FEB 24, 2011 9:08 AM

FUEL ALARM
FEB 23, 2010 9:40 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 4:87 STP SUMP
STP SUMP
SENSOR OUT ALARM
FEB 24, 2011 10:34 AM

FUEL ALARM
FEB 24, 2011 9:06 AM

FUEL ALARM
FEB 24, 2011 9:01 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 6:DIESEL STP SUMP
STP SUMP
SENSOR OUT ALARM
FEB 24, 2011 10:34 AM

FUEL ALARM
FEB 24, 2011 9:07 AM

SENSOR OUT ALARM
APR 12, 2010 9:31 PM

* * * * * END * * * * *

* * * * * END * * * * *

* * * * * END * * * * *

ALARM HISTORY REPORT

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 3:DIESEL ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 24, 2011 10:34 AM

FUEL ALARM
FEB 24, 2011 9:08 AM

FUEL ALARM
FEB 23, 2010 9:40 AM

----- SENSOR ALARM -----
L 5:91 STP SUMP
STP SUMP
SENSOR OUT ALARM
FEB 24, 2011 10:34 AM

FUEL ALARM
FEB 24, 2011 9:07 AM

FUEL ALARM
APR 12, 2010 9:37 PM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
e 1:
OTHER SENSORS.

* * * * * END * * * * *

* * * * * END * * * * *

* * * * * END * * * * *

ALARM HISTORY REPORT

----- SENSOR ALARM -----
e 1:
OTHER SENSORS

* * * * * END * * * * *

40232 //

MONITOR CERT. FAILURE REPORT

SITE NAME: JOHNNY QUICK **DATE:** 02/24/11

ADDRESS: 2126 TAFT HWY. **TECHNICIAN:** RYAN MASON

CITY: BAKERSFIELD **SIGNATURE:** *[Signature]*

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS: NONE

LABOR: NONE

PARTS INTALLED: NONE

NAME: **TITLE:**

SIGNATURE:

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENENCE.

MONITORING SYSTEM CERTIFICATION

34726 SS

For Use By All Jurisdictions Within the State of California

Authority Cited: Chapter 6.7, Health and Safety Code; Chapter 16, Division 3, Title 23, California Code of Regulations

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

CR-3201

A. General Information

Facility Name: **JOHNNY QUICK** Bldg. No.: _____
 Site Address: **2126 TAFT HWY.** City: **BAKERSFIELD** Zip: **93313**
 Facility Contact Person: **MR. KOOL** Contact Phone No.: **(661) 834-9113**
 Make/Model of Monitoring System: **TLS-350** Date of Testing/Service: **2/23/2010**

B. Inventory of Equipment Tested/Certified

Check the appropriate boxes to indicate specific equipment inspected/serviced:

<p>Tank ID: REGULAR 87</p> <p><input type="checkbox"/> In-Tank Gauging Probe. Model: _____</p> <p><input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: 420</p> <p><input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: 208</p> <p><input type="checkbox"/> Fill Sump Sensor(s). Model: _____</p> <p><input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: RED JACKET</p> <p><input type="checkbox"/> Electronic Line Leak Detector. Model: _____</p> <p><input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____</p> <p><input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2): _____</p>	<p>Tank ID: PREMIUM 91</p> <p><input type="checkbox"/> In-Tank Gauging Probe. Model: _____</p> <p><input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: 420</p> <p><input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: 208</p> <p><input type="checkbox"/> Fill Sump Sensor(s). Model: _____</p> <p><input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: RED JACKET</p> <p><input type="checkbox"/> Electronic Line Leak Detector. Model: _____</p> <p><input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____</p> <p><input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2): _____</p>
<p>Tank ID: DIESEL</p> <p><input type="checkbox"/> In-Tank Gauging Probe. Model: _____</p> <p><input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: 420</p> <p><input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: 208</p> <p><input type="checkbox"/> Fill Sump Sensor(s). Model: _____</p> <p><input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: RED JACKET</p> <p><input type="checkbox"/> Electronic Line Leak Detector. Model: _____</p> <p><input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____</p> <p><input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2): _____</p>	<p>Tank ID: _____</p> <p><input type="checkbox"/> In-Tank Gauging Probe. Model: _____</p> <p><input type="checkbox"/> Annular Space or Vault Sensor. Model: _____</p> <p><input type="checkbox"/> Piping Sump / Trench Sensor(s). Model: _____</p> <p><input type="checkbox"/> Fill Sump Sensor(s). Model: _____</p> <p><input type="checkbox"/> Mechanical Line Leak Detector. Model: _____</p> <p><input type="checkbox"/> Electronic Line Leak Detector. Model: _____</p> <p><input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____</p> <p><input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2): _____</p>
<p>Dispenser ID: 1/2</p> <p><input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: 406</p> <p><input checked="" type="checkbox"/> Shear Valve(s).</p> <p><input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).</p>	<p>Dispenser ID: 3/4</p> <p><input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: 406</p> <p><input checked="" type="checkbox"/> Shear Valve(s).</p> <p><input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).</p>
<p>Dispenser ID: 5/6</p> <p><input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: 406</p> <p><input checked="" type="checkbox"/> Shear Valve(s).</p> <p><input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).</p>	<p>Dispenser ID: 7/8</p> <p><input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: 406</p> <p><input checked="" type="checkbox"/> Shear Valve(s).</p> <p><input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).</p>
<p>Dispenser ID: _____</p> <p><input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____</p> <p><input type="checkbox"/> Shear Valve(s).</p> <p><input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).</p>	<p>Dispenser ID: _____</p> <p><input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____</p> <p><input type="checkbox"/> Shear Valve(s).</p> <p><input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).</p>

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply):

System set-up Alarm history report

Technician Name (print): **BRANDON MASON** Signature: _____
 Certification No.: **B34335** License No.: **5284980-UT**
 Testing Company Name: **RICH ENVIRONMENTAL** Phone No.: **(661) 392-8687**
 Testing Company Address: **5643 BROOKS CT. BAKERSFIELD, CA. 93308** Date of Testing/Service: **2/23/2010**

D. Results of Testing/Service

Software Version Installed: 329.01

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the audible alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the visual alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors visually inspected, functionally tested, and confirmed operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors installed at lowest point of secondary containment and positioned so that other equipment will not interfere with their proper operation?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	If alarms are relayed to a remote monitoring station, is all communications equipment (e.g., modem) operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected? If yes: which sensors initiate positive shut-down? <i>(Check all that apply)</i> <input checked="" type="checkbox"/> Sump/Trench Sensors; <input type="checkbox"/> Dispenser Containment Sensors. Did you confirm positive shut-down due to leaks and sensor failure/disconnection? <input checked="" type="checkbox"/> Yes; <input type="checkbox"/> No.
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For tank systems that utilize the monitoring system as the primary tank overflow warning device (i.e., no mechanical overflow prevention valve is installed), is the overflow warning alarm visible and audible at the tank fill point(s) and operating properly? If so, at what percent of tank capacity does the alarm trigger? %
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes, or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E, below.
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was liquid found inside any secondary containment systems designed as dry systems? <i>(Check all that apply)</i> <input type="checkbox"/> Product; <input type="checkbox"/> Water. If yes, describe causes in Section E, below.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was monitoring system set-up reviewed to ensure proper settings? Attach set up reports, if applicable
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is all monitoring equipment operational per manufacturer's specifications?

* In Section E below, describe how and when these deficiencies were or will be corrected.

E. Comments:

F. In-Tank Gauging / SIR Equipment:

- Check this box if tank gauging is used only for inventory control.
- Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all tank gauging probes visually inspected for damage and residue buildup?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system product level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system water level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all probes reinstalled properly?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

G. Line Leak Detectors (LLD):

- Check this box if LLDs are not installed.

Complete the following checklist:


<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For equipment start-up or annual equipment certification, was a leak simulated to verify LLD performance? (Check all that apply) Simulated leak rate: <input checked="" type="checkbox"/> 3 g.p.h.; <input type="checkbox"/> 0.1 g.p.h.; <input type="checkbox"/> 0.2 g.p.h.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all LLDs confirmed operational and accurate within regulatory requirements?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was the testing apparatus properly calibrated?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

H. Comments:

UST Monitoring Site Plan

Site Address: 2126 TAFT HWY. BAKERSFIELD, CA. 93313



Date map was drawn: 2/23/2009

Instructions

If you already have a diagram that shows all required information, you may include it, rather than this page, with your Monitoring System Certification. On your site plan, show the general layout of tanks and piping. Clearly identify locations of the following equipment, if installed: monitoring system control panels; sensors monitoring tank annular spaces, sumps, dispenser pans, spill containers, or other secondary containment areas; mechanical or electronic line leak detectors; and in-tank liquid level probes (if used for leak detection). In the space provided, note the date this Site Plan was prepared.

RICH ENVIRONMENTAL
 5643 BROOKS CT. BAKERSFIELD, CA. 93308
 OFFICE (661)392-8687 FAX (661)392-0621
PRODUCT LINE LEAK DETECTOR TEST

WORK SHEET

W/O#: _____

FACILITY NAME: JOHNNY QUICK

FACILITY ADDRESS: 2126 TAFT HWY. BAKERSFIELD, CA. 93313

PRODUCT LINE TYPE: PRESSURE

PRODUCT	LEAK DETECTOR TYPE SERIAL NUMBER	TEST BELOW 3 G.P.H.	TRIP P.S.I.	PASS OR FAIL
REGULAR 87	L/D TYPE: <u>RED JACKET</u> SERIAL # <u>MECHANICAL</u>	YES	10 PSI	PASS
PREMIUM 91	L/D TYPE: <u>RED JACKET</u> SERIAL # <u>MECHANICAL</u>	YES	10 PSI	PASS
DIESEL	L/D TYPE: <u>RED JACKET</u> SERIAL # <u>MECHANICAL</u>	YES	10 PSI	PASS
	L/D TYPE: <u> </u> SERIAL # <u> </u>	YES NO		PASS FAIL

I CERTIFY THE ABOVE TESTS WERE CONDUCTED ON THIS DATE ACCORDING TO RED JACKET PUMPS FIELD TEST APPARATUS TESTING PROCEDURE AND LIMITATIONS. THE MECHANICAL LEAK DETECTOR TEST PASS / FAIL IS DETERMINED BY USING A LOW FLOW THRESHOLD TRIP RATE OF 3 GALLONS PER HOUR OR LESS AT 10 P.S.I. I ACKNOWLEDGE THAT ALL DATA COLLECTED IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE.

TECHNICIAN: BRANDON MASON

SIGNATURE: _____

DATE: 02/23/10

Spill Bucket Testing Report Form

This form is intended for use by contractors performing annual testing of UST spill containment structures. The completed form and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name:	JOHNNY QUICK	Date of Testing:	02/23/10
Facility Address:	2126 TAFT HWY, BAKERSFIELD, CA 93313		
Facility Contact:	MR. KOOL	Phone:	(661)834-9113
Date Local Agency Was Notified of Testing:	02/12/10		
Name of Local Agency Inspector (if present during testing):	LAUREL FUNK		

2. TESTING CONTRACTOR INFORMATION

Company Name:	RICH ENVIRONMENTAL		
Technician Conducting Test:	STEVEN OBERT		
Credentials:	<input checked="" type="checkbox"/> CSLB Contractor	<input checked="" type="checkbox"/> ICC Service Tech.	<input checked="" type="checkbox"/> SWRCB Tank Tester <input type="checkbox"/> Other (Specify)
License Number(s):	5261246-UT		

3. SPILL BUCKET TESTING INFORMATION

Test Method Used:	<input checked="" type="checkbox"/> Hydrostatic <input type="checkbox"/> Vacuum <input type="checkbox"/> Other		
Test Equipment Used:	VISUAL		
	Equipment Resolution: 0:00		
Identify Spill Bucket (By Tank Number, Stored Product, etc.):	1 REGULAR 87-FILL	2-PREMIUM 91-FILL	3 DIESEL
Bucket Installation Type:	<input checked="" type="checkbox"/> Direct-Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct-Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct-Bury <input type="checkbox"/> Contained in Sump
Bucket Diameter:	12"	12"	12"
Bucket Depth:	12"	12"	12"
Wait time between applying vacuum/water and start of test:	30 MIN	30 MIN	30 MIN
Test Start Time (T _i):	0900	0900	0900
Initial Reading (R _i):	10"	10"	10"
Test End Time (T _f):	1000	1000	1000
Final Reading (R _f):	10"	10"	10"
Test Duration (T _f - T _i):	1-HOUR	1-HOUR	1-HOUR
Change in Reading (R _f - R _i):	0	0	0
Pass/Fail Threshold or Criteria:	+/- 0.00	+/- 0.00	+/- 0.00
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

I hereby certify that all the information contained in this report is true, accurate, and in full compliance with legal requirements.

Technician's Signature: _____

Date: 02/23/10

State laws and regulations do not currently require testing to be performed by a qualified contractor. However, local requirements may be more stringent.

SOFTWARE REVISION LEVEL
VERSION 329.01
SOFTWARE# 346329-100-B
CREATED - 09.01.29.15.44

NO SOFTWARE MODULE
SYSTEM FEATURES:
PERIODIC IN-TANK TESTS
ANNUAL IN-TANK TESTS

SYSTEM SETUP

FEB 23. 2010 10:44 AM

SYSTEM UNITS

U.S.
SYSTEM LANGUAGE
ENGLISH
SYSTEM DATE/TIME FORMAT
MON DD YYYY HH:MM:SS XM

JOHNNY QUIK 143
2126 TAFT HWY
BAKERSFIELD CA 93313
661-834-9113

SHIFT TIME 1 : 8:00 AM
SHIFT TIME 2 : DISABLED
SHIFT TIME 3 : DISABLED
SHIFT TIME 4 : DISABLED

TANK PER TST NEEDED WRN
DISABLED
TANK ANN TST NEEDED WRN
DISABLED

LINE RE-ENABLE METHOD
PASS LINE TEST

LINE PER TST NEEDED WRN
DISABLED
LINE ANN TST NEEDED WRN
DISABLED

PRINT TO VOLUMES
ENABLED

TEMP COMPENSATION
VALUE (DEG F) : 60.0
STICK HEIGHT OFFSET
DISABLED
ULLAGE: 90%

H-PROTOCOL DATA FORMAT
HEIGHT
DAYLIGHT SAVING TIME
ENABLED
START DATE
MAR WEEK 2 SUN
START TIME
2:00 AM
END DATE
NOV WEEK 1 SUN
END TIME
2:00 AM

RE-DIRECT LOCAL PRINTOUT
DISABLED

EURO PROTOCOL PREFIX
S

COMMUNICATIONS SETUP

PORT SETTINGS:

COMM BOARD : 1 (RS-232)
BAUD RATE : 9600
PARITY : ODD
STOP BIT : 1 STOP
DATA LENGTH: 7 DATA
RS-232 SECURITY
CODE : DISABLED

COMM BOARD : 3 (RS-232)
BAUD RATE : 1200
PARITY : ODD
STOP BIT : 1 STOP
DATA LENGTH: 7 DATA
RS-232 SECURITY
CODE : DISABLED

AUTO TRANSMIT SETTINGS:

AUTO LEAK ALARM LIMIT
DISABLED
AUTO HIGH WATER LIMIT
DISABLED
AUTO OVERFILL LIMIT
DISABLED
AUTO LOW PRODUCT
DISABLED
AUTO THEFT LIMIT
DISABLED
AUTO DELIVERY START
DISABLED
AUTO DELIVERY END
DISABLED
AUTO EXTERNAL INPUT ON
DISABLED
AUTO EXTERNAL INPUT OFF
DISABLED
AUTO SENSOR FUEL ALARM
DISABLED
AUTO SENSOR WATER ALARM
DISABLED
AUTO SENSOR OUT ALARM
DISABLED

RS-232 END OF MESSAGE
DISABLED

IN-TANK SETUP

T 1:UNLB7
PRODUCT CODE : 1
THERMAL COEFF : .000700
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTB
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%

HIGH PRODUCT : 95%

DELIVERY LIMIT : 9500
10%

LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
1000

LEAK MIN ANNUAL : 10%
1000

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

T 2:PREM91
PRODUCT CODE :
THERMAL COEFF : 000700
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 6091
24.0 INCH VOL : 1991

T 3:DIESEL
PRODUCT CODE : 3
THERMAL COEFF : 000450
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 6091
24.0 INCH VOL : 1991

24 100
LEAK TEST METHOD
TEST ON DATE : ALL TANK
JAN 29, 2009
START TIME : DISABLED
TEST RATE : 0.20 GAL/HR
DURATION : 2 HOURS

TST EARLY STOP:DISABLED

FLOAT SIZE: 4.0 IN.
WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
9000
HIGH PRODUCT : 95%
9500
DELIVERY LIMIT : 10%
1000
LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

FLOAT SIZE: 4.0 IN.
WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
9000
HIGH PRODUCT : 95%
9500
DELIVERY LIMIT : 10%
1000
LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

LEAK TEST REPORT FORMAT
NORMAL

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LIQUID SENSOR SETUP

L 1:87 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

LEAK MIN PERIODIC: 10%
1000
LEAK MIN ANNUAL : 10%
1000

LEAK MIN PERIODIC: 10%
1000
LEAK MIN ANNUAL : 10%
1000

L 2:91 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

PERIODIC TEST TYPE
STANDARD

PERIODIC TEST TYPE
STANDARD

L 3:DIESEL ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

ANNUAL TEST FAIL
ALARM DISABLED

ANNUAL TEST FAIL
ALARM DISABLED

L 4:87 STP SUMP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

PERIODIC TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

L 5:91 STP SUMP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

GROSS TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

L 6:DIESEL STP SUMP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

OUTPUT RELAY SETUP

R 1:87
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 1:FUEL ALARM
L 4:FUEL ALARM
L 1:SENSOR OUT ALARM
L 4:SENSOR OUT ALARM

R 2:91
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 2:FUEL ALARM
L 5:FUEL ALARM
L 2:SENSOR OUT ALARM
L 5:SENSOR OUT ALARM

R 3:DSL
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 3:FUEL ALARM
L 6:FUEL ALARM
L 3:SENSOR OUT ALARM
L 6:SENSOR OUT ALARM

SMARTSENSOR SETUP

S 1:CARBON CANISTOR
CATEGORY VAPOR VALVE

S 2:VAPOR PRESSURE
CATEGORY VAPOR PREBSURE

S 8:ATM
CATEGORY ATM P SENSOR

PMC SETUP

PMC VERSION: 01102

VAPOR PROCESSOR TYPE
VEEDER-ROOT POLISHER

ANALYSIS TIMES
TIME: 10:00 AM
DELAY MINUTES: 1

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 1:87 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 23, 2010 9:40 AM

FUEL ALARM
FEB 23, 2010 9:29 AM

SETUP DATA WARNING
OCT 16, 2009 1:38 PM

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 2:91 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 23, 2010 9:40 AM

FUEL ALARM
FEB 23, 2010 9:29 AM

SETUP DATA WARNING
OCT 16, 2009 1:38 PM

***** END *****

34126

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 3: DIESEL ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 23, 2010 9:40 AM

FUEL ALARM
FEB 23, 2010 9:30 AM

SETUP DATA WARNING
OCT 16, 2009 1:38 PM

***** END *****

ALARM HISTORY REPORT

34/26

----- SENSOR ALARM -----
L 5:91 STP SUMP
STP SUMP
SENSOR OUT ALARM
FEB 23, 2010 9:40 AM

FUEL ALARM
FEB 23, 2010 9:29 AM

SETUP DATA WARNING
OCT 16, 2009 1:38 PM

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 4:87 STP SUMP
STP SUMP
SENSOR OUT ALARM
FEB 23, 2010 9:40 AM

FUEL ALARM
FEB 23, 2010 9:29 AM

SENSOR OUT ALARM
JAN 6, 2010 11:05 AM

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 6: DIESEL STP SUMP
STP SUMP
SENSOR OUT ALARM
FEB 23, 2010 9:40 AM

FUEL ALARM
FEB 23, 2010 9:30 AM

SETUP DATA WARNING
OCT 16, 2009 1:38 PM

***** END *****

34/26

50

MONITOR CERT. FAILURE REPORT

SITE NAME: JOHNNY QUICK **DATE:** 02/23/10

ADDRESS: 2126 TAFT HWY. **TECHNICIAN:** BRANDON MASON

CITY: BAKERSFIELD **SIGNATURE:** 

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS: NONE

LABOR: NONE

PARTS INTALLED: NONE

NAME: **TITLE:**

SIGNATURE:

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENCE.

Secondary Containment Testing Report Form

3201

This form is intended for use by contractors performing periodic testing of UST secondary containment systems. Use the appropriate pages of this form to report results for all components tested. The completed form, written test procedures, and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: JOHNNY QUICK	Date of Testing: 9-28-09
Facility Address: 2126 TAFT HWY BAKERSFIELD, CA	
Facility Contact:	Phone:
Date Local Agency Was Notified of Testing :	
Name of Local Agency Inspector (if present during testing): NONE	

2. TESTING CONTRACTOR INFORMATION

Company Name: Rich Environmental	
Technician Conducting Test: RYAN MASON	
Credentials: <input checked="" type="checkbox"/> CSLB Licensed Contractor	<input type="checkbox"/> SWRCB Licensed Tank Tester
License Type: C61/D40 A HAZ	License Number: 809850
Manufacturer Training	
Manufacturer	Component(s)
Date Training Expires	


3. SUMMARY OF TEST RESULTS

Component	Pass	Fail	Not Tested	Repairs Made	Component	Pass	Fail	Not Tested	Repairs Made
UNL87 SEC. PIPE	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PREM91 SEC. PIPE	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DIESEL SEC. PIPE	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
UDC 1-2	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
UDC 3-4	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
UDC 5-6	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
UDC 7-8	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

If hydrostatic testing was performed, describe what was done with the water after completion of tests:

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

To the best of my knowledge, the facts stated in this document are accurate and in full compliance with legal requirements

Technician's Signature: 

Date: 9-28-09

7. UNDER-DISPENSER CONTAINMENT (UDC) TESTING

Test Method Developed By:	<input type="checkbox"/> UDC Manufacturer	<input type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer	
	<input type="checkbox"/> Other (Specify)			
Test Method Used:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input type="checkbox"/> Hydrostatic	
	<input type="checkbox"/> Other (Specify)			
Test Equipment Used:	Equipment Resolution:			
	UDC # 1-2	UDC # 3-4	UDC # 5-6	UDC # 7-8
UDC Manufacturer:	UNKNOWN	UNKNOWN	UNKNOWN	UNKNOWN
UDC Material:	FIBERGLASS	FIBERGLASS	FIBERGLASS	FIBERGLASS
UDC Depth:	30"	30"	30"	30"
Height from UDC Bottom to Top of Highest Piping Penetration:	12"	12"	12"	12"
Height from UDC Bottom to Lowest Electrical Penetration:	12"	12"	12"	12"
Condition of UDC prior to testing:	CLEAN	CLEAN	CLEAN	CLEAN
Portion of UDC Tested ¹	14"	14"	14"	14"
Does turbine shut down when UDC sensor detects liquid (both product and water)?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Turbine shutdown response time	N/A	N/A	N/A	N/A
Is system programmed for fail-safe shutdown?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Was fail-safe verified to be operational?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Wait time between applying pressure/vacuum/water and starting test	30MIN	30MIN	30MIN	30MIN
Test Start Time:	3:21PM	3:38PM	3:21PM	3:38PM
Initial Reading (R _i):	3.026IN	3.025IN	3.931IN	3.931IN
Test End Time:	3:37PM	3:53PM	3:37PM	3:53PM
Final Reading (R _f):	3.025IN	3.025IN	3.931IN	3.931IN
Test Duration:	15MIN	15MIN	15MIN	15MIN
Change in Reading (R _f -R _i):	.000IN	.000IN	.000IN	.000IN
Pass/Fail Threshold or Criteria:	.002IN	.002IN	.002IN	.002IN
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	X Yes <input type="checkbox"/> No <input type="checkbox"/> NA	X Yes <input type="checkbox"/> No <input type="checkbox"/> NA	X Yes <input type="checkbox"/> No <input type="checkbox"/> NA	X Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	X Yes <input type="checkbox"/> No <input type="checkbox"/> NA	X Yes <input type="checkbox"/> No <input type="checkbox"/> NA	X Yes <input type="checkbox"/> No <input type="checkbox"/> NA	X Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

INSTALLED TEST BOOTS AND RESEALED PENETRATIONS AS NEEDED

¹ If the entire depth of the UDC is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire UDC must be tested. (See SWRCB LG-160)

JOHNNY QUICK
2126 TAFT HWY
BAKERSFIELD CA

09/28/2009 3:37 PM

SUMP LEAK TEST REPORT

UDC1-2

TEST STARTED 3:21 PM
TEST STARTED 09/28/2009
BEGIN LEVEL 3.0260 IN
END TIME 3:37 PM
END DATE 09/28/2009
END LEVEL 3.0259 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC3-4

TEST STARTED 3:21 PM
TEST STARTED 09/28/2009
BEGIN LEVEL 3.9310 IN
END TIME 3:37 PM
END DATE 09/28/2009
END LEVEL 3.9313 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC5-6

TEST STARTED 3:21 PM
TEST STARTED 09/28/2009
BEGIN LEVEL 5.3487 IN
END TIME 3:37 PM
END DATE 09/28/2009
END LEVEL 5.3484 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC7-8

TEST STARTED 3:21 PM
TEST STARTED 09/28/2009
BEGIN LEVEL 4.4442 IN
END TIME 3:37 PM
END DATE 09/28/2009
END LEVEL 4.4441 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

JOHNNY QUICK
2126 TAFT HWY
BAKERSFIELD CA

09/28/2009 3:53 PM

SUMP LEAK TEST REPORT

UDC1-2

TEST STARTED 3:38 PM
TEST STARTED 09/28/2009
BEGIN LEVEL 3.0258 IN
END TIME 3:53 PM
END DATE 09/28/2009
END LEVEL 3.0259 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC3-4

TEST STARTED 3:38 PM
TEST STARTED 09/28/2009
BEGIN LEVEL 3.9313 IN
END TIME 3:53 PM
END DATE 09/28/2009
END LEVEL 3.9313 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC5-6

TEST STARTED 3:38 PM
TEST STARTED 09/28/2009
BEGIN LEVEL 5.3484 IN
END TIME 3:53 PM
END DATE 09/28/2009
END LEVEL 5.3483 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

UDC7-8

TEST STARTED 3:38 PM
TEST STARTED 09/28/2009
BEGIN LEVEL 4.4441 IN
END TIME 3:53 PM
END DATE 09/28/2009
END LEVEL 4.4440 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

SB989 TESTING FAILURE REPORT

SITE NAME: JOHNNY QUICK


DATE: 9-28-09

ADDRESS: 2126 TAFT HWY

TECHNICIAN: RYAN MASON

CITY: BAKERSFIELD

SIGNATURE:



REPAIRS:

-INSTALLED TEST BOOT AS NEEDED

- RESEALED PENETRATIONS IN UDC'S AS NEEDED

PARTS INSTALLED:

-MULTIPLE TEST BOOTS

- 4 PARASEAL 626

NAME:

TITLE:

SIGNATURE:

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE.

A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENENCE.

Secondary Containment Testing Report Form

This form is intended for use by contractors performing periodic testing of UST secondary containment systems. Use the appropriate pages of this form to report results for all components tested. The completed form, written test procedures, and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: <u>JOHNNY QUICK</u>	Date of Testing: <u>9-28-09</u>
Facility Address: <u>2126 TAFT HWY BAKERSFIELD, CA</u>	
Facility Contact:	Phone:
Date Local Agency Was Notified of Testing:	
Name of Local Agency Inspector (if present during testing): <u>NONE</u>	

2. TESTING CONTRACTOR INFORMATION

Company Name: <u>RICH ENVIRONMENTAL</u>		
Technician Conducting Test: <u>RYAN MASON</u>		
Credentials: <input checked="" type="checkbox"/> CSLB Licensed Contractor	<input type="checkbox"/> SWRCB Licensed Tank Tester	
License Type: <u>CGI/040 A NAR</u>	License Number: <u>809850</u>	
Manufacturer Training		
Manufacturer	Component(s)	Date Training Expires


3. SUMMARY OF TEST RESULTS

Component	Pass	Fail	Not Tested	Repairs Made	Component	Pass	Fail	Not Tested	Repairs Made
<u>UUL87 STP</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>PREMS1 STP</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>DIESEL STP</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

If hydrostatic testing was performed, describe what was done with the water after completion of tests:

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

To the best of my knowledge, the facts stated in this document are accurate and in full compliance with legal requirements

Technician's Signature: 

Date: 9-28-09

6. PIPING SUMP TESTING

Test Method Developed By:	<input type="checkbox"/> Sump Manufacturer	<input type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer	
	<input type="checkbox"/> Other (Specify)			
Test Method Used:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input type="checkbox"/> Hydrostatic	
	<input type="checkbox"/> Other (Specify)			
Test Equipment Used:				Equipment Resolution:
	Sump # 87	Sump # 91	Sump # DSL	Sump #
Sump Diameter:	36.0	36.0	36.0	
Sump Depth:	42.0	42.0	42.0	
Sump Material:	PLASTIC	PLASTIC	PLASTIC	
Height from Tank Top to Top of Highest Piping Penetration:	6.0	7.0	6.0	
Height from Tank Top to Lowest Electrical Penetration:	17.0	17.0	17.0	
Condition of sump prior to testing:	CLEAN	CLEAN	CLEAN	
Portion of Sump Tested ¹	8.0	8.0	8.0	
Does turbine shut down when sump sensor detects liquid (both product and water)?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Turbine shutdown response time	5 SEC	5 SEC	5 SEC	
Is system programmed for fail-safe shutdown?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was fail-safe verified to be operational?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Wait time between applying pressure/vacuum/water and starting test:	30 min	30 min	30 min	
Test Start Time:	2:24pm	2:40pm	2:24pm	2:40pm
Initial Reading (R _i):	4.868	4.868	5.088	5.088
Test End Time:	2:39pm	2:55pm	2:39pm	2:55pm
Final Reading (R _f):	4.868	4.868	5.088	5.087
Test Duration:	15 min	15 min	15 min	15 min
Change in Reading (R _f -R _i):	.000	.000	.000	.001
Pass/Fail Threshold or Criteria:	.002	.002	.002	.002
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

-INSTALLED NEW TEST BOOTS ON SEC. PIPING IN SFP SUMP.

-RESEALED PIPING PENETRATION IN ALL SFP SUMPS

¹ If the entire depth of the sump is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire sump must be tested. (See SWRCB LG-160)

JOHNNY QUICK
2126 TAFT HWY
BAKERSFIELD

09/28/2009 2:40 PM

SUMP LEAK TEST REPORT

91STP

TEST STARTED 2:24 PM
TEST STARTED 09/28/2009
BEGIN LEVEL 5.0885 IN
END TIME 2:39 PM
END DATE 09/28/2009
END LEVEL 5.0882 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

87STP

TEST STARTED 2:24 PM
TEST STARTED 09/28/2009
BEGIN LEVEL 4.8686 IN
END TIME 2:39 PM
END DATE 09/28/2009
END LEVEL 4.8685 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

JOHNNY QUICK
2126 TAFT HWY
BAKERSFIELD

09/28/2009 2:55 PM

SUMP LEAK TEST REPORT

91STP

TEST STARTED 2:40 PM
TEST STARTED 09/28/2009
BEGIN LEVEL 5.0881 IN
END TIME 2:55 PM
END DATE 09/28/2009
END LEVEL 5.0879 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

87STP

TEST STARTED 2:40 PM
TEST STARTED 09/28/2009
BEGIN LEVEL 4.8683 IN
END TIME 2:55 PM
END DATE 09/28/2009
END LEVEL 4.8684 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

JOHNNY QUICK
2126 TAFT HWY
BAKERSFIELD

09/28/2009 12:25 PM

SUMP LEAK TEST REPORT

DSLSTP

TEST STARTED 12:10 PM
TEST STARTED 09/28/2009
BEGIN LEVEL 4.1412 IN
END TIME 12:25 PM
END DATE 09/28/2009
END LEVEL 4.1403 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

JOHNNY QUICK
2126 TAFT HWY
BAKERSFIELD

09/28/2009 12:57 PM

SUMP LEAK TEST REPORT

DSLSTP

TEST STARTED 12:42 PM
TEST STARTED 09/28/2009
BEGIN LEVEL 4.1316 IN
END TIME 12:57 PM
END DATE 09/28/2009
END LEVEL 4.1314 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

SB989 TESTING FAILURE REPORT

SITE NAME: JOHNNY QUICK DATE: 9-28-09

ADDRESS: 2126 TART HWY TECHNICIAN: RYAN MAON

CITY: BAIERSFIELD SIGNATURE: [Signature]

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS:

INSTALLED TEST BOOTS ON ALL SEC. PIPES
IN STP SUMPS

LABOR:

PARTS INTALLED:

3- 3.9x2.4 TEST BOOTS

NAME: _____ TITLE: _____

SIGNATURE:

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENENCE.

Secondary Containment Testing Report Form

This form is intended for use by contractors performing periodic testing of UST secondary containment systems. Use the appropriate pages of this form to report results for all components tested. The completed form, written test procedures, and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: <u>JOHNNY QUACK</u>	Date of Testing: <u>7-7-09</u>
Facility Address: <u>2126 TAFT HWY</u>	
Facility Contact: <u>MR KOOL</u>	Phone: <u>834-9113</u>
Date Local Agency Was Notified of Testing: <u>6-12-09</u>	
Name of Local Agency Inspector (if present during testing): <u>NONE</u>	

RECEIVED 2-3-01

2. TESTING CONTRACTOR INFORMATION

Company Name: <u>RIGHT ENVIRONMENTAL</u>		AUG 4 2009
Technician Conducting Test: <u>BRIANTON MASON</u>		
Credentials: <input type="checkbox"/> CSLB Licensed Contractor	<input checked="" type="checkbox"/> SWRCB Licensed Tank Tester	
License Type:	License Number:	KERN COUNTY ENVIRONMENTAL SERVICES
Manufacturer Training		
Manufacturer	Component(s)	Date Training Expires
<u>INCON</u>	<u>TS-ST3</u>	<u>4-10-2010</u>

3. SUMMARY OF TEST RESULTS

Component	Pass	Fail	Not Tested	Repairs Made	Component	Pass	Fail	Not Tested	Repairs Made
<u>87 ANNULAR</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>UDC 7-8</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>91 ANNULAR</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>87 VAPOR</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>DIESEL ANNULAR</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>91 VAPOR</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>87 SECONDARY</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>DIESEL VAPOR</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>91 SECONDARY</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>DIESEL SECONDARY</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>87 STP</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>91 STP</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>DIESEL STP</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>UDC 1-2</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>UDC 3-4</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>UDC 5-6</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

If hydrostatic testing was performed, describe what was done with the water after completion of tests:

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

To the best of my knowledge, the facts stated in this document are accurate and in full compliance with legal requirements

Technician's Signature: _____

Date: 7-7-09

4. TANK ANNULAR TESTING

Test Method Developed By:	<input type="checkbox"/> Tank Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
	<input type="checkbox"/> Other (Specify)		
Test Method Used:	<input type="checkbox"/> Pressure	<input checked="" type="checkbox"/> Vacuum	<input type="checkbox"/> Hydrostatic
	<input type="checkbox"/> Other (Specify)		
Test Equipment Used: GAUGE	Equipment Resolution:		
	Tank # 87	Tank # 91	Tank # DIESEL
Is Tank Exempt From Testing? ¹	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Tank Capacity:	10,000	10,000	10,000
Tank Material:	STEEL	STEEL	STEEL
Tank Manufacturer:	UNKNOWN	UNKNOWN	UNKNOWN
Product Stored:	GASOLINE	GASOLINE	
Wait time between applying pressure/vacuum/water and starting test:	30 MIN	30 MIN	30 MIN
Test Start Time:	11:30 AM	11:30 AM	12:00 PM
Initial Reading (R _i):	-10 HG	-10 HG	-10 HG
Test End Time:	12:30 PM	12:30 PM	1:00 PM
Final Reading (R _f):	-10 HG	-10 HG	-10 HG
Test Duration:	1 HR	1 HR	1 HR
Change in Reading (R _f -R _i):	-0 HG	-0 HG	-0 HG
Pass/Fail Threshold or Criteria:	-0 HG	-0 HG	-0 HG
Pass/Fail	Pass	Pass	Pass
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ Secondary containment systems where the continuous monitoring automatically monitors both the primary and secondary containment, such as systems that are hydrostatically monitored or under constant vacuum, are exempt from periodic containment testing. {California Code of Regulations, Title 23, Section 2637(a)(6)}

5. SECONDARY PIPE TESTING

Test Method Developed By:	<input type="checkbox"/> Piping Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
	<input type="checkbox"/> Other (Specify)		
Test Method Used:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input type="checkbox"/> Hydrostatic
	<input type="checkbox"/> Other (Specify)		
Test Equipment Used:	Equipment Resolution:		
	Piping Run # 87	Piping Run # 91	Piping Run # 125
Piping Material:			
Piping Manufacturer:			
Piping Diameter:			
Length of Piping Run:			
Product Stored:			
Method and location of piping-run isolation:			
Wait time between applying pressure/vacuum/water and starting test:			
Test Start Time:			
Initial Reading (R _i):			
Test End Time:			
Final Reading (R _f):			
Test Duration:			
Change in Reading (R _f -R _i):			
Pass/Fail Threshold or Criteria:			

Comments - (include information on repairs made prior to testing; and recommended follow-up for failed tests)

SECONDARY'S WERE NOT TESTED BECAUSE THERE ARE NO BOOTS ON THE SECONDARY'S IN THE SUMPS. BOOTS WILL BE ORDERED AND INSTALLED AS SOON AS POSSIBLE. WHEN REPAIRS ARE MADE THE SITE WILL BE RETESTED.

6. PIPING SUMP TESTING

Test Method Developed By:	<input type="checkbox"/> Sump Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
	<input type="checkbox"/> Other (Specify)		
Test Method Used:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic
	<input type="checkbox"/> Other (Specify)		
Test Equipment Used:	Equipment Resolution:		
	Sump # 87	Sump # 91	Sump # DIESEL
Sump Diameter:			
Sump Depth:			
Sump Material:			
Height from Tank Top to Top of Highest Piping Penetration:			
Height from Tank Top to Lowest Electrical Penetration:			
Condition of sump prior to testing:			
Portion of Sump Tested ¹			
Does turbine shut down when sump sensor detects liquid (both product and water)?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Turbine shutdown response time			
Is system programmed for fail-safe shutdown?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was fail-safe verified to be operational?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Wait time between applying pressure/vacuum/water and starting test:			
Test Start Time:			
Initial Reading (R _i):			
Test End Time:			
Final Reading (R _f):			
Test Duration:			
Change in Reading (R _f -R _i):			
Pass/Fail Threshold or Criteria:			
Test Result:	<input type="checkbox"/> Pass	<input type="checkbox"/> Fail	<input type="checkbox"/> Fail
Was sensor removed for testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

SUMPS WERE NOT TESTED AND FAIL BECAUSE THERE ARE NO BOOTS IN THE TURBIN SUMPS TO ISOLATE THAT COMPONENT TO BE TESTED.

¹ If the entire depth of the sump is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire sump must be tested. (See SWRCB LG-160)

7. UNDER-DISPENSER CONTAINMENT (UDC) TESTING

Test Method Developed By:	<input type="checkbox"/> UDC Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
	<input type="checkbox"/> Other (Specify)		
Test Method Used:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic
	<input type="checkbox"/> Other (Specify)		
Test Equipment Used:	Equipment Resolution:		
	UDC# 1-2	UDC# 3-4	UDC# 5-6
	UDC# 7-8		
UDC Manufacturer:			
UDC Material:			
UDC Depth:			
Height from UDC Bottom to Top of Highest Piping Penetration:			
Height from UDC Bottom to Lowest Electrical Penetration:			
Condition of UDC prior to testing:			
Portion of UDC Tested ¹			
Does turbine shut down when UDC sensor detects liquid (both product and water)?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Turbine shutdown response time			
Is system programmed for fail-safe shutdown?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was fail-safe verified to be operational?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Wait time between applying pressure/vacuum/water and starting test			
Test Start Time:			
Initial Reading (R _i):			
Test End Time:			
Final Reading (R _f):			
Test Duration:			
Change in Reading (R _f -R _i):			
Pass/Fail Threshold or Criteria:			
Test Result:			
Was sensor removed for testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

UDC'S WERE NOT TESTED BECAUSE BOOTS HAVE TO BE INSTALLED ON SECONDARIES TO ISOLATE THE UDC'S FOR TESTING.

¹ If the entire depth of the UDC is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire UDC must be tested. (See SWRCB LG-160)

8. FILL RISER CONTAINMENT SUMP TESTING

Facility is Not Equipped With Fill Riser Containment Sumps <input checked="" type="checkbox"/>				
Fill Riser Containment Sumps are Present, but were Not Tested <input type="checkbox"/>				
Test Method Developed By:		<input type="checkbox"/> Sump Manufacturer	<input type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
		<input type="checkbox"/> Other (Specify)		
Test Method Used:		<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input type="checkbox"/> Hydrostatic
		<input type="checkbox"/> Other (Specify)		
Test Equipment Used:			Equipment Resolution:	
	Fill Sump #	Fill Sump #	Fill Sump #	Fill Sump #
Sump Diameter:				
Sump Depth:				
Height from Tank Top to Top of Highest Piping Penetration:				
Height from Tank Top to Lowest Electrical Penetration:				
Condition of sump prior to testing:				
Portion of Sump Tested				
Sump Material:				
Wait time between applying pressure/vacuum/water and starting test:				
Test Start Time:				
Initial Reading (R _i):				
Test End Time:				
Final Reading (R _f):				
Test Duration:				
Change in Reading (R _f -R _i):				
Pass/Fail Threshold or Criteria:				
Test Result:	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Is there a sensor in the sump?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Does the sensor alarm when either product or water is detected?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Was sensor removed for testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Was sensor properly replaced and verified functional after testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

N/A NONE INSTALLED

9. SPILL/OVERFILL CONTAINMENT BOXES

Facility is Not Equipped With Spill/Overfill Containment Boxes <input type="checkbox"/>						
Spill/Overfill Containment Boxes are Present, but were Not Tested <input type="checkbox"/>						
Test Method Developed By:		<input type="checkbox"/> Spill Bucket Manufacturer		<input checked="" type="checkbox"/> Industry Standard		<input type="checkbox"/> Professional Engineer
		<input type="checkbox"/> Other (Specify)				
Test Method Used:		<input type="checkbox"/> Pressure		<input type="checkbox"/> Vacuum		<input checked="" type="checkbox"/> Hydrostatic
		<input type="checkbox"/> Other (Specify)				
Test Equipment Used: <u>INCON</u>				Equipment Resolution: <u>0.002</u>		
	Spill Box # <u>87</u>		Spill Box # <u>91</u>		Spill Box # <u>118</u>	
Bucket Diameter:	<u>12 IN</u>		<u>12 IN</u>		<u>12 IN</u>	
Bucket Depth:	<u>16 IN</u>		<u>16 IN</u>		<u>16 IN</u>	
Wait time between applying pressure/vacuum/water and starting test:	<u>30 MIN</u>		<u>30 MIN</u>		<u>30 MIN</u>	
Test Start Time:	<u>11:10 A</u>	<u>11:37 A</u>	<u>12:11 P</u>	<u>12:38 P</u>	<u>11:10 A</u>	<u>11:37 A</u>
Initial Reading (R _i):	<u>7.461</u>	<u>7.460</u>	<u>5.845</u>	<u>5.844</u>	<u>7.013</u>	<u>7.012</u>
Test End Time:	<u>11:25 A</u>	<u>11:52 A</u>	<u>12:26 P</u>	<u>12:53 P</u>	<u>11:25 A</u>	<u>11:52</u>
Final Reading (R _f):	<u>7.460</u>	<u>7.460</u>	<u>5.845</u>	<u>5.845</u>	<u>7.012</u>	<u>7.011</u>
Test Duration:	<u>15 MIN</u>		<u>15 MIN</u>		<u>15 MIN</u>	
Change in Reading (R _f -R _i):	<u>0.001</u>	<u>0.000</u>	<u>0.000</u>	<u>0.001</u>	<u>0.001</u>	<u>0.001</u>
Pass/Fail Threshold or Criteria:	<u>0.002</u>	<u>0.002</u>	<u>0.002</u>	<u>0.002</u>	<u>0.002</u>	<u>0.002</u>
Test Result:	<u>Pass</u>	<u>Pass</u>	<u>Pass</u>	<u>Pass</u>	<u>Pass</u>	<u>Pass</u>

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

30862

JOHNNY QUICK
2126 TAFT HWY
BAKERSFIELD

07/07/2009 11:37 AM

SUMP LEAK TEST REPORT

87 UPR

TEST STARTED 11:10 AM
TEST STARTED 07/07/2009
BEGIN LEVEL 7.4610 IN
END TIME 11:25 AM
END DATE 07/07/2009
END LEVEL 7.4601 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

JOHNNY QUICK
2126 TAFT HWY
BAKERSFIELD

07/07/2009 11:53 AM

SUMP LEAK TEST REPORT

87 UPR

TEST STARTED 11:37 AM
TEST STARTED 07/07/2009
BEGIN LEVEL 7.4600 IN
END TIME 11:52 AM
END DATE 07/07/2009
END LEVEL 7.4600 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

JOHNNY QUICK
2126 TAFT HWY
BAKERSFIELD

07/07/2009 12:26 PM

SUMP LEAK TEST REPORT

91 UPR

TEST STARTED 12:11 PM
TEST STARTED 07/07/2009
BEGIN LEVEL 5.8458 IN
END TIME 12:26 PM
END DATE 07/07/2009
END LEVEL 5.8450 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

JOHNNY QUICK
2126 TAFT HWY
BAKERSFIELD

07/07/2009 12:53 PM

SUMP LEAK TEST REPORT

91 UPR

TEST STARTED 12:38 PM
TEST STARTED 07/07/2009
BEGIN LEVEL 5.8449 IN
END TIME 12:53 PM
END DATE 07/07/2009
END LEVEL 5.8451 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

DSL UPR

TEST STARTED 11:10 AM
TEST STARTED 07/07/2009
BEGIN LEVEL 7.0131 IN
END TIME 11:25 AM
END DATE 07/07/2009
END LEVEL 7.0122 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

DSL UPR

TEST STARTED 11:37 AM
TEST STARTED 07/07/2009
BEGIN LEVEL 7.0121 IN
END TIME 11:52 AM
END DATE 07/07/2009
END LEVEL 7.0118 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

SB989 TESTING FAILURE REPORT

SITE NAME: JOHN W. QUICK

DATE: 7-7-09

ADDRESS: 2126 TAFT HWY

TECHNICIAN: BRANDON MASON

CITY: BAKERSFIELD

SIGNATURE: [Signature]

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS: UDC'S, SECONDARY'S, AND TURBIN SUMPS
WERE NOT TESTED AND FAIL BECAUSE THERE
ARE NO SECONDARY BOOTS TO ISOLATE
THE COMPONENTS TO BE TESTED.

LABOR: NONE

PARTS INTALLED: NONE

NAME: _____

TITLE: _____

SIGNATURE: _____

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENENCE.

23386 50

MONITORING SYSTEM CERTIFICATION

For Use By All Jurisdictions Within the State of California

Authority Cited: Chapter 6.7, Health and Safety Code; Chapter 16, Division 3, Title 23, California Code of Regulations

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

A. General Information

Facility Name: JOHNNY QUICK Bldg. No.: _____
 Site Address: 2126 TAFT HWY. City: BAKERSFIELD Zip: 93313
 Facility Contact Person: MR. KOOL Contact Phone No.: (661) 834-9113
 Make/Model of Monitoring System: TLS-350 Date of Testing/Service: 2/13/2009

MAR 13 2009

ENVIRONMENTAL HEALTH SERVICES

CR-3201

B. Inventory of Equipment Tested/Certified

Check the appropriate boxes to indicate specific equipment inspected/serviced:

Tank ID: REGULAR 87 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: PREMIUM 91 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Tank ID: DIESEL <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input type="checkbox"/> Annular Space or Vault Sensor. Model: _____ <input type="checkbox"/> Piping Sump / Trench Sensor(s). Model: _____ <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Dispenser ID: 1/2 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s) <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 3/4 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s) <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: 5/6 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s) <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 7/8 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s) <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s) <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s) <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply):

System set-up Alarm history report

Technician Name (print): BRANDON MASON Signature: _____
 Certification No.: B34335 License No.: 5284980-UT
 Testing Company Name: RICH ENVIRONMENTAL Phone No.: (661) 392-8687
 Testing Company Address: 5643 BROOKS CT. BAKERSFIELD, CA. 93308 Date of Testing/Service: _____

Monitoring System Certification

D. Results of Testing/Serviceing

Software Version Installed: 18.01

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the audible alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the visual alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors visually inspected, functionally tested, and confirmed operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors installed at lowest point of secondary containment and positioned so that other equipment will not interfere with their proper operation?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	If alarms are relayed to a remote monitoring station, is all communications equipment (e.g., modem) operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected? If yes: which sensors initiate positive shut-down? (Check all that apply) <input checked="" type="checkbox"/> Sump/Trench Sensors; <input type="checkbox"/> Dispenser Containment Sensors. Did you confirm positive shut-down due to leaks and sensor failure/disconnection? <input checked="" type="checkbox"/> Yes; <input type="checkbox"/> No.
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For tank systems that utilize the monitoring system as the primary tank overfill warning device (i.e., no mechanical overfill prevention valve is installed), is the overfill warning alarm visible and audible at the tank fill point(s) and operating properly? If so, at what percent of tank capacity does the alarm trigger? %
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes, or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E, below.
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was liquid found inside any secondary containment systems designed as dry systems? (Check all that apply) <input type="checkbox"/> Product; <input type="checkbox"/> Water. If yes, describe causes in Section E, below.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was monitoring system set-up reviewed to ensure proper settings? Attach set up reports, if applicable
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is all monitoring equipment operational per manufacturer's specifications?

* In Section E below, describe how and when these deficiencies were or will be corrected.

E. Comments:

Monitoring System Certification

F. In-Tank Gauging / SIR Equipment:

- Check this box if tank gauging is used only for inventory control.
- Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all tank gauging probes visually inspected for damage and residue buildup?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system product level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system water level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all probes reinstalled properly?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

G. Line Leak Detectors (LLD):

- Check this box if LLDs are not installed.

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For equipment start-up or annual equipment certification, was a leak simulated to verify LLD performance? (Check all that apply) Simulated leak rate: <input checked="" type="checkbox"/> 3 g.p.h.; <input type="checkbox"/> 0.1 g.p.h.; <input type="checkbox"/> 0.2 g.p.h.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all LLDs confirmed operational and accurate within regulatory requirements?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was the testing apparatus properly calibrated?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

H. Comments:

I. Results of Vacuum/Pressure Monitoring Equipment Testing

This page should be used to document testing and servicing of vacuum and pressure interstitial sensors. A copy of this form must be included with the Monitoring System Certification Form, which must be provided to the tank system owner/operator. The owner/operator must submit a copy of the Monitoring System Certification Form to the local agency regulating UST systems within 30 days of test date.


Manufacturer: N/A		Model:	System Type: <input type="checkbox"/> Pressure; <input type="checkbox"/> Vacuum
Sensor ID			
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
How was interstitial communication verified?			
<input type="checkbox"/> Leak Introduced at Far End of Interstitial Space; ¹ <input type="checkbox"/> Gauge; <input type="checkbox"/> Visual Inspection; <input type="checkbox"/> Other (Describe in Sec. J. below)			
Was vacuum/pressure restored to operating levels in all interstitial spaces? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no, describe in Sec. J. below)			

J. Comments: N/A

¹ If the sensor successfully detects a simulated vacuum/pressure leak introduced in the interstitial space at the furthest point from the sensor, vacuum/pressure has been demonstrated to be communicating throughout the interstice.

UST Monitoring Site Plan

Site Address: 2126 TAFT HWY. BAKERSFIELD, CA. 93313



Date map was drawn: 2/13/2009.

Instructions

If you already have a diagram that shows all required information, you may include it, rather than this page, with your Monitoring System Certification. On your site plan, show the general layout of tanks and piping. Clearly identify locations of the following equipment, if installed: monitoring system control panels; sensors monitoring tank annular spaces, sumps, dispenser pans, spill containers, or other secondary containment areas; mechanical or electronic line leak detectors; and in-tank liquid level probes (if used for leak detection). In the space provided, note the date this Site Plan was prepared.

RICH ENVIRONMENTAL
5643 BROOKS CT. BAKERSFIELD, CA. 93308
OFFICE (661)392-8687 FAX (661)392-0621
PRODUCT LINE LEAK DETECTOR TEST

WORK SHEET

W/O#: _____

FACILITY NAME: JOHNNY QUICK


FACILITY ADDRESS: 2126 TAFT HWY. BAKERSFIELD, CA. 93313

PRODUCT LINE TYPE: PRESSURE

PRODUCT	LEAK DETECTOR TYPE SERIAL NUMBER	TEST BELOW 3 G.P.H.	TRIP P.S.I.	PASS OR FAIL
REGULAR 87	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>MECHANICAL</u>	YES	10 PSI	PASS
PREMIUM 91	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>MECHANICAL</u>	YES	10 PSI	PASS
DIESEL	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>MECHANICAL</u>	YES	10 PSI	PASS
	L/D TYPE : <u> </u> SERIAL # <u> </u>	YES NO		PASS FAIL

I CERTIFY THE ABOVE TESTS WERE CONDUCTED ON THIS DATE ACCORDING TO RED JACKET PUMPS FIELD TEST APPARATUS TESTING PROCEDURE AND LIMITATIONS. THE MECHANICAL LEAK DETECTOR TEST PASS / FAIL IS DETERMINED BY USING A LOW FLOW THRESHOLD TRIP RATE OF 3 GALLONS PER HOUR OR LESS AT 10 P.S.I. I ACKNOWLEDGE THAT ALL DATA COLLECTED IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE.

TECHNICIAN: BRANDON MASON

SIGNATURE: 

DATE: 02/13/09

Spill Bucket Testing Report Form

This form is intended for use by contractors performing annual testing of UST spill containment structures. The completed form and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: JOHNNY QUICK	Date of Testing: 02/13/09
Facility Address: 2126 TAFT HWY, BAKERSFIELD, CA. 93313	
Facility Contact: MR. KOOL	Phone: (661) 834-9113
Date Local Agency Was Notified of Testing: 02/09/09	
Name of Local Agency Inspector (if present during testing):	LAUREL FUNK

2. TESTING CONTRACTOR INFORMATION

Company Name: RICH ENVIRONMENTAL	
Technician Conducting Test: STEVEN OBERT	
Credentials ¹ : CSLB Contractor	X ICC Service Tech. SWRCB Tank Tester Other (Specify) _____
License Number(s): 5261246-UT	


3. SPILL BUCKET TESTING INFORMATION

Test Method Used: X Hydrostatic	Vacuum	Other		
Test Equipment Used: VISUAL		Equipment Resolution: 0.00		
Identify Spill Bucket (By Tank Number, Stored Product, etc.)	1 REGULAR 87-FILL	2 PREMIUM 91-FILL	3 DIESEL	4
Bucket Installation Type:	X Direct Bury Contained in Sump	X Direct Bury Contained in Sump	X Direct Bury Contained in Sump	Direct Bury Contained in Sump
Bucket Diameter:	12"	12"	12"	
Bucket Depth:	12"	12"	12"	
Wait time between applying vacuum/water and start of test:	30 MIN	30 MIN	30 MIN	
Test Start Time (T _i):	0900	0900	0900	
Initial Reading (R _i):	10"	10"	10"	
Test End Time (T _f):	1000	1000	1000	
Final Reading (R _f):	10"	10"	10"	
Test Duration (T _f - T _i):	1-HOUR	1-HOUR	1-HOUR	
Change in Reading (R _f - R _i):	0	0	0	
Pass/Fail Threshold or Criteria:	+/- 0.00	+/- 0.00	+/- 0.00	
Test Result:	X Pass <input type="checkbox"/> Fail	X Pass <input type="checkbox"/> Fail	X Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

I hereby certify that all the information contained in this report is true, accurate, and in full compliance with legal requirements.

Technician's Signature:  Date: 02/13/09

¹ State laws and regulations do not currently require testing to be performed by a qualified contractor. However, local requirements may be more stringent.

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 6:92 OCTANE
STP SUMP
SENSOR OUT ALARM
FEB 13, 2009 10:46 AM

FUEL ALARM
FEB 13, 2009 10:36 AM

SENSOR OUT ALARM
FEB 12, 2008 10:59 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 1:87 OCTANE
ANNULAR SPACE
FUEL ALARM
FEB 13, 2009 10:46 AM

FUEL ALARM
FEB 13, 2009 10:35 AM

FUEL ALARM
FEB 12, 2008 10:59 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 5:89 OCTANE
STP SUMP
SENSOR OUT ALARM
FEB 13, 2009 10:46 AM

FUEL ALARM
FEB 13, 2009 10:34 AM

SENSOR OUT ALARM
FEB 12, 2008 10:59 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 2:89 OCTANE
ANNULAR SPACE
FUEL ALARM
FEB 13, 2009 10:46 AM

FUEL ALARM
FEB 13, 2009 10:35 AM

FUEL ALARM
FEB 12, 2008 10:59 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 4:87 OCTANE
STP SUMP
SENSOR OUT ALARM
FEB 13, 2009 10:46 AM

FUEL ALARM
FEB 13, 2009 10:35 AM

SENSOR OUT ALARM
FEB 12, 2008 10:59 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 3:92 OCTANE
ANNULAR SPACE
FUEL ALARM
FEB 13, 2009 10:46 AM

FUEL ALARM
FEB 13, 2009 10:36 AM

FUEL ALARM
FEB 12, 2008 10:59 AM

OUTPUT RELAY SETUP

23386

R 1:87 POSI-SHUTDOWN
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 1:FUEL ALARM
L 4:FUEL ALARM
L 1:SENSOR OUT ALARM
L 4:SENSOR OUT ALARM

R 2:89 POSI-SHUTDOWN
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 2:FUEL ALARM
L 5:FUEL ALARM
L 2:SENSOR OUT ALARM
L 5:SENSOR OUT ALARM

R 3:92 POSI-SHUTDOWN
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 3:FUEL ALARM
L 6:FUEL ALARM
L 3:SENSOR OUT ALARM
L 6:SENSOR OUT ALARM

LIQUID SENSOR SETUP

L 1:87 OCTANE
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 2:89 OCTANE
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 3:92 OCTANE
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 4:87 OCTANE
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 5:89 OCTANE
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 6:92 OCTANE
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

SYSTEM SETUP

50

FEB 13, 2009 12:40 PM

SYSTEM UNITS
U.S.
SYSTEM LANGUAGE
ENGLISH
SYSTEM DATE/TIME FORM
MON DD YYYY HH:MM:SS x

Johnny Guik #143
2126 Taft Hwy.
Bakersfield Ca. 98313
(805) 834-9113

SHIFT TIME 1 : DISABLE
SHIFT TIME 2 : DISABLE
SHIFT TIME 3 : DISABLE
SHIFT TIME 4 : DISABLE

TANK PERIODIC WARNINGS
DISABLED
TANK ANNUAL WARNINGS
DISABLED
LINE PERIODIC WARNINGS
DISABLED
LINE ANNUAL WARNINGS
DISABLED

PRINT TC VOLUMES
ENABLED

TEMP COMPENSATION
VALUE (DEG F) : 60.0
STICK HEIGHT OFFSET
DISABLED
DAYLIGHT SAVING TIME
ENABLED

START DATE
APR WEEK 1 SUN
START TIME
2:00 AM
END DATE
OCT WEEK 6 SUN
END TIME
2:00 AM

SYSTEM SECURITY
CODE : 000000

COMMUNICATIONS SETUP

PORT SETTINGS:
NONE FOUND

RS-232 SECURITY
CODE : 000000

RS-232 END OF MESSAGE
DISABLED

SOFTWARE REVISION LEVI
VERSION 18.01
SOFTWARE# 346018-100-1
CREATED - 99.07.23.19

NO SOFTWARE MODULE
SYSTEM FEATURES:
PERIODIC IN-TANK TESTS
ANNUAL IN-TANK TESTS

MONITOR CERT. FAILURE REPORT

SITE NAME: JOHNNY QUICK DATE: 02/13/09

ADDRESS: 2126 TAFT HWY. TECHNICIAN: BRANDON MASON

CITY: BAKERSFIELD SIGNATURE: *[Handwritten Signature]*

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS: ~~NONE~~

- CHANGED UNL87 AND PRENG1. MLLD

LABOR: NONE

PARTS INTALLED: ~~NONE~~

2 - RED JACKET MLLD

NAME: TITLE:

SIGNATURE:

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENENCE.

193629

MONITORING SYSTEM CERTIFICATION

For Use By All Jurisdictions Within the State of California

Authority Cited Chapter 6 7, Health and Safety Code; Chapter 16, Division 3, Title 23, California Code of Regulations

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

A. General Information

Facility Name: JOHNNY QUICK Bldg. No.: 3201
 Site Address: 2126 TAFT HWY City: BAKERSFIELD Zip: 93313
 Facility Contact Person: _____ Contact Phone No.: (____) _____
 Make/Model of Monitoring System: GILBARCO EMC Date of Testing/Serviceing: 2/12/08

B. Inventory of Equipment Tested/Certified

INSPECTOR ON-SITE: YES/ NO NAME: _____

Check the appropriate boxes to indicate specific equipment inspected/serviced:

Tank ID: <u>00287</u> <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: <u>PLEM91</u> <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Tank ID: <u>DIESEL</u> <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: _____ <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input type="checkbox"/> Annular Space or Vault Sensor. Model: _____ <input type="checkbox"/> Piping Sump / Trench Sensor(s). Model: _____ <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Dispenser ID: <u>1-2</u> <input type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: <u>3-4</u> <input type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: <u>5-6</u> <input type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: <u>7-8</u> <input type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply):
 System set-up Alarm history report

Technician Name (print): RYAN MASON Signature: [Signature]
 Certification No.: A82367 1167 52101213-01 License No.: 2011040 609850
 Testing Company Name: RICH ENVIRONMENTAL Phone No.: (661) 392-8687
 Site Address: 2126 TAFT HWY BAKERSFIELD, CA Date of Testing/Serviceing: 2/12/08

D. Results of Testing/Serviceing

Software Version Installed: 18.01

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the audible alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the visual alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors visually inspected, functionally tested, and confined operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors installed at lowest point of secondary containment and positioned so that other equipment will not interfere with their proper operation?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	If alarms are relayed to a remote monitoring station, is all communications equipment (e.g. modem) operational?
	<input checked="" type="checkbox"/> N/A	
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected? If yes: which sensors initiate positive shut-down? (Check all that apply) <input checked="" type="checkbox"/> Sump/Trench Sensors; <input type="checkbox"/> Dispenser Containment Sensors. Did you confirm positive shut-down due to leaks and sensor failure/disconnection? <input checked="" type="checkbox"/> Yes; <input type="checkbox"/> No.
	<input type="checkbox"/> N/A	
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	For tank systems that utilize the monitoring system as the primary tank overfill warning device (i.e. no mechanical overfill prevention valve is installed), is the overfill warning alarm visible and audible at the tank fill point(s) and operating properly? If so, at what percent of tank capacity does the alarm trigger? %
	<input checked="" type="checkbox"/> N/A	
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes, or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E, below.
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was liquid found inside any secondary containment systems designed as dry systems? (Check all that apply) <input type="checkbox"/> Product; <input type="checkbox"/> Water. If yes, describe causes in Section E, below.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was monitoring system set-up reviewed to ensure proper settings? Attach set up reports, if applicable
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is all monitoring equipment operational per manufacturer's specifications?

* In Section E below, describe how and when these deficiencies were or will be corrected.

E. Comments: _____

F. In-Tank Gauging / SIR Equipment:

- Check this box if tank gauging is used only for inventory control.
 Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all tank gauging probes visually inspected for damage and residue buildup?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system product level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system water level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all probes reinstalled properly?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In the Section H, below, describe how and when these deficiencies were or will be corrected.

G. Line Leak Detectors (LLD):

- Check this box if LLDs are not installed.

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For equipment start-up or annual equipment certification, was a leak simulated to verify LLD performance? (Check all that apply) Simulated leak rate: <input checked="" type="checkbox"/> 3 g.p.h., <input type="checkbox"/> 0.1 g.p.h., <input type="checkbox"/> 0.2 g.p.h.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all LLDs confirmed operational and accurate within regulatory requirements?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	Was the testing apparatus properly calibrated?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In the Section H, below, describe how and when these deficiencies were or will be corrected.

H. Comments:

19362

I. Results of Vacuum/Pressure Monitoring Equipment Testing

This page should be used to document testing and servicing of vacuum and pressure interstitial sensors. A copy of this form must be included with the Monitoring System Certification Form, which must be provided to the tank system owner/operator. The owner/operator must submit a copy of the Monitoring System Certification Form to the local agency regulating UST systems within 30 days of test date.

Manufacturer:		Model:	System Type: <input checked="" type="checkbox"/> Pressure; <input type="checkbox"/> Vacuum
Sensor ID			
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
How was interstitial communication verified?			
<input type="checkbox"/> Leak Introduced at Far End of Interstitial Space; <input type="checkbox"/> Gauge; <input type="checkbox"/> Visual Inspection; <input type="checkbox"/> Other (Describe in Sec. J, below)			
Vacuum was restored to operating levels in all interstitial spaces: <input type="checkbox"/> Yes <input type="checkbox"/> No (If no, describe in Sec. J, below)			


J. Comments:

¹ If the sensor successfully detects a simulated vacuum/pressure leak introduced in the interstitial space at the furthest point from the sensor, vacuum/pressure has been demonstrated to be communicating throughout the interstice.

Monitoring System Certification

UST Monitoring Site Plan

Site Address: 2126 TAPP HWY BAKERSFIELD, CA 93313



Date map was drawn: 2/12/08

Instructions

If you already have a diagram that shows all required information, you may include it, rather than this page, with your Monitoring System Certification. On your site plan, show the general layout of tanks and piping. Clearly identify locations of the following equipment, if installed: monitoring system control panels; sensors monitoring tank annular spaces, sumps, dispenser pans, spill containers, or other secondary containment areas; mechanical or electronic line leak detectors; and in-tank liquid level probes (if used for leak detection). In the space provided, note the date this Site Plan was prepared.

19362

RICH ENVIRONMENTAL

5643 BROOKS CT BAKERSFIELD, CA. 93308
OFFICE (661) 392-8687 & FAX (661) 392-0621
MECHANICAL LEAK DETECTOR TEST

WORK SHEET

W/O#: _____

Facility Name: JOHNNY QUICK

Facility Address: 2126 TRT HWY BAKERSFIELD CA

Product Line Type (Pressure, Suction, Gravity) PRESSURE

PRODUCT	LEAK DETECTOR TYPE SERIAL NUMBER	TEST BELOW 3 GPH	TRIP PSI	PASS OR FAIL
<u>WUL87</u>	L/D TYPE <u>MECHANICAL</u> SERIAL # _____	<input checked="" type="radio"/> YES <input type="radio"/> NO	<u>10</u>	<input checked="" type="radio"/> PASS <input type="radio"/> FAIL
<u>PREM91</u>	L/D TYPE <u>MECHANICAL</u> SERIAL # _____	<input checked="" type="radio"/> YES <input type="radio"/> NO	<u>7</u>	<input checked="" type="radio"/> PASS <input type="radio"/> FAIL
<u>DIESEL</u>	L/D TYPE <u>MECHANICAL</u> SERIAL # _____	<input checked="" type="radio"/> YES <input type="radio"/> NO	<u>9</u>	<input checked="" type="radio"/> PASS <input type="radio"/> FAIL
	L/D TYPE _____ SERIAL # _____	YES NO		PASS FAIL

I certify the above tests were conducted on this date according to Rad Jacket Pumps field test apparatus testing procedure and limitations.

The Mechanical Leak Detector Test pass / fail is determined by using a low flow threshold trip rate of 3 gallon per hour or less at 10 PSI.

I acknowledge that all data collected is true and correct to the best of my knowledge.

Tech: RYAN MASON

Signature: [Signature]

Date: 2-12-08

19302

SWRCB, January 2006

Spill Bucket Testing Report Form

This form is intended for use by contractors performing annual testing of UST spill containment structures. The completed form and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: <u>JOHNNY QUICK</u>	Date of Testing: <u>2-12-08</u>
Facility Address: <u>2120 MFT HWY BAKERSFIELD, CA</u>	
Facility Contact:	Phone:
Date Local Agency Was Notified of Testing:	
Name of Local Agency Inspector (if present during testing):	

2. TESTING CONTRACTOR INFORMATION

Company Name: <u>RICH ENVIRONMENTAL</u>			
Technician Conducting Test: <u>KYAN MYSON</u>			
Credentials:	<input checked="" type="checkbox"/> CSLB Contractor	<input checked="" type="checkbox"/> ICC Service Tech.	<input type="checkbox"/> SWRCB Tank Tester
Other (Specify):			
License Number(s): <u>5011213-U1</u>			


3. SPILL BUCKET TESTING INFORMATION

Test Method Used:	<input checked="" type="radio"/> Hydrostatic	<input type="radio"/> Vacuum	<input type="radio"/> Other
Test Equipment Used: <u>VISUAL</u>	Equipment Resolution:		
Identify Spill Bucket (By Tank Number, Stored Product, etc.)	1 <u>UUL87</u>	2 <u>PREM91</u>	3 <u>DIESEL</u>
Bucket Installation Type:	<input checked="" type="radio"/> Direct Bury Contained in Sump	<input checked="" type="radio"/> Direct Bury Contained in Sump	<input checked="" type="radio"/> Direct Bury Contained in Sump
Bucket Diameter:	<u>12"v</u>	<u>12"v</u>	<u>12"v</u>
Bucket Depth:	<u>14"v</u>	<u>11"v</u>	<u>14"v</u>
Wait time between applying vacuum/water and start of test:	<u>30 min</u>	<u>30 min</u>	<u>30 min</u>
Test Start Time (T _i):	<u>9:00am</u>	<u>9:00am</u>	<u>9:00am</u>
Initial Reading (R _i):	<u>10"v</u>	<u>10"v</u>	<u>10"v</u>
Test End Time (T _f):	<u>10:00am</u>	<u>10:00am</u>	<u>10:00am</u>
Final Reading (R _f):	<u>10"v</u>	<u>10"v</u>	<u>10"v</u>
Test Duration (T _f - T _i):	<u>1h00min</u>	<u>1h00min</u>	<u>1h00min</u>
Change in Reading (R _f - R _i):	<u>0"v</u>	<u>0"v</u>	<u>0"v</u>
Pass/Fail Threshold or Criteria:	<u>0"v</u>	<u>0"v</u>	<u>0"v</u>
Test Result:	<u>PASS</u>	<u>PASS</u>	<u>PASS</u>

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

I hereby certify that all the information contained in this report is true, accurate, and in full compliance with legal requirements.

Technician's Signature: 

Date: 2-12-08

¹ State laws and regulations do not currently require testing to be performed by a qualified contractor. However, local requirements may be more stringent.

SOFTWARE REVISION LEVEL
VERSION 18.01
SOFTWARE# 346018-100-B
CREATED - 99.07.23.19.14

NO SOFTWARE MODULE
SYSTEM FEATURES:
PERIODIC IN-TANK TESTS
ANNUAL IN-TANK TESTS

COMMUNICATIONS SETUP

PORT SETTINGS:

NONE FOUND

RS-232 SECURITY
CODE : 000000

RS-232 END OF MESSAGE
DISABLED

OUTPUT RELAY SETUP

R 1:87 POSI-SHUTDOWN
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 1:FUEL ALARM
L 4:FUEL ALARM
L 1:SENSOR OUT ALARM
L 4:SENSOR OUT ALARM

R 2:89 POSI-SHUTDOWN
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 2:FUEL ALARM
L 5:FUEL ALARM
L 2:SENSOR OUT ALARM
L 5:SENSOR OUT ALARM

R 3:92 POSI-SHUTDOWN
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 3:FUEL ALARM
L 6:FUEL ALARM
L 3:SENSOR OUT ALARM
L 6:SENSOR OUT ALARM

SYSTEM SETUP

FEB 12, 2008 11:36 AM

SYSTEM UNITS

U.S.
SYSTEM LANGUAGE
ENGLISH
SYSTEM DATE/TIME FORMAT
MON DD YYYY HH:MM:SS xm

Johnny Quik #143
2126 Taft Hwy.
Bakersfield Ca.93313
(805) 834-9113

SHIFT TIME 1 : DISABLED
SHIFT TIME 2 : DISABLED
SHIFT TIME 3 : DISABLED
SHIFT TIME 4 : DISABLED

TANK PERIODIC WARNINGS
DISABLED
TANK ANNUAL WARNINGS
DISABLED
LINE PERIODIC WARNINGS
DISABLED
LINE ANNUAL WARNINGS
DISABLED

PRINT TO VOLUMES
ENABLED

TEMP COMPENSATION
VALUE (DEG F) : 60.0
STICK HEIGHT OFFSET
DISABLED
DAYLIGHT SAVING TIME
ENABLED
START DATE
APR WEEK 1 SUN
START TIME
2:00 AM
END DATE
OCT WEEK 6 SUN
END TIME
2:00 AM

SYSTEM SECURITY
CODE : 000000

LIQUID SENSOR SETUP

L 1:87 OCTANE
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 2:89 OCTANE
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 3:92 OCTANE
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 4:87 OCTANE
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 5:89 OCTANE
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 6:92 OCTANE
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

ALARM HISTORY REPORT

----- SYSTEM ALARM -----
PAPER OUT
NOV 7, 2006 2:38 PM
PRINTER ERROR
NOV 7, 2006 2:38 PM
BATTERY IS OFF
JAN 1, 1996 8:00 AM

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 1:87 OCTANE
ANNULAR SPACE
FUEL ALARM
FEB 12, 2008 10:59 AM

FUEL ALARM
FEB 12, 2008 10:21 AM

FUEL ALARM
FEB 1, 2007 10:21 AM

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 3:92 OCTANE
ANNULAR SPACE
FUEL ALARM
FEB 12, 2008 10:59 AM

FUEL ALARM
FEB 12, 2008 10:20 AM

FUEL ALARM
FEB 1, 2007 10:28 AM

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 5:89 OCTANE
STP SUMP
SENSOR OUT ALARM
FEB 12, 2008 10:59 AM

FUEL ALARM
FEB 12, 2008 10:19 AM

FUEL ALARM
FEB 1, 2007 10:47 AM

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 2:89 OCTANE
ANNULAR SPACE
FUEL ALARM
FEB 12, 2008 10:59 AM

FUEL ALARM
FEB 12, 2008 10:21 AM

FUEL ALARM
FEB 1, 2007 10:22 AM

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 4:87 OCTANE
STP SUMP
SENSOR OUT ALARM
FEB 12, 2008 10:59 AM

FUEL ALARM
FEB 12, 2008 10:17 AM

FUEL ALARM
FEB 1, 2007 10:48 AM

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 6:92 OCTANE
STP SUMP
SENSOR OUT ALARM
FEB 12, 2008 10:59 AM

FUEL ALARM
FEB 12, 2008 10:20 AM

FUEL ALARM
FEB 1, 2007 10:50 AM

***** END *****

19362

MONITOR CERT. FAILURE REPORT

SITE NAME: JOHNNY QUICK DATE: 2-12-08

ADDRESS: 2126 TAFT HWY TECHNICIAN: RYAN MASON

CITY: BAKERSFIELD SIGNATURE: [Signature]

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS:

NONE

LABOR:

NONE

PARTS INSTALLED:

NONE

NAME: _____ TITLE: _____

SIGNATURE: _____

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENENCE.

15498

MONITORING SYSTEM CERTIFICATION

For Use By All Jurisdictions Within the State of California

Authority Cited Chapter 6 7, Health and Safety Code; Chapter 16, Division 3, Title 23, California Code of Regulations

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

FEB 26 2007

3201

A. General Information

Facility Name: JOHNNY QUICK Bldg. No.: _____

Site Address: 2126 TAFT HWY. City: BAKERSFIELD Zip: _____

Facility Contact Person: _____ Contact Phone No.: (____) _____

Make/Model of Monitoring System: GILBARCO EMC Date of Testing/Servicing: 2/1/07

RICH ENVIRONMENTAL HEALTH SERVICES

B. Inventory of Equipment Tested/Certified

Check the appropriate boxes to indicate specific equipment inspected/serviced: INSPECTOR ON-SITE: YES NAME: NONE

<p>Tank ID: <u>UM 87</u></p> <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	<p>Tank ID: <u>PREM 91</u></p> <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
<p>Tank ID: <u>DIESEL</u></p> <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	<p>Tank ID: _____</p> <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input type="checkbox"/> Annular Space or Vault Sensor. Model: _____ <input type="checkbox"/> Piping Sump / Trench Sensor(s). Model: _____ <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
<p>Dispenser ID: <u>1,2</u></p> <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>BEAUDREAU</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	<p>Dispenser ID: <u>3,4</u></p> <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>BEAUDREAU</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
<p>Dispenser ID: <u>5,6</u></p> <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>BEAUDREAU</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	<p>Dispenser ID: <u>7,8</u></p> <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>BEAUDREAU</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
<p>Dispenser ID: _____</p> <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	<p>Dispenser ID: _____</p> <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply):

System set-up Alarm history report

Technician Name (print): BRANDON MASON Signature: _____

Certification No.: B34335 License No.: 5284980-UT

Testing Company Name: RICH ENVIRONMENTAL Phone No.: (661) 392-8687

Site Address: 2126 TAFT HWY, BAKERSFIELD, CA Date of Testing/Servicing: 2/1/07

D. Results of Testing/Servicing

Software Version Installed: 18.01

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the audible alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the visual alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors visually inspected, functionally tested, and confirmed operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors installed at lowest point of secondary containment and positioned so that other equipment will not interfere with their proper operation?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	If alarms are relayed to a remote monitoring station, is all communications equipment (e.g. modem) operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected? If yes: which sensors initiate positive shut-down? (Check all that apply) <input checked="" type="checkbox"/> Sump/Trench Sensors; <input type="checkbox"/> Dispenser Containment Sensors. Did you confirm positive shut-down due to leaks and sensor failure/disconnection? <input checked="" type="checkbox"/> Yes; <input type="checkbox"/> No.
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For tank systems that utilize the monitoring system as the primary tank overflow warning device (i.e. no mechanical overflow prevention valve is installed), is the overflow warning alarm visible and audible at the tank fill point(s) and operating properly? If so, at what percent of tank capacity does the alarm trigger? %
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes, or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E, below.
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was liquid found inside any secondary containment systems designed as dry systems? (Check all that apply) <input type="checkbox"/> Product; <input type="checkbox"/> Water. If yes, describe causes in Section E, below.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was monitoring system set-up reviewed to ensure proper settings? Attach set up reports, if applicable
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is all monitoring equipment operational per manufacturer's specifications?

* In Section E below, describe how and when these deficiencies were or will be corrected.

E. Comments:

F. In-Tank Gauging / SIR Equipment:

- Check this box if tank gauging is used only for inventory control.
- Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all tank gauging probes visually inspected for damage and residue buildup?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system product level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system water level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all probes reinstalled properly?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In the Section H, below, describe how and when these deficiencies were or will be corrected.

G. Line Leak Detectors (LLD):

- Check this box if LLDs are not installed.

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For equipment start-up or annual equipment certification, was a leak simulated to verify LLD performance? (Check all that apply) Simulated leak rate: <input checked="" type="checkbox"/> 3 g.p.h., <input type="checkbox"/> 0.1 g.p.h., <input type="checkbox"/> 0.2 g.p.h.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all LLDs confirmed operational and accurate within regulatory requirements?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was the testing apparatus properly calibrated?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?


* In the Section H, below, describe how and when these deficiencies were or will be corrected.

H. Comments:

Monitoring System Certification

UST Monitoring Site Plan

Site Address: 2126 TAFT HWY, BAKERSFIELD, CA



Date map was drawn: 2/1/07

Instructions

If you already have a diagram that shows all required information, you may include it, rather than this page, with your Monitoring System Certification. On your site plan, show the general layout of tanks and piping. Clearly identify locations of the following equipment, if installed: monitoring system control panels; sensors monitoring tank annular spaces, sumps, dispenser pans, spill containers, or other secondary containment areas; mechanical or electronic line leak detectors; and in-tank liquid level probes (if used for leak detection). In the space provided, note the date this Site Plan was prepared.

15498

13

RICH ENVIRONMENTAL

5643 BROOKS CT. BAKERSFIELD, CA. 93308
OFFICE (661) 392-8687 & FAX (661) 392-0621
MECHANICAL LEAK DETECTOR TEST

WORK SHEET

W/O#: _____

Facility Name: JOHNNY QUICK

Facility Address: 2126 TAFT HWY, BAKERSFIELD, CA

Product Line Type (Pressure, Suction, Gravity) PRESSURE

PRODUCT	LEAK DETECTOR TYPE SERIAL NUMBER	TEST BELOW 3 GPH	TRIP PSI	PASS OR FAIL
87	L/D TYPE <u>RED JACKET</u> SERIAL # <u>MECHANICAL</u>	<u>YES</u> NO	12	<u>PASS</u> FAIL
91	L/D TYPE <u>RED JACKET</u> SERIAL # <u>MECHANICAL</u>	<u>YES</u> NO	12	<u>PASS</u> FAIL
DIESEL	L/D TYPE <u>RED JACKET</u> SERIAL # <u>MECHANICAL</u>	<u>YES</u> NO	12	<u>PASS</u> FAIL
	L/D TYPE _____ SERIAL # _____	YES NO		PASS FAIL

I certify the above tests were conducted on this date according to Red Jacket Pumps field test apparatus testing procedure and limitations. The Mechanical Leak Detector Test pass / fail is determined by using a low flow threshold trip rate of 3 gallon per hour or less at 10 PSI. I acknowledge that all data collected is true and correct to the best of my knowledge.

Tech: BRANDON MASON

Signature: _____

Date: 7-1-07

15498

SWRCB, January 2006

Spill Bucket Testing Report Form

This form is intended for use by contractors performing annual testing of UST spill containment structures. The completed form and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: <u>JOHNNY QUICK</u>	Date of Testing: <u>2-1-07</u>
Facility Address: <u>2126 TAFT HWY, BAKERSFIELD, CA</u>	
Facility Contact:	Phone:
Date Local Agency Was Notified of Testing: <u>1-25-07</u>	
Name of Local Agency Inspector (if present during testing): <u>NONE</u>	

2. TESTING CONTRACTOR INFORMATION

Company Name: <u>FISH ENVIRONMENTAL</u>
Technician Conducting Test: <u>BRANDON MASON</u>
Credentials: <input type="checkbox"/> CSLB Contractor <input checked="" type="checkbox"/> ICC Service Tech <input type="checkbox"/> SWRCB Tank Tester <input type="checkbox"/> Other (Specify)
License Number(s): <u>5284920-UT</u>

3. SPILL BUCKET TESTING INFORMATION

Test Method Used:	<input checked="" type="checkbox"/> Hydrostatic	<input type="checkbox"/> Vacuum	<input type="checkbox"/> Other	
Test Equipment Used:	<u>VISUAL</u>		Equipment Resolution:	
Identify Spill Bucket (By Tank Number, Stored Product, etc.)	1 <u>87</u>	2 <u>91</u>	3 <u>DIESEL</u>	4
Bucket Installation Type:	<input checked="" type="checkbox"/> Direct Bury Contained in Sump	<input checked="" type="checkbox"/> Direct Bury Contained in Sump	<input checked="" type="checkbox"/> Direct Bury Contained in Sump	Direct Bury Contained in Sump
Bucket Diameter:	<u>12"</u>	<u>12"</u>	<u>12"</u>	
Bucket Depth:	<u>12"</u>	<u>12"</u>	<u>12"</u>	
Wait time between applying vacuum/water and start of test:	<u>30 MIN</u>	<u>30 MIN</u>	<u>30 MIN</u>	
Test Start Time (T _D):	<u>9:30 AM</u>	<u>9:30 AM</u>	<u>9:30 AM</u>	
Initial Reading (R _D):	<u>9 1/2"</u>	<u>9"</u>	<u>9"</u>	
Test End Time (T _F):	<u>10:30 AM</u>	<u>10:30 AM</u>	<u>10:30 AM</u>	
Final Reading (R _F):	<u>9 1/2"</u>	<u>9"</u>	<u>9"</u>	
Test Duration (T _F - T _D):	<u>1 HR</u>	<u>1 HR</u>	<u>1 HR</u>	
Change in Reading (R _F - R _D):	<u>0"</u>	<u>0"</u>	<u>0"</u>	
Pass/Fail Threshold or Criteria:	<u>0"</u>	<u>0"</u>	<u>0"</u>	

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

I hereby certify that all the information contained in this report is true, accurate, and in full compliance with legal requirements.

Technician's Signature: [Signature]

Date: 2-1-07

¹ State laws and regulations do not currently require testing to be performed by a qualified contractor. However, local requirements may be more stringent.

15498

COMMUNICATIONS SETUP

PORT SETTINGS:

NONE FOUND

RS-232 SECURITY
CODE : 000000

RS-232 END OF MESSAGE
DISABLED

OUTPUT RELAY SETUP

R 1:87 POSI-SHUTDOWN
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 1:FUEL ALARM
L 4:FUEL ALARM

R 2:89 POSI-SHUTDOWN
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 2:FUEL ALARM
L 5:FUEL ALARM

R 3:92 POSI-SHUTDOWN
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 3:FUEL ALARM
L 6:FUEL ALARM

SOFTWARE REVISION LEVEL
VERSION 18.01
SOFTWARE# 346018-100-B
CREATED - 99.07.23.19.14

NO SOFTWARE MODULE
SYSTEM FEATURES:
PERIODIC IN-TANK TESTS
ANNUAL IN-TANK TESTS

SYSTEM SETUP

FEB 1, 2007 5:46 PM

SYSTEM UNITS

U.S.
SYSTEM LANGUAGE
ENGLISH
SYSTEM DATE/TIME FORMAT
MON DD YYYY HH:MM:SS XM

Johnny Quik #143
2126 Taft Hwy.
Bakersfield Ca. 93313
(805) 834-9113

SHIFT TIME 1 : DISABLED
SHIFT TIME 2 : DISABLED
SHIFT TIME 3 : DISABLED
SHIFT TIME 4 : DISABLED

TANK PERIODIC WARNINGS
DISABLED
TANK ANNUAL WARNINGS
DISABLED
LINE PERIODIC WARNINGS
DISABLED
LINE ANNUAL WARNINGS
DISABLED

PRINT TC VOLUMES
ENABLED

TEMP COMPENSATION
VALUE (DEG F) : 60.0
STICK HEIGHT OFFSET
DISABLED
DAYLIGHT SAVING TIME
ENABLED
START DATE
APR WEEK 1 SUN
START TIME
2:00 AM
END DATE
OCT WEEK 6 SUN
END TIME
2:00 AM

SYSTEM SECURITY
CODE : 000000

LIQUID SENSOR SETUP

L 1:87 OCTANE
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 2:89 OCTANE
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 3:92 OCTANE
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 4:87 OCTANE
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 5:89 OCTANE
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 6:92 OCTANE
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 1:87 OCTANE
ANNULAR SPACE
FUEL ALARM
FEB 1, 2007 10:21 AM
FUEL ALARM
FEB 1, 2006 10:01 AM
FUEL ALARM
JAN 27, 2005 3:02 PM

15498

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 2:89 OCTANE
ANNULAR SPACE
FUEL ALARM
FEB 1, 2007 10:22 AM

FUEL ALARM
FEB 1, 2006 10:01 AM

FUEL ALARM
JAN 27, 2005 3:00 PM

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 5:89 OCTANE
STP SUMP
FUEL ALARM
FEB 1, 2007 10:47 AM

FUEL ALARM
FEB 1, 2007 10:29 AM

FUEL ALARM
JUN 4, 2006 12:53 PM

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 3:92 OCTANE
ANNULAR SPACE
FUEL ALARM
FEB 1, 2007 10:28 AM

FUEL ALARM
JUL 13, 2006 10:01 AM

FUEL ALARM
FEB 1, 2006 10:30 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 4:87 OCTANE
STP SUMP
FUEL ALARM
FEB 1, 2007 10:48 AM

FUEL ALARM
FEB 1, 2006 10:00 AM

FUEL ALARM
JAN 27, 2005 2:53 PM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 6:92 OCTANE
STP SUMP
FUEL ALARM
FEB 1, 2007 10:50 AM

FUEL ALARM
FEB 1, 2007 10:42 AM

FUEL ALARM
JUN 4, 2006 2:15 PM

15498

MONITOR CERT. FAILURE REPORT

SITE NAME: JOHNNY QUICK DATE: 2-1-07

ADDRESS: 2126 TAFT HWY TECHNICIAN: BRANDON MASON

CITY: BAKERSFIELD SIGNATURE: [Signature]

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS: NONE

LABOR: NONE

PARTS INTALLED: NONE

NAME: _____ TITLE: _____

SIGNATURE:
THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENENCE.

RECEIVED

13594

JUL 19 2006

SWRCB, January 2002

Page 1 of 9

Secondary Containment Testing Report Form

KERN COUNTY

This form is intended for use by contractors performing maintenance on secondary containment systems. Use the appropriate pages of this form to report results for all components tested. The completed form, written test procedures, and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

3201

1. FACILITY INFORMATION

Facility Name: <u>Johnny Quik</u>	Date of Testing: <u>7-13-06</u>
Facility Address: <u>2126 Taft Hwy</u>	<u>Bakersfield</u>
Facility Contact:	Phone:
Date Local Agency Was Notified of Testing:	
Name of Local Agency Inspector (if present during testing):	

2. TESTING CONTRACTOR INFORMATION

Company Name: <u>RICH ENVIRONMENTAL</u>		
Technician Conducting Test: <u>JAMES J RICH 1064166-UT</u>		
Credentials: <input checked="" type="checkbox"/> CSLB Licensed Contractor	<input type="checkbox"/> SWRCB Licensed Tank Tester	
License Type: <u>C611D40</u>	License Number: <u>809850</u>	
Manufacturer Training		
Manufacturer	Component(s)	Date Training Expires
<u>INCON</u>	<u>INCON TS-ST5</u>	

3. SUMMARY OF TEST RESULTS

Component	Pass	Fail	Not Tested	Repairs Made	Component	Pass	Fail	Not Tested	Repairs Made
<u>Unl 87 Annular</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>UDC 7-8</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>Prem 91 Annular</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>Unl 87 Fill Sump</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<u>DSL Annular</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>Prem 91 Fill Sump</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<u>Unl 87 Sec. p. pe</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>DSL Fill Sump</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<u>Prem 91 Sec. p. pe</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>Unl 87 Spill Box</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>DSL Sec. p. pe</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>Unl 87 Vapor Spill Box</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>Unl 87 p. piping sump</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>Prem 91 Spill Box</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>Prem 91 p. piping sump</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>Prem 91 Vapor Spill Box</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>DSL p. piping sump</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>DSL Spill Box</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>UDC 1-2</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>UDC 3-4</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>UDC 5-6</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

If hydrostatic testing was performed, describe what was done with the water after completion of tests:

RECYCLE AND REUSED

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

To the best of my knowledge, the facts stated in this document are accurate and in full compliance with legal requirements

Technician's Signature:

James J Rich 1064166UT

Date: 7-13-06

4. TANK ANNULAR TESTING

Test Method Developed By:	<input type="checkbox"/> Tank Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer	
	<input type="checkbox"/> Other (Specify)			
Test Method Used:	<input type="checkbox"/> Pressure	<input checked="" type="checkbox"/> Vacuum	<input type="checkbox"/> Hydrostatic	
	<input type="checkbox"/> Other (Specify)			
Test Equipment Used:	4 in. DIAL GAUGE		Equipment Resolution: .5%	
	Tank # 87	Tank # 91	Tank # DSL	Tank #
Is Tank Exempt From Testing? ¹	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Tank Capacity:	Unknown	Unknown	Unknown	
Tank Material:	steel	steel	steel	
Tank Manufacturer:	Unknown	Unknown	Unknown	
Product Stored:	Unl 87	Prem 91	Diesel	
Wait time between applying pressure/vacuum/water and starting test:	30 min	30 min	30 min	
Test Start Time:	9:30am	10:00am	10:25am	
Initial Reading (R _i):	10hg	10hg	10hg	
Test End Time:	10:30am	11:00am	11:25am	
Final Reading (R _f):	10hg	10hg	10hg	
Test Duration:	1 hour	1 hour	1 hour	
Change in Reading (R _f -R _i):	0hg	0hg	0hg	
Pass/Fail Threshold or Criteria:	0	0	0	
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ Secondary containment systems where the continuous monitoring automatically monitors both the primary and secondary containment, such as systems that are hydrostatically monitored or under constant vacuum, are exempt from periodic containment testing. (California Code of Regulations, Title 23, Section 2637(a)(6))

5. SECONDARY PIPE TESTING

Test Method Developed By:		<input type="checkbox"/> Piping Manufacturer	<input checked="checked" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
		<input type="checkbox"/> Other (Specify)		
Test Method Used:		<input checked="checked" type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="checked" type="checkbox"/> Hydrostatic
		<input type="checkbox"/> Other (Specify)		
Test Equipment Used: 4 in. DIAL GAUGE			Equipment Resolution: .5%	
	Piping Run # 8)	Piplog Run # 9)	Piping Run # DL	Piping Run #
Piping Material:	Fiberglass	Fiberglass	Fiberglass	
Piping Manufacturer:	Unknown	Unknown	Unknown	
Piping Diameter:	2"	2"	2"	
Length of Piping Run:	100ft	100ft	100ft	
Product Stored:	Unl 8)	Prem 9)	Diesel	
Method and location of piping-run isolation:	Boat in Sump	Boat in Sump	Boat in Sump	
Wait time between applying pressure/vacuum/water and starting test:	30 min	30 min	30 min	
Test Start Time:	2:31pm 2:53pm	2:31pm 2:53pm	3:12pm 3:29pm	
Initial Reading (R _i):	2.432in 2.432in	2.542in 2.541in	3.384in 3.383in	
Test End Time:	2:46pm 3:08pm	2:46pm 3:08pm	3:27pm 3:44pm	
Final Reading (R _f):	2.432in 2.432in	2.541in 2.541in	3.383in 3.383in	
Test Duration:	15min 15min	15min 15min	15min 15min	
Change in Reading (R _f -R _i):	.000in .000in	.001in .000in	.001in .000in	
Pass/Fail Threshold or Criteria:	.002in	.002in	.002in	
Test Result:	<input checked="checked" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="checked" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="checked" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Comments - (Include information on repairs made prior to testing, and recommended follow-up for failed tests)

- Performed a hydrostatic lake test on secondary piping -

6. PIPING SUMP TESTING

Test Method Developed By:	<input type="checkbox"/> Sump Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer	
	<input type="checkbox"/> Other (Specify)			
Test Method Used:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic	
	<input type="checkbox"/> Other (Specify)			
Test Equipment Used: INCON TS-ST5			Equipment Resolution: .000in.	
	Sump # 87	Sump # 91	Sump # DSL	Sump #
Sump Diameter:	36"	36"	36"	
Sump Depth:				
Sump Material:	Plastic	Plastic	Plastic	
Height from Tank Top to Top of Highest Piping Penetration:	6'	7'	6'	
Height from Tank Top to Lowest Electrical Penetration:	10"	17"	17"	
Condition of sump prior to testing:	Clean	Clean	Clean	
Portion of Sump Tested ¹	Bottom half	Bottom half	Bottom half	
Does turbine shut down when sump sensor detects liquid (both product and water)?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Turbine shutdown response time	Unknown	Unknown	Unknown	
Is system programmed for fail-safe shutdown?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was fail-safe verified to be operational?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Wait time between applying pressure/vacuum/water and starting test:	30 min	30 min	30 min	
Test Start Time:	1:31pm 1:48pm	1:31pm 1:48pm	12:51pm 1:07pm	
Initial Reading (R _i):	1.927in 3.141in	3.508in 3.511in	3.097in 3.096in	
Test End Time:	1:46pm 2:03pm	1:46pm 2:03pm	1:06pm 1:22pm	
Final Reading (R _f):	1.926in 3.141in	3.509in 3.512in	3.096in 3.096in	
Test Duration:	15min 15min	15min 15min	15min 15min	
Change in Reading (R _f -R _i):	.001in .000in	.001in .000in	.001in .000in	
Pass/Fail Threshold or Criteria:	.002in .002in	.002in .002in	.002in .002in	
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ If the entire depth of the sump is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire sump must be tested. (See SWRCB LG-160)

7. UNDER-DISPENSER CONTAINMENT (UDC) TESTING

Test Method Developed By:	<input type="checkbox"/> UDC Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
	<input type="checkbox"/> Other (Specify)		
Test Method Used:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic
	<input type="checkbox"/> Other (Specify)		
Test Equipment Used:	INCON TS-ST5		Equipment Resolution: .000in.
	UDC# 1-2	UDC# 3-4	UDC# 5-6
UDC Manufacturer:	Unknown	Unknown	Unknown
UDC Material:	Fiberglass	Fiberglass	Fiberglass
UDC Depth:	30"	30"	30"
Height from UDC Bottom to Top of Highest Piping Penetration:	5'	5'	5'
Height from UDC Bottom to Lowest Electrical Penetration:	13'	12'	13'
Condition of UDC prior to testing:	clean	clean	clean
Portion of UDC Tested ¹	Bottom half	Bottom half	Bottom half
Does turbine shut down when UDC sensor detects liquid (both product and water)?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Turbine shutdown response time	Unknown	Unknown	Unknown
Is system programmed for fail-safe shutdown?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Was fail-safe verified to be operational?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Wait time between applying pressure/vacuum/water and starting test	30 min	30 min	30 min
Test Start Time:	2:31pm	2:53pm	3:12pm
Initial Reading (R _i):	3.479in	2.344in	5.334in
Test End Time:	2:46pm	3:08pm	3:27pm
Final Reading (R _f):	3.479in	2.345in	5.333in
Test Duration:	15min	15min	15min
Change in Reading (R _f -R _i):	.000in	.001in	.000in
Pass/Fail Threshold or Criteria:	.002in	.002in	.002in
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ If the entire depth of the UDC is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire UDC must be tested. (See SWRCB LG-160)

8. FILL RISER CONTAINMENT SUMP TESTING

Facility is Not Equipped With Fill Riser Containment Sumps <input type="checkbox"/>				
Fill Riser Containment Sumps are Present, but were Not Tested <input type="checkbox"/>				
Test Method Developed By:	<input type="checkbox"/> Sump Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer	
	<input type="checkbox"/> Other (Specify)			
Test Method Used:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic	
	<input type="checkbox"/> Other (Specify)			
Test Equipment Used: INCON TS-ST5			Equipment Resolution: .000in.	
	Fill Sump #	Fill Sump #	Fill Sump #	Fill Sump #
Sump Diameter:				
Sump Depth:				
Height from Tank Top to Top of Highest Piping Penetration:				
Height from Tank Top to Lowest Electrical Penetration:				
Condition of sump prior to testing:				
Portion of Sump Tested				
Sump Material:				
Wait time between applying pressure/vacuum/water and starting test:	* NO Fill Sumps *			
Test Start Time:				
Initial Reading (R _i):				
Test End Time:				
Final Reading (R _f):				
Test Duration:				
Change in Reading (R _f -R _i):				
Pass/Fail Threshold or Criteria:				
Test Result:	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Is there a sensor in the sump?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Does the sensor alarm when either product or water is detected?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor removed for testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments -- (include information on repairs made prior to testing, and recommended follow-up for failed tests)

- No Fill Sumps to be tested -

9. SPILL/OVERFILL CONTAINMENT BOXES

Facility is Not Equipped With Spill/Overfill Containment Boxes <input type="checkbox"/>									
Spill/Overfill Containment Boxes are Present, but were Not Tested <input type="checkbox"/>									
Test Method Developed By: <input type="checkbox"/> Spill Bucket Manufacturer <input checked="" type="checkbox"/> Industry Standard <input type="checkbox"/> Professional Engineer <input type="checkbox"/> Other (Specify)									
Test Method Used: <input type="checkbox"/> Pressure <input type="checkbox"/> Vacuum <input checked="" type="checkbox"/> Hydrostatic <input type="checkbox"/> Other (Specify)									
Test Equipment Used: INCON TS-ST5					Equipment Resolution: .0001 in.				
	UNL Spill Box # 87		VPR Spill Box # 87		Prem Spill Box # 91		VPR Spill Box # 91		
Bucket Diameter:	12"		12"		12"		12"		
Bucket Depth:	12"		12"		12"		12"		
Wait time between applying pressure/vacuum/water and starting test:	30 min		30 min		30 min		30 min		
Test Start Time:	9:33am	10:02am	10:02am	10:21am	9:16am	9:33am	9:16am	9:33am	
Initial Reading (R _i):	2.442in	2.442in	5.078in	5.077in	2.791in	2.790in	4.811in	4.810in	
Test End Time:	9:48am	10:17am	10:17am	10:36am	9:31am	9:48am	9:31am	9:48am	
Final Reading (R _f):	2.442in	2.441in	5.078in	5.077in	2.790in	2.790in	4.811in	4.810in	
Test Duration:	15min	15min	15min	15min	15min	15min	15min	15min	
Change in Reading (R _f -R _i):	.000in	.001in	.000in	.000in	.001in	.000in	.000in	.000in	
Pass/Fail Threshold or Criteria:	.002in		.002in		.002in		.002in		
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail		<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail		<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail		<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail		

Comments — (include information on repairs made prior to testing, and recommended follow-up for failed tests)

13594
9 of 9

SB989 TESTING FAILURE REPORT

SITE NAME: Johnny Quik DATE: 7-13-06

ADDRESS: 2126 Taft Hwy TECHNICIAN: _____

CITY: Boxersfield SIGNATURE: _____

SITE CONTACT: _____

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE THE SB989 TESTING.

LIST OF PARTS REPLACED/REPAIRED:

REPAIRS: None

LABOR: None

PARTS INSTALLED: None

SUMP LEAK TEST REPORT

DSLSTP

91SPL
 TEST STARTED 9:33 AM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 2.7908 IN
 END TIME 9:48 AM
 END DATE 07/13/2006
 END LEVEL 2.7909 IN
 LEAK THRESHOLD 0.002 IN
 TEST RESULT PASSED

TEST STARTED 12:51 PM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 3.0970 IN
 END TIME 1:06 PM
 END DATE 07/13/2006
 END LEVEL 3.0967 IN
 LEAK THRESHOLD 0.002 IN
 TEST RESULT PASSED

DSLSTP
 TEST STARTED 9:33 AM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 4.2371 IN
 END TIME 9:48 AM
 END DATE 07/13/2006
 END LEVEL 4.2368 IN
 LEAK THRESHOLD 0.002 IN
 TEST RESULT PASSED

DSLSTP

91UPR

91STP
 TEST STARTED 1:48 PM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 3.5116 IN
 END TIME 2:03 PM
 END DATE 07/13/2006
 END LEVEL 3.5128 IN
 LEAK THRESHOLD 0.002 IN
 TEST RESULT PASSED

TEST STARTED 1:07 PM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 3.0966 IN
 END TIME 1:22 PM
 END DATE 07/13/2006
 END LEVEL 3.0963 IN
 LEAK THRESHOLD 0.002 IN
 TEST RESULT PASSED

TEST STARTED 9:33 AM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 4.8108 IN
 END TIME 9:48 AM
 END DATE 07/13/2006
 END LEVEL 4.8103 IN
 LEAK THRESHOLD 0.002 IN
 TEST RESULT PASSED

SUMP LEAK TEST REPORT

87UPR

07/13/2006 9:31 AM

87STP
 TEST STARTED 1:48 PM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 3.1411 IN
 END TIME 2:03 PM
 END DATE 07/13/2006
 END LEVEL 3.1413 IN
 LEAK THRESHOLD 0.002 IN
 TEST RESULT PASSED

TEST STARTED 10:21 AM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 5.0778 IN
 END TIME 10:36 AM
 END DATE 07/13/2006
 END LEVEL 5.0775 IN
 LEAK THRESHOLD 0.002 IN
 TEST RESULT PASSED

SUMP LEAK TEST REPORT

DSLSTP

87STP
 TEST STARTED 1:31 PM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 1.9273 IN
 END TIME 1:46 PM
 END DATE 07/13/2006
 END LEVEL 1.9265 IN
 LEAK THRESHOLD 0.002 IN
 TEST RESULT PASSED

SUMP LEAK TEST REPORT

87UPR

TEST STARTED 9:16 AM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 4.2378 IN
 END TIME 9:31 AM
 END DATE 07/13/2006
 END LEVEL 4.2372 IN
 LEAK THRESHOLD 0.002 IN
 TEST RESULT PASSED

TEST STARTED 10:02 AM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 5.0785 IN
 END TIME 10:17 AM
 END DATE 07/13/2006
 END LEVEL 5.0782 IN
 LEAK THRESHOLD 0.002 IN

91UPR

91STP
 TEST STARTED 1:31 PM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 3.5080 IN
 END TIME 1:46 PM
 END DATE 07/13/2006
 END LEVEL 3.5095 IN
 LEAK THRESHOLD 0.002 IN
 TEST RESULT PASSED

87SPL

TEST STARTED 9:16 AM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 4.8116 IN
 END TIME 9:31 AM
 END DATE 07/13/2006
 END LEVEL 4.8110 IN
 LEAK THRESHOLD 0.002 IN
 TEST RESULT PASSED

TEST STARTED 9:33 AM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 2.4425 IN
 END TIME 9:48 AM
 END DATE 07/13/2006
 END LEVEL 2.4426 IN
 LEAK THRESHOLD 0.002 IN
 TEST RESULT PASSED

91SPL

87SPL
 TEST STARTED 10:02 AM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 2.4422 IN
 END TIME 10:17 AM
 END DATE 07/13/2006
 END LEVEL 2.4416 IN
 LEAK THRESHOLD 0.002 IN
 TEST RESULT PASSED

87SPL

TEST STARTED 9:16 AM
 TEST STARTED 07/13/2006
 BEGIN LEVEL 2.7914 IN
 END TIME 9:31 AM
 END DATE 07/13/2006
 END LEVEL 2.7904 IN
 LEAK THRESHOLD 0.002 IN
 TEST RESULT PASSED

5-6

TEST STARTED 3:12 PM
TEST STARTED 07/13/2006
BEGIN LEVEL 5.3349 IN
END TIME 3:27 PM
END DATE 07/13/2006
END LEVEL 5.3342 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

07/13/2006 3:08 PM

SUMP LEAK TEST REPORT

1-2

TEST STARTED 2:53 PM
TEST STARTED 07/13/2006
BEGIN LEVEL 3.4790 IN
END TIME 3:08 PM
END DATE 07/13/2006
END LEVEL 3.4790 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

7-8

07/13/2006 2:46 PM

SUMP LEAK TEST REPORT

1-2

TEST STARTED 3:12 PM
TEST STARTED 07/13/2006
BEGIN LEVEL 4.6303 IN
END TIME 3:27 PM
END DATE 07/13/2006
END LEVEL 4.6300 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

TEST STARTED 2:31 PM
TEST STARTED 07/13/2006
BEGIN LEVEL 3.4795 IN
END TIME 2:46 PM
END DATE 07/13/2006
END LEVEL 3.4793 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

3-4

TEST STARTED 2:53 PM
TEST STARTED 07/13/2006
BEGIN LEVEL 2.3455 IN
END TIME 3:08 PM
END DATE 07/13/2006
END LEVEL 2.3456 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

DSLSEC

TEST STARTED 3:12 PM
TEST STARTED 07/13/2006
BEGIN LEVEL 3.3840 IN
END TIME 3:27 PM
END DATE 07/13/2006
END LEVEL 3.3838 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

3-4

TEST STARTED 2:31 PM
TEST STARTED 07/13/2006
BEGIN LEVEL 2.3448 IN
END TIME 2:46 PM
END DATE 07/13/2006
END LEVEL 2.3453 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

87SEC

TEST STARTED 2:53 PM
TEST STARTED 07/13/2006
BEGIN LEVEL 2.4324 IN
END TIME 3:08 PM
END DATE 07/13/2006
END LEVEL 2.4323 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

87SEC

TEST STARTED 2:31 PM
TEST STARTED 07/13/2006
BEGIN LEVEL 2.4326 IN
END TIME 2:46 PM
END DATE 07/13/2006
END LEVEL 2.4324 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

91SEC

TEST STARTED 2:53 PM
TEST STARTED 07/13/2006
BEGIN LEVEL 2.5416 IN
END TIME 3:08 PM
END DATE 07/13/2006
END LEVEL 2.5415 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

07/13/2006 3:44 PM

SUMP LEAK TEST REPORT

5-6

TEST STARTED 3:29 PM
TEST STARTED 07/13/2006
BEGIN LEVEL 5.3339 IN
END TIME 3:44 PM
END DATE 07/13/2006
END LEVEL 5.3335 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

91SEC

TEST STARTED 2:31 PM
TEST STARTED 07/13/2006
BEGIN LEVEL 2.5422 IN
END TIME 2:46 PM
END DATE 07/13/2006
END LEVEL 2.5418 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

7-8

TEST STARTED 3:29 PM
TEST STARTED 07/13/2006
BEGIN LEVEL 4.6300 IN
END TIME 3:44 PM
END DATE 07/13/2006
END LEVEL 4.6298 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

DSLSEC

TEST STARTED 3:29 PM
TEST STARTED 07/13/2006
BEGIN LEVEL 3.3838 IN
END TIME 3:44 PM
END DATE 07/13/2006
END LEVEL 3.3838 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

Secondary Containment Testing Report Form

320028

This form is intended for use by contractors performing periodic testing of UST secondary containment systems. Use the appropriate pages of this form to report results for all components tested. The completed form, written test procedures, and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: <u>Johnny Quick #143</u>	Date of Testing: <u>7/8/05</u>
Facility Address: <u>2126 Tart Hwy</u>	
Facility Contact:	Phone:
Date Local Agency Was Notified of Testing: <u>7-7-05</u>	
Name of Local Agency Inspector (if present during testing):	

2. TESTING CONTRACTOR INFORMATION

Company Name: <u>Redwine Testing</u>		
Technician Conducting Test: <u>JOSEPH DAVIS</u>		
Credentials:	<input checked="" type="checkbox"/> CSLB Licensed Contractor	<input type="checkbox"/> SWRCB Licensed Tank Tester
License Type: <u>532878AHA2</u>	License Number: <u>809850</u>	
Manufacturer	<u>Manufacturer Training</u> Component(s)	Date Training Expires
INCON	INCON TS-STs	

3. SUMMARY OF TEST RESULTS

Component	Pass	Fail	Not Tested	Repairs Made	Component	Pass	Fail	Not Tested	Repairs Made
<u>UWL-81- Annular</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>UWC 748</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<u>PUSS89- Annular</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>UWL-81- Fill sump</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
<u>PRM191- Annular</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>PUSS89- Fill sump</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
<u>UWL-81- SEC. PIPING</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>PRM191- Fill sump</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
<u>PUSS89- SEC. PIPING</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>UWL-81- Spill Box</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<u>PRM191- SEC. PIPING</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>PUSS89- Spill Box</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<u>UWL-81- Sub. pump sump</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>PRM191- Spill Box</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<u>PUSS89- Sub. pump sump</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<u>PRM191- Sub. pump sump</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<u>UWC 102</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<u>UWC 347</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<u>UWC 546</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

If hydrostatic testing was performed, describe what was done with the water after completion of tests:

RECYCLE AND REUSED

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

To the best of my knowledge, the facts stated in this document are accurate and in full compliance with legal requirements

Technician's Signature: 

Date: 7/8/05

4. TANK ANNULAR TESTING

Test Method Developed By: Tank Manufacturer Industry Standard Professional Engineer
 Other (Specify)

Test Method Used: Pressure Vacuum Hydrostatic
 Other (Specify)

Test Equipment Used: 4in. DIAL GAUGE Equipment Resolution: .5%

	Tank # UNL-87	Tank # PLUS89	Tank # Flem 91	Tank #
Is Tank Exempt From Testing? ¹	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Tank Capacity:	UNKNOWN	UNKNOWN	UNKNOWN	
Tank Material:	STEEL	STEEL	STEEL	
Tank Manufacturer:	UNKNOWN	UNKNOWN	UNKNOWN	
Product Stored:	UNLEADED	UNLEADED	UNLEADED	
Wait time between applying pressure/vacuum/water and starting test:	10min	10min	10min	
Test Start Time:	10:15am	10:30am	10:45am	
Initial Reading (R _i):	10Hg	10Hg	10Hg	
Test End Time:	11:15am	11:30am	11:45am	
Final Reading (R _f):	10Hg	10Hg	10Hg	
Test Duration:	60min	60min	60min	
Change in Reading (R _f -R _i):	0Hg	0Hg	0Hg	
Pass/Fail Threshold or Criteria:	0Hg	0Hg	0Hg	
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ Secondary containment systems where the continuous monitoring automatically monitors both the primary and secondary containment, such as systems that are hydrostatically monitored or under constant vacuum, are exempt from periodic containment testing under the Code of Regulations, Title 23, Section 2637(a)(6).

5. SECONDARY PIPE TESTING

Test Method Developed By: Piping Manufacturer Industry Standard Professional Engineer
 Other (Specify)

Test Method Used: Pressure Vacuum Hydrostatic
 Other (Specify)

Test Equipment Used: 4 in. DIAL GAUGE Equipment Resolution: .5%

	Piping Run # 87	Piping Run # 89	Piping Run # 91	Piping Run #
Piping Material:	PLASTIC	PLASTIC	PLASTIC	
Piping Manufacturer:	UNKNOWN	UNKNOWN	UNKNOWN	
Piping Diameter:	2"	2"	2"	
Length of Piping Run:	50'	50'	50'	
Product Stored:	UNLEADED	UNLEADED	UNLEADED	
Method and location of piping-run isolation:	Boot in sump	Boot in sump	Boot in sump	
Wait time between applying pressure/vacuum/water and starting test:	10 min	10 min	10 min	
Test Start Time:	10:30am	10:45am	10:30am	10:45am
Initial Reading (R _i):	1.807in	1.807in	1.701in	1.701in
Test End Time:	10:45am	11:00am	10:45am	11:00am
Final Reading (R _f):	1.807in	1.807in	1.701in	1.701in
Test Duration:	15 min	15 min	15 min	15 min
Change in Reading (R _f -R _i):	.000in	.000in	.000in	.000in
Pass/Fail Threshold or Criteria:	.002in	.002in	.002in	
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

TESTED SECONDARY LINES HYDROSTATICALLY

6. PIPING SUMP TESTING

Test Method Developed By: Sump Manufacturer Industry Standard Professional Engineer
 Other (Specify)

Test Method Used: Pressure Vacuum Hydrostatic
 Other (Specify)

Test Equipment Used: INCON TS-STS Equipment Resolution: .000 in.

	Sump # 87	Sump # 89	Sump # 91	Sump #
Sump Diameter:	36"	36"	36"	
Sump Depth:	48"	48"	48"	
Sump Material:	PLASTIC	PLASTIC	PLASTIC	
Height from Tank Top to Top of Highest Piping Penetration:	20"	19"	20"	
Height from Tank Top to Lowest Electrical Penetration:	19"	27"	27"	
Condition of sump prior to testing:	CLEAN	CLEAN	CLEAN	
Portion of Sump Tested ¹	Bottom Half	Bottom Half	Bottom Half	
Does turbine shut down when sump sensor detects liquid (both product and water)?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Turbine shutdown response time	N/A	N/A	N/A	
Is system programmed for fail-safe shutdown?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was fail-safe verified to be operational?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Wait time between applying pressure/vacuum/water and starting test:	10 min	10 min	10 min	
Test Start Time:	11:10am 11:05am	11:10am 11:05am	11:10am 11:05am	
Initial Reading (R _i):	1.987 in	1.887 in	1.907 in	.817 in
Test End Time:	11:25am 11:40am	11:25am 11:40am	11:25am 11:40am	
Final Reading (R _f):	1.887 in	1.887 in	1.907 in	.817 in
Test Duration:	15 min	15 min	15 min	15 min
Change in Reading (R _f -R _i):	.000 in	.000 in	.000 in	.000 in
Pass/Fail Threshold or Criteria:	.002 in	.002 in	.002 in	
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments -- (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ If the entire depth of the sump is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire sump must be tested. (See SWRCB LG-160)

7. UNDER-DEVELOPER CONTAINMENT (UDC) TESTING

Test Method Developed By: UDC Manufacturer Industry Standard Professional Engineer
 Other (Specify)

Test Method Used: Pressure Vacuum Hydrostatic
 Other (Specify)

Test Equipment Used: INCON TS-ST5 Equipment Resolution: .000in.

	UDC # 102	UDC # 374	UDC # 596	UDC # 798
UDC Manufacturer:	UNKNOWN	UNKNOWN	UNKNOWN	UNKNOWN
UDC Material:	PLASTIC	PLASTIC	PLASTIC	PLASTIC
UDC Depth:	36"	36"	36"	36"
Height from UDC Bottom to Top of Highest Piping Penetration:	16"	16"	16"	16"
Height from UDC Bottom to Lowest Electrical Penetration:	17"	19"	20"	20"
Condition of UDC prior to testing:	CLEAN	CLEAN	CLEAN	CLEAN
Portion of UDC Tested ¹	Bottom half	Bottom half	Bottom half	Bottom half
Does turbine shut down when UDC sensor detects liquid (both product and water)?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Turbine shutdown response time	N/A	N/A	N/A	N/A
Is system programmed for fail-safe shutdown?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Was fail-safe verified to be operational?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Wait time between applying pressure/vacuum/water and starting test	10min	10min	10min	10min
Test Start Time:	11:50am 12:05pm	11:50am 12:05pm	11:50am 12:05pm	11:50am 12:05pm
Initial Reading (R _i):	.688in .687in	.705in .704in	.704in .703in	.801in .800in
Test End Time:	12:05pm 12:20pm	12:05pm 12:20pm	12:05pm 12:20pm	12:05pm 12:09pm
Final Reading (R _f):	.687in .686in	.704in .703in	.703in .702in	.800in .799in
Test Duration:	15min 15min	15min 15min	15min 15min	15min 15min
Change in Reading (R _f -R _i):	.001in .001in	.001in .001in	.001in .001in	.001in .001in
Pass/Fail Threshold or Criteria:	.002in	.002in	.002in	.002in
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ If the entire depth of the UDC is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire UDC must be tested. (See SWRCB LG-160)

8. FILL RISER CONTAINMENT SUMP TESTING

Facility is Not Equipped With Fill Riser Containment Sumps

Fill Riser Containment Sumps are Present, but were Not Tested

Test Method Developed By: Sump Manufacturer Industry Standard Professional Engineer

Other (Specify)

Test Method Used: Pressure Vacuum Hydrostatic

Other (Specify)

Equipment Resolution: .000 in.

Test Equipment Used: INCON TS-ST5	Equipment Resolution: .000 in.			
	Fill Sump #	Fill Sump #	Fill Sump #	Fill Sump #
Sump Diameter:				
Sump Depth:				
Height from Tank Top to Top of Highest Piping Penetration:				
Height from Tank Top to Lowest Electrical Penetration:				
Condition of sump prior to testing:				
Portion of Sump Tested				
Sump Material:				
Wait time between applying pressure/vacuum/water and starting test:	NO FILL SUMPS			
Test Start Time:				
Initial Reading (R _i):				
Test End Time:				
Final Reading (R _f):				
Test Duration:				
Change in Reading (R _f -R _i):				
Pass/Fail Threshold or Criteria:				
Test Result:	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Is there a sensor in the sump?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Does the sensor alarm when either product or water is detected?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor removed for testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

NO FILL SUMPS

SB989 TESTING FAILURE REPORT

SITE NAME: Johnny Quick

DATE: 7/8/05

ADDRESS: 2126 Taft Hwy

TECHNICIAN: JOSH DAVIS

CITY: BAKERSFIELD

SIGNATURE: *Josh Davis*

SITE CONTACT:

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE THE SB989 TESTING.

LIST OF PARTS REPLACED/REPAIRED:

REPAIRS: NONE

LABOR: NONE

PARTS INSTALLED: NONE

MONITORING SYSTEM CERTIFICATION

For Use By All Jurisdictions Within the State of California

Authority Cited: Chapter 6.7, Health and Safety Code; Chapter 16, Division 3, Title 23, California Code of Regulations

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

A. General Information

Facility Name: JOHNNY QUIK Bldg. No.: _____

Site Address: 2126 TAFT HWY City: BAKERSFIELD Zip: _____

Facility Contact Person: _____ Contact Phone No.: (____) _____

Make/Model of Monitoring System: GILBARCO EMC Date of Testing/Serviceing: 1/27/95

B. Inventory of Equipment Tested/Certified

Check the appropriate boxes to indicate specific equipment inspected/serviced:

Tank ID: <u>UUL87</u> <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>LD-2000</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: <u>PLUS 89</u> <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>410</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Tank ID: <u>PREM91</u> <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>410</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: _____ <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input type="checkbox"/> Annular Space or Vault Sensor. Model: _____ <input type="checkbox"/> Piping Sump / Trench Sensor(s). Model: _____ <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Dispenser ID: <u>1-2</u> <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>NO SENSOR</u> <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: <u>3-4</u> <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>NO SENSOR</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: <u>5-6</u> <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>NO SENSOR</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: <u>7-8</u> <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>NO SENSOR</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply):

System set-up Alarm history report
 Technician Name (print): RYAN MASON Signature: [Signature]

Certification No.: 006-05-1273 License No.: C61/D40- #809850

Testing Company Name: RICH ENVIRONMENTAL Phone No.: (661) 392-8687

Site Address: 2126 TAFT HWY BAKERSFIELD, CA Date of Testing/Serviceing: 1/27/95

D. Results of Testing/Serviceing

Software Version Installed: 14.01

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the audible alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the visual alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors visually inspected, functionally tested, and confirmed operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors installed at lowest point of secondary containment and positioned so that other equipment will not interfere with their proper operation?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	If alarms are relayed to a remote monitoring station, is all communications equipment (e.g. modem) operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected? If yes: which sensors initiate positive shut-down? (Check all that apply) <input checked="" type="checkbox"/> Sump/Trench Sensors; <input type="checkbox"/> Dispenser Containment Sensors. Did you confirm positive shut-down due to leaks and sensor failure/disconnection? <input checked="" type="checkbox"/> Yes; <input type="checkbox"/> No.
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For tank systems that utilize the monitoring system as the primary tank overflow warning device (i.e. no mechanical overflow prevention valve is installed), is the overflow warning alarm visible and audible at the tank fill point(s) and operating properly? If so, at what percent of tank capacity does the alarm trigger? %
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes, or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E, below.
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was liquid found inside any secondary containment systems designed as dry systems? (Check all that apply) <input type="checkbox"/> Product; <input type="checkbox"/> Water. If yes, describe causes in Section E, below.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was monitoring system set-up reviewed to ensure proper settings? Attach set up reports, if applicable
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is all monitoring equipment operational per manufacturer's specifications?

* In Section E below, describe how and when these deficiencies were or will be corrected.

E. Comments:

F. In-Tank Gauging / SIR Equipment:

- Check this box if tank gauging is used only for inventory control.
 Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all tank gauging probes visually inspected for damage and residue buildup?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system product level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system water level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all probes reinstalled properly?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In the Section H, below, describe how and when these deficiencies were or will be corrected.

G. Line Leak Detectors (LLD):

- Check this box if LLDs are not installed.

Complete the following checklist:


<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For equipment start-up or annual equipment certification, was a leak simulated to verify LLD performance? (Check all that apply) Simulated leak rate: <input checked="" type="checkbox"/> 3 g.p.h.; <input type="checkbox"/> 0.1 g.p.h.; <input type="checkbox"/> 0.2 g.p.h.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all LLDs confirmed operational and accurate within regulatory requirements?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was the testing apparatus properly calibrated?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In the Section H, below, describe how and when these deficiencies were or will be corrected.

H. Comments:

UST Monitoring Site Plan

Site Address: 2182 TAFT HWY BAKERSFIELD, CA



Date map was drawn: 1/27/05

Instructions

If you already have a diagram that shows all required information, you may include it, rather than this page, with your Monitoring System Certification. On your site plan, show the general layout of tanks and piping. Clearly identify locations of the following equipment, if installed: monitoring system control panels; sensors monitoring tank annular spaces, sumps, dispenser pans, spill containers, or other secondary containment areas; mechanical or electronic line leak detectors; and in-tank liquid level probes (if used for leak detection). In the space provided, note the date this Site Plan was prepared.

MONITOR CERT. FAILURE REPORT

SITE NAME: JOHNNY GUIK

DATE: 1-27-05

ADDRESS: 2126 TART HWY

TECHNICIAN: Ryan Mason

CITY: BAKERSFIELD

SIGNATURE: *[Handwritten Signature]*

SITE CONTACT:

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE THE MONITOR CERTIFICATION TESTING.

LIST OF PARTS REPLACED/REPAIRED:

REPAIRS:

NONE

LABOR:

NONE

PARTS INSTALLED:

NONE

RICH ENVIRONMENTAL

5643 BROOKS CT BAKERSFIELD, CA. 93308
 OFFICE (661) 392-8687 & FAX (661) 392-0621
MECHANICAL LEAK DETECTOR TEST

WORK SHEET

W/O#: _____

Facility Name: JOHNNY QUIK

Facility Address: 7120 TAFT HWY BAKERSFIELD, CA

Product Line Type (Pressure, Suction, Gravity) PRESSURE

PRODUCT	LEAK DETECTOR TYPE SERIAL NUMBER	TEST BELOW 3 GPH	TRIP PSI	PASS OR FAIL
<u>UNL87</u>	L/D TYPE <u>MECHANICAL</u> SERIAL # <u>LD-2000</u>	<input checked="" type="radio"/> YES <input type="radio"/> NO	<u>15</u>	<input checked="" type="radio"/> PASS <input type="radio"/> FAIL
<u>PLUS 89</u>	L/D TYPE <u>MECHANICAL</u> SERIAL # <u>RED JACKET</u>	<input checked="" type="radio"/> YES <input type="radio"/> NO	<u>10</u>	<input checked="" type="radio"/> PASS <input type="radio"/> FAIL
<u>PREM 91</u>	L/D TYPE <u>MECHANICAL</u> SERIAL # <u>RED JACKET</u>	<input checked="" type="radio"/> YES <input type="radio"/> NO	<u>12</u>	<input checked="" type="radio"/> PASS <input type="radio"/> FAIL
	L/D TYPE _____ SERIAL # _____	YES NO		PASS FAIL

I certify the above tests were conducted on this date according to Red Jacket Pumps field test apparatus testing procedure and limitations. The Mechanical Leak Detector Test pass / fail is determined by using a low flow threshold trip rate of 3 gallon per hour or less at 10 PSI. I acknowledge that all data collected is true and correct to the best of my knowledge.

Tech: RYAN MASON

Signature: [Handwritten Signature]

Date: 1-27-05

SOFTWARE REVISION LEVEL
VERSION 18.01
SOFTWARE# 346018-100-B
CREATED - 99.07.23.19.14

NO SOFTWARE MODULE
SYSTEM FEATURES:
PERIODIC IN-TANK TESTS
ANNUAL IN-TANK TESTS

SYSTEM SETUP

JAN 27, 2005 2:47 PM

SYSTEM UNITS
U.S.
SYSTEM LANGUAGE
ENGLISH
SYSTEM DATE/TIME FORMAT
MON DD YYYY HH:MM:SS XM

Johnny Quik #143
2126 Taft Hwy.
Bakersfield Ca. 93313
(805) 834-9113

SHIFT TIME 1 : DISABLED
SHIFT TIME 2 : DISABLED
SHIFT TIME 3 : DISABLED
SHIFT TIME 4 : DISABLED

TANK PERIODIC WARNINGS
DISABLED
TANK ANNUAL WARNINGS
DISABLED
LINE PERIODIC WARNINGS
DISABLED
LINE ANNUAL WARNINGS
DISABLED

PRINT TC VOLUMES
ENABLED

TEMP COMPENSATION
VALUE (DEG F) : 60.0
STICK HEIGHT OFFSET
DISABLED
DAYLIGHT SAVING TIME
ENABLED
START DATE
APR WEEK 1 SUN
START TIME
2:00 AM
END DATE
OCT WEEK 6 SUN
END TIME
2:00 AM

SYSTEM SECURITY
CODE : 000000

COMMUNICATIONS SETUP

PORT SETTINGS:

NONE FOUND

RS-232 SECURITY
CODE : 000000

RS-232 END OF MESSAGE
DISABLED

LIQUID SENSOR SETUP

L 1:87 OCTANE
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 2:89 OCTANE
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 3:92 OCTANE
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 4:87 OCTANE
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 5:89 OCTANE
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 6:92 OCTANE
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

OUTPUT RELAY SETUP

R 1:87 POSI-SHUTDOWN
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 4:FUEL ALARM

R 2:89 POSI-SHUTDOWN
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 5:FUEL ALARM

R 3:92 POSI-SHUTDOWN
TYPE:
STANDARD
NORMALLY CLOSED

LIQUID SENSOR ALMS
L 6:FUEL ALARM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 2:89 OCTANE
ANNULAR SPACE
FUEL ALARM
AUG 20, 2004 2:11 PM

FUEL ALARM
AUG 20, 2004 2:10 PM

FUEL ALARM
AUG 20, 2004 2:07 PM

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 3:92 OCTANE
ANNULAR SPACE
FUEL ALARM
JAN 1, 1996 8:19 AM

SETUP DATA WARNING
JAN 1, 1996 8:02 AM

***** END *****

ALARM HISTORY REPORT

----- SYSTEM ALARM -----
PAPER OUT
NOV 9, 1999 1:31 PM
PRINTER ERROR
NOV 9, 1999 1:31 PM
BATTERY IS OFF
JAN 1, 1996 8:00 AM

***** END *****

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 1:87 OCTANE
ANNULAR SPACE
FUEL ALARM
DEC 3, 2002 5:43 PM

FUEL ALARM
DEC 3, 2002 5:25 PM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 4:87 OCTANE
STP SUMP
SETUP DATA WARNING
DEC 3, 2002 5:23 PM

SETUP DATA WARNING
DEC 3, 2002 5:18 PM

FUEL ALARM
DEC 3, 2002 5:10 PM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 5:89 OCTANE
STP SUMP
FUEL ALARM
OCT 14, 2001 2:28 PM

FUEL ALARM
OCT 14, 2001 2:28 PM

FUEL ALARM
NOV 9, 1999 12:31 PM

* * * * * END * * * * *

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 6:92 OCTANE
STP SUMP
FUEL ALARM
JUN 3, 2003 9:27 AM

FUEL ALARM
DEC 3, 2002 5:43 PM

FUEL ALARM
DEC 3, 2002 5:42 PM

* * * * * END * * * * *

----- SENSOR ALARM -----
L 6:92 OCTANE
STP SUMP
FUEL ALARM
JAN 27, 2005 2:52 PM

----- SENSOR ALARM -----
L 5:89 OCTANE
STP SUMP
FUEL ALARM
JAN 27, 2005 2:52 PM

----- SENSOR ALARM -----
L 4:87 OCTANE
STP SUMP
FUEL ALARM
JAN 27, 2005 2:53 PM

----- SENSOR ALARM -----
L 3:92 OCTANE
ANNULAR SPACE
FUEL ALARM
JAN 27, 2005 2:57 PM

----- SENSOR ALARM -----
L 2:89 OCTANE
ANNULAR SPACE
FUEL ALARM
JAN 27, 2005 3:00 PM

----- SENSOR ALARM -----
L 1:87 OCTANE
ANNULAR SPACE
FUEL ALARM
JAN 27, 2005 3:02 PM

Secondary Containment Testing Report Form

This form is intended for use by contractors performing periodic testing of UST secondary containment systems. Use the appropriate pages of this form to report results for all components tested. The completed form, written test procedures, and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: <u>JOHNNY QUICK</u>	Date of Testing: <u>6-3-03</u>
Facility Address: <u>2126 TAFE HWY BAKERSFIELD CA</u>	
Facility Contact:	Phone:
Date Local Agency Was Notified of Testing:	
Name of Local Agency Inspector (if present during testing):	

2. TESTING CONTRACTOR INFORMATION

Company Name: <u>RICH ENVIRONMENTAL</u>		
Technician Conducting Test: <u>JOSH DAVIS</u>		
Credentials: <input checked="" type="checkbox"/> SWRCB Licensed Contractor	<input type="checkbox"/> SWRCB Licensed Tank Tester	
License Type: <u>CG1/D40</u>	License Number: <u>809850</u>	
Manufacturer Training		
Manufacturer	Component(s)	Date Training Expires
<u>INCON</u>	<u>INCON TS-STS</u>	<u>8-4-04</u>

3. SUMMARY OF TEST RESULTS

Component	Pass	Fail	Not Tested	Repairs Made	Component	Pass	Fail	Not Tested	Repairs Made
<u>UNI-87-ANNUAL</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>UDC-798</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>PLUS89-ANNUAL</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>UNI-87-FILL SUMP</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<u>PREM91-ANNUAL</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>PLUS89-FILL SUMP</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<u>UNI-87-SEC. PIPING</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>PREM91-FILL SUMP</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<u>PLUS89-SEC. PIPING</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>UNI-87-SPILL BOX</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<u>PREM91-SEC. PIPING</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>PLUS89-SPILL BOX</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<u>UNI-87-SUB. DUMP SUMP</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>PREM91-SPILL BOX</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<u>PLUS89-SUB. DUMP SUMP</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>PREM91-SUB. PUMP SUMP</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>UDC-142</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>UDC-344</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>UDC-546</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

If hydrostatic testing was performed, describe what was done with the water after completion of tests:

RECYCLED & REUSEN

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

To the best of my knowledge, the facts stated in this document are accurate and in full compliance with legal requirements

Technician's Signature: 

Date: 6-3-03

4. TANK ANNULAR TESTING

Test Method Developed By:	<input type="checkbox"/> Tank Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
	<input type="checkbox"/> Other (Specify)		
Test Method Used:	<input checked="" type="checkbox"/> Pressure	<input checked="" type="checkbox"/> Vacuum	<input type="checkbox"/> Hydrostatic
	<input type="checkbox"/> Other (Specify)		
Test Equipment Used:	4 in DIAG (GUAGE)		Equipment Resolution: 5%
	Tank #	Tank #	Tank #
Is Tank Exempt From Testing? ¹	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Tank Capacity:			
Tank Material:			
Tank Manufacturer:			
Product Stored:			
Wait time between applying pressure/vacuum/water and starting test:			
Test Start Time:	TESTED AT A PREVIOUS DATE		
Initial Reading (R _i):			
Test End Time:			
Final Reading (R _f):			
Test Duration:			
Change in Reading (R _f -R _i):			
Pass/Fail Threshold or Criteria:			
Test Result:	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Was sensor properly replaced and verified functional after testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

ALL GRADES WERE TESTED AT A PREVIOUS DATE.

¹ Secondary containment systems where the continuous monitoring automatically monitors both the primary and secondary containment, such as systems that are hydrostatically monitored or under constant vacuum, are exempt from periodic containment testing. (California Code of Regulations, Title 23, Section 2637(a)(6))

6. PIPING SUMP TESTING

Test Method Developed By:	<input type="checkbox"/> Sump Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
	<input type="checkbox"/> Other (Specify)		
Test Method Used:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic
	<input type="checkbox"/> Other (Specify)		
Test Equipment Used: <u>INCON TS-8TS</u>	Equipment Resolution: <u>.003 (A)</u>		
	Sump # <u>UNL-87</u>	Sump # <u>PUS-89</u>	Sump # <u>PREM-91</u>
Sump Diameter:	<u>36"</u>	<u>36"</u>	<u>36"</u>
Sump Depth:	<u>48"</u>	<u>48"</u>	<u>48"</u>
Sump Material:	<u>PLASTIC</u>	<u>PLASTIC</u>	<u>PLASTIC</u>
Height from Tank Top to Top of Highest Piping Penetration:	<u>10"</u>	<u>10"</u>	<u>10"</u>
Height from Tank Top to Lowest Electrical Penetration:	<u>21"</u>	<u>23"</u>	<u>23"</u>
Condition of sump prior to testing:	<u>CLEAN</u>	<u>CLEAN</u>	<u>CLEAN</u>
Portion of Sump Tested ¹	<u>BOTTOM HALF</u>	<u>BOTTOM HALF</u>	<u>BOTTOM HALF</u>
Does turbine shut down when sump sensor detects liquid (both product and water)?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A
Turbine shutdown response time	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Is system programmed for fail-safe shutdown?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A
Was fail-safe verified to be operational?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A
Wait time between applying pressure/vacuum/water and starting test:	<u>30 MIN</u>	<u>30 MIN</u>	<u>30 MIN</u>
Test Start Time:	<u>9:30 AM</u>	<u>9:45 AM</u>	<u>9:30 AM</u>
Initial Reading (R _i):	<u>2.097 in</u>	<u>1.431 in</u>	<u>2.993 in</u>
Test End Time:	<u>9:45 AM</u>	<u>9:45 AM</u>	<u>9:45 AM</u>
Final Reading (R _f):	<u>2.097 in</u>	<u>1.430 in</u>	<u>2.992 in</u>
Test Duration:	<u>15 MIN</u>	<u>15 MIN</u>	<u>15 MIN</u>
Change in Reading (R _f -R _i):	<u>0.000 in</u>	<u>.001 in</u>	<u>.001 in</u>
Pass/Fail Threshold or Criteria:	<u>0.02 in</u>	<u>0.02 in</u>	<u>0.02 in</u>
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ If the entire depth of the sump is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire sump must be tested. (See SWRCB I.G-160)

7. UNDERDISPENSER CONTAINMENT (UDC) TESTING

Test Method Developed By:	<input type="checkbox"/> UDC Manufacturer		<input checked="" type="checkbox"/> Industry Standard		<input type="checkbox"/> Professional Engineer	
	<input type="checkbox"/> Other (Specify)					
Test Method Used:	<input type="checkbox"/> Pressure		<input type="checkbox"/> Vacuum		<input checked="" type="checkbox"/> Hydrostatic	
	<input type="checkbox"/> Other (Specify)					
Test Equipment Used:	INCUN TS-STS				Equipment Resolution: 0.001	
UDC Manufacturer:	UDC # 140	UDC # 394	UDC # 500	UDC # 748		
UDC Material:	FIBERGLASS	FIBERGLASS	FIBERGLASS	FIBERGLASS		
UDC Depth:	UNKNOWN	UNKNOWN	UNKNOWN	UNKNOWN		
Height from UDC Bottom to Top of Highest Piping Penetration:	26"	26"	24"	26"		
Height from UDC Bottom to Lowest Electrical Penetration:	10"	10"	10"	10"		
Condition of UDC prior to testing:	17"	19"	17"	17"		
Portion of UDC Tested ¹ :	CLEAN	CLEAN	CLEAN	CLEAN		
Does turbine shut down when UDC sensor detects liquid (both product and water)?	BOTTOM HALF	BOTTOM HALF	BOTTOM HALF	BOTTOM HALF		
Turbine shutdown response time	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA		
Is system programmed for fail-safe shutdown?	N/A	N/A	N/A	N/A		
Was fail-safe verified to be operational?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA		
Wait time between applying pressure/vacuum/water and starting test	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA		
Test Start Time:	30min	30min	30min	30min		
Initial Reading (R _i):	11:00AM 11:15AM	11:00AM 11:15AM	11:00AM 11:15AM	11:00AM 11:15AM		
Test End Time:	2:019in 2:018in	1:479in 1:478in	1:443in 1:443in	1:99in 1:99in		
Final Reading (R _f):	11:15AM 11:30AM	11:15AM 11:30AM	11:15AM 11:30AM	11:15AM 11:30AM		
Test Duration:	2:018in 2:017in	1:478in 1:477in	1:443in 1:443in	1:99in 1:98in		
Change in Reading (R _f -R _i):	15min	15min	15min	15min		
Pass/Fail Threshold or Criteria:	.001in	.001in	.000in	.001in		
Test Result:	.002in	.003in	.003in	.003in		
Was sensor removed for testing?	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail		
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA		

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ If the entire depth of the UDC is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire UDC must be tested. (See SWRCB LG-160)

8. FILL RISER CONTAINMENT SUMP TESTING

Facility is Not Equipped With Fill Riser Containment Sumps <input type="checkbox"/>				
Fill Riser Containment Sumps are Present, but were Not Tested <input type="checkbox"/>				
Test Method Developed By: <input type="checkbox"/> Sump Manufacturer <input checked="" type="checkbox"/> Industry Standard <input type="checkbox"/> Professional Engineer				
<input type="checkbox"/> Other (Specify)				
Test Method Used: <input type="checkbox"/> Pressure <input type="checkbox"/> Vacuum <input checked="" type="checkbox"/> Hydrostatic				
<input type="checkbox"/> Other (Specify)				
Test Equipment Used: INCW TS-533			Equipment Resolution: .000, N	
	Fill Sump #	Fill Sump #	Fill Sump #	Fill Sump #
Sump Diameter:				
Sump Depth:				
Height from Tank Top to Top of Highest Piping Penetration:				
Height from Tank Top to Lowest Electrical Penetration:				
Condition of sump prior to testing:	TESTED AT A PREVIOUS DATE			
Portion of Sump Tested:	TESTED AT A PREVIOUS DATE			
Sump Material:				
Wait time between applying pressure/vacuum/water and starting test:				
Test Start Time:				
Initial Reading (R _i):				
Test End Time:				
Final Reading (R _f):				
Test Duration:				
Change in Reading (R _f -R _i):				
Pass/Fail Threshold or Criteria:				
Test Result:	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Is there a sensor in the sump?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Does the sensor alarm when either product or water is detected?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor removed for testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

TESTED AT A PREVIOUS DATE.

9. SPILL/OVERFILL CONTAINMENT BOXES

Facility is Not Equipped With Spill/Overflow Containment Boxes

Spill/Overflow Containment Boxes are Present, but were Not Tested

Test Method Developed By: Spill Bucket Manufacturer Industry Standard Professional Engineer
 Other (Specify)

Test Method Used: Pressure Vacuum Hydrostatic
 Other (Specify)

Test Equipment Used: INCUB TS-STS Equipment Resolution: 0.001N

	Spill Box #	Spill Box #	Spill Box #	Spill Box #
Bucket Diameter:				
Bucket Depth:				
Wait time between applying pressure/vacuum/water and starting test:				
Test Start Time:	TESTED AT A PREVIOUS DATE			
Initial Reading (R _I):				
Test End Time:				
Final Reading (R _F):				
Test Duration:				
Change in Reading (R _F -R _I):				
Pass/Fail Threshold or Criteria:				
Test Result:	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Comments - (include information on repairs made prior to testing, and recommended follow-up for failed tests)

TESTED AT A PREVIOUS DATE.

川 177
JUN 13 2003

320028

Secondary Containment Testing Report Form - DRAFT

This form is intended for use by contractors performing periodic testing of UST secondary containment systems. Use the appropriate pages of this form to report results for all components tested. The completed form, written test procedures, and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: JOHNY QUICK	Date of Testing: 12-03-02
Facility Address: 2126 TAFT HWY BAKERSFIELD, CA	Phone:
Facility Contact:	
Date Local Agency Was Notified of Testing: 11-29-02	
Name of Local Agency Inspector Present: KERN CO	

2. TESTING CONTRACTOR INFORMATION

Company Name: REDWINE TESTING		
Technician Conducting Test: AARON KUOT		
Credentials: <input checked="" type="checkbox"/> CSLB Licensed Contractor		<input type="checkbox"/> SWRCB Licensed Tank Tester
License Type and #: 532878 A-HAZ		
Manufacturer	Training by Manufacturer Component(s)	Date Training Expires
INCON	TS-STS	2004

3-TANKS

3. SUMMARY OF TEST RESULTS

Number of Tanks Tested: 3	Number of Piping Runs Tested: 3		
Number of Submersible Pump Sumps Tested: 3	Number of UDC Boxes Tested: 4		
Number of Fill Sumps Tested: 0	Number of Overfill Boxes Tested: 3		
Component	Pass	Fail	Comments
UNL 87 TANK ANNULAR	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
UNL P89 TANK ANNULAR	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
PREM 91 TANK ANNULAR	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
UNL 87 SUB PUMP SUMP	<input type="checkbox"/>	<input checked="" type="checkbox"/>	NO PENITRATION SEALED
UNL P89 SUB PUMP SUMP	<input type="checkbox"/>	<input checked="" type="checkbox"/>	NO PENITRATION SEALED
PREM 91 SUB PUMP SUMP	<input type="checkbox"/>	<input checked="" type="checkbox"/>	NO PENITRATION SEALED
UNL 87 SEL. PIPING	<input type="checkbox"/>	<input checked="" type="checkbox"/>	VISUAL (NO TEST BOOTS)
UNL P89 SEL. PIPING	<input type="checkbox"/>	<input checked="" type="checkbox"/>	VISUAL (NO TEST BOOTS)
PREM 91 SEL. PIPING	<input type="checkbox"/>	<input checked="" type="checkbox"/>	VISUAL (NO TEST BOOTS)
UDC 1+2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	VISUAL (NO PENITRATIONS SEALED)
UDC 3+4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	VISUAL (NO PENITRATIONS SEALED)
UDC 5+6	<input type="checkbox"/>	<input checked="" type="checkbox"/>	VISUAL (NO PENITRATIONS SEALED)
UDC 7+8	<input type="checkbox"/>	<input checked="" type="checkbox"/>	VISUAL (NO PENITRATIONS SEALED)
SPILL BOX UNL 87	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Technician's Signature:

Date: **12-03-02**

Secondary Containment Testing Report Form - DRAFT

This form is intended for use by contractors performing periodic testing of UST secondary containment systems. Use the appropriate pages of this form to report results for all components tested. The completed form, written test procedures, and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: JOHN WY QUILK	Date of Testing: 12-03-02
Facility Address: 2126 TAFT Hwy BAKERSFIELD, CA	
Facility Contact:	Phone:
Date Local Agency Was Notified of Testing:	
Name of Local Agency Inspector Present:	

2. TESTING CONTRACTOR INFORMATION

Company Name: REDWINE TESTING		
Technician Conducting Test: AARON		
Credentials: <input type="checkbox"/> CSLB Licensed Contractor <input type="checkbox"/> SWRCB Licensed Tank Tester		
License Type and #:		
Manufacturer	Training by Manufacturer Component(s)	Date Training Expires
Incon	95 - SVS	2004

3 - TANKS

3. SUMMARY OF TEST RESULTS

Number of Tanks Tested: 3	Number of Piping Runs Tested: 3
Number of Submersible Pump Sumps Tested: 3	Number of UDC Boxes Tested: 4
Number of Fill Sumps Tested: 0	Number of Overfill Boxes Tested: 3

Component	Pass	Fail	Comments
SPILL BOX UMLP 89	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
SPILL BOX PREM 91	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	

Technician's Signature: _____

Date: **12-3-02**

4. TANK ANNULAR TESTING

Test Method Developed By:	<input type="checkbox"/> Tank Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
	<input type="checkbox"/> Other (Specify)		
Test Method Uses:	<input type="checkbox"/> Pressure	<input checked="" type="checkbox"/> Vacuum	<input type="checkbox"/> Hydrostatic
	<input type="checkbox"/> Other (Specify)		
Measuring Equipment Used for Testing: <u>DIAL GAUGE</u>			
	<u>UNL 87</u> Tank #	<u>UNLP 89</u> Tank #	<u>PREM 91</u> Tank #
Tank Capacity:	10,000	10,000	10,000
Tank Material:	UNKNOWN	UNKNOWN	UNKNOWN
Tank Manufacturer:	UNKNOWN	UNKNOWN	UNKNOWN
Product Stored:	UNL 87	UNLP 89	PREM 91
Wait time between applying pressure/vacuum/water and starting test:	10 MIN	10 MIN	10 MIN
Test Start Time:	3:45 PM	3:45 PM	3:45 PM
Initial Reading (R _i):	10 HS	10 HS	10 HS
Test End Time:	4:45 PM	4:45 PM	4:45 PM
Final Reading (R _f):	10 HS	10 HS	10 HS
Test Duration:	1 Hour	1 Hour	1 Hour
Change in Reading (R _f -R _i):	0 HS	0 HS	0 HS
Pass/Fail Threshold:	0 HS	0 HS	0 HS
Test Result:	PASS	PASS	PASS
Was sensor removed for testing?	YES	YES	YES
Was sensor properly replaced after testing?	YES	YES	YES

Comments - (include information on repairs made prior to testing)

5. SECONDARY PIPE TESTING

Test Method Developed By: Piping Manufacturer Industry Standard Professional Engineer
 Other (Specify)

Test Method Uses: Pressure Vacuum Hydrostatic
 Other (Specify)

Measuring Equipment Used for Testing: DIAL GAUGE

	UML 87 Piping Run #	UMLP 89 Piping Run #	PREM 91 Piping Run #
Piping Material:	PLASTIC	PLASTIC	PLASTIC
Piping Manufacturer:	UNKNOWN	UNKNOWN	UNKNOWN
Piping Diameter:	3 IN	3 IN	3 IN
Length of Piping Run:	50 FEET	50 FEET	50 FEET
Product Stored:	UML 87	UMLP 89	PREM 91
Method and location of piping-run isolation:	N/A	N/A	N/A
Wait time between applying pressure/vacuum/water and starting test:	N/A	N/A	N/A
Test Start Time:	N/A	N/A	N/A
Initial Reading (R _i):	N/A	N/A	N/A
Test End Time:	N/A	N/A	N/A
Final Reading (R _f):	N/A	N/A	N/A
Test Duration:	N/A	N/A	N/A
Change in Reading (R _f -R _i):	N/A	N/A	N/A
Pass/Fail Threshold:	N/A PSI	N/A PSI	N/A PSI
Test Result:	FAIL	FAIL	FAIL

Comments - (include information on repairs made prior to testing)

1) ALL SEC. PIPING COULD NOT BE TESTED, NO BOOTS IN BUMPS OR DISPENSERS. SUB PUMP BUMPS FAILED SO HYDROSTATIC TEST COULD NOT BE PERFORMED.

6. SUBMERSIBLE PUMP CONTAINMENT SUMP TESTING

Test Method Developed By:	<input type="checkbox"/> Sump Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
	<input type="checkbox"/> Other (Specify)		
Test Method Uses:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic
	<input type="checkbox"/> Other (Specify)		
Measuring Equipment Used for Testing:	WCON TS-ST5		
	UNL 87 Sump #	UNLP 89 Sump #	PREM 91 Sump #
Sump Diameter:	36 in	36 in	36 in
Sump Depth:	54 in	54 in	54 in
Sump Material:	PLASTIC	PLASTIC	PLASTIC
Height from Tank Top to Highest Piping Penetration:	10 in	10 in	10 in
Height from Tank Top to Lowest Electrical Penetration:	18 in	18 in	18 in
Condition of sump prior to testing:	GOOD	GOOD	GOOD
Portion of Sump Tested ¹	BOTTOM 1/3 53%	BOTTOM 1/3 38%	BOTTOM 1/3 33%
Does turbine shut down when sump sensor detects either product or water?	N/A	N/A	N/A
Turbine shutdown response time ²	N/A	N/A	N/A
Is system programmed for fail-safe shutdown?	N/A	N/A	N/A
Was fail-safe verified to be operational?	N/A	N/A	N/A
Wait time between applying pressure/vacuum/water and starting test:	30 min	30 min	30 min
Test Start Time:	4:30 pm	4:30 pm	4:30 pm
Initial Reading (R _i):	4.23 in	7.72 in	5.378 in
Test End Time:	4:45 pm	4:45 pm	4:45 pm
Final Reading (R _f):	0 in	0 in	0 in
Test Duration:	15 min	15 min	15 min
Change in Reading (R _f -R _i):	4.23 in	7.72 in	5.378 in
Pass/Fail Threshold:	.002 in	.002 in	.002 in
Test Result:	FAIL	FAIL	FAIL
Was sensor removed for testing?			
Was sensor properly replaced after testing?			

Comments - (include information on repairs made prior to testing)

* ALL SUMPS GROSS FAIL, NEED PENETRATIONS SEALED. NO SEC. TEST.

¹ If the testing method does not test the entire depth of the sump, specify how much of the sump was tested. Methods not testing the entire sump should only be used if the monitoring system provides fail-safe turbine shutdown.

² With the submersible pump running, place the sensor in product (discriminating sensors should also be placed in water). The time between placing the sensor in product and the turbine shutting down is the response time. This should be done if the secondary containment testing method used does not test the entire volume of the sump.

7. UNDER-DISPENSER CONTAINMENT (UDC) TESTING

Test Method Developed By: UDC Manufacturer Industry Standard Professional Engineer
 Other (Specify)

Test Method Uses: Pressure Vacuum Hydrostatic
 Other (Specify)

Measuring Equipment Used for Testing: INCON 75 -STS

	UDC# 1+2	UDC# 3+4	UDC# 5+6
UDC Manufacturer:	UNKNOWN	UNKNOWN	UNKNOWN
UDC Material:	PLASTIC	PLASTIC	PLASTIC
UDC Depth:	24 in	24 in	24 in
Height from UDC Bottom to Highest Piping Penetration:	6 in	6 in	6 in
Height from UDC Bottom to Lowest Electrical Penetration:	UNKNOWN	UNKNOWN	UNKNOWN
Condition of UDC prior to testing:	GOOD	GOOD	GOOD
Portion of UDC Tested ¹	N/A	N/A	N/A
Does turbine shut down when UDC sensor detects either product or water?	N/A	N/A	N/A
Turbine shutdown response time ² :	N/A	N/A	N/A
Is system programmed for fail-safe shutdown?	N/A	N/A	N/A
Was fail-safe verified to be operational?	N/A	N/A	N/A
Wait time between applying pressure/vacuum/water and starting test:	N/A	N/A	N/A
Test Start Time:	N/A	N/A	N/A
Initial Reading (R _i):	N/A	N/A	N/A
Test End Time:	N/A	N/A	N/A
Final Reading (R _f):	N/A	N/A	N/A
Test Duration:	N/A	N/A	N/A
Change in Reading (R _f -R _i):	N/A	N/A	N/A
Pass/Fail Threshold:	N/A	N/A	N/A
Test Result:	FAIL	FAIL	FAIL
Was sensor removed for testing?	N/A	N/A	N/A
Was sensor properly replaced after testing?	N/A	N/A	N/A

Comments - (include information on repairs made prior to testing)

ALL DISP NEED PENETRATION SEALED AND BOOTS ON SEC. PIPING.

¹ If the testing method does not test the entire depth of the UDC, specify how much of the UDC was tested. Methods not testing the entire UDC should only be used if the monitoring system provides fail-safe turbine shutdown.

² With the submersible pump running, place the sensor in product (discriminating sensors should also be placed in water). The time between placing the sensor in product and the turbine shutting down is the response time. This should be done if the secondary containment testing method used does not test the entire volume of the UDC

7. UNDER-DISPENSER CONTAINMENT (UDC) TESTING

Test Method Developed By:	<input type="checkbox"/> UDC Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
	<input type="checkbox"/> Other (Specify)		
Test Method Uses:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic
	<input type="checkbox"/> Other (Specify)		
Measuring Equipment Used for Testing:	1 NCON TS-STS		
	UDC # 748	UDC #	UDC #
UDC Manufacturer:	UNKNOWN		
UDC Material:	PLASTIC		
UDC Depth:	24 IN		
Height from UDC Bottom to Highest Piping Penetration:	6 IN		
Height from UDC Bottom to Lowest Electrical Penetration:	UNKNOWN		
Condition of UDC prior to testing:	GOOD		
Portion of UDC Tested ¹	N/A		
Does turbine shut down when UDC sensor detects either product or water?	N/A		
Turbine shutdown response time ²	N/A		
Is system programmed for fail-safe shutdown?	N/A		
Was fail-safe verified to be operational?	N/A		
Wait time between applying pressure/vacuum/water and starting test:	N/A		
Test Start Time:	N/A		
Initial Reading (R _i):	N/A		
Test End Time:	N/A		
Final Reading (R _f):	N/A		
Test Duration:	N/A		
Change in Reading (R _f -R _i):	N/A		
Pass/Fail Threshold:	N/A		
Test Result:	FAIL		
Was sensor removed for testing?	N/A		
Was sensor properly replaced after testing?	N/A		

Comments - (include information on repairs made prior to testing)

ALL DISP NEED PENETRATIONS SEALED AND BOOTS ON SEL. PIPING.

¹ If the testing method does not test the entire depth of the UDC, specify how much of the UDC was tested. Methods not testing the entire UDC should only be used if the monitoring system provides fail-safe turbine shutdown.

² With the submersible pump running, place the sensor in product (discriminating sensors should also be placed in water). The time between placing the sensor in product and the turbine shutting down is the response time. This should be done if the secondary containment testing method used does not test the entire volume of the UDC

8. FILL RISER CONTAINMENT SUMP TESTING

Test Method Developed By: Sump Manufacturer Industry Standard Professional Engineer
 Other (Specify)

Test Method Uses: Pressure Vacuum Hydrostatic
 Other (Specify)

Measuring Equipment Used for Testing:

	Fill Sump #	Fill Sump #	Fill Sump #
Sump Diameter:	NO	FILL	TO TEST
Sump Depth:			
Height from Tank Top to Highest Piping Penetration:			
Height from Tank Top to Lowest Electrical Penetration:			
Condition of sump prior to testing:			
Portion of Sump Tested			
Sump Material:			
Wait time between applying pressure/vacuum/water and starting test:			
Test Start Time:			
Initial Reading (R _i):			
Test End Time:			
Final Reading (R _f):			
Test Duration:			
Change in Reading (R _f -R _i):			
Pass/Fail Threshold:			
Test Result:			
Is there a sensor in the sump?			
Does the sensor alarm when either product or water is detected?			
Was sensor removed for testing?			
Was sensor properly replaced after testing?			

Comments - (include information on repairs made prior to testing)

* NO FILL SUMPS TO TEST.

9. SPILL/OVERFILL CONTAINMENT BOXES

Test Method Developed By:	<input type="checkbox"/> Spill Bucket Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer			
	<input type="checkbox"/> Other (Specify)					
Test Method Uses:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic			
	<input type="checkbox"/> Other (Specify)					
Measuring Equipment Used for Testing: <u>INCOW TS-ST5</u>						
	<u>UNL 87</u> Spill Box #	<u>UNP 89</u> Spill Box #	<u>PREM 7A</u> Spill Box #			
Bucket Diameter:	<u>10 in</u>	<u>10 in</u>	<u>10 in</u>			
Bucket Depth:	<u>10 in</u>	<u>10 in</u>	<u>10 in</u>			
Wait time between applying pressure/vacuum/water and starting test:	<u>30 min</u>	<u>30 min</u>	<u>30 min</u>			
Test Start Time:	<u>5:30pm</u>	<u>5:45pm</u>	<u>5:50pm</u>	<u>5:45pm</u>	<u>5:30pm</u>	<u>5:45pm</u>
Initial Reading (R _i):	<u>2.534 in</u>	<u>2.534</u>	<u>1.716 in</u>	<u>1.715 in</u>	<u>2.443 in</u>	<u>2.443 in</u>
Test End Time:	<u>5:45pm</u>	<u>6:00pm</u>	<u>5:45pm</u>	<u>6:00pm</u>	<u>5:45pm</u>	<u>6:00pm</u>
Final Reading (R _f):	<u>2.534 in</u>	<u>2.533 in</u>	<u>1.715 in</u>	<u>1.714 in</u>	<u>2.443 in</u>	<u>2.443 in</u>
Test Duration:	<u>15 min</u>	<u>15 min</u>	<u>15 min</u>	<u>15 min</u>	<u>15 min</u>	<u>15 min</u>
Change in Reading (R _f -R _i):	<u>.000 in</u>	<u>.001 in</u>	<u>.001 in</u>	<u>.001 in</u>	<u>.000 in</u>	<u>.000 in</u>
Pass/Fail Threshold:	<u>.002 in</u>	<u>.002 in</u>	<u>.002 in</u>	<u>.002 in</u>	<u>.002 in</u>	<u>.002 in</u>
Test Result:	<u>PASS</u>	<u>PASS</u>	<u>PASS</u>	<u>PASS</u>	<u>PASS</u>	<u>PASS</u>

Comments - (include information on repairs made prior to testing)

This is a draft document intended for public review and comment. Your input is appreciated. Please direct any comments regarding this form to:

SWRCB UST Program, Attn: Scott Bacon
 1001 I' Street, Box 944212
 Sacramento, CA 95814
 Phone: (916) 341-5873, Fax: (916) 341-5808
 e-mail: bacons@cwpswrcb.ca.gov

RECEIVED
JAN 21 2003

UNDERGROUND STORAGE TANK UNAUTHORIZED RELEASE (LEAK) / CONTAMINATION SITE REPORT

EMERGENCY <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		FOR LOCAL AGENCY USE ONLY I HEREBY CERTIFY THAT I AM A DESIGNATED GOVERNMENT EMPLOYEE AND THAT I HAVE REPORTED THIS INFORMATION TO LOCAL OFFICIALS PURSUANT TO SECTION 25180.7 OF THE HEALTH AND SAFETY CODE.		
REPORT DATE 5/28/2013		CASE #		SIGNED _____ DATE _____		
REPORTED BY	NAME OF INDIVIDUAL FILING REPORT Jeffrey Marshall		PHONE (661) 862-8775		SIGNATURE	
	REPRESENTING <input checked="" type="checkbox"/> LOCAL AGENCY <input type="checkbox"/> REGIONAL BOARD <input type="checkbox"/> OWNER/OPERATOR <input type="checkbox"/> OTHER		COMPANY OR AGENCY NAME Kern County Environmental Health Division			
RESPONSIBLE PARTY	ADDRESS 2700 M Street, Suite 300		Bakersfield		CA 93301	
	STREET		CITY		STATE ZIP	
SITE LOCATION	NAME Kuljit Ghuman <input type="checkbox"/> Unknown		CONTACT PERSON Kuljit Ghuman		PHONE (661) 834-9113	
	ADDRESS 2126 Taft Hwy		Bakersfield		CA 93313	
IMPLEMENTING AGENCIES	FACILITY NAME (IF APPLICABLE) Johnny Quik #143		OPERATOR Kuljit Ghuman		PHONE (661) 834-9113	
	ADDRESS 2126 Taft Hwy		Bakersfield Kern		93313	
SUBSTANCES INVOLVED	LOCAL AGENCY AGENCY NAME Kern County Environmental Health Division		PHONE (661) 862-8775			
	REGIONAL BOARD		PHONE ()			
DISCOVERY/ABATEMENT	(1) NAME Gasoline		QUANTITY LOST (GALLONS) <input checked="" type="checkbox"/> Unknown			
	(2)		<input type="checkbox"/> Unknown			
SOURCE/ CAUSE	DATE DISCOVERED 5/9/2013		HOW DISCOVERED <input type="checkbox"/> Tank Test <input type="checkbox"/> Tank Removal <input type="checkbox"/> Nuisance Conditions <input type="checkbox"/> Inventory Control <input checked="" type="checkbox"/> Subsurface Monitoring <input type="checkbox"/> Other			
	DATE DISCHARGE BEGAN <input checked="" type="checkbox"/> UNKNOWN		METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY) <input type="checkbox"/> Remove Contents <input type="checkbox"/> Close Tank <input type="checkbox"/> Repair Tank <input type="checkbox"/> Change Procedure <input type="checkbox"/> Replace Tank <input checked="" type="checkbox"/> Other <input type="checkbox"/> Repair Piping			
	HAS DISCHARGE BEEN STOPPED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO IF YES, DATE 5/9/2013					
CASE TYPE	SOURCE OF DISCHARGE <input type="checkbox"/> Tank Leak <input type="checkbox"/> Piping Leak <input checked="" type="checkbox"/> Unknown <input type="checkbox"/> Other		CAUSE(S) <input type="checkbox"/> Overfill <input type="checkbox"/> Corrosion <input type="checkbox"/> Rupture/Failure <input checked="" type="checkbox"/> Unknown <input type="checkbox"/> Spill <input type="checkbox"/> Other			
	CHECK ONE ONLY <input checked="" type="checkbox"/> Undetermined <input type="checkbox"/> Soil Only <input type="checkbox"/> Groundwater <input type="checkbox"/> Drinking Water - (CHECK ONLY IF WATER WELLS HAVE ACTUALLY BEEN AFFECTED)					
CURRENT STATUS	CHECK ONE ONLY <input type="checkbox"/> No Action Taken <input type="checkbox"/> Case Closed (Cleanup Completed or Unnecessary) <input checked="" type="checkbox"/> Leak Being Confirmed <input type="checkbox"/> Pollution Characterization <input type="checkbox"/> Remediation Plan <input type="checkbox"/> Post Cleanup Monitoring in Progress <input type="checkbox"/> Preliminary Site Assessment Workplan Submitted <input type="checkbox"/> Cleanup Underway <input type="checkbox"/> Preliminary Site Assessment Underway					
	CHECK APPROPRIATE ACTION(S) <input type="checkbox"/> Cap Site (CD) <input type="checkbox"/> Excavate & Treat (ET) <input type="checkbox"/> Treatment At Hookup (HU) <input checked="" type="checkbox"/> Other <input type="checkbox"/> Contamination Barrier (CB) <input type="checkbox"/> No Action Required (NA) <input type="checkbox"/> Enhanced Bio Degradation (IT) <input type="checkbox"/> Vacuum Extract (VE) <input type="checkbox"/> Remove Free Product (FP) <input type="checkbox"/> Replace Supply (RS) <input type="checkbox"/> Excavate & Dispose (ED) <input type="checkbox"/> Pump & Treat Groundwater (GT) <input type="checkbox"/> Vent Soil (VS)					
COMMENTS	The facilities is currently in the process of removing product lines and replacing them with new fiberglass double walled lines. Contamination was uncovered after samples were taken under the product lines to the dispensers. The contamination was observed in the northeast samples. Two samples were taken at depths of two (2) feet and six (6) feet. Attached in a copy of the lab results obtained for the samples taken at the facility.					

Instructions for Completing UST Unauthorized Release (Leak) / Contamination Site Report

EMERGENCY: Indicate whether emergency response personnel and equipment were involved at any time. If so, a Hazardous Material Incident Report should be filed with the State Office of Emergency Services (OES). Indicate whether the OES report has been filed as of the date of this report.

LOCAL AGENCY USE ONLY: To avoid duplicate notifications pursuant to Health and safety Code Section 25180.7, a designated government employee should sign and date the form in this block. A signature here does not mean that the leak has been determined to pose a significant threat to human health or safety, only that notification procedures have been followed if required.

REPORTED BY: Enter name, telephone number, and address. Indicate which party you represent and provide company or agency name.

SIGNATURE: Sign the form in the space provided.

RESPONSIBLE PARTY: Enter the name, telephone number, contact person, and address of the party responsible for the leak. The Responsible Party would normally be the tank owner.

SITE LOCATION: Enter information regarding the tank facility. At a minimum, you must provide the facility name and full site address.

IMPLEMENTING AGENCIES: Enter the names of the local agency and Regional Water Quality Control Board having jurisdiction over the site.

SUBSTANCES INVOLVED: Enter the name and quantity lost of the hazardous substance(s) involved. If more than two substances leaked, list the two of most concern for cleanup.

DISCOVERY/ABATEMENT: Provide information regarding the discovery and abatement of the leak.

SOURCE/CAUSE: Indicate the source(s) of leak. Check box(es) indicating the cause(s) of leak.

CASE TYPE: Check one box only. Indicate the Case Type category for this leak. Case Type is based on the most sensitive resource affected. For example, if both soil and ground water have been affected, Case Type will be "Groundwater." Indicate "Drinking Water" only if one or more municipal or domestic water wells have actually been affected. A "Groundwater" designation does not imply that the affected water cannot be, or is not, used for drinking water, but only that water wells have not yet been affected. It is understood that Case Type may change upon further investigation.

CURRENT STATUS: Check one box only. Indicate the category which best describes the Current Status of the case. The response should be relative to the Case Type. For example, if the Case Type is "Groundwater," then Current Status should refer to the status of the ground water investigation or cleanup, as opposed to that of soil. Descriptions of options are as follows:

- **No Action Taken** – No action has been taken by the Responsible Party beyond initial reporting of the leak.
- **Leak Being Confirmed** – A leak is suspected at the site, but has not yet been confirmed.
- **Remediation Plan** – Remediation Plan submitted evaluating long term remediation options. Proposal and implementation schedule for appropriate remediation options also submitted.
- **Preliminary Site Assessment Workplan Submitted** – Workplan/proposal requested of/submitted by Responsible Party to determine whether ground water has been, or will be, impacted as a result of the release.
- **Preliminary Site Assessment Underway** – Workplan is being implemented.
- **Case Closed** – Regional Water Quality Control Board and local agency Local Oversight Program (LOP) agree that no further work is necessary at the site.
- **Pollution Characterization** – Responsible Party is in the process of fully defining the extent of contamination in soil and ground water and assessing impacts on surface and/or ground water.
- **Post Cleanup Monitoring in Progress** – Periodic ground water or other monitoring at site, as necessary, to verify and/or evaluate the effectiveness of remedial activities.
- **Cleanup Underway** – Remediation Plan is being implemented.

IMPORTANT: THE INFORMATION PROVIDED ON THIS FORM IS INTENDED FOR GENERAL STATISTICAL PURPOSES ONLY AND IS NOT TO BE CONSTRUED AS REPRESENTING THE OFFICIAL POSITION OF ANY GOVERNMENTAL AGENCY.

REMEDIAL ACTION: Indicate which actions have been used to clean up or remediate the leak. Descriptions of options are as follows:

- **Cap Site** – Install horizontal impermeable layer to reduce rainfall infiltration.
- **Containment Barrier** – Install vertical dike to block horizontal movement of contaminants.
- **Excavate and Dispose** – Remove contaminated soil and dispose at approved site.
- **Excavate and Treat** – Remove contaminated soil and treat (includes spreading or land farming).
- **Remove Free Product** – Remove floating product from water table.
- **Pump and Treat Groundwater** – Generally employed to remove dissolved contaminants.
- **Enhanced Biodegradation** – Use of any available technology to promote bacterial decomposition of contaminants.
- **Replace Supply** – Provide alternate water supply to affected parties.
- **Treatment at Hookup** – Install water treatment devices at each dwelling or other place of use.
- **Vacuum Extract** – Use pumps or blowers to draw air through soil.
- **Vent Soil** – Bore holes in soil to allow volatilization of contaminants.
- **No Action Required** – Incident is minor, requiring no remedial action.

COMMENTS: Use this space to elaborate on any aspects of the incident.

DISTRIBUTION: If this form is completed by the tank owner or his/her agent, retain a copy and forward the original to your local tank permitting agency for distribution.

- Original – Local UST permitting agency. (Agency contact information is available at www.unidocs.org.)
- Copy – Regional Water Quality Control Board. (Boundaries and contact information are available at www.swrcb.ca.gov/regions.html.)
- Copy – Local Oversight Program (LOP) agency. (Agency contact information is available at www.unidocs.org.)
- Copy – Local Health Officer and County Board of Supervisors or their designee to receive Proposition 65 notifications.
- Copy – Owner/Responsible Party.



Associated Laboratories

806 N. Batavia - Orange, CA 92868
Tel (714)771-6900 Fax (714)538-1209
www.associatedlabs.com
Info@associatedlabs.com



Client: Advanced Environmental Concepts Inc.
Address: 220 E. Truxtun Ave.
Bakersfield, CA 93305
Attn: Jonathan Buck

Lab Request: 322938
Report Date: 05/22/2013
Date Received: 05/11/2013
Client ID: 10022

Comments: Johnny Quik
2126 Taft Highway, Old River, CA

This laboratory request covers the following listed samples which were analyzed for the parameters indicated on the attached Analytical Result Report. All analyses were conducted using the appropriate methods. Methods accredited by NELAC are indicated on the report. This cover letter is an integral part of the final report.

<u>Sample #</u>	<u>Client Sample ID</u>
322938-001	NE-T-2'
322938-002	NE-T-6'
322938-003	E-C-T-2'
322938-004	E-C-T-6'
322938-005	SE-T-2'
322938-006	SE-T-6'
322938-007	NW-T-2'
322938-008	NW-T-6'
322938-009	W-C-T-2'
322938-010	W-C-T-6'
322938-011	SW-T-2'
322938-012	SW-T-6'

DRAFT

Thank you for the opportunity to be of service to your company. Please feel free to call if there are any questions regarding this report or if we can be of further service.

ASSOCIATED LABORATORIES by,

Nina Prasad
President

NOTE: Unless notified in writing, all samples will be discarded by appropriate disposal protocol 45 days from date reported.

The reports of the Associated Laboratories are confidential property of our clients and may not be reproduced or used for publication in part or in full without our written permission. This is for the mutual protection of the public, our clients, and ourselves.


TESTING & CONSULTING
Chemical
Microbiological
Environmental

Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 14:20 **Site:** **Client Sample #:** NE-T-2' **Sample Type:**
Sample #: 322938-001

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes	
Method: EPA 8015 NELAC		Prep Method: EPA 3545		QCBatchID: QC1136596					
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt		
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt		
TPH (C28 to C36)	9.51	1	2.1	5	mg/Kg	05/15/13	lyt		

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	95	60-140	

Method: EPA 8260 NELAC		Prep Method: EPA 5035		QCBatchID: QC1136527					
1,1,1,2-Tetrachloroethane	ND	1	0.24	5	ug/Kg	05/13/13	nicollez		
1,1,1-Trichloroethane	ND	1	0.15	5	ug/Kg	05/13/13	nicollez		
1,1,2,2-Tetrachloroethane	ND	1	0.29	5	ug/Kg	05/13/13	nicollez		
1,1,2-Trichloroethane	ND	1	0.22	5	ug/Kg	05/13/13	nicollez		
1,1,2-Trichlorotrifluoroethane	ND	1	0.74	5	ug/Kg	05/13/13	nicollez		
1,1-Dichloroethane	ND	1	0.23	5	ug/Kg	05/13/13	nicollez		
1,1-Dichloroethene	ND	1	0.18	5	ug/Kg	05/13/13	nicollez		
1,1-Dichloropropene	ND	1	0.21	5	ug/Kg	05/13/13	nicollez		
1,2,3-Trichlorobenzene	ND	1	0.18	5	ug/Kg	05/13/13	nicollez		
1,2,3-Trichloropropane	ND	1	0.2	5	ug/Kg	05/13/13	nicollez		
1,2,4-Trichlorobenzene	ND	1	0.33	5	ug/Kg	05/13/13	nicollez		
1,2,4-Trimethylbenzene	ND	1	0.28	5	ug/Kg	05/13/13	nicollez		
1,2-Dibromo-3-chloropropane	ND	1	0.2	5	ug/Kg	05/13/13	nicollez		
1,2-Dibromoethane	ND	1	0.12	5	ug/Kg	05/13/13	nicollez		
1,2-Dichlorobenzene	ND	1	0.18	5	ug/Kg	05/13/13	nicollez		
1,2-Dichloroethane	ND	1	0.14	5	ug/Kg	05/13/13	nicollez		
1,2-Dichloropropane	ND	1	0.34	5	ug/Kg	05/13/13	nicollez		
1,3,5-Trimethylbenzene	ND	1	0.23	5	ug/Kg	05/13/13	nicollez		
1,3-Dichlorobenzene	ND	1	0.21	5	ug/Kg	05/13/13	nicollez		
1,3-Dichloropropane	ND	1	0.19	5	ug/Kg	05/13/13	nicollez		
1,4-Dichlorobenzene	ND	1	0.24	5	ug/Kg	05/13/13	nicollez		
2,2-Dichloropropane	ND	1	0.19	5	ug/Kg	05/13/13	nicollez		
2-Butanone (MEK)	ND	1	0.72	100	ug/Kg	05/13/13	nicollez		
2-Chloroethyl Vinyl Ether	ND	1	0.3	5	ug/Kg	05/13/13	nicollez		
2-Chlorotoluene	ND	1	0.25	5	ug/Kg	05/13/13	nicollez		
4-Chlorotoluene	ND	1	0.22	5	ug/Kg	05/13/13	nicollez		
4-Isopropyltoluene	ND	1	0.27	5	ug/Kg	05/13/13	nicollez		
4-Methyl-2-pentanone (MIBK)	ND	1	0.17	5	ug/Kg	05/13/13	nicollez		
Acetone	ND	1	10	100	ug/Kg	05/13/13	nicollez		
Allyl Chloride	ND	1	0.14	5	ug/Kg	05/13/13	nicollez		
Benzene	ND	1	0.18	5	ug/Kg	05/13/13	nicollez		
Bromobenzene	ND	1	0.3	5	ug/Kg	05/13/13	nicollez		
Bromochloromethane	ND	1	0.18	5	ug/Kg	05/13/13	nicollez		
Bromodichloromethane	ND	1	0.2	5	ug/Kg	05/13/13	nicollez		
Bromoform	ND	1	0.19	5	ug/Kg	05/13/13	nicollez		
Bromomethane	ND	1	0.22	5	ug/Kg	05/13/13	nicollez		
Carbon Tetrachloride	ND	1	0.18	5	ug/Kg	05/13/13	nicollez		
Chlorobenzene	ND	1	0.18	5	ug/Kg	05/13/13	nicollez		
Chlorodibromomethane	ND	1	0.19	5	ug/Kg	05/13/13	nicollez		
Chloroethane	ND	1	0.2	5	ug/Kg	05/13/13	nicollez		
Chloroform	ND	1	0.17	5	ug/Kg	05/13/13	nicollez		
Chloromethane	ND	1	0.21	5	ug/Kg	05/13/13	nicollez		
cis-1,2-Dichloroethene	ND	1	0.2	5	ug/Kg	05/13/13	nicollez		



ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 14:20 **Site:** **Client Sample #:** NE-T-2' **Sample Type:**
Sample #: 322938-001

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
cis-1,3-dichloropropene	ND	1	0.2	5	ug/Kg	05/13/13	nicollez	
cis-1,4-dichloro-2-butene	ND	1	0.2	5	ug/Kg	05/13/13	nicollez	
Dibromomethane	ND	1	0.23	5	ug/Kg	05/13/13	nicollez	
Dichlorodifluoromethane	ND	1	0.23	5	ug/Kg	05/13/13	nicollez	
Di-isopropyl ether (DIPE)	ND	1	0.21	5	ug/Kg	05/13/13	nicollez	
Ethylbenzene	ND	1	0.25	5	ug/Kg	05/13/13	nicollez	
Ethyl-tertbutylether (ETBE)	ND	1	0.42	5	ug/Kg	05/13/13	nicollez	
Hexachlorobutadiene	ND	1	0.38	5	ug/Kg	05/13/13	nicollez	
Isopropylbenzene	ND	1	0.17	5	ug/Kg	05/13/13	nicollez	
m and p-Xylene	ND	1	0.21	5	ug/Kg	05/13/13	nicollez	
Methylene chloride	ND	1	0.22	5	ug/Kg	05/13/13	nicollez	
Methyl-t-butyl Ether (MTBE)	ND	1	0.25	5	ug/Kg	05/13/13	nicollez	
Naphthalene	ND	1	0.28	5	ug/Kg	05/13/13	nicollez	
N-butylbenzene	ND	1	0.16	5	ug/Kg	05/13/13	nicollez	
N-propylbenzene	ND	1	0.19	5	ug/Kg	05/13/13	nicollez	
o-Xylene	ND	1	0.13	5	ug/Kg	05/13/13	nicollez	
Sec-butylbenzene	ND	1	0.34	5	ug/Kg	05/13/13	nicollez	
Styrene	ND	1	0.23	5	ug/Kg	05/13/13	nicollez	
t-Butyl alcohol (TBA)	ND	1	8.8	10	ug/Kg	05/13/13	nicollez	
Tert-amylmethylether (TAME)	ND	1	0.19	5	ug/Kg	05/13/13	nicollez	
Tert-butylbenzene	ND	1	0.18	5	ug/Kg	05/13/13	nicollez	
Tetrachloroethene	ND	1	0.2	5	ug/Kg	05/13/13	nicollez	
Toluene	ND	1	0.23	5	ug/Kg	05/13/13	nicollez	
trans-1,2-dichloroethene	ND	1	0.23	5	ug/Kg	05/13/13	nicollez	
trans-1,3-dichloropropene	ND	1	0.14	5	ug/Kg	05/13/13	nicollez	
trans-1,4-dichloro-2-butene	ND	1	0.38	5	ug/Kg	05/13/13	nicollez	
Trichloroethene	ND	1	0.39	5	ug/Kg	05/13/13	nicollez	
Trichlorofluoromethane	ND	1	0.25	5	ug/Kg	05/13/13	nicollez	
Vinyl Chloride	ND	1	0.18	5	ug/Kg	05/13/13	nicollez	
Xylenes (Total)	ND	1	0.45	5	ug/Kg	05/13/13	nicollez	

Analyte	% Recovery	Limits	Notes
1,2-Dichloroethane-d4 (SUR)	110	70-145	
4-Bromofluorobenzene (SUR)	96	70-145	
Dibromodifluoromethane (SUR)	97	70-145	
Toluene-d8 (SUR)	102	70-145	

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid Client: Advanced Environmental Concepts Inc. Collector: Client
 Sampled: 05/09/2013 14:25 Site:
 Sample #: 322938-002 Client Sample #: NE-T-6' Sample Type:

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Method: EPA 8015 NELAC	Prep Method: EPA 3545		QCBatchID: QC1136596					
TPH (C6 to C10)	1270	20	34	60	mg/Kg	05/17/13	lyt	
TPH (C10 to C22)	788	20	8	60	mg/Kg	05/17/13	lyt	
TPH (C28 to C36)	ND	20	42	100	mg/Kg	05/17/13	lyt	

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	365	60-140	S

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Method: EPA 8260 NELAC	Prep Method: EPA 5035		QCBatchID: QC1136684					
1,1,1,2-Tetrachloroethane	ND	1000	240	5000	ug/Kg	05/17/13	nicollez	
1,1,1-Trichloroethane	ND	1000	150	5000	ug/Kg	05/17/13	nicollez	
1,1,2,2-Tetrachloroethane	ND	1000	290	5000	ug/Kg	05/17/13	nicollez	
1,1,2-Trichloroethane	ND	1000	220	5000	ug/Kg	05/17/13	nicollez	
1,1,2-Trichlorotrifluoroethane	ND	1000	740	5000	ug/Kg	05/17/13	nicollez	
1,1-Dichloroethane	ND	1000	230	5000	ug/Kg	05/17/13	nicollez	
1,1-Dichloroethene	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
1,1-Dichloropropane	ND	1000	210	5000	ug/Kg	05/17/13	nicollez	
1,2,3-Trichlorobenzene	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
1,2,3-Trichloropropane	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	
1,2,4-Trichlorobenzene	ND	1000	330	5000	ug/Kg	05/17/13	nicollez	
1,2,4-Trimethylbenzene	160000	1000	280	5000	ug/Kg	05/17/13	nicollez	
1,2-Dibromo-3-chloropropane	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	
1,2-Dibromoethane	ND	1000	120	5000	ug/Kg	05/17/13	nicollez	
1,2-Dichlorobenzene	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
1,2-Dichloroethane	ND	1000	140	5000	ug/Kg	05/17/13	nicollez	
1,2-Dichloropropane	ND	1000	340	5000	ug/Kg	05/17/13	nicollez	
1,3,5-Trimethylbenzene	160000	1000	230	5000	ug/Kg	05/17/13	nicollez	
1,3-Dichlorobenzene	ND	1000	210	5000	ug/Kg	05/17/13	nicollez	
1,3-Dichloropropane	ND	1000	190	5000	ug/Kg	05/17/13	nicollez	
1,4-Dichlorobenzene	ND	1000	240	5000	ug/Kg	05/17/13	nicollez	
2,2-Dichloropropane	ND	1000	190	5000	ug/Kg	05/17/13	nicollez	
2-Butanone (MEK)	ND	1000	720	100000	ug/Kg	05/17/13	nicollez	
2-Chloroethyl Vinyl Ether	ND	1000	300	5000	ug/Kg	05/17/13	nicollez	
2-Chlorotoluene	ND	1000	250	5000	ug/Kg	05/17/13	nicollez	
4-Chlorotoluene	ND	1000	220	5000	ug/Kg	05/17/13	nicollez	
4-Isopropyltoluene	13000	1000	270	5000	ug/Kg	05/17/13	nicollez	
4-Methyl-2-pentanone (MIBK)	ND	1000	170	5000	ug/Kg	05/17/13	nicollez	
Acetone	ND	1000	10000	100000	ug/Kg	05/17/13	nicollez	
Allyl Chloride	ND	1000	140	5000	ug/Kg	05/17/13	nicollez	
Benzene	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
Bromobenzene	ND	1000	300	5000	ug/Kg	05/17/13	nicollez	
Bromochloromethane	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
Bromodichloromethane	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	
Bromoform	ND	1000	190	5000	ug/Kg	05/17/13	nicollez	
Bromomethane	ND	1000	220	5000	ug/Kg	05/17/13	nicollez	
Carbon Tetrachloride	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
Chlorobenzene	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
Chlorodibromomethane	ND	1000	190	5000	ug/Kg	05/17/13	nicollez	
Chloroethane	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	
Chloroform	ND	1000	170	5000	ug/Kg	05/17/13	nicollez	
Chloromethane	ND	1000	210	5000	ug/Kg	05/17/13	nicollez	
cis-1,2-Dichloroethene	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 14:25 **Site:**
Sample #: 322938-002 **Client Sample #:** NE-T-6' **Sample Type:**

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
cis-1,3-dichloropropene	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	
cis-1,4-dichloro-2-butene	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	
Dibromomethane	ND	1000	230	5000	ug/Kg	05/17/13	nicollez	
Dichlorodifluoromethane	ND	1000	230	5000	ug/Kg	05/17/13	nicollez	
Di-isopropyl ether (DIPE)	ND	1000	210	5000	ug/Kg	05/17/13	nicollez	
Ethylbenzene	ND	1000	250	5000	ug/Kg	05/17/13	nicollez	
Ethyl-tertbutylether (ETBE)	ND	1000	420	5000	ug/Kg	05/17/13	nicollez	
Hexachlorobutadiene	ND	1000	380	5000	ug/Kg	05/17/13	nicollez	
Isopropylbenzene	ND	1000	170	5000	ug/Kg	05/17/13	nicollez	
m and p-Xylene	19000	1000	210	5000	ug/Kg	05/17/13	nicollez	
Methylene chloride	ND	1000	220	5000	ug/Kg	05/17/13	nicollez	
Methyl-t-butyl Ether (MTBE)	ND	1000	250	5000	ug/Kg	05/17/13	nicollez	
Naphthalene	26000	1000	280	5000	ug/Kg	05/17/13	nicollez	
N-butylbenzene	56000	1000	160	5000	ug/Kg	05/17/13	nicollez	
N-propylbenzene	ND	1000	190	5000	ug/Kg	05/17/13	nicollez	
o-Xylene	59000	1000	130	5000	ug/Kg	05/17/13	nicollez	
Sec-butylbenzene	ND	1000	340	5000	ug/Kg	05/17/13	nicollez	
Styrene	ND	1000	230	5000	ug/Kg	05/17/13	nicollez	
t-Butyl alcohol (TBA)	ND	1000	8800	10000	ug/Kg	05/17/13	nicollez	
Tert-amylmethylether (TAME)	ND	1000	190	5000	ug/Kg	05/17/13	nicollez	
Tert-butylbenzene	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
Tetrachloroethene	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	
Toluene	ND	1000	230	5000	ug/Kg	05/17/13	nicollez	
trans-1,2-dichloroethene	ND	1000	230	5000	ug/Kg	05/17/13	nicollez	
trans-1,3-dichloropropene	ND	1000	140	5000	ug/Kg	05/17/13	nicollez	
trans-1,4-dichloro-2-butene	ND	1000	380	5000	ug/Kg	05/17/13	nicollez	
Trichloroethene	ND	1000	390	5000	ug/Kg	05/17/13	nicollez	
Trichlorofluoromethane	ND	1000	250	5000	ug/Kg	05/17/13	nicollez	
Vinyl Chloride	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
Xylenes (Total)	78000	1000	450	5000	ug/Kg	05/17/13	nicollez	

Analyte	% Recovery	Limits	Notes
1,2-Dichloroethane-d4 (SUR)	104	70-145	
4-Bromofluorobenzene (SUR)	105	70-145	
Dibromodifluoromethane (SUR)	95	70-145	
Toluene-d8 (SUR)	106	70-145	

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid	Client: Advanced Environmental Concepts Inc.	Collector: Client
Sampled: 05/09/2013 14:32	Site:	
Sample #: 322938-003	Client Sample #: E-C-T-2	Sample Type:

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Method: EPA 8015 NELAC		Prep Method: EPA 3545		QCBatchID: QC1136596				
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt	
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt	
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt	

Analyte	% Recovery	Limits	Notes
Triacotane (SUR)	65	60-140	

Method: EPA 8021 NELAC		Prep Method: EPA 5035		QCBatchID: QC1136586				
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish	
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish	
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish	
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish	
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish	

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	85	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 14:37 **Site:**
Sample #: 322938-004 **Client Sample #:** E-C-T-6' **Sample Type:**

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes	
Method: EPA 8015 <i>NELAC</i>		Prep Method: EPA 3545		QCBatchID: QC1136596					
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt		
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt		
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt		

Analyte	% Recovery	Limits	Notes
<i>Triacotane (SUR)</i>	63	60-140	

Method: EPA 8021 <i>NELAC</i>		Prep Method: EPA 5035		QCBatchID: QC1136586					
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish		
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish		
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish		
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish		
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish		

Analyte	% Recovery	Limits	Notes
<i>4-Bromofluorobenzene (SUR)</i>	93	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid	Client: Advanced Environmental Concepts Inc.	Collector: Client
Sampled: 05/09/2013 14:42	Site:	
Sample #: 322938-005	Client Sample #: SE-T-2'	Sample Type:

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Method: EPA 8015 NELAC		Prep Method: EPA 3545		QCBatchID: QC1136596				
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt	
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt	
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt	

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	75	60-140	

Method: EPA 8021 NELAC		Prep Method: EPA 5035		QCBatchID: QC1136586				
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish	
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish	
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish	
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish	
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish	

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	91	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 14:47 **Site:**
Sample #: 322938-006 **Client Sample #:** SE-T-6' **Sample Type:**

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Method: EPA 8015 <i>NELAC</i>		Prep Method: EPA 3545		QCBatchID: QC1136596				
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt	
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt	
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt	

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	85	60-140	

Method: EPA 8021 <i>NELAC</i>		Prep Method: EPA 5035		QCBatchID: QC1136586				
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish	
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish	
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish	
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish	
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish	

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	93	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 14:55 **Site:**
Sample #: 322938-007 **Client Sample #:** NW-T-2' **Sample Type:**

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes	
Method: EPA 8015 <i>NELAC</i>		Prep Method: EPA 3545		QCBatchID: QC1136596					
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt		
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt		
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt		

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	66	60-140	

Method: EPA 8021 <i>NELAC</i>		Prep Method: EPA 5035		QCBatchID: QC1136586					
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish		
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish		
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish		
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish		
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish		

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	91	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid	Client: Advanced Environmental Concepts Inc.	Collector: Client
Sampled: 05/09/2013 15:00	Site:	
Sample #: 322938-008	Client Sample #: NW-T-6	Sample Type:

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Method: EPA 8015 NELAC		Prep Method: EPA 3545		QCBatchID: QC1136596				
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt	
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt	
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt	

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	93	60-140	

Method: EPA 8021 NELAC		Prep Method: EPA 5035		QCBatchID: QC1136586				
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish	
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish	
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish	
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish	
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish	

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	91	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 15:05 **Site:**
Sample #: 322938-009 **Client Sample #:** W-C-T-2' **Sample Type:**

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes	
Method: EPA 8015 <i>NELAC</i>		Prep Method: EPA 3545		QCBatchID: QC1136596					
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt		
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt		
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt		

Analyte	% Recovery	Limits	Notes
Triacotane (SUR)	69	60-140	

Method: EPA 8021 <i>NELAC</i>		Prep Method: EPA 5035		QCBatchID: QC1136586					
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish		
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish		
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish		
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish		
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish		

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	88	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid	Client: Advanced Environmental Concepts Inc.	Collector: Client
Sampled: 05/09/2013 15:10	Site:	
Sample #: 322938-010	Client Sample #: W-C-T-6'	Sample Type:

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Method: EPA 8015 NELAC		Prep Method: EPA 3545		QCBatchID: QC1136596				
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt	
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt	
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt	

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	95	60-140	

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Method: EPA 8021 NELAC		Prep Method: EPA 5035		QCBatchID: QC1136586				
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish	
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish	
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish	
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish	
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish	

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	92	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 15:15 **Site:** **Client Sample #:** SW-T-2' **Sample Type:**
Sample #: 322938-011

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Method: EPA 8015 NELAC		Prep Method: EPA 3545		QCBatchID: QC1136596				
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt	
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt	
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt	

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	68	60-140	

Method: EPA 8021 NELAC		Prep Method: EPA 5035		QCBatchID: QC1136586				
Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish	
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish	
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish	
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish	
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish	

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	84	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid	Client: Advanced Environmental Concepts Inc.	Collector: Client
Sampled: 05/09/2013 15:22	Site:	
Sample #: 322938-012	Client Sample #: SW-T-6'	Sample Type:

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Method: EPA 8015 NELAC		Prep Method: EPA 3545		QCBatchID: QC1136596				
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt	
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt	
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt	

Analyte	% Recovery	Limits	Notes
Triacotane (SUR)	79	60-140	

Method: EPA 8021 NELAC		Prep Method: EPA 5035		QCBatchID: QC1136586				
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish	
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish	
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish	
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish	
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish	

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	87	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Central Valley Regional Water Quality Control Board

UST File
3201

17 July 2013

Kuljit Ghuman
2126 Taft Highway
Bakersfield, CA 93313

**REVIEW – SOIL ASSESSMENT WORK PLAN, UNDERGROUND STORAGE TANK
RELEASE, JOHNNY QUICK #143, 2126 TAFT HIGHWAY, BAKERSFIELD, KERN COUNTY,
RB CASE 5T15000929**

The *Soil Assessment Work Plan* (Work Plan) dated July 2013, was submitted by the consultant, Advanced Environmental Concepts, Inc. (AEC). The Work Plan is in response to the Central Valley Regional Water Quality Control Board (Central Valley Water Board) staff letter dated 2 July 2013. The Work Plan proposes investigation to define the vertical and lateral extent of petroleum fuel constituents detected in soil during May 2013 underground storage tank (UST) system piping replacement. This letter summarizes the Work Plan, addresses concerns and provides comments.

SUMMARY

The Work Plan proposes three direct-push soil borings. Boring TH-1 will be advanced adjacent to the south side of the northeast fuel dispenser, at the location of known soil contamination, to determine the vertical extent of fuel constituents. Borings TH-2 and TH-3 will be advanced approximately 10 feet west and 15 feet east-southeast of TH-1, respectively, to define the lateral extent of fuel constituents. TH-1 is expected to reach 30 feet below ground surface (bgs) and TH-2 and TH-3 will be advanced to 20 feet bgs. The borings will be sampled at five-foot intervals, beginning at 10 feet bgs in TH-1, and beginning at five feet bgs in TH-2 and TH-3.

Selected soil samples will be submitted to a California-certified laboratory for total petroleum hydrocarbons as gasoline (TPHg); benzene, toluene, ethylbenzene, and xylenes (BTEX); and the fuel oxygenate methyl tertiary butyl ether (MTBE).

A site-specific Health and Safety Plan is included as Appendix B of the Work Plan. AEC will complete a report summarizing the investigation within two weeks of the completion of field work.

COMMENTS

Central Valley Water Board staff concurs with the investigation proposed in the Work Plan, but the following comments need to be incorporated:

1. The frequency of soil sample analysis should be sufficient to determine the distribution and vertical extent of petroleum fuel constituents. The vertical extent of affected soil in

RECEIVED

JUL 23 2013


LV

each boring is to be defined by laboratory analysis of two consecutive samples lacking field evidence of petroleum impact.

2. Lateral extent borings TH-2 and TH-3 need to be advanced to the maximum depth of impacted soil observed in vertical extent boring TH-1.
3. TPHg and total petroleum hydrocarbons as diesel (TPHd) were detected at 1,270 and 788 milligrams per kilogram, respectively, during the May 2013 investigation. TPHd analysis needs to be included at sufficient frequency to determine the extent of diesel constituents.
4. One sample from the most highly contaminated zone between zero and five feet bgs and one sample from the most highly contaminated zone between five and ten feet bgs in each boring needs to be analyzed to determine if the State Water Resources Control Board's *Low Threat Underground Storage Tank Case Closure Policy* (Policy) criteria for Direct Contact and Outdoor Air Exposure are met. At a minimum, analysis for benzene, ethylbenzene and naphthalene should be included.
5. Fieldwork should be conducted in accordance with an updated site-specific Health and Safety Plan.

By 17 October 2013, please submit the investigation report of findings.

Please call me at (559) 445-5504 or email at jwhiting@waterboards.ca.gov if you have any questions, and in advance of fieldwork.



JOHN D. WHITING
Engineering Geologist
PG No. 5951

cc: Lydia V. von Sydow, Kern County Environmental Health Division, Bakersfield
Jonathon Buck, Advanced Environmental Concepts, Inc., Bakersfield

Central Valley Regional Water Quality Control Board

2 July 2013

Kuljit Ghuman
2126 Taft Highway
Bakersfield, CA 93313

UNDERGROUND STORAGE TANK SYSTEM RELEASE, JOHNNY QUIK #143, 2126 TAFT HIGHWAY, BAKERSFIELD, KERN COUNTY, RB CASE 5T15000929

In a letter dated 29 May 2013, the Kern County Environmental Health Division (Kern County) referred the above referenced site to the Central Valley Regional Water Quality Control Board, (Central Valley Water Board) to conduct regulatory oversight of a release of petroleum fuel from the underground storage tank (UST) system. In May 2013, a release of gasoline and diesel fuel was discovered from the system piping that leads to a multi-product fuel dispenser. Analytical results indicated total petroleum hydrocarbons as gasoline and diesel were detected at 1,270 and 788 milligrams per kilogram (mg/kg), respectively, beneath the piping, at a depth of six feet. The petroleum constituents xylenes and naphthalene were also detected at 78 mg/kg, and 26 mg/kg, respectively.

As owner of the property or operator of the UST system, you are a responsible party for the release. State regulations require that responsible parties investigate, and if necessary, clean up such releases.

Health and Safety Code section 25296.10(a) states:

"Each owner, operator, or other responsible party shall take corrective action in response to an unauthorized release in compliance with this chapter and the regulations adopted pursuant to Section 25299.3."

Health and Safety Code section 25296.10(c)(1) states:

"When a local agency, the board, or a regional board requires an owner, operator, or other responsible party to undertake corrective action, including preliminary site assessment and investigation pursuant to an oral or written order, directive, notification, or approval issued pursuant to this section, or pursuant to a cleanup and abatement order or other oral or written directive issued pursuant to Division 7 (commencing with Section 13000) of the Water Code, the owner, operator, or other responsible party shall prepare a work plan that details the corrective action, the owner, operator, or other responsible party shall take..."

You are requested to submit a work plan to assess the extent and concentration of the fuel constituents in soil and groundwater, and identify sensitive environmental receptors within a 1,000-foot radius of the release. You will need to secure the services of an experienced environmental consultant to prepare the work plan. The proposed investigation would be conducted following review and concurrence from the Central Valley Water Board staff. 2013

VF

KERN COUNTY
ENVIRONMENTAL HEALTH SERVICES

The work plan needs to include a time schedule to implement the plan and submit reports. All technical submittals must contain the signature and seal of a California licensed engineer, certified engineering geologist, or professional geologist who is responsible for the content of the submittal. The proposed investigation should provide data to determine whether criteria in the State Water Resources Control Board (State Water Board) *Low-Threat Underground Storage Tank Case Closure Policy* are satisfied.

If there is evidence to support identification of other potentially responsible parties for the UST release, please provide the names and current addresses, the beginning and ending dates and type of involvement, and copies of any documents that would verify the terms and conditions of involvement. Our records indicate that you are the "primary or active" responsible party for the site. Under the "landowner notification" of Health and Safety Code, Section 25299.37.2, all current record owners of fee title to the site are required to be notified of your proposed actions relating to investigation, cleanup, and closure of the UST release. Please provide a complete mailing list of all record fee title owners, and certify in writing that the list is complete and contains the names and addresses of all record fee title owners. If you are the only record fee title owner, please so state. Copy all future correspondence to us regarding this site to the record fee title owners, and encourage them to comment on your proposed actions. If ownership of fee title changes prior to case closure, submit within 30 days of recording a change in ownership, a mailing list of all new record fee title owners and certify that it is complete.


State Water Board regulations require the electronic submittal of information (including reports) pertaining to soil and groundwater relating to the UST cases, into the State Water Board's GeoTracker database system. At this time, the Central Valley Water Board is not prepared to handle reports exclusively in electronic format, and paper copies of reports are also required to be submitted by the specified deadlines.

Lastly, the State Water Board Underground Storage Tank Cleanup Fund Program (Fund) assists owners and operators of underground tanks, and other eligible individuals, by providing reimbursement of expenses associated with the investigation and cleanup of UST releases. We urge you to apply to the Fund. An application form and information are available at the following web page: http://www.waterboards.ca.gov/water_issues/programs/ustcf.

By 15 August 2013, please provide a complete mailing list of all record fee title owners.

By 3 September 2013, please submit a work plan to assess the extent and concentration of fuel constituents, evaluate health risk, and identify sensitive receptors.

If you have any questions, or wish to meet to discuss this case, please contact John Whiting at (559) 445-5504 or by email at jwhiting@waterboards.ca.gov.



JOHN D. WHITING
Engineering Geologist
PG 5951



SHELTON R. GRAY
Senior Engineering Geologist

cc: Lydia V. von Sydow, Kern County Environmental Health Division, Bakersfield
Jonathon Buck, Advanced Environmental Concepts, Inc., Bakersfield



KERN COUNTY
Public Health Services
DEPARTMENT

MATTHEW CONSTANTINE
DIRECTOR

2700 M STREET, SUITE 300 BAKERSFIELD, CALIFORNIA, 93301-2370 VOICE: 661-862-8740 FAX: 661-862-8701 WWW.CO.KERN.CA.US/EH

May 31, 2013

Johnny Quik #143
Attention: Kuljit Ghuman
2126 Taft Hwy
Bakersfield, CA 93313

SUBJECT: Underground Storage Tank Unauthorized Release
Johnny Quik #143
2126 Taft Hwy
Bakersfield, CA 93313

Dear Mr. Ghuman:

The Kern County Environmental Health Division has referred the oversight of the unauthorized release from the underground storage tank system at the Johnny Quik #143 to the Central Valley Regional Water Quality Control Board. They will be contacting you regarding the requirements for assessing and mitigating the release.

As always, this department is available to assist you. If you have any questions or comments, please call Jeffrey Marshall (661) 862-878775.

Sincerely,

Lydia V. von Sydow
Waste Management Technician II
Certified Unified Program Agency



MATTHEW CONSTANTINE
DIRECTOR

2700 M STREET, SUITE 300 BAKERSFIELD, CALIFORNIA, 93301-2370 VOICE: 661-862-8740 FAX: 661-862-8701 WWW.CO.KERN.CA.US/EH

May 29, 2013

Central Valley Region
Regional Water Quality Control Board
Attention: Shelton Gray
1685 "E" Street
Fresno, CA 93706-2007

SUBJECT: Johnny Quik #143
2126 Taft Hwy.
Bakersfield, CA 93313

Dear Mr. Gray:


The Kern County Environmental Health Division is referring the facility noted above to the Central Valley RWQCB for oversight of an unauthorized release from an underground storage tank system. Jeffery Marshall, REHS, is the facility's inspector for Kern County. He can be reached at (661) 862-8775 or marshallj@co.kern.ca.us.

As always, this department is available to assist you. If you have any questions or comments, please call (661) 862-8748.

Sincerely,

A handwritten signature in black ink, appearing to read "Lydia V. von Sydow".

Lydia V. von Sydow
Waste Management Technician II
Certified Unified Program Agency



Associated Laboratories

806 N. Batavia - Orange, CA 92868
Tel (714)771-6900 Fax (714)538-1209
www.associatedlabs.com
Info@associatedlabs.com



Client: Advanced Environmental Concepts Inc.
Address: 220 E. Truxtun Ave.
Bakersfield, CA 93305
Attn: Jonathan Buck

Lab Request: 322938
Report Date: 05/22/2013
Date Received: 05/11/2013
Client ID: 10022

Comments: Johnny Quik
2126 Taft Highway, Old River, CA

This laboratory request covers the following listed samples which were analyzed for the parameters indicated on the attached Analytical Result Report. All analyses were conducted using the appropriate methods. Methods accredited by NELAC are indicated on the report. This cover letter is an integral part of the final report.

<u>Sample #</u>	<u>Client Sample ID</u>
322938-001	NE-T-2'
322938-002	NE-T-6'
322938-003	E-C-T-2'
322938-004	E-C-T-6'
322938-005	SE-T-2'
322938-006	SE-T-6'
322938-007	NW-T-2'
322938-008	NW-T-6'
322938-009	W-C-T-2'
322938-010	W-C-T-6'
322938-011	SW-T-2'
322938-012	SW-T-6'

DRAFT

Thank you for the opportunity to be of service to your company. Please feel free to call if there are any questions regarding this report or if we can be of further service.

ASSOCIATED LABORATORIES by,

Nina Prasad
President

NOTE: Unless notified in writing, all samples will be discarded by appropriate disposal protocol 45 days from date reported.

The reports of the Associated Laboratories are confidential property of our clients and may not be reproduced or used for publication in part or in full without our written permission. This is for the mutual protection of the public, our clients, and ourselves.

TESTING & CONSULTING
Chemical
Microbiological
Environmental

Matrix: Solid
 Sampled: 05/09/2013 14:20
 Sample #: 322938-001

Client: Advanced Environmental Concepts Inc.
 Site:
 Client Sample #: NE-T-2'

Collector: Client
 Sample Type:

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes	
Method: EPA 8015 NELAC		Prep Method: EPA 3545		QCBatchID: QC1136596					
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt		
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt		
TPH (C28 to C36)	9.51	1	2.1	5	mg/Kg	05/15/13	lyt		

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	95	60-140	

Method: EPA 8260 NELAC		Prep Method: EPA 5035		QCBatchID: QC1136527					
1,1,1,2-Tetrachloroethane	ND	1	0.24	5	ug/Kg	05/13/13	nicollez		
1,1,1-Trichloroethane	ND	1	0.15	5	ug/Kg	05/13/13	nicollez		
1,1,2,2-Tetrachloroethane	ND	1	0.29	5	ug/Kg	05/13/13	nicollez		
1,1,2-Trichloroethane	ND	1	0.22	5	ug/Kg	05/13/13	nicollez		
1,1,2-Trichlorotrifluoroethane	ND	1	0.74	5	ug/Kg	05/13/13	nicollez		
1,1-Dichloroethane	ND	1	0.23	5	ug/Kg	05/13/13	nicollez		
1,1-Dichloroethene	ND	1	0.18	5	ug/Kg	05/13/13	nicollez		
1,1-Dichloropropene	ND	1	0.21	5	ug/Kg	05/13/13	nicollez		
1,2,3-Trichlorobenzene	ND	1	0.18	5	ug/Kg	05/13/13	nicollez		
1,2,3-Trichloropropane	ND	1	0.2	5	ug/Kg	05/13/13	nicollez		
1,2,4-Trichlorobenzene	ND	1	0.33	5	ug/Kg	05/13/13	nicollez		
1,2,4-Trimethylbenzene	ND	1	0.28	5	ug/Kg	05/13/13	nicollez		
1,2-Dibromo-3-chloropropane	ND	1	0.2	5	ug/Kg	05/13/13	nicollez		
1,2-Dibromoethane	ND	1	0.12	5	ug/Kg	05/13/13	nicollez		
1,2-Dichlorobenzene	ND	1	0.18	5	ug/Kg	05/13/13	nicollez		
1,2-Dichloroethane	ND	1	0.14	5	ug/Kg	05/13/13	nicollez		
1,2-Dichloropropane	ND	1	0.34	5	ug/Kg	05/13/13	nicollez		
1,3,5-Trimethylbenzene	ND	1	0.23	5	ug/Kg	05/13/13	nicollez		
1,3-Dichlorobenzene	ND	1	0.21	5	ug/Kg	05/13/13	nicollez		
1,3-Dichloropropane	ND	1	0.19	5	ug/Kg	05/13/13	nicollez		
1,4-Dichlorobenzene	ND	1	0.24	5	ug/Kg	05/13/13	nicollez		
2,2-Dichloropropane	ND	1	0.19	5	ug/Kg	05/13/13	nicollez		
2-Butanone (MEK)	ND	1	0.72	100	ug/Kg	05/13/13	nicollez		
2-Chloroethyl Vinyl Ether	ND	1	0.3	5	ug/Kg	05/13/13	nicollez		
2-Chlorotoluene	ND	1	0.25	5	ug/Kg	05/13/13	nicollez		
4-Chlorotoluene	ND	1	0.22	5	ug/Kg	05/13/13	nicollez		
4-Isopropyltoluene	ND	1	0.27	5	ug/Kg	05/13/13	nicollez		
4-Methyl-2-pentanone (MIBK)	ND	1	0.17	5	ug/Kg	05/13/13	nicollez		
Acetone	ND	1	10	100	ug/Kg	05/13/13	nicollez		
Allyl Chloride	ND	1	0.14	5	ug/Kg	05/13/13	nicollez		
Benzene	ND	1	0.18	5	ug/Kg	05/13/13	nicollez		
Bromobenzene	ND	1	0.3	5	ug/Kg	05/13/13	nicollez		
Bromochloromethane	ND	1	0.18	5	ug/Kg	05/13/13	nicollez		
Bromodichloromethane	ND	1	0.2	5	ug/Kg	05/13/13	nicollez		
Bromoform	ND	1	0.19	5	ug/Kg	05/13/13	nicollez		
Bromomethane	ND	1	0.22	5	ug/Kg	05/13/13	nicollez		
Carbon Tetrachloride	ND	1	0.18	5	ug/Kg	05/13/13	nicollez		
Chlorobenzene	ND	1	0.18	5	ug/Kg	05/13/13	nicollez		
Chlorodibromomethane	ND	1	0.19	5	ug/Kg	05/13/13	nicollez		
Chloroethane	ND	1	0.2	5	ug/Kg	05/13/13	nicollez		
Chloroform	ND	1	0.17	5	ug/Kg	05/13/13	nicollez		
Chloromethane	ND	1	0.21	5	ug/Kg	05/13/13	nicollez		
cis-1,2-Dichloroethene	ND	1	0.2	5	ug/Kg	05/13/13	nicollez		

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid

Client: Advanced Environmental Concepts Inc.

Collector: Client

Sampled: 05/09/2013 14:20

Site:

Sample #: 322938-001

Client Sample #: NE-T-2'

Sample Type:

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
cis-1,3-dichloropropene	ND	1	0.2	5	ug/Kg	05/13/13	nicollez	
cis-1,4-dichloro-2-butene	ND	1	0.2	5	ug/Kg	05/13/13	nicollez	
Dibromomethane	ND	1	0.23	5	ug/Kg	05/13/13	nicollez	
Dichlorodifluoromethane	ND	1	0.23	5	ug/Kg	05/13/13	nicollez	
Di-isopropyl ether (DIPE)	ND	1	0.21	5	ug/Kg	05/13/13	nicollez	
Ethylbenzene	ND	1	0.25	5	ug/Kg	05/13/13	nicollez	
Ethyl-terbutylether (ETBE)	ND	1	0.42	5	ug/Kg	05/13/13	nicollez	
Hexachlorobutadiene	ND	1	0.38	5	ug/Kg	05/13/13	nicollez	
Isopropylbenzene	ND	1	0.17	5	ug/Kg	05/13/13	nicollez	
m and p-Xylene	ND	1	0.21	5	ug/Kg	05/13/13	nicollez	
Methylene chloride	ND	1	0.22	5	ug/Kg	05/13/13	nicollez	
Methyl-t-butyl Ether (MTBE)	ND	1	0.25	5	ug/Kg	05/13/13	nicollez	
Naphthalene	ND	1	0.28	5	ug/Kg	05/13/13	nicollez	
N-butylbenzene	ND	1	0.16	5	ug/Kg	05/13/13	nicollez	
N-propylbenzene	ND	1	0.19	5	ug/Kg	05/13/13	nicollez	
o-Xylene	ND	1	0.13	5	ug/Kg	05/13/13	nicollez	
Sec-butylbenzene	ND	1	0.34	5	ug/Kg	05/13/13	nicollez	
Styrene	ND	1	0.23	5	ug/Kg	05/13/13	nicollez	
t-Butyl alcohol (TBA)	ND	1	8.8	10	ug/Kg	05/13/13	nicollez	
Tert-amylmethylether (TAME)	ND	1	0.19	5	ug/Kg	05/13/13	nicollez	
Tert-butylbenzene	ND	1	0.18	5	ug/Kg	05/13/13	nicollez	
Tetrachloroethene	ND	1	0.2	5	ug/Kg	05/13/13	nicollez	
Toluene	ND	1	0.23	5	ug/Kg	05/13/13	nicollez	
trans-1,2-dichloroethene	ND	1	0.23	5	ug/Kg	05/13/13	nicollez	
trans-1,3-dichloropropene	ND	1	0.14	5	ug/Kg	05/13/13	nicollez	
trans-1,4-dichloro-2-butene	ND	1	0.38	5	ug/Kg	05/13/13	nicollez	
Trichloroethene	ND	1	0.39	5	ug/Kg	05/13/13	nicollez	
Trichlorofluoromethane	ND	1	0.25	5	ug/Kg	05/13/13	nicollez	
Vinyl Chloride	ND	1	0.18	5	ug/Kg	05/13/13	nicollez	
Xylenes (Total)	ND	1	0.45	5	ug/Kg	05/13/13	nicollez	

Analyte	% Recovery	Limits	Notes
1,2-Dichloroethane-d4 (SUR)	110	70-145	
4-Bromofluorobenzene (SUR)	96	70-145	
Dibromodifluoromethane (SUR)	97	70-145	
Toluene-d8 (SUR)	102	70-145	

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor

ASSOCIATED LABORATORIES

Analytical Results Report

Lab Request 322938 Page 3 of 15



Matrix: Solid Client: Advanced Environmental Concepts Inc. Collector: Client
 Sampled: 05/09/2013 14:25 Site: 1
 Sample #: 322938-002 Client Sample #: NE-T-6' Sample Type:

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Method: EPA 8015 NELAC	Prep Method: EPA 3545		QCBatchID: QC1136596					
TPH (C6 to C10)	1270	20	34	60	mg/Kg	05/17/13	lyt	
TPH (C10 to C22)	788	20	8	60	mg/Kg	05/17/13	lyt	
TPH (C28 to C36)	ND	20	42	100	mg/Kg	05/17/13	lyt	

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	365	60-140	S

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Method: EPA 8260 NELAC	Prep Method: EPA 5035		QCBatchID: QC1136684					
1,1,1,2-Tetrachloroethane	ND	1000	240	5000	ug/Kg	05/17/13	nicollez	
1,1,1-Trichloroethane	ND	1000	150	5000	ug/Kg	05/17/13	nicollez	
1,1,2,2-Tetrachloroethane	ND	1000	290	5000	ug/Kg	05/17/13	nicollez	
1,1,2-Trichloroethane	ND	1000	220	5000	ug/Kg	05/17/13	nicollez	
1,1,2-Trichlorotrifluoroethane	ND	1000	740	5000	ug/Kg	05/17/13	nicollez	
1,1-Dichloroethane	ND	1000	230	5000	ug/Kg	05/17/13	nicollez	
1,1-Dichloroethene	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
1,1-Dichloropropene	ND	1000	210	5000	ug/Kg	05/17/13	nicollez	
1,2,3-Trichlorobenzene	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
1,2,3-Trichloropropane	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	
1,2,4-Trichlorobenzene	ND	1000	330	5000	ug/Kg	05/17/13	nicollez	
1,2,4-Trimethylbenzene	160000	1000	280	5000	ug/Kg	05/17/13	nicollez	
1,2-Dibromo-3-chloropropane	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	
1,2-Dibromoethane	ND	1000	120	5000	ug/Kg	05/17/13	nicollez	
1,2-Dichlorobenzene	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
1,2-Dichloroethane	ND	1000	140	5000	ug/Kg	05/17/13	nicollez	
1,2-Dichloropropane	ND	1000	340	5000	ug/Kg	05/17/13	nicollez	
1,3,5-Trimethylbenzene	160000	1000	230	5000	ug/Kg	05/17/13	nicollez	
1,3-Dichlorobenzene	ND	1000	210	5000	ug/Kg	05/17/13	nicollez	
1,3-Dichloropropane	ND	1000	190	5000	ug/Kg	05/17/13	nicollez	
1,4-Dichlorobenzene	ND	1000	240	5000	ug/Kg	05/17/13	nicollez	
2,2-Dichloropropane	ND	1000	190	5000	ug/Kg	05/17/13	nicollez	
2-Butanone (MEK)	ND	1000	720	100000	ug/Kg	05/17/13	nicollez	
2-Chloroethyl Vinyl Ether	ND	1000	300	5000	ug/Kg	05/17/13	nicollez	
2-Chlorotoluene	ND	1000	250	5000	ug/Kg	05/17/13	nicollez	
4-Chlorotoluene	ND	1000	220	5000	ug/Kg	05/17/13	nicollez	
4-Isopropyltoluene	13000	1000	270	5000	ug/Kg	05/17/13	nicollez	
4-Methyl-2-pentanone (MIBK)	ND	1000	170	5000	ug/Kg	05/17/13	nicollez	
Acetone	ND	1000	10000	100000	ug/Kg	05/17/13	nicollez	
Allyl Chloride	ND	1000	140	5000	ug/Kg	05/17/13	nicollez	
Benzene	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
Bromobenzene	ND	1000	300	5000	ug/Kg	05/17/13	nicollez	
Bromochloromethane	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
Bromodichloromethane	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	
Bromoform	ND	1000	190	5000	ug/Kg	05/17/13	nicollez	
Bromomethane	ND	1000	220	5000	ug/Kg	05/17/13	nicollez	
Carbon Tetrachloride	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
Chlorobenzene	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
Chlorodibromomethane	ND	1000	190	5000	ug/Kg	05/17/13	nicollez	
Chloroethane	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	
Chloroform	ND	1000	170	5000	ug/Kg	05/17/13	nicollez	
Chloromethane	ND	1000	210	5000	ug/Kg	05/17/13	nicollez	
cis-1,2-Dichloroethene	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 14:25 **Site:**
Sample #: 322938-002 **Client Sample #:** NE-T-6' **Sample Type:**

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
cis-1,3-dichloropropene	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	
cis-1,4-dichloro-2-butene	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	
Dibromomethane	ND	1000	230	5000	ug/Kg	05/17/13	nicollez	
Dichlorodifluoromethane	ND	1000	230	5000	ug/Kg	05/17/13	nicollez	
Di-isopropyl ether (DIPE)	ND	1000	210	5000	ug/Kg	05/17/13	nicollez	
Ethylbenzene	ND	1000	250	5000	ug/Kg	05/17/13	nicollez	
Ethyl-tertbutylether (ETBE)	ND	1000	420	5000	ug/Kg	05/17/13	nicollez	
Hexachlorobutadiene	ND	1000	380	5000	ug/Kg	05/17/13	nicollez	
Isopropylbenzene	ND	1000	170	5000	ug/Kg	05/17/13	nicollez	
m and p-Xylene	19000	1000	210	5000	ug/Kg	05/17/13	nicollez	
Methylene chloride	ND	1000	220	5000	ug/Kg	05/17/13	nicollez	
Methyl-t-butyl Ether (MTBE)	ND	1000	250	5000	ug/Kg	05/17/13	nicollez	
Naphthalene	26000	1000	280	5000	ug/Kg	05/17/13	nicollez	
N-butylbenzene	56000	1000	160	5000	ug/Kg	05/17/13	nicollez	
N-propylbenzene	ND	1000	190	5000	ug/Kg	05/17/13	nicollez	
o-Xylene	59000	1000	130	5000	ug/Kg	05/17/13	nicollez	
Sec-butylbenzene	ND	1000	340	5000	ug/Kg	05/17/13	nicollez	
Styrene	ND	1000	230	5000	ug/Kg	05/17/13	nicollez	
t-Butyl alcohol (TBA)	ND	1000	8800	10000	ug/Kg	05/17/13	nicollez	
Tert-amylmethylether (TAME)	ND	1000	190	5000	ug/Kg	05/17/13	nicollez	
Tert-butylbenzene	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
Tetrachloroethene	ND	1000	200	5000	ug/Kg	05/17/13	nicollez	
Toluene	ND	1000	230	5000	ug/Kg	05/17/13	nicollez	
trans-1,2-dichloroethene	ND	1000	230	5000	ug/Kg	05/17/13	nicollez	
trans-1,3-dichloropropene	ND	1000	140	5000	ug/Kg	05/17/13	nicollez	
trans-1,4-dichloro-2-butene	ND	1000	380	5000	ug/Kg	05/17/13	nicollez	
Trichloroethene	ND	1000	390	5000	ug/Kg	05/17/13	nicollez	
Trichlorofluoromethane	ND	1000	250	5000	ug/Kg	05/17/13	nicollez	
Vinyl Chloride	ND	1000	180	5000	ug/Kg	05/17/13	nicollez	
Xylenes (Total)	78000	1000	450	5000	ug/Kg	05/17/13	nicollez	

Analyte	% Recovery	Limits	Notes
1,2-Dichloroethane-d4 (SUR)	104	70-145	
4-Bromofluorobenzene (SUR)	105	70-145	
Dibromodifluoromethane (SUR)	95	70-145	
Toluene-d8 (SUR)	106	70-145	

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 14:32 **Site:**
Sample #: 322938-003 **Client Sample #:** E-C-T-2' **Sample Type:**

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes	
Method: EPA 8015 <i>NELAC</i>		Prep Method: EPA 3545		QCBatchID: QC1136596					
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt		
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt		
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt		

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	65	60-140	

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes	
Method: EPA 8021 <i>NELAC</i>		Prep Method: EPA 5035		QCBatchID: QC1136586					
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish		
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish		
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish		
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish		
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish		

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	85	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 14:37 **Site:** **Sample Type:**
Sample #: 322938-004 **Client Sample #:** E-C-T-6

Analyte **Result** **DF** **MDL** **RDL** **Units** **Analyzed** **By** **Notes**
Method: EPA 8015 *NELAC* **Prep Method:** EPA 3545 **QCBatchID:** QC1136596

TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt	
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt	
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt	

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	63	60-140	

Method: EPA 8021 *NELAC* **Prep Method:** EPA 5035 **QCBatchID:** QC1136586

Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish	
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish	
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish	
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish	
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish	

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	93	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid Client: Advanced Environmental Concepts Inc. Collector: Client
 Sampled: 05/09/2013 14:42 Site:
 Sample #: 322938-005 Client Sample #: SE-T-2' Sample Type:

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes	
Method: EPA 8015 <i>NELAC</i>		Prep Method: EPA 3545		QCBatchID: QC1136596					
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt		
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt		
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt		

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	75	60-140	

Method: EPA 8021 <i>NELAC</i>		Prep Method: EPA 5035		QCBatchID: QC1136586					
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish		
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish		
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish		
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish		
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish		

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	91	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor

ASSOCIATED LABORATORIES

Analytical Results Report
 Lab Request 322938 Page 8 of 15



Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 14:47 **Site:**
Sample #: 322938-006 **Client Sample #:** SE-T-6' **Sample Type:**

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Method: EPA 8015 <i>NELAC</i>		Prep Method: EPA 3545			QCBatchID: QC1136596			
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt	
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt	
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt	

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	85	60-140	

Method: EPA 8021 <i>NELAC</i>		Prep Method: EPA 5035			QCBatchID: QC1136586			
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish	
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish	
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish	
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish	
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish	

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	93	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 14:55 **Site:**
Sample #: 322938-007 **Client Sample #:** NW-T-2' **Sample Type:**

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes	
Method: EPA 8015 <i>NELAC</i>		Prep Method: EPA 3545		QCBatchID: QC1136596					
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt		
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt		
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt		

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	66	60-140	

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes	
Method: EPA 8021 <i>NELAC</i>		Prep Method: EPA 5035		QCBatchID: QC1136586					
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish		
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish		
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish		
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish		
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish		

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	91	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor

ASSOCIATED LABORATORIES

Analytical Results Report

Lab Request 322938 Page 10 of 15



Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 15:00 **Site:**
Sample #: 322938-008 **Client Sample #:** NW-T-6' **Sample Type:**

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes	
Method: EPA 8015 <i>NELAC</i>		Prep Method: EPA 3545		QCBatchID: QC1136596					
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt		
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt		
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt		

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	93	60-140	

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes	
Method: EPA 8021 <i>NELAC</i>		Prep Method: EPA 5035		QCBatchID: QC1136586					
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish		
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish		
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish		
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish		
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish		

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	91	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid	Client: Advanced Environmental Concepts Inc.	Collector: Client
Sampled: 05/09/2013 15:05	Site:	
Sample #: 322938-009	Client Sample #: W-C-T-2'	Sample Type:

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes	
Method: EPA 8015 NELAC		Prep Method: EPA 3545		QCBatchID: QC1136596					
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt		
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt		
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt		

Analyte	% Recovery	Limits	Notes
Triacotane (SUR)	69	60-140	

Method: EPA 8021 NELAC		Prep Method: EPA 5035		QCBatchID: QC1136586					
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish		
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish		
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish		
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish		
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish		

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	88	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



Matrix: Solid	Client: Advanced Environmental Concepts Inc.	Collector: Client
Sampled: 05/09/2013 15:10	Site:	
Sample #: 322938-010	Client Sample #: W-C-T-6'	Sample Type:

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Method: EPA 8015 <i>NELAC</i>	Prep Method: EPA 3545		QCBatchID: QC1136596					
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt	
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt	
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt	

Analyte	% Recovery	Limits	Notes
Triacontane (SUR)	95	60-140	

Method: EPA 8021 <i>NELAC</i>	Prep Method: EPA 5035		QCBatchID: QC1136586					
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish	
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish	
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish	
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish	
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish	

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	92	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor

ASSOCIATED LABORATORIES

Analytical Results Report

Lab Request 322938 Page 13 of 15



Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 15:15 **Site:** **Sample Type:**
Sample #: 322938-011 **Client Sample #:** SW-T-2'

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes	
Method: EPA 8015 <i>NELAC</i>		Prep Method: EPA 3545		QCBatchID: QC1136596					
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt		
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt		
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt		

Analyte	% Recovery	Limits	Notes
Triacotane (SUR)	68	60-140	

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes	
Method: EPA 8021 <i>NELAC</i>		Prep Method: EPA 5035		QCBatchID: QC1136586					
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish		
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish		
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish		
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish		
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish		

Analyte	% Recovery	Limits	Notes
4-Bromofluorobenzene (SUR)	84	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor

ASSOCIATED LABORATORIES

Analytical Results Report

Lab Request 322938 Page 14 of 15



Matrix: Solid **Client:** Advanced Environmental Concepts Inc. **Collector:** Client
Sampled: 05/09/2013 15:22 **Site:**
Sample #: 322938-012 **Client Sample #:** SW-T-6' **Sample Type:**

Analyte	Result	DF	MDL	RDL	Units	Analyzed	By	Notes
Method: EPA 8015 <i>NELAC</i>		Prep Method: EPA 3545		QCBatchID: QC1136596				
TPH (C6 to C10)	ND	1	1.7	3	mg/Kg	05/15/13	lyt	
TPH (C10 to C22)	ND	1	0.4	3	mg/Kg	05/15/13	lyt	
TPH (C28 to C36)	ND	1	2.1	5	mg/Kg	05/15/13	lyt	

Analyte	% Recovery	Limits	Notes
<i>Triacontane (SUR)</i>	79	60-140	

Method: EPA 8021 <i>NELAC</i>		Prep Method: EPA 5035		QCBatchID: QC1136586				
Benzene	ND	1	0.0006	0.005	mg/Kg	05/14/13	rparish	
Ethylbenzene	ND	1	0.0005	0.005	mg/Kg	05/14/13	rparish	
MTBE	ND	1	0.0009	0.035	mg/Kg	05/14/13	rparish	
Toluene	ND	1	0.0004	0.005	mg/Kg	05/14/13	rparish	
Xylenes (Total)	ND	1	0.0012	0.015	mg/Kg	05/14/13	rparish	

Analyte	% Recovery	Limits	Notes
<i>4-Bromofluorobenzene (SUR)</i>	87	60-140	

DRAFT

ND = Not Detected or < MDL MDL = Method Detection Limit RDL = Reporting Detection Limit DF = Dilution Factor



UNDERGROUND STORAGE TANK UNAUTHORIZED RELEASE (LEAK) / CONTAMINATION SITE REPORT

EMERGENCY <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		FOR LOCAL AGENCY USE ONLY I HEREBY CERTIFY THAT I AM A DESIGNATED GOVERNMENT EMPLOYEE AND THAT I HAVE REPORTED THIS INFORMATION TO LOCAL OFFICIALS PURSUANT TO SECTION 25180.7 OF THE HEALTH AND SAFETY CODE.	
REPORT DATE 5/28/2013		CASE #		SIGNED _____ DATE _____	
REPORTED BY	NAME OF INDIVIDUAL FILING REPORT Jeffrey Marshall		PHONE (661) 862-8775		SIGNATURE
	REPRESENTING <input checked="" type="checkbox"/> LOCAL AGENCY <input type="checkbox"/> REGIONAL BOARD <input type="checkbox"/> OWNER/OPERATOR <input type="checkbox"/> OTHER		COMPANY OR AGENCY NAME Kern County Environmental Health Division		
RESPONSIBLE PARTY	NAME Kuljit Ghuman <input type="checkbox"/> Unknown		CONTACT PERSON Kuljit Ghuman		PHONE (661) 834-9113
	ADDRESS 2126 Taft Hwy <small>STREET</small>		Bakersfield <small>CITY</small>		CA 93313 <small>STATE ZIP</small>
SITE LOCATION	FACILITY NAME (IF APPLICABLE) Johnny Quik #143		OPERATOR Kuljit Ghuman		PHONE (661) 834-9113
	ADDRESS 2126 Taft Hwy <small>STREET</small>		Bakersfield <small>CITY</small>		Kern 93313 <small>COUNTY ZIP</small>
	CROSS STREET Highway 99				
IMPLEMENTING AGENCIES	LOCAL AGENCY AGENCY NAME Kern County Environmental Health Division				PHONE (661) 862-8775
	REGIONAL BOARD				PHONE ()
SUBSTANCES INVOLVED	(1) NAME		QUANTITY LOST (GALLONS)		
	Gasoline		<input checked="" type="checkbox"/> Unknown		
(2)		<input type="checkbox"/> Unknown			
DISCOVERY/ABATEMENT	DATE DISCOVERED 5/9/2013		HOW DISCOVERED <input type="checkbox"/> Tank Test <input type="checkbox"/> Tank Removal <input type="checkbox"/> Nuisance Conditions <input type="checkbox"/> Inventory Control <input checked="" type="checkbox"/> Subsurface Monitoring <input type="checkbox"/> Other		
	DATE DISCHARGE BEGAN		METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY)		
	<input checked="" type="checkbox"/> UNKNOWN		<input type="checkbox"/> Remove Contents <input type="checkbox"/> Close Tank <input type="checkbox"/> Repair Tank <input type="checkbox"/> Change Procedure <input type="checkbox"/> Replace Tank <input checked="" type="checkbox"/> Other <input type="checkbox"/> Repair Piping		
HAS DISCHARGE BEEN STOPPED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO IF YES, DATE 5/9/2013					
SOURCE/ CAUSE	SOURCE OF DISCHARGE		CAUSE(S)		
	<input type="checkbox"/> Tank Leak <input type="checkbox"/> Piping Leak <input checked="" type="checkbox"/> Unknown <input type="checkbox"/> Other		<input type="checkbox"/> Overfill <input type="checkbox"/> Corrosion <input type="checkbox"/> Rupture/Failure <input checked="" type="checkbox"/> Unknown <input type="checkbox"/> Spill <input type="checkbox"/> Other		
CASE TYPE	CHECK ONE ONLY				
	<input checked="" type="checkbox"/> Undetermined <input type="checkbox"/> Soil Only <input type="checkbox"/> Groundwater <input type="checkbox"/> Drinking Water - (CHECK ONLY IF WATER WELLS HAVE ACTUALLY BEEN AFFECTED)				
CURRENT STATUS	CHECK ONE ONLY				
	<input type="checkbox"/> No Action Taken <input type="checkbox"/> Case Closed (Cleanup Completed or Unnecessary) <input checked="" type="checkbox"/> Leak Being Confirmed <input type="checkbox"/> Pollution Characterization <input type="checkbox"/> Remediation Plan <input type="checkbox"/> Post Cleanup Monitoring in Progress <input type="checkbox"/> Preliminary Site Assessment Workplan Submitted <input type="checkbox"/> Cleanup Underway <input type="checkbox"/> Preliminary Site Assessment Underway				
REMEDIAL ACTION	CHECK APPROPRIATE ACTION(S)				
	<input type="checkbox"/> Cap Site (CD) <input type="checkbox"/> Excavate & Treat (ET) <input type="checkbox"/> Treatment At Hookup (HU) <input checked="" type="checkbox"/> Other <input type="checkbox"/> Contamination Barrier (CB) <input type="checkbox"/> No Action Required (NA) <input type="checkbox"/> Enhanced Bio Degradation (IT) <input type="checkbox"/> Vacuum Extract (VE) <input type="checkbox"/> Remove Free Product (FP) <input type="checkbox"/> Replace Supply (RS) <input type="checkbox"/> Excavate & Dispose (ED) <input type="checkbox"/> Pump & Treat Groundwater (GT) <input type="checkbox"/> Vent Soil (VS)				
COMMENTS	The facilities is currently in the process of removing product lines and replacing them with new fiberglass double walled lines. Contamination was uncovered after samples were taken under the product lines to the dispensers. The contamination was observed in the northeast samples. Two samples were taken at depths of two (2) feet and six (6) feet. Attached in a copy of the lab results obtained for the samples taken at the facility.				

Instructions for Completing UST Unauthorized Release (Leak) / Contamination Site Report

EMERGENCY: Indicate whether emergency response personnel and equipment were involved at any time. If so, a Hazardous Material Incident Report should be filed with the State Office of Emergency Services (OES). Indicate whether the OES report has been filed as of the date of this report.

LOCAL AGENCY USE ONLY: To avoid duplicate notifications pursuant to Health and safety Code Section 25180.7, a designated government employee should sign and date the form in this block. A signature here does not mean that the leak has been determined to pose a significant threat to human health or safety, only that notification procedures have been followed if required.

REPORTED BY: Enter name, telephone number, and address. Indicate which party you represent and provide company or agency name.

SIGNATURE: Sign the form in the space provided.

RESPONSIBLE PARTY: Enter the name, telephone number, contact person, and address of the party responsible for the leak. The Responsible Party would normally be the tank owner.

SITE LOCATION: Enter information regarding the tank facility. At a minimum, you must provide the facility name and full site address.

IMPLEMENTING AGENCIES: Enter the names of the local agency and Regional Water Quality Control Board having jurisdiction over the site.

SUBSTANCES INVOLVED: Enter the name and quantity lost of the hazardous substance(s) involved. If more than two substances leaked, list the two of most concern for cleanup.

DISCOVERY/ABATEMENT: Provide information regarding the discovery and abatement of the leak.

SOURCE/CAUSE: Indicate the source(s) of leak. Check box(es) indicating the cause(s) of leak.

CASE TYPE: Check one box only. Indicate the Case Type category for this leak. Case Type is based on the most sensitive resource affected. For example, if both soil and ground water have been affected, Case Type will be "Groundwater." Indicate "Drinking Water" only if one or more municipal or domestic water wells have actually been affected. A "Groundwater" designation does not imply that the affected water cannot be, or is not, used for drinking water, but only that water wells have not yet been affected. It is understood that Case Type may change upon further investigation.

CURRENT STATUS: Check one box only. Indicate the category which best describes the Current Status of the case. The response should be relative to the Case Type. For example, if the Case Type is "Groundwater," then Current Status should refer to the status of the ground water investigation or cleanup, as opposed to that of soil. Descriptions of options are as follows:

- **No Action Taken** – No action has been taken by the Responsible Party beyond initial reporting of the leak.
- **Leak Being Confirmed** – A leak is suspected at the site, but has not yet been confirmed.
- **Remediation Plan** – Remediation Plan submitted evaluating long term remediation options. Proposal and implementation schedule for appropriate remediation options also submitted.
- **Preliminary Site Assessment Workplan Submitted** – Workplan/proposal requested of/submitted by Responsible Party to determine whether ground water has been, or will be, impacted as a result of the release.
- **Preliminary Site Assessment Underway** – Workplan is being implemented.
- **Case Closed** – Regional Water Quality Control Board and local agency Local Oversight Program (LOP) agree that no further work is necessary at the site.
- **Pollution Characterization** – Responsible Party is in the process of fully defining the extent of contamination in soil and ground water and assessing impacts on surface and/or ground water.
- **Post Cleanup Monitoring in Progress** – Periodic ground water or other monitoring at site, as necessary, to verify and/or evaluate the effectiveness of remedial activities.
- **Cleanup Underway** – Remediation Plan is being implemented.

IMPORTANT: THE INFORMATION PROVIDED ON THIS FORM IS INTENDED FOR GENERAL STATISTICAL PURPOSES ONLY AND IS NOT TO BE CONSTRUED AS REPRESENTING THE OFFICIAL POSITION OF ANY GOVERNMENTAL AGENCY.

REMEDIAL ACTION: Indicate which actions have been used to clean up or remediate the leak. Descriptions of options are as follows:

- **Cap Site** – Install horizontal impermeable layer to reduce rainfall infiltration.
- **Containment Barrier** – Install vertical dike to block horizontal movement of contaminants.
- **Excavate and Dispose** – Remove contaminated soil and dispose at approved site.
- **Excavate and Treat** – Remove contaminated soil and treat (includes spreading or land farming).
- **Remove Free Product** – Remove floating product from water table.
- **Pump and Treat Groundwater** – Generally employed to remove dissolved contaminants.
- **Enhanced Biodegradation** – Use of any available technology to promote bacterial decomposition of contaminants.
- **Replace Supply** – Provide alternate water supply to affected parties.
- **Treatment at Hookup** – Install water treatment devices at each dwelling or other place of use.
- **Vacuum Extract** – Use pumps or blowers to draw air through soil.
- **Vent Soil** – Bore holes in soil to allow volatilization of contaminants.
- **No Action Required** – Incident is minor, requiring no remedial action.

COMMENTS: Use this space to elaborate on any aspects of the incident.

DISTRIBUTION: If this form is completed by the tank owner or his/her agent, retain a copy and forward the original to your local tank permitting agency for distribution.

- Original – Local UST permitting agency. (Agency contact information is available at www.unidocs.org.)
- Copy – Regional Water Quality Control Board. (Boundaries and contact information are available at www.swrcb.ca.gov/regions.html.)
- Copy – Local Oversight Program (LOP) agency. (Agency contact information is available at www.unidocs.org.)
- Copy – Local Health Officer and County Board of Supervisors or their designee to receive Proposition 65 notifications.
- Copy – Owner/Responsible Party.

2700 M Street
Bakersfield, California
Mailing Address:
1415 Truxtun Avenue
Bakersfield, California 93301
(805) 861-3636

ERN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

HEALTH OFFICER
Leon M Hebertson, M.D.

DIRECTOR OF ENVIRONMENTAL HEALTH
Vernon S. Reichard



November 28, 1988

George Beal
7955 N. Cedar Ste. 104
Fresno, CA 93710

Dear Mr. Beal:

This is to advise you that this department has reviewed the project results for the subsurface contamination investigation conducted at the Johnny Quik Food Store located at 2126 Taft Hwy.

Based upon the findings described in the report, this department is satisfied that the assessment is complete and no significant soil contamination resulting from fuel tank leakage exists at the site.

Should you have any questions regarding the above matters, please feel free to contact me at (805) 861-3636.

Sincerely,

A handwritten signature in cursive script, appearing to read 'Joe Canas', is written over a horizontal line.

Joe Canas
Environmental Health Specialist
Hazardous Materials Management Program

JC:cd

1110-18

DISTRICT OFFICES

Delano • Lamont • Lake • Bella • Mojave • Ridgecrest • Shafter • Taft

KRAZAN & ASSOCIATES, INC.

Construction Testing and Inspection

Geotechnical Investigations

Environmental Engineering

Laboratory Soils Testing

Monitoring Wells



September 20, 1988

Proj. No. E88-105

Johnny Kwik Food Stores, Inc.
Attention: Mr. George Beal
4955 North Cedar Avenue, Suite 104
Fresno, California 93710

RE: Tank Removal Soil Sampling
Future Johnny Quik Store
2100-2126 Taft Highway (Highway 119)
Kern County, California

INTRODUCTION

In accordance with your authorization, we have completed the sampling of soils and the subsequent chemical analysis at the above referenced project site. The sampling took place following the removal of three 10,000-gallon underground gasoline storage tanks, a waste oil tank, dispenser islands, and associated product lines.

SITE DESCRIPTION

The project site is located in the South 1/2 of the Southeast 1/4 of Section 36, T30S R27E of the Mount Diablo Baseline and Meridian. Specifically, the subject property is located at the northwest corner of Taft Highway (Highway 119) and Highway 99 in Kern County, California. The property is described as APN 373-120-28 and APN 373-120-30 by the Kern County Assessors Office.

The site covers approximately one-half acre in area and is square in shape. It is bound on the south and the east by Highway 119 and Highway 99, respectively. The western boundary is shared with a retail facility's parking area. Property to the north is vacant land. The site is entirely covered with concrete and asphaltic concrete with the exception of small planter areas.

GEOLOGIC & HYDROLOGIC SETTING

The topography of the site is relatively level.

The site is located within the San Joaquin Valley, which is situated between the Sierra Nevada Mountains and Coast Range of California. The San Joaquin Valley makes up the southern portion of the Great Central Valley.

Unconsolidated materials found in the vicinity of the project site are generally composed of alluvial deposits made up of sands, silty sands and silts with some minor clays and gravels. The source rock for this material is primarily granitic and metamorphic rocks located in the Sierra Nevada Mountains. The deposition of these alluvial sediments began to take place in the Late Cretaceous age (100-65 million years before present). The majority of the San Joaquin Valley was covered at the time by epeiric seas. Epeiric seas were shallow salt water bodies which were generally situated on the continental shelf or within the continental interior (inland sea). Sediments currently at or near the surface are believed to be of the Quaternary age (i.e., 2 million years old or younger).

Major faults in the vicinity of the project site are the White Wolf Fault and the Garlock Fault, to the south, and the San Andreas Fault Zone to the west. Of these faults, only the White Wolf and San Andreas have been active in historic times.

The project site is located within the San Joaquin Valley Hydrologic Study area, which is primarily an arid and semi-arid environment. Within the study area, 37 groundwater basins have been identified. Storage capacity is approximately 570 million acre-feet; useable storage totals, 80 million acre feet. Fresh-water bearing deposits, generally alluvium, have a maximum thickness of 4,400 feet. The project site is located in the Kern County Basin, which is bounded on three sides by mountain ranges. This basin is experiencing an overdraft problem, in which the static groundwater levels are increasing in depth due to extensive pumping of the upper unconfined aquifer for agricultural use. Some land subsidence has occurred because of this pumping, but artificial recharge projects have been initiated to replenish the groundwater.

The depth to ground water below the project site may vary seasonally. According to the U.S. Department of the Interior Mid-Pacific Region 36th



Annual Water Supply Report plate entitled "Lines of Equal Depth to Ground Water, Spring 1987", groundwater in the vicinity of the project site can be estimated to exist at approximately 140 feet below grade.

SAMPLING & LABORATORY TESTING PROTOCOL

Sampling was conducted under the guidelines established by the Kern County Environmental Health Department and under the direction of its representative, Ms. Janis Lehman. Relatively undisturbed samples were obtained from a backhoe bucket and placed in mason jars. Aluminum foil was placed under the lid to insure a tight fit. All samples were labeled and were placed in a cooler chest which contained synthetic ice. Samples were then transported under chain of custody protocol to a state approved laboratory for analysis. The samples obtained from below the removed gasoline tanks, product lines, and dispenser islands were analyzed for the detection and concentration of benzene, toluene, ethylbenzene, xylene isomers, and total petroleum hydrocarbons. Samples taken from beneath the previous waste oil tank location were analyzed for oil and grease, total volatile organics (TOX), and total lead.

FINDINGS OF THIS INVESTIGATION

The tanks were removed by Harrel and Son on September 12, 1988. The removal process was observed by Ms. Lehman of Kern County, Mr. Roy Ruch, our Environmental Technician, and Mr. George Beal, representing Johnny Quik Stores.

At the time of tank removal the soils were noted to be light to medium brown, well graded and silty sands. Results of the chemical analysis of soil samples taken are presented in Table I.

TABLE I
Concentrations of Petroleum Constituents in Soils
 (Concentrations in parts per million)

WASTE OIL TANK

<u>Sample I.D.</u>	<u>Depth Below Tank</u>	<u>Oil & Grease</u>	<u>TOX</u>	<u>Total Lead</u>
1	2	ND	ND	13.2
2	6	ND	ND	16.7

GASOLINE TANKS

<u>Sample I.D.</u>	<u>Depth Below Tank</u>	<u>Benzene</u>	<u>Toluene</u>	<u>Ethyl-benzene</u>	<u>para-xylene</u>	<u>meta-xylene</u>	<u>ortho-xylene</u>	<u>Iso-benzene</u>	<u>TPH</u>
3	2'	ND	ND	29	46	110	130	ND	2000
4	6'	ND	ND	3.6	4.9	9.4	18	ND	350
5	2'	ND	ND	ND	ND	ND	ND	ND	ND
6	6'	ND	ND	ND	0.1	0.1	ND	0.54	14
7	2'	ND	ND	ND	ND	ND	ND	ND	3.7
8	6'	ND	ND	0.88	1.9	3.8	4.7	1.0	130
9	2'	ND	ND	ND	ND	ND	ND	ND	ND
10	6'	ND	ND	ND	ND	ND	ND	ND	ND
11	2'	ND	ND	ND	ND	ND	ND	ND	20
12	6'	ND	ND	ND	ND	ND	ND	ND	12
13	2'	ND	ND	ND	ND	ND	ND	ND	ND
14	6'	ND	ND	ND	ND	ND	ND	ND	ND

PRODUCT LINES & DISPENSER ISLANDS

<u>Sample I.D.</u>	<u>Depth Below Line</u>	<u>Benzene</u>	<u>Toluene</u>	<u>Ethyl-benzene</u>	<u>para-xylene</u>	<u>meta-xylene</u>	<u>ortho-xylene</u>	<u>Iso-benzene</u>	<u>TPH</u>
15	2'	ND	ND	ND	ND	ND	ND	ND	ND
16	6'	ND	ND	ND	ND	ND	ND	ND	ND
17	2'	ND	ND	ND	ND	ND	ND	ND	ND
18	6'	ND	ND	ND	ND	ND	ND	ND	ND

ND = Non-detected

TOX = Total Volatile Organics

TPH = Total Petroleum Hydrocarbons

CONCLUSIONS

Based on the results of this investigation, it was determined that contamination by petroleum constituents exists at the site, specifically under the eastern end of Tank #1. However, concentrations of contaminants attenuate sharply with an increase in depth of only four feet. Interpolation from this attenuation suggests that concentrations of petroleum constituents would continue to diminish rapidly with increasing depth.

Groundwater beneath the project site exists at depths greater than 100 feet. Because of this depth, the apparently limited physical extent of the contamination, and the fact that contaminant concentrations appear to attenuate rapidly, it is our opinion that the contaminated soil could be left in place without posing a threat to groundwater resources. We do not recommend any further remediation measures at this time.

If you have any questions or if we can be of further assistance, please do not hesitate to contact our office.

Respectfully submitted,
KRAZAN & ASSOCIATES, INC.

Marlis Curra


Marlis Curra
Project Geologist

Dean Alexander


Dean Alexander
Geotechnical Engineer
RGE #002051/RCE #34274

MC/DA/mdc

1 c Kern County Environmental Health Department
Attn: Janis Lehman







VICINITY MAP

NOTE:
 MAP TAKEN FROM USGS.
 "GOSFORD" QUADRANGLE
 1954 7.5 MINUTE SERIES.

SCALE 1" = 3000' ±
 0 1000 2000 3000

**FUTURE JOHNNY
 QUIK STORE**
 2100-2126 TAFT HWY.
 KERN CO., CA

Scale: 1" = 3000' ±

Date: 9-19-88

Drawn by: J.R.

Approved by: D.A.


Project No. E88-105

Drawing No. 1 of 2



KRAZAN & ASSOCIATES

Merced Fresno Visalia Bakersfield



TAFT HWY.

SITE PLAN

X SAMPLE LOCATION

FUTURE JOHNNY
QUICK STORE
2100-2126 TAFT HWY
KERN CO., CA

Scale: N.T.S.	Date: 9-20-88
Drawn by: J.R.	Approved by: D.A.
Project No. E88-105	Drawing No. 2 of 2



KRAZAN & ASSOCIATES

Merced Fresno Visalia Bakersfield



Client Name: Krazan & Associates
Address : 3860 N. Winery
Fresno, CA 93726

Date sample received : 9-14-88
Date analysis completed: 9-16-88
Date of report : 9-16-88

Laboratory No. 1978 through 1995 Project No. E88-105

RESULTS OF ANALYSIS

#1978 ID: Sample #1 Tank #4 , Middle @ 2'

	ugm/gm	MRL,ugm/gm
TOX	ND	20
Oil & Grease	ND	20
Total lead	13.2 (mg/kg)	*

#1979 ID: Sample #2 Tank #4 , Middle @ 6'

	ugm/gm	MRL,ugm/gm
TOX	ND	20
Oil & Grease	ND	20
Total lead	16.7 (mg/kg)	

Method of Analysis for TOX: 600/4-84 008
Method of Analysis for Oil & Grease: EPA 9071
Total lead analysis done by BC Laboratories, Inc.
MRL = Minimum Reporting Level
TOX = Total Organic Halogen
ugm/gm = micrograms per gram
mg/kg = milligram per kilogram
ND = Not detected

Stan Comer
Stan Comer



Laboratory No. 1978 through 1995 Project No. E88-105

RESULTS OF ANALYSIS

#1980 ID: Sample #3 S. Tank #1 E. End @ 2'

	ugm/gm	MRL, ugm/gm
Benzene	ND	0.1
Toluene	ND	0.1
Ethylbenzene	29	0.1
p-Xylene	46	0.1
m-Xylene	110	0.1
o-Xylene	130	0.1
Isopropylbenzene	ND	0.1
TPH (Gasoline)	2,000	1.0
TPH (Diesel)	ND	10

#1981 ID: Sample #4 S. Tank #1 E. End @ 6'

	ugm/gm	MRL, ugm/gm
Benzene	ND	0.1
Toluene	ND	0.1
Ethylbenzene	3.6	0.1
p-Xylene	4.9	0.1
m-Xylene	9.4	0.1
o-Xylene	18	0.1
Isopropylbenzene	ND	0.1
TPH (Gasoline)	350	1.0
TPH (Diesel)	ND	10

Method of Analysis: California DOHS LUFT manual

MRL = Minimum Reporting Level

TPH = Total Petroleum Hydrocarbons

ugm/gm = micrograms per gram

ND = Not detected

Stan Comer
Stan Comer



Laboratory No. 1978 through 1995 Project No. E88-105

RESULTS OF ANALYSIS

#1984 ID: Sample #7 C. Tank #2 E. End @ 2'

ugm/gm	MRL, ugm/gm
Benzene	ND
Toluene	0.1
Ethylbenzene	0.1
p-Xylene	0.1
m-Xylene	0.1
o-Xylene	0.1
Isopropylbenzene	0.1
TPH (Gasoline)	3.7
TPH (Diesel)	ND

#1985 ID: Sample #8 C. Tank #2 E. End @ 6'

ugm/gm	MRL, ugm/gm
Benzene	ND
Toluene	0.1
Ethylbenzene	0.1
p-Xylene	0.1
m-Xylene	0.1
o-Xylene	0.1
Isopropylbenzene	0.1
TPH (Gasoline)	130
TPH (Diesel)	ND

Method of Analysis: California DOHS LUFF manual
MRL = Minimum Reporting Level
TPH = Total Petroleum Hydrocarbons
ugm/gm = micrograms per gram
ND = Not detected

Stan Comer
Stan Comer



Laboratory No. 1978 through 1995 Project No. E88-105

RESULTS OF ANALYSIS

#1988 ID: Sample #11 N.Tank #3 E. End @ 2'

	ugm/gm	MRL, ugm/gm
Benzene	ND	0.1
Toluene	ND	0.1
Ethylbenzene	ND	0.1
p-Xylene	ND	0.1
m-Xylene	ND	0.1
o-Xylene	ND	0.1
Isopropylbenzene	ND	0.1
TPH (Gasoline)	20	1.0
TPH (Diesel)	ND	10

#1989 ID: Sample #12 N.Tank #3 E. End @ 6'

	ugm/gm	MRL, ugm/gm
Benzene	ND	0.1
Toluene	ND	0.1
Ethylbenzene	ND	0.1
p-Xylene	ND	0.1
m-Xylene	ND	0.1
o-Xylene	ND	0.1
Isopropylbenzene	ND	0.1
TPH (Gasoline)	12	1.0
TPH (Diesel)	ND	10

Method of Analysis: California DOHS LUFT manual

MRL = Minimum Reporting Level

TPH = Total Petroleum Hydrocarbons

ugm/gm = micrograms per gram

ND = Not detected

Stan Comer
Stan Comer



Laboratory No. 1978 through 1995

Project No. E88-105

RESULTS OF ANALYSIS

#1986 ID: Sample #9 C. Tank #2 W. End @ 2'

	ugm/gm	MRL, ugm/gm
Benzene	ND	0.1
Toluene	ND	0.1
Ethylbenzene	ND	0.1
p-Xylene	ND	0.1
m-Xylene	ND	0.1
o-Xylene	ND	0.1
Isopropylbenzene	ND	0.1
TPH (Gasoline)	ND	1.0
TPH (Diesel)	ND	10

#1987 ID: Sample #10 C. Tank #2 W. End @ 6'

	ugm/gm	MRL, ugm/gm
Benzene	ND	0.1
Toluene	ND	0.1
Ethylbenzene	ND	0.1
p-Xylene	ND	0.1
m-Xylene	ND	0.1
o-Xylene	ND	0.1
Isopropylbenzene	ND	0.1
TPH (Gasoline)	ND	1.0
TPH (Diesel)	ND	10

Method of Analysis: California DOHS LUFT manual

MRL = Minimum Reporting Level

TPH = Total Petroleum Hydrocarbons

ugm/gm = micrograms per gram

ND = Not detected

Stan Comer
Stan Comer



Laboratory No. 1978 through 1995 Project No. E88-105

RESULTS OF ANALYSIS

#1990 ID: Sample #13 N.Tank #3 W. End @ 2'

ugm/gm	MRL, ugm/gm
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	1.0
ND	10


#1991 ID: Sample #14 N.Tank #3 W. End @ 6'

ugm/gm	MRL, ugm/gm
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	1.0
ND	10

Method of Analysis: California DOHS LUFT manual
MRL = Minimum Reporting Level
TPH = Total Petroleum Hydrocarbons
ugm/gm = micrograms per gram
ND = Not detected

Stan Comer

Stan Comer



Laboratory No. 1978 through 1995 Project No. E88-105

RESULTS OF ANALYSIS

#1982 ID: Sample #5 S. Tank #1 W. End @ 2'


ugm/gm	MRL, ugm/gm
Benzene	ND
Toluene	ND
Ethylbenzene	ND
p-Xylene	ND
m-Xylene	ND
o-Xylene	ND
Isopropylbenzene	ND
TPH (Gasoline)	1.0
TPH (Diesel)	ND

#1983 ID: Sample #6 S. Tank #1 W. End @ 6'

ugm/gm	MRL, ugm/gm
Benzene	ND
Toluene	ND
Ethylbenzene	ND
p-Xylene	0.1
m-Xylene	0.1
o-Xylene	0.1
Isopropylbenzene	0.1
TPH (Gasoline)	1.0
TPH (Diesel)	ND

Method of Analysis: California DOTS LUPP manual
MRL = Minimum Reporting Level
TPH = Total Petroleum Hydrocarbons
ugm/gm = micrograms per gram
ND = Not detected

Stan Gentry
Stan Gomer



Laboratory No. 1978 through 1995 Project No. E88-105

RESULTS OF ANALYSTS

#1992 ID: Sample #15 Dispensing Area, Mid. @ 2'

ugm/gm	MRL, ugm/gm
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	1.0
ND	10


#1993 ID: Sample #16 Dispensing Area, Mid. @ 6'

ugm/gm	MRL, ugm/gm
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	0.1
ND	1.0
ND	10

Method of Analysis: California DOHS LUPT manual
MRL = Minimum Reporting Level
TPH = Total Petroleum Hydrocarbons
ugm/gm = micrograms per gram
ND = Not detected

Stan Gomer

Stan Gomer



Laboratory No. 1978 through 1995 Project No. B88-105

RESULTS OF ANALYSIS

#1994 ID: Sample #17 Product Lines @ 2'

Compound	ugm/gm	MRL, ugm/gm
Benzene	ND	0.1
Toluene	ND	0.1
Ethylbenzene	ND	0.1
p-Xylene	ND	0.1
m-Xylene	ND	0.1
o-Xylene	ND	0.1
Isopropylbenzene	ND	0.1
TPH (Gasoline)	1.0	1.0
TPH (Diesel)	ND	10


#1995 ID: Sample #18 Product Lines @ 6'

Compound	ugm/gm	MRL, ugm/gm
Benzene	ND	0.1
Toluene	ND	0.1
Ethylbenzene	ND	0.1
p-Xylene	ND	0.1
m-Xylene	ND	0.1
o-Xylene	ND	0.1
Isopropylbenzene	ND	0.1
TPH (Gasoline)	ND	1.0
TPH (Diesel)	ND	10

Method of Analysis: California DOHS LUPP manual
MRL = Minimum Reporting Level
TPH = Total Petroleum Hydrocarbons
ugm/gm = micrograms per gram
ND = Not detected

Stan Comer

Stan Comer



Environmental Field Testing and Sampling
 Specialized Fuel Spillage Studies
 Laboratory Soils Testing
 Soils Engineering
 Geotechnical Investigations



Chain of Custody Record

DATE 9-14-88 PAGE 1 OF 2

ADDRESS KRAZAN & ASSOCIATES, INC. 3860 NORTH WINERY FRESNO, CALIFORNIA 93726 (209) 291-7337				PARAMETERS															OTHER	OBSERVATIONS/ COMMENTS				
PROJECT <u>E88-105</u>				CAM METALS (18)	PR. POLLUTANT METALS (13)	TPH-DIESEL	OIL & GREASE	TOTAL PETROLEUM HYDROCARBONS-GAS	HALOGENATED VOLATILE ORGANICS	BTX-TVH	VOLATILE ORGANICS (601)	VOLATILE ORGANICS (602)	TOTAL LEAD	PENTACHLOROPHENOL	CREOSOTE	DIOXINS/FURANS	PH	TURBIDITY	CHLOROFORM		TOX	BTX-TPH(GAS)	NUMBER OF CONTAINERS	
SAMPLERS (SIGNATURE) <u>Roy W. Ruch</u>																								
Printed Name <u>Roy W. Ruch</u>																								
SAMPLE NO	DATE	TIME	LOCATION																					
1978	1	9/12/88	4:57 PM	TANK #4, MIDDLE			X						X							X			1 WASTE OIL 2'	
1979	2	1	5:10 PM	TANK #4, MIDDLE			X						X							X			1 WASTE OIL 6'	
1980	3		5:41 PM	TANK (#1) E. END																X			1 GASOLINE 2'	
1981	4		5:44 PM	TANK (#1) E. END																X			1 GASOLINE 6'	
1982	5		6:08 PM	S. TANK (#1) W. END																X			1 GAS. 2'	
1983	6		6:11 PM	S. TANK (#1) W. END																X			1 GAS. 6'	
1984	7		5:50 PM	C. TANK (#2) E. END																X			1 GAS. 2'	
1985	8		5:52 PM	C. TANK (#2) E. END																X			1 GAS. 6'	
1986	9		6:13 PM	C. TANK (#2) W. END																X			1 GAS. 2'	
1987	10		6:15 PM	C. TANK (#2) W. END																X			1 GAS. 6'	
1988	11		5:55 PM	N. TANK (#3) E. END																X			1 GAS. 2'	
1989	12		5:38 PM	N. TANK (#3) E. END																X			1 GAS. 6'	
1990	13		6:18 PM	N. TANK (#3) W. END																X			1 GAS. 2'	
REINQUISHED BY <u>Roy W. Ruch</u>				DATE <u>9/14/88</u>	RECEIVED BY <u>Karla Henry</u>				DATE <u>9/14/88</u>	REINQUISHED BY				DATE	RECEIVED BY				DATE	13 TOTAL NUMBER OF CONTAINERS (SUB TOTAL) METHOD OF SHIPMENT				
Signature <u>Roy W. Ruch</u>				TIME	Signature <u>Karla Henry</u>				TIME	Signature				TIME	Signature									
Printed Name <u>Roy W. Ruch</u>					Printed Name <u>Karla Henry</u>					Printed Name					Printed Name					SPECIAL SHIPMENT/HANDLING OR STORAGE REQUIREMENTS				
Company <u>Krazan Assoc.</u>					Company <u>SMA LABS</u>					Company					Company									
REINQUISHED BY				DATE	RECEIVED BY				DATE	REINQUISHED BY				DATE	RECEIVED BY (laboratory)				DATE	48 HR. TURN - Around				
Signature				TIME	Signature				TIME	Signature				TIME	Signature									
Printed Name					Printed Name					Printed Name					Printed Name									
Company					Company					Company					Company									

P. 06



Environmental Field Testing and Sampling
 Specialized Fuel Seepage Studies
 Laboratory Soils Testing
 Soils Engineering
 Geotechnical Investigations



DATE 9-14-88 PAGE 2 OF 2

ADDRESS KRAZAN & ASSOCIATES, INC. 3860 NORTH WINERY FRESNO, CALIFORNIA 93726 (209) 291-7337				PARAMETERS													OTHER	OBSERVATIONS/ COMMENTS			
				CAM METALS (18)	PR. POLLUTANT METALS (13)	TPH-DIESEL	OIL & GREASE	TOTAL PETROLEUM HYDROCARBONS-GAS	HALOGENATED VOLATILE ORGANICS	BTX-TVH	VOLATILE ORGANICS (601)	VOLATILE ORGANICS (602)	TOTAL LEAD	PENTACHLOROPHENOL	CREOSOTE	DIOXINS/FURANS	PH		TURBIDITY	CHLOROFORM	BIKE--TPH
PROJECT	E88-105																				
SAMPLERS (SIGNATURE)	<i>Koz W. Ruch</i>																				
Printed Name	Ron W. Ruch																				
SAMPLE NO	DATE	TIME	LOCATION														BIKE--TPH	NUMBER OF CONTAINERS	OBSERVATIONS/ COMMENTS		
1991	14	9/12/88	6:20 PM	N. TANK (#3) W. END														X	1	6' GAS.	
1992	15	}	6:26 PM	DISPENSING AREA, MID.														X	1	2'	
1993	16		6:28 PM	DISPENSING AREA MID.														X	1	6'	
1994	17		6:31 PM	PRODUCT LINES														X	1	2'	
1995	18		6:33 PM	PRODUCT LINES														X	1	6'	
RELINQUISHED BY				DATE	RECEIVED BY				DATE	RELINQUISHED BY				DATE	RECEIVED BY				DATE	18	TOTAL NUMBER OF CONTAINERS (TOTAL)
<i>Koz W. Ruch</i>				9/14/88	<i>Karla Henry</i>				9/14/88												METHOD OF SHIPMENT
Signature					Signature					Signature					Signature					SPECIAL SHIPMENT HANDLING OR STORAGE REQUIREMENTS	
Printed Name					Printed Name					Printed Name					Printed Name						
Company					Company					Company					Company						
RELINQUISHED BY				DATE	RECEIVED BY				DATE	RELINQUISHED BY				DATE	RECEIVED BY (laboratory)				DATE	48 HR. TURN AROUND	
<i>KRAZAN/ASSOC.</i>				9:20 A.M.	<i>KARIA HENRY</i>				9:20 Am.												
Signature					Signature					Signature					Signature						
Printed Name					Printed Name					Printed Name					Printed Name						
Company					Company					Company					Company						

FROM

9.12.1988 9:36

P. 6





Facility Name

Johnny Quik Food
Stores 2126 Tost Hwy
2100 Tost Hwy
Tost, CA

Kern County Permit #

A757-32

* * UNDERGROUND TANK DISPOSITION TRACKING RECORD * *

This form is to be returned to the Kern County Health Department within 14 days of acceptance of tank(s) by disposal or recycling facility. The holder of the permit with number noted above is responsible for insuring that this form is completed and returned.

Section 1 - To be filled out by tank removal contractor:

Tank Removal Contractor: Donle Sumrall Contractor
Address 7619 Ellwood Phone # _____
Clavis, CA Zip 93612
Date Tanks Removed _____ No. of Tanks 2

Section 2 - To be filled out by contractor "decontaminating tank(s)":

Tank "Decontamination" Contractor MP Vacuum Service
Address 3400 Manor Phone # 805-393-1151
Bakersfield Zip 93308

Authorized representative of contractor certifies by signing below that tank(s) have been decontaminated in accordance with Kern County Health Department requirements.

Paul D. Rehr Environmental Spec
Signature Title


Section 3 - To be filled out and signed by an authorized representative of the treatment, storage, or disposal facility accepting tank(s):

Facility Name Amr
Address 2202 S. Milliken Phone # 714-947-2888
Ontario Zip 91764
Date Tanks Received 2-27-88 No. of Tanks 1
Signature N. J. ... Title P.T.O.
(Authorized Representative)

* * * MAILING INSTRUCTIONS: Fold in half and staple. Postage and mailing label have already been affixed to outside for your convenience.


Kern County Health Dept.
Environmental Health Div.

R E C E I V E D
OCT 03 1988



KERN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1415 TRUXTON AVENUE
BAKERSFIELD, CA 93301

ATTN: Underground Tank Section



Please print or type. (Form designed for use on elite or dot matrix typewriter).

UNIFORM HAZARDOUS WASTE MANIFEST

Generator's US EPA ID No. **CAC00011440500379** Manifest Document No. **1**

2. Page 1 of 1

Information in the shaded areas is not required by Federal law.

3. Generator's Name and Mailing Address
**Deale Properties, Inc
7955 N. Cedar, Ste 104, Fresno**

A. State Manifest Document Number
37200399

4. Generator's Phone **(209) 432-1405**

B. State Generator's ID

5. Transporter 1 Company Name
MP Vacuum Service

6. US EPA ID Number
PAT000624247

C. State Transporter's ID
903527

D. Transporter's Phone
805-393-1181

7. Transporter 2 Company Name

8. US EPA ID Number

E. State Transporter's ID

F. Transporter's Phone

9. Designated Facility Name and Site Address
**Gibson Oil and Refining
Commercial St
Bakersfield CA**

10. US EPA ID Number
PAD980883177

G. State Facility's ID
CA09810883177

H. Facility's Phone
805-327-0413

11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)

12. Containers No. Type

13. Total Quantity

14. Unit Wt/Vol

I. Waste No.

a. **Waste Gasoline/Diesel Residue
California Regulated Waste Only**

901 TIT02090G

State **221**

EPA/Other **A**

b.

State

EPA/Other

c.

State

EPA/Other

d.

State

EPA/Other

J. Additional Descriptions for Materials Listed Above

K. Handling Codes for Wastes Listed Above

a. **C1**

b.

c.

d.

15. Special Handling Instructions and Additional Information
Release 8256-4

16. **GENERATOR'S CERTIFICATION:** I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations.

If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.

Printed/Typed Name
George J. Beal

Signature
[Signature]

Month Day Year
10 19 10 8 18 18

17. Transporter 1 Acknowledgement of Receipt of Materials
Printed/Typed Name
Jim Blevins

Signature
[Signature]

Month Day Year
10 19 10 8 18 18

18. Transporter 2 Acknowledgement of Receipt of Materials
Printed/Typed Name

Signature

Month Day Year

19. Discrepancy Indication Space

20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.

Printed/Typed Name
Larry Coel

Signature
[Signature]

Month Day Year
09 17 18 18

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA, CALL 1-800-852-7550

GENERATOR

TRANSPORTER

FACILITY

ENVIRONMENTAL HEALTH

NOV 08 1988

REGISTERED

KERN COUNTY HEALTH DEPARTMENT

2700 M Street
 Bakersfield, California
 Mailing Address:
 1415 Truxtun Avenue
 Bakersfield, California 93301
 (805) 861-3636

ENVIRONMENTAL HEALTH DIVISION

HEALTH OFFICER
 Leon M Hebertson, M.D.

DIRECTOR OF ENVIRONMENTAL HEALTH
 Vernion S. Reichard



PERMIT FOR PERMANENT CLOSURE
 OF UNDERGROUND HAZARDOUS
 SUBSTANCES STORAGE FACILITY

PERMIT NUMBER A757-32

FACILITY NAME/ADDRESS:

OWNER(S) NAME/ADDRESS:

CONTRACTOR:

Johnny Quick Food Stores
 2126 Taft Highway
 Bakersfield, CA

Beal Properties
 7955 N. Cedar, #104
 Fresno, CA 93710

Doyle Sumrall Construction
 7619 Ellivial
 Clovis, CA 93612
 License No. A449943

Phone # (209) 432-1405

PERMIT FOR CLOSURE OF

PERMIT EXPIRES December 7, 1988

3 TANK(S) AT ABOVE

APPROVAL DATE September 7, 1988

LOCATION.

APPROVED BY

Joe Canas
 Joe Canas

POST ON PREMISES.

CONDITIONS AS FOLLOW:

1. A copy of this permit has been provided to the Kern County Fire Department. Permittee must notify the County Fire Department at (805) 861-2577 two working days prior to tank (removal) or (inerting and filling) to arrange for required inspection(s).
2. Tank closure activities must be per Kern County Health and Fire Department approved methods as described in Handout #UT-30.
3. Soil Sampling
 Any deviation from sample locations and numbers or constituents to be sampled for which are described below and in Handbook #UT-30 must receive prior approval by the Health Department.
 - a. (Tank size between 1,000 to 10,000 gallons) - a minimum of four samples must be retrieved one-third of the way in from the ends of each tank at depths of approximately two feet and six feet.
4. If any contractors other than those listed on permit and permit application are to be utilized, prior approval must be granted by the specialist listed on the permit.
5. Soil Sampling (piping area)
 A minimum of two samples must be retrieved at depths of approximately two feet and six feet for every 15 linear feet of pipe run and also near the dispenser area(s).
6. Sample analysis
 - a. All (leaded/unleaded) gasoline samples must be analyzed for benzene, toluene, xylene, and total petroleum hydrocarbons.
7. Copies of transportation manifests must be submitted to the Health Department within five days of waste disposal.
8. All applicable state laws for hazardous waste disposal, transportation, or treatment must be adhered to. The Kern County Health Department must be notified before moving and/or disposing of any contaminated soil.

DISTRICT OFFICES


Delano • Lamont • Lake Isabella • Mojave • Ridgecrest • Shafter • Taft

PERMIT FOR PERMANENT CLOSURE
OF UNDERGROUND HAZARDOUS
SUBSTANCES STORAGE FACILITY

PERMIT NUMBER A757-32
ADDENDUM

9. Permittee is responsible for making sure that "tank disposition tracking record" issued with this permit is properly filled out and returned within 14 days of tank removal.
10. Advise this office of the time and date of the proposed sampling with 24 hours advance notice.
11. Results must be submitted to this office within three days of analysis completion.

ACCEPTED BY



DATE

9-8-88

RECEIVED
SEP 01 1988

Beal Properties, Inc.

7955 N. Cedar Avenue, Suite 104
Fresno, California 93710
(209) 432-1405

September 1, 1988

Kern County Health Dept.
Division of Env. Health
1415 Truxton Avenue
Bakersfield, CA 93301


ATTENTION: JOE CANAS

RE: Taft Hwy and Hwy 99 - Tank removal.

We have scheduled the Fire Dept, M.X.P. Vacuum, and Krazan & Associates to be at the site for tank removal on Wednesday, September 7, 1988.



1. MPV Vacuum will clean the tanks before removal, starting at 8:00 AM.
Don Adams.
2. Soil tests will be performed by Krazan & Associates.
3. Contractor is Doyle Sumrall Construction. *A 44 9943 7619 Ellwood Clovis, CA 93612*
4. MXP will make arrangements to have tanks removed from the site.

Thank you.



George J. Beal
President

attachment.

1" = 30'



EXISTING TANKS



- ① Test Soil under Tanks
1/3 of the dist in from
Each end of TANK
- ② Test the Soil
At 2 depths
(1) at 2' deep
(1) at 6' deep

Taft Hwy

KERN COUNTY HEALTH DEPARTMENT
 DIVISION OF ENVIRONMENTAL HEALTH
 1700 FLOWER STREET, BAKERSFIELD, CA 93305
 (805) 861-3836

INTERNAL USE ONLY:
 PTO 3200 PTA A757-32
 APPLICATION DATE 7/29/88
 # OF TANKS TO BE ABANDONED 3
 LENGTH OF PIPING TO ABANDON _____

APPLICATION FOR PERMIT FOR PERMANENT
 CLOSURE/ABANDONMENT OF UNDERGROUND
 HAZARDOUS SUBSTANCES STORAGE FACILITY

THIS APPLICATION IS FOR REMOVAL, OR ABANDONMENT IN PLACE (FILL OUT ONE APPLICATION PER FACILITY)

FACILITY INFORMATION

PROJECT CONTACT New Convenience Stores PHONE # 432-1405 SEC/T/R (RURAL LOCATIONS ONLY) Hwy 99 X 119
 FACILITY NAME Johnny Quick Food Stores ADDRESS 2126 Taft Hwy NEAREST CROSS STREET Hwy 99
 OWNER Beal Properties Inc ADDRESS 7955 N. Cedar #104 Fresno CA 93710 PHONE (209) 432-1405

CONTRACTOR INFORMATION

TANK REMOVAL CONTRACTOR Harrell & Sons ADDRESS P.O. Box 839 Fresno PHONE 209 674 2271
 PROPOSED PROJECT STARTING DATE _____ CALIFORNIA LICENSE # 248133 WORKER'S COMPENSATION # _____ INSURER FARMERS
209 674-9771
 PRELIMINARY SITE ASSESSMENT CONTRACTOR _____ ADDRESS _____ PHONE () - _____
 WORKER'S COMPENSATION # _____ INSURER _____ PHONE () - _____
 LABORATORY THAT WILL ANALYZE SAMPLES Twing Lab Inc ADDRESS 5301 Olive Park Dr. #310 Bakersfield CA 93309 PHONE 805 322 5216

CHEMICAL COMPOSITION OF MATERIALS STORED

TANK #	VOLUME	CHEMICAL STORED (NON-COMMERCIAL NAME)	DATES STORED	CHEMICAL PREVIOUSLY STORED
<u>1</u>	<u>10000</u>	<u>gasoline empty</u>	<u>TO 1986</u>	<u>gasoline</u>
<u>2</u>	<u>10000</u>	<u>" "</u>	<u>TO 1986</u>	<u>" "</u>
<u>3</u>	<u>10000</u>	<u>" "</u>	<u>TO 1986</u>	<u>" "</u>

ENVIRONMENTAL INFORMATION

WATER TO FACILITY PROVIDED BY Individual Well DEPTH TO GROUNDWATER Unknown
 NEAREST WATER WELL - GIVE DISTANCE AND DESCRIBE TYPE IF WITHIN 500 FEET 75' From Tanks SOIL TYPE AT FACILITY _____
 BASIS FOR SOIL TYPE AND GROUNDWATER DEPTH DETERMINATION Private Well
 TOTAL NUMBER OF SAMPLES TO BE ANALYZED _____ SAMPLES WILL BE ANALYZED FOR: Health Dept to Specify

DISPOSAL INFORMATION

DESCRIBE HOW RESIDUE IN TANK(S) AND PIPING IS TO BE REMOVED AND DISPOSED OF (INCLUDE TRANSPORTATION AND DISPOSAL COMPANIES):
Gasoline & Water - Gibson Refining AMR
 DESCRIBE BOTH THE DISPOSAL METHOD AND DISPOSAL LOCATION FOR:
 TANK(S) By M.P. Vacuum 805-393-1151 We will
 PIPING AMR be keeping tanks on site for

** PLEASE PROVIDE INFORMATION REQUESTED ON REVERSE SIDE OF THIS SHEET BEFORE SUBMITTING APPLICATION FOR REVIEW **

THIS FORM HAS BEEN COMPLETED UNDER PENALTY OF PERJURY AND TO THE BEST OF MY KNOWLEDGE IS TRUE AND CORRECT.


SIGNATURE George J. Beal TITLE President DATE 7/25/88
 (Form #HMMP-140) Water Storage for Fire Protection.

PROVIDE DRAWING OF PHYSICAL LAYOUT OF FACILITY USING SPACE PROVIDED BELOW.

ALL OF THE FOLLOWING INFORMATION MUST BE INCLUDED IN ORDER FOR APPLICATION TO BE PROCESSED:

- _____ TANK(S), PIPING & DISPENSER(S), INCLUDING LENGTHS AND DIMENSIONS
- _____ PROPOSED SAMPLING LOCATIONS DESIGNATED BY THIS SYMBOL "⊗"
- _____ NEAREST STREET OR INTERSECTION
- _____ ANY WATER WELLS OR SURFACE WATERS WITHIN 100' RADIUS OF FACILITY
- _____ NORTH ARROW

Johnny Quik Food Stores, Inc.



George J. Beal
President

7955 N. Cedar, Suite 104
Fresno, CA 93710

(209) 432-1405



The Twining Laboratories, Inc.

Since 1898

July 20, 1988 Geotechnical and Environmental Consultants • Engineering and Chemical Laboratories
TL 488-0342-00

Johnny Quick Food Stores
7955 N. Cedar, Suite 104
Fresno, CA 93710

RE: Tank Decontamination Procedures
Johnny Quick Food Store
2126 Taft Highway
Bakersfield, California

Dear Mr. Beale:

It is our understanding that you wish to utilize an existing underground fuel storage tank as an above-ground water storage tank for fire emergencies. The concern of the Kern County Fire Department is the possibility that the water stored in the tank may contain fuel in concentrations in excess of 5%. This concentration, according to the fire department, has a potential of becoming inflammable.

The decontamination procedures for the tank would consist of:

1. Pumping out any remaining fuel.
2. Triple-rinsing the tank prior to removal using a steam pressure washer.
3. The rinsate would be pumped from the tank between rinses.
4. The tank would be removed following the Kern County Health Department and Fire Department guidelines.
5. The tank would be rinsed a final time prior to filling the tank with water.

2527 Fresno Street • P.O. Box 1472
Fresno, California 93716 • (209) 268-7021

1405 Granite Lane, Suite 1
Modesto, California 95351 • (209) 523-0994

9401 West Goshen Avenue
Visalia, California 93291 • (209) 651-2190

5301 Office Park Drive, Suite 310
Bakersfield, California 93309 • (805) 322-5216

Based on our experience regarding underground storage tanks, this process should leave the tank with fuel constituents in concentrations much less than 5%. To confirm the remaining fuel concentrations in the tank, a water sample would be obtained from within the tank and analyzed for total petroleum hydrocarbons.

Furthermore, in discussing this matter with Mr. Lancelot Leitch of the Fresno County Health Department, Mr. Leitch indicated that he has had success in utilizing former underground fuel storage tanks for above-ground water storage. His criteria was that the tank be in satisfactory physical condition; i.e., having satisfactory wall thickness and structural strength.

If we could be of further assistance to you in this matter, please do not hesitate to contact our office.

Sincerely,

THE TWINING LABORATORIES INC.

Dale S. Stanton

Dale S. Stanton
Project Engineer
Environmental Engineering Department

DSS:pb

The Twining Laboratories, Inc.

Fresno Modesto Visalia Bakersfield



MATTHEW CONSTANTINE, DIRECTOR
PUBLIC HEALTH SERVICES

ENVIRONMENTAL HEALTH DIVISION

2700 M STREET, SUITE 300, BAKERSFIELD, CA 93301-2370
VOICE: (661) 862-8740 FAX: (661) 862-8701
Web: www.co.kern.ca.us/eh E-mail: eh@co.kern.ca.us
"ONE VOICE"



CLAUDIA JONAH, MD
PUBLIC HEALTH OFFICER

PERMIT TO CONSTRUCT or MODIFY UNDERGROUND STORAGE FACILITY

Facility ID: FA0002691

NEW CONSTRUCTION MODIFICATION

FACILITY NAME/ADDRESS	OWNER(S) NAME/ADDRESS:	CONTRACTOR NAME/ADDRESS
Johnny Quik #143 2126 Taft Hwy Bakersfield, CA 93313	Kuljit Ghuman 2126 Taft Hwy Bakersfield, CA 93313	D n J Construction Inc. 3430- A Gilmore Ave Bakersfield, CA 93308
	Phone No. (661) 834-9113	License # 792494 Phone No. (661) 864-1023
DATE ISSUED: 05/06/2013	EXPIRES ON: 11/06/2013	APPROVED BY: Jeffrey S. Marshall

POST ON PREMISES

CONDITIONS:


1. All construction to be as per facility plans approved by this department and verified by inspection by Permitting Authority.
2. All equipment and materials in this construction must be installed in accordance with all manufacturers' specifications.
3. Any individual installing underground storage tank systems components shall possess a current underground storage tank system installer certification from the International Code Council (ICC), which indicates that the individual has passed the ICC UST Installation/Retrofitting exam.
4. Permittee must contact Permitting Authority for on-site inspection(s) with 48-hour advance notice.
5. Backfill material for piping and tanks to be as per manufacturers' specifications.
6. Construction inspection record card is included with permit given to Permittee. This card must be posted at job site prior to initial inspection. Permittee must contact Permitting Authority and arrange for each group of required inspections numbered as per instructions on card. Generally, inspections will be made of:
 - a. Piping system with secondary containment;
 - b. Tank top sumps & penetrations; and
 - c. Any other inspection deemed necessary by Permitting Authority.
7. Primary and secondary containment of both tank(s) and underground piping must not be subject to physical or chemical deterioration due to the substance(s) stored in them. Documentation from tank, piping, and seal manufacturers of compatibility with these substance(s) must be submitted to Permitting Authority prior to construction.
8. Piping samples shall be retrieved at depths of approximately two feet and six feet of pipe run. The required samples shall be analyzed by a State Certified Laboratory.
9. A Secondary Containment Test (SB 989) shall be conducted on all repaired equipment within six (6) months of the completed repairs.



10. All new Underground Storage Tank documentation shall be completed and submitted on the California Environmental Reporting System (CERS).

11. A Certificate of Installation/Modification shall be completed and submitted once all repairs have been completed.

ACCEPTED BY:



DATE:

5-11-13



PERMIT #: FA 0002691	OWNER: Kuljit Ghuman
FACILITY: Johnny Quik #143	CONTACT: Daniel D Cruz or Jerry Hale
ADDRESS: 2126 Taft Hwy	ADDRESS: 2126 Taft Hwy
CITY: Bakersfield	CITY: Bakersfield
PHONE #: (661) 834-9113	PHONE #: (661) 864-1023

INSTRUCTIONS: Please call for an inspection or submit the requested information when ready. They will run in consecutive order beginning with number 1. DO NOT cover work for any numbered group or continue with the next phase of work until all items in that group are signed off by the Permitting Authority. Following these instructions will reduce the number of required inspection visits and therefore the assessment of additional fees.

INSPECTION

DATE

INSPECTOR

- TANKS & BACKFILL -

1	Backfill of tanks	N/A	
1	Copy of installation check list	N/A	
1	Spark Test Certificate	N/A	

- PIPING SYSTEM -

1	Soil samples retrieved at depths of approximately two feet and six feet of pipe run	05/09/2013	<i>J. Hale</i>
2	Primary piping, vapor, and vent lines pressure/soap test	05/21/2013	<i>J. Hale</i>
3	Corrosion protection of piping & fill pipe	N/A	

- SECONDARY CONTAINMENT -

2	Secondary piping, vapor and vent lines pressure/soap test	05/24/2013	<i>J. Hale</i>
2	Sump and UDC test	05/24/2013	<i>J. Hale</i>
2	Electrical Conduits	N/A	

Please contact the Fire Department at (661) 391-7082 and Building (electrical) Department at (661) 862-8661 to schedule final inspections with them before calling this department for the final inspection.

- FINAL -

3	Overspill boxes / Drop tube valves	N/A	
3	Line Leak Detectors and Positive Shut Down	N/A	
3	Electrical Seal Offs and Sealed Field Connections	N/A	
3	Monitor System Check	N/A	
3	Enhanced Leak Detection (ELD) test of system	N/A	
3	As-built drawings (if required)	06/17/2013	<i>J. Hale</i>
3	Monitoring Requirements	N/A	
3	Submittal of owner information and Form C	06/17/2013	<i>J. Hale</i>

CONTRACTOR: D n J Construction Inc.
CONTACT: Daniel D Cruz or Jerry Hale

LICENSE #: 792494
PHONE #: (661) 864-1023



MATTHEW CONSTANTINE, DIRECTOR
PUBLIC HEALTH SERVICES

ENVIRONMENTAL HEALTH DIVISION

2700 M STREET, SUITE 300, BAKERSFIELD, CA 93301-2370

VOICE: (661) 862-8740 FAX: (661) 862-8701

Web: www.co.kern.ca.us/eh E-mail: eh@co.kern.ca.us

"ONE VOICE"



CLAUDIA JONAH, MD
PUBLIC HEALTH OFFICER

Application for Underground Tank Construction/Modification

In order to expedite permit processing, before submitting your permit application(s) for construction/modification, check to see that all of the following are completed (copies of required forms are attached):

- New Construction/Modification Application.** Applications must be fully completed or they will be returned; no exceptions. The use of the answer "NA" (not applicable) is unacceptable. See matrix located at: <http://www.co.kern.ca.us/eh/> to determine if a modification permit is required.

Permit fee(s) must be submitted with the application or it will be returned.

Contractor information:

- Current pocket copy of the contractors' license with license expiration date clearly visible. Only General A, C-61/D-40 issued prior to January 18, 2001, General B with restrictions will be accepted. All contractors shall also have a hazardous substance certification on their licenses.
- Current copies of certificates of workers compensation insurance.
- Site safety plan.
- Copy of current International Code Council certification. ✓

UST Facility page – Form A (New Construction Only)

Tank Information Page - Form B (each tank)

- New Construction – complete all sections.
- Modification – complete sections that have been upgraded or repaired.

Two sets of plot plans for the facility. Plans must include:

- location of property lines, all buildings and openings to each building (such as windows, doors, vents, etc.), with at least a 100-foot radius around all equipment.
- nearest road or intersection;
- all tanks, piping, any fixed source of ignition (i.e., water heaters, forced air AC units, etc.);
- all equipment to be installed;
- any source of water infiltration and wells;
- north arrow;
- scale of drawing, minimum acceptable scale is 1-inch = 16 feet.

- Two sets of site specific detailed drawings of proposed construction.** Drawings must show side and top views of tanks, piping, secondary containment, leak detection and monitoring equipment, overflow protection and all other equipment required. All equipment must be clearly labeled. The minimum acceptable scale is 1-inch = 10 feet.

Equipment Description Checklist

- Certificate of Installation/Modification – Form C (submit upon project completion)**

This Page was Intentionally Left Blank

OPERATING PERMIT APPLICATION – FACILITY INFORMATION

KERN COUNTY ENVIRONMENTAL HEALTH SERVICES DIVISION
 2700 M STREET, SUITE 300
 BAKERSFIELD, CA 93301
 (661) 862-8740 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
UNDERGROUND STORAGE TANK

(one page per site) Page of

TYPE OF ACTION (Check one item only)	<input type="checkbox"/> 1. NEW PERMIT	<input type="checkbox"/> 5. CHANGE OF INFORMATION	<input type="checkbox"/> 7. PERMANENT FACILITY CLOSURE
	<input type="checkbox"/> 3. RENEWAL PERMIT	<input type="checkbox"/> 6. TEMPORARY FACILITY CLOSURE	<input type="checkbox"/> 9. TRANSFER PERMIT

I. FACILITY INFORMATION

TOTAL NUMBER OF USTs AT FACILITY ^{404.} 3	FACILITY ID # ^{1.} (Agency Use Only)
---	--

BUSINESS NAME (Same as FACILITY NAME or DBA – Doing Business As) CHANNY QUICK #143	^{3.}
---	---------------

BUSINESS SITE ADDRESS ^{103.} 2120 TAFT HWY	CITY ^{104.} BKSFD
--	-------------------------------

FACILITY TYPE ^{403.} <input checked="" type="checkbox"/> 1. MOTOR VEHICLE FUELING <input type="checkbox"/> 2. FUEL DISTRIBUTION <input type="checkbox"/> 3. FARM <input type="checkbox"/> 4. PROCESSOR <input type="checkbox"/> 6. OTHER	Is the facility located on Indian Reservation or Trust lands? ^{405.} <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
---	--

II. PROPERTY OWNER INFORMATION

PROPERTY OWNER NAME ^{407.} KULJIT SINGH GHUMAN	PHONE ^{408.} (661) 834-9113
--	---

MAILING ADDRESS ^{409.} 2120 TAFT HWY
--

CITY ^{410.} BKSFD	STATE ^{411.} CA	ZIP CODE ^{412.} 93313
-------------------------------	-----------------------------	-----------------------------------

III. TANK OPERATOR INFORMATION Check if same as Property Owner

TANK OPERATOR NAME ^{428-1.} KULJIT SINGH GHUMAN	PHONE ^{428-2.} (661) 834-9113
---	---

MAILING ADDRESS ^{428-3.} 2120 TAFT HWY
--

CITY ^{428-4.} BKSFD CA	STATE ^{428-5.} CA	ZIP CODE ^{428-6.} 93313
------------------------------------	-------------------------------	-------------------------------------

IV. TANK OWNER INFORMATION Check if same as Property Owner

TANK OWNER NAME ^{414.} KULJIT SINGH GHUMAN	PHONE ^{415.} (661) 834-9113
--	---

MAILING ADDRESS ^{416.} 2120 TAFT HWY
--

CITY ^{417.} BKSFD	STATE ^{418.} CA	ZIP CODE ^{419.} 93313
-------------------------------	-----------------------------	-----------------------------------

OWNER TYPE:	<input type="checkbox"/> 4. LOCAL AGENCY/DISTRICT	<input type="checkbox"/> 5. COUNTY AGENCY	<input type="checkbox"/> 6. STATE AGENCY
	<input type="checkbox"/> 7. FEDERAL AGENCY	<input type="checkbox"/> 8. NON-GOVERNMENT	^{420.}

V. BOARD OF EQUALIZATION UST STORAGE FEE ACCOUNT NUMBER

TY (TK) HQ 44-	Call the State Board of Equalization, Fuel Tax Division, if there are questions.	^{421.}
----------------	--	-----------------

VI. PERMIT HOLDER INFORMATION

Issue permit and send legal notifications and mailings to:	<input checked="" type="checkbox"/> 1. FACILITY OWNER <input type="checkbox"/> 4. TANK OPERATOR <input type="checkbox"/> 3. TANK OWNER <input type="checkbox"/> 5. FACILITY OPERATOR
--	---

SUPERVISOR OF DIVISION, SECTION, OR OFFICE (Required For Public Agencies Only) ^{406.}
--

VII. APPLICANT SIGNATURE

CERTIFICATION: I certify that the information provided herein is true, accurate, and in full compliance with legal requirements.

APPLICANT SIGNATURE 	DATE ^{424.} 4-19-13	PHONE ^{425.} (661) 201-3707
-------------------------	---------------------------------	---

APPLICANT NAME (Print) ^{426.} Jerry Hale	APPLICANT TITLE ^{427.} Contractor
--	---

UST Operating Permit Application – Facility Information Instructions
(Formerly SWRCB UST Permit Application Form A and UPCF Form hwfvr-a)

Complete this form for all new permits, permit changes, or facility information changes. This form must be submitted within 30 days of permit or facility information changes, unless approval is required prior to making the changes. For changes, submit only that form that contains the change.

Submit one UST Operating Permit Application – Facility Information form per facility, regardless of the number of USTs located at the facility. If not already on file with the Kern County Environmental Health Services Division (KCEHSD), the tank owner must submit with this form, a current UST Operating Permit Application – Tank Information form for each UST; a UST Monitoring Plan and a UST Response Plan pursuant to 23 CCR § 2632, 2634 and 2641; and, for USTs containing petroleum, a certification of financial responsibility pursuant to 23 CCR § 2807.

The following documents, at a minimum, are also required, if applicable:

- Written agreement between UST Owner and UST Operator per Health and Safety Code § 25284(a)(3);
- Letter from the Chief Financial Officer (if using State Cleanup Fund, financial test of self-insurance, guarantee, local government financial test, or Local Government Fund as a financial responsibility mechanism).

Please number all pages of your submittal. This helps the Kern County Environmental Health Services Division (KCEHSD) identify whether the submittal is complete and if any pages are separated. (Note: Numbering of these instructions matches the data element numbers on the form.)

400. TYPE OF ACTION – Check the reason this form is being submitted. CHECK ONE ITEM ONLY.
404. TOTAL NUMBER OF USTs AT SITE – Indicate the number of tanks that will remain on the site after the requested action.
1. FACILITY ID NUMBER – Leave this blank. This number is assigned by KCEHSD. This is the unique number which identifies your facility.
3. BUSINESS NAME – Enter the complete Business Name. (Same as FACILITY NAME or DBA (Doing Business As)).
103. BUSINESS SITE ADDRESS – Enter the street address of the facility, including building number, if applicable. This address must be the physical location of the facility. Post office box numbers are not acceptable.
104. CITY – Enter the city or unincorporated area in which the facility is located.
403. FACILITY TYPE – Indicate the type of facility.
405. INDIAN RESERVATION OR TRUST LANDS – Check whether the facility is located on an Indian reservation or other trust lands.

407. PROPERTY OWNER NAME – 408. PROPERTY OWNER PHONE – 409. PROPERTY OWNER MAILING ADDRESS – 410. PROPERTY OWNER CITY – 411. PROPERTY OWNER STATE – 412. PROPERTY OWNER ZIP CODE –	Complete items 407 - 412 for the property owner. Include the area code and any extension number.
---	--

428-1. TANK OPERATOR NAME – 428-2. TANK OPERATOR PHONE – 428-3. TANK OPERATOR MAILING ADDRESS – 428-4. TANK OPERATOR CITY – 428-5. TANK OPERATOR STATE – 428-6. TANK OPERATOR ZIP CODE –	Complete items 428-1 to 428-6 for the UST operator. Include the area code and any extension number.
---	---

414. TANK OWNER NAME – 415. TANK OWNER PHONE – 416. TANK OWNER MAILING ADDRESS – 417. TANK OWNER CITY – 418. TANK OWNER STATE – 419. TANK OWNER ZIP CODE –	Complete items 414 - 419 for the UST owner. Include the area code and any extension number.
---	---

420. TANK OWNER TYPE – Check the type of tank ownership.
421. BOE NUMBER – Enter your State Board of Equalization (BOE) UST storage fee account number. This fee applies to regulated USTs storing petroleum products and is required before your permit application will be processed. If you do not have an account number with the BOE, or if you have any questions regarding the fee or exemptions, contact the BOE at (916) 322-9669 or by mail at: Board of Equalization, Fuel Taxes Division, P O Box 942879, Sacramento, CA 94279-0030.
423. PERMIT HOLDER INFORMATION – Indicate the party to whom the UST operating permit is to be issued and legal notifications and mailings should be sent.
406. SUPERVISOR OF DIVISION SECTION OR OFFICE SUPERVISOR – If the facility owner is a public agency, enter the name of the supervisor of the division section or office that operates the UST. This person must have access to the UST records.
- APPLICANT SIGNATURE – The application form must be signed, in the space provided, by:
- The UST owner or operator, facility owner or operator, or a duly authorized representative of the owner; or
 - If the UST(s) is/are owned by a corporation, partnership, or public agency:
 - 1.) A principal executive officer at the level of vice-president or by an authorized representative responsible for the overall operation of the facility where the UST(s) is/are located; or
 - 2.) A general partner or proprietor; or
 - 3.) A principal executive officer, ranking elected official, or authorized representative of a public agency.
424. DATE – Enter the date the form was signed.
425. PHONE – Enter the phone number of the applicant (i.e., person signing the form). Include the area code and any extension number.
426. APPLICANT NAME – Print or type the full name of the person signing the form.
427. APPLICANT TITLE – Enter the title of the person signing the form.

FA 2691
Event 193

UNDERGROUND STORAGE TANKS NEW CONSTRUCTION/MODIFICATION APPLICATION

KERN COUNTY ENVIRONMENTAL HEALTH SERVICES DIVISION
2700 M STREET, SUITE 300
BAKERSFIELD, CA 93301
(661) 862-8740 Fax (661) 862-8701

(one page per site) Page of

TYPE OF ACTION 1. NEW SITE CONSTRUCTION 2. MODIFICATION 3. NEW TANK INSTALLATION AT EXISTING FACILITY A
(Check one item only)

I. FACILITY / SITE INFORMATION

FACILITY ID# 1501000 UST FILE NUMBER 1 B

BUSINESS NAME (same as FACILITY NAME or DBA - Doing Business As) JOHNNY QUICK #143 3

BUSINESS SITE ADDRESS 2126 TAFT HWY 103

CITY BKSPD CA 93313 104 BUSINESS PHONE 661 834-9113 102

NEAREST CROSS STREET 401

II. CONTRACTOR INFORMATION

CONTRACTOR NAME DNJ CONST INC C CONTRACTOR PHONE 661 804-1023 D

MAILING OR STREET ADDRESS 3430-A GILMORE AVE E

CITY BKSPD F STATE CA G ZIP CODE 93308 H

CALIFORNIA CONTRATORS LICENSE NUMBER 792494 I LICENSE TYPE A-1A (click for drop-down) J

CERTIFIED INSTALLER DAN CRUZ K ICC INSTALLER CERTIFICATION NUMBER 5255732 L

III. SCOPE OF WORK

BRIEFLY DESCRIBE THE PROPOSED SCOPE OF WORK: REMOVE & REPLACE EXISTING PRODUCT PIPING & (S) EXISTING TANK TURBIN SUMPS M

IV. TANK LIST

TANK NUMBER	PRODUCT(S)	CAPACITY
#1	DIESEL	10,000 GAL
#2	GAS UNL	10,000 GAL
#3	GAS PREMIUM	10,000 GAL
(add additional on separate sheet)		

V. INTERGRITY TESTING/ENHANCED LEAK DETECTION

TESTING COMPANY CONFIDENCE "UST" TESTING O PHONE 661 213-6372 P

TEST METHOD Q

VII. APPLICANT SIGNATURE

Certification - I certify that the information provided herein is true and accurate to the best of my knowledge.

SIGNATURE OF APPLICANT [Signature] DATE 4-19-13 424 PHONE 661 201-3707 425

NAME OF APPLICANT (print) JERRY HALE 426 TITLE OF APPLICANT Contractor 427

I – New Construction/Modification Applica

Complete the UST – New Construction/Modification page for any new installations or modifications at a UST facility. This page must be submitted 30 days and a permit issued prior to beginning any work.

A Completed UST- Facility page and a UST – Tank Information Page for each tank is to be included with the application. Two sets of scaled facility plot plans and site specific detailed drawings of the proposed work are also to be submitted with this application.

Please number all pages of your submittal. This helps the Kern County Environmental Health Services Division (KCEHSD) identify whether the submittal is complete and if any pages are separated.

- A. TYPE OF ACTION - Check the reason the page is being completed. CHECK ONE ITEM ONLY.
- 1. FACILITY ID NUMBER - Leave this blank. This number is assigned by KCEHSD. This is the unique number which identifies your facility.
- B. UST FILE NUMBER - Leave this blank. This number is assigned by KCEHSD.
- 3. BUSINESS NAME - Enter the full legal name of the business.
- 103. BUSINESS SITE ADDRESS - Enter the street address where the facility is located. No post office box numbers are allowed. This information must provide a means to geographically locate the facility.
- 104. CITY - Enter the city or unincorporated area in which business site is located.
- 102. BUSINESS PHONE - Enter the phone number, area code first, and any extension.
- 401. NEAREST CROSS STREET - Enter the name of the cross street nearest to the site of the tank.
- C. CONTRACTOR NAME - Enter the name of the contracting firm performing the installation or modification of the UST system. The permit will not be issued until valid contractor information is provided.
- D. CONTRACTOR PHONE - Enter the phone number, area code first, and any extension.
- E. MAILING OR STREET ADDRESS - Enter the contractor's address information.
- F. CITY - Enter the contractor's city.
- G. STATE - Enter the contractor's state.
- H. ZIP - Enter the contractor's zip code
- I. CALIFORNIA CONTRACTORS LICENSE NUMBER - Enter the appropriate contractor's license number.
- J. LICENSE TYPE - Enter the type of contractor's license.
- K. CERTIFIED INSTALLER - Enter the name of the ICC (International Code Council) certified installer that will be on site during construction.
- L. ICC INSTALLER CERTIFICATION NUMBER - Enter the ICC certification number.
- M. SCOPE OF WORK - Briefly describe the proposed scope of work. This is required for any modifications.
- N. TANK LIST - Enter the owner's assigned tank number, contents and capacity of all the tanks on the site including any tanks being installed.
- O. TESTING COMPANY - Enter the name of the company that will complete the post modification or construction testing, if required.
- P. PHONE - Enter the phone number of the testing company.
- Q. TEST METHOD - Enter the testing method that will be used.
- 424. DATE - Enter the date the form was signed.
- 425. PHONE - Enter the phone number of the applicant (i.e., person signing the form). Include the area code and any extension number.
- 426. APPLICANT NAME - Print or type the full name of the person signing the form.
- 427. APPLICANT TITLE - Enter the title of the person signing the form.

OPERATING PERMIT APPLICATION - TANK INFORMATION (One form per UST)

KERN COUNTY ENVIRONMENTAL HEALTH SERVICES DIVISION
 2700 M STREET, SUITE 300
 BAKERSFIELD, CA 93301
 (661) 862-8700 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
 UNDERGROUND STORAGE TANKS

(one page per tank) Page of

TYPE OF ACTION (Check one item only. For an UST permanent closure or removal, complete only this section and Sections I, II, III, IV, and IX below) 430

<input type="checkbox"/> 1. NEW PERMIT	<input type="checkbox"/> 3. RENEWAL PERMIT	<input type="checkbox"/> 5. CHANGE OF INFORMATION
<input type="checkbox"/> 6. TEMPORARY UST CLOSURE	<input type="checkbox"/> 7. UST PERMANENT CLOSURE ON SITE	<input type="checkbox"/> 8. UST REMOVAL

DATE UST PERMANENTLY CLOSED: 430a DATE EXISTING UST DISCOVERED: 430b

I. FACILITY INFORMATION

FACILITY ID # (Agency Use Only) FA 000-2091

BUSINESS NAME (Same as FACILITY NAME or DBA-Doing Business As) JOHNNY QUICK #143

BUSINESS SITE ADDRESS 2126 TART HWY 103 CITY BKSF D CA 93313 104

II. TANK DESCRIPTION

TANK ID # 432	TANK MANUFACTURER 433	TANK CONFIGURATION: THIS TANK IS COMPARTMENTED UNIT 434
DATE UST SYSTEM INSTALLED <u>1988</u> 435	TANK CAPACITY IN GALLONS <u>10,000</u> 436	NUMBER OF COMPARTMENTS IN THE UNIT <u>1</u> 437

III. TANK USE AND CONTENTS

TANK USE 439

<input checked="" type="checkbox"/> 1a. MOTOR VEHICLE FUELING	<input type="checkbox"/> 1b. MARINA FUELING	<input type="checkbox"/> 1c. AVIATION FUELING
<input type="checkbox"/> 3. CHEMICAL PRODUCT STORAGE	<input type="checkbox"/> 4. HAZARDOUS WASTE (Includes Used Oil)	<input type="checkbox"/> 5. EMERGENCY GENERATOR FUEL [HSC §25281.5(c)]
<input type="checkbox"/> 6. OTHER GENERATOR FUEL	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):

CONTENTS 439a

PETROLEUM: 440

<input type="checkbox"/> 1a. REGULAR UNLEADED	<input type="checkbox"/> 1c. MIDGRADE UNLEADED	<input checked="" type="checkbox"/> 1b. PREMIUM UNLEADED
<input type="checkbox"/> 3. DIESEL	<input type="checkbox"/> 5. JET FUEL	<input type="checkbox"/> 6. AVIATION GAS
<input type="checkbox"/> 8. PETROLEUM BLEND FUEL	<input type="checkbox"/> 9. OTHER PETROLEUM (Specify):	

NON-PETROLEUM: 440a

<input type="checkbox"/> 7. USED OIL	<input type="checkbox"/> 10. ETHANOL
<input type="checkbox"/> 11. OTHER NON-PETROLEUM (Specify): 440b	

IV. TANK CONSTRUCTION

TYPE OF TANK 443

<input type="checkbox"/> 1. SINGLE WALL	<input checked="" type="checkbox"/> 2. DOUBLE WALL	<input type="checkbox"/> 95. UNKNOWN
---	--	--------------------------------------

PRIMARY CONTAINMENT 444

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 3. FIBERGLASS	<input type="checkbox"/> 6. INTERNAL BLADDER
<input type="checkbox"/> 7. STEEL + INTERNAL LINING	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):

SECONDARY CONTAINMENT 444a

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 3. FIBERGLASS	<input type="checkbox"/> 6. EXTERIOR MEMBRANE LINER
<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):

OVERFILL PREVENTION 445a

<input checked="" type="checkbox"/> 1. AUDIBLE & VISUAL ALARMS	<input type="checkbox"/> 2. BALL FLOAT	<input type="checkbox"/> 3. FILL TUBE SHUT-OFF VALVE
<input type="checkbox"/> 4. TANK MEETS REQUIREMENTS FOR EXEMPTION FROM OVERFILL PREVENTION EQUIPMENT 452		

V. PRODUCT/WASTE PIPING CONSTRUCTION

PIPING CONSTRUCTION 460

<input type="checkbox"/> 1. SINGLE-WALLED	<input checked="" type="checkbox"/> 2. DOUBLE-WALLED	<input type="checkbox"/> 99. OTHER
---	--	------------------------------------

SYSTEM TYPE 458

<input checked="" type="checkbox"/> 1. PRESSURE	<input type="checkbox"/> 2. GRAVITY	<input type="checkbox"/> 3. CONVENTIONAL SUCTION	<input type="checkbox"/> 4. SAFE SUCTION [23 CCR §2636(a)(3)]
---	-------------------------------------	--	---

PRIMARY CONTAINMENT 464

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 8. FLEXIBLE	<input type="checkbox"/> 10. RIGID PLASTIC
<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):	

SECONDARY CONTAINMENT 464a

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 8. FLEXIBLE	<input type="checkbox"/> 10. RIGID PLASTIC
<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):	

PIPING/TURBINE CONTAINMENT SUMP TYPE 464b

<input checked="" type="checkbox"/> 1. SINGLE WALL	<input type="checkbox"/> 2. DOUBLE WALL	<input type="checkbox"/> 90. NONE
--	---	-----------------------------------

VI. VENT VAPOR RECOVERY (VR) AND RISER/FILL PIPE PIPING CONSTRUCTION

VENT PRIMARY CONTAINMENT 464e

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)
-----------------------------------	---	--	-----------------------------------	--

464e1

VENT SECONDARY CONTAINMENT 464f

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input checked="" type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)
-----------------------------------	--	--	--	--

464f1

VR PRIMARY CONTAINMENT 464g

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)
-----------------------------------	---	--	-----------------------------------	--

464g1

VR SECONDARY CONTAINMENT 464h

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input checked="" type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)
-----------------------------------	--	--	--	--

464h1

VENT PIPING TRANSITION SUMP TYPE 464i

<input type="checkbox"/> 1. SINGLE WALL	<input type="checkbox"/> 2. DOUBLE WALL	<input checked="" type="checkbox"/> 90. NONE
---	---	--

464i

RISER PRIMARY CONTAINMENT 464j

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)
-----------------------------------	--	--	-----------------------------------	--

464j1

RISER SECONDARY CONTAINMENT 464k

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)
-----------------------------------	--	--	-----------------------------------	--

464k1

FILL COMPONENTS INSTALLED 451a-c

<input checked="" type="checkbox"/> 1. SPILL BUCKET	<input type="checkbox"/> 3. STRIKER PLATE/BOTTOM PROTECTOR	<input type="checkbox"/> 4. CONTAINMENT SUMP
---	--	--

VII. UNDER-DISPENSER CONTAINMENT (UDC)

CONSTRUCTION TYPE 469a

<input checked="" type="checkbox"/> 1. SINGLE WALL	<input type="checkbox"/> 2. DOUBLE WALL	<input type="checkbox"/> 3. NO DISPENSERS	<input type="checkbox"/> 90. NONE
--	---	---	-----------------------------------

CONSTRUCTION MATERIAL 469b-c

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 99. OTHER (Specify)
-----------------------------------	---	--	--

VIII. CORROSION PROTECTION

STEEL COMPONENT PROTECTION 448

<input type="checkbox"/> 2. SACRIFICIAL ANODE(S)	<input type="checkbox"/> 4. IMPRESSED CURRENT	<input type="checkbox"/> 6. ISOLATION
--	---	---------------------------------------

IX. APPLICANT SIGNATURE

CERTIFICATION: I certify that this UST system is compatible with the hazardous substance stored and that the information provided herein is true, accurate, and in full compliance with legal requirements.

APPLICANT SIGNATURE <u>[Signature]</u> 470	DATE <u>4-26-13</u>
APPLICANT NAME (print) <u>JERRY HANE</u> 471	APPLICANT TITLE <u>Contractor</u> 472

OPERATING PERMIT APPLICATION – TANK INFORMATION (One form per UST)

KERN COUNTY ENVIRONMENTAL HEALTH SERVICES DIVISION
 2700 M STREET, SUITE 300
 BAKERSFIELD, CA 93301
 (661) 862-8700 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
UNDERGROUND STORAGE TANKS

(one page per tank) Page **of**

TYPE OF ACTION (Check one item only. For an UST permanent closure or removal, complete only this section and Sections I, II, III, IV, and IX below) 430

<input type="checkbox"/> 1. NEW PERMIT	<input type="checkbox"/> 3. RENEWAL PERMIT	<input type="checkbox"/> 5. CHANGE OF INFORMATION
<input type="checkbox"/> 6. TEMPORARY UST CLOSURE	<input type="checkbox"/> 7. UST PERMANENT CLOSURE ON SITE	<input type="checkbox"/> 8. UST REMOVAL

DATE UST PERMANENTLY CLOSED: 430a DATE EXISTING UST DISCOVERED: 430b

I. FACILITY INFORMATION

FACILITY ID # (Agency Use Only) **FA 000 2091** 41

BUSINESS NAME (Same as FACILITY NAME or DBA-Doing Business As) **JOHNNY QUICK #143** 3

BUSINESS SITE ADDRESS **2120 TAFT HWY** ¹⁰³ CITY **BKSF D CA 93313** 104

II. TANK DESCRIPTION

TANK ID # 432	TANK MANUFACTURER 433	TANK CONFIGURATION: THIS TANK IS COMPARTMENTED UNIT 434
DATE UST SYSTEM INSTALLED 1988 435	TANK CAPACITY IN GALLONS 10,000 436	NUMBER OF COMPARTMENTS IN THE UNIT 1 437

III. TANK USE AND CONTENTS

TANK USE 439

<input checked="" type="checkbox"/> 1a. MOTOR VEHICLE FUELING	<input type="checkbox"/> 1b. MARINA FUELING	<input type="checkbox"/> 1c. AVIATION FUELING
<input type="checkbox"/> 3. CHEMICAL PRODUCT STORAGE	<input type="checkbox"/> 4. HAZARDOUS WASTE (Includes Used Oil)	<input type="checkbox"/> 5. EMERGENCY GENERATOR FUEL [HSC §25281.5(e)]
<input type="checkbox"/> 6. OTHER GENERATOR FUEL	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):

CONTENTS 439a

PETROLEUM: 440

<input type="checkbox"/> 1a. REGULAR UNLEADED	<input type="checkbox"/> 1c. MIDGRADE UNLEADED	<input type="checkbox"/> 1b. PREMIUM UNLEADED
<input checked="" type="checkbox"/> 3. DIESEL	<input type="checkbox"/> 5. JET FUEL	<input type="checkbox"/> 6. AVIATION GAS
<input type="checkbox"/> 8. PETROLEUM BLEND FUEL	<input type="checkbox"/> 9. OTHER PETROLEUM (Specify):	

NON-PETROLEUM: 440a

<input type="checkbox"/> 7. USED OIL	<input type="checkbox"/> 10. ETHANOL
<input type="checkbox"/> 11. OTHER NON-PETROLEUM (Specify):	

440b

IV. TANK CONSTRUCTION

TYPE OF TANK 443

<input type="checkbox"/> 1. SINGLE WALL	<input checked="" type="checkbox"/> 2. DOUBLE WALL	<input type="checkbox"/> 95. UNKNOWN
---	--	--------------------------------------

PRIMARY CONTAINMENT 444

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 3. FIBERGLASS	<input type="checkbox"/> 6. INTERNAL BLADDER
<input type="checkbox"/> 7. STEEL + INTERNAL LINING	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):

SECONDARY CONTAINMENT 444a

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 3. FIBERGLASS	<input type="checkbox"/> 6. EXTERIOR MEMBRANE LINER	<input type="checkbox"/> 7. JACKETED
<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):	

OVERFILL PREVENTION 445a

<input checked="" type="checkbox"/> 1. AUDIBLE & VISUAL ALARMS	<input type="checkbox"/> 2. BALL FLOAT	<input type="checkbox"/> 3. FILL TUBE SHUT-OFF VALVE
<input type="checkbox"/> 4. TANK MEETS REQUIREMENTS FOR EXEMPTION FROM OVERFILL PREVENTION EQUIPMENT		

452

V. PRODUCT/WASTE PIPING CONSTRUCTION

PIPING CONSTRUCTION 460

<input type="checkbox"/> 1. SINGLE-WALLED	<input checked="" type="checkbox"/> 2. DOUBLE-WALLED	<input type="checkbox"/> 99. OTHER
---	--	------------------------------------

SYSTEM TYPE 458

<input checked="" type="checkbox"/> 1. PRESSURE	<input type="checkbox"/> 2. GRAVITY	<input type="checkbox"/> 3. CONVENTIONAL SUCTION	<input type="checkbox"/> 4. SAFE SUCTION [23 CCR §2636(a)(3)]
---	-------------------------------------	--	---

PRIMARY CONTAINMENT 464

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 8. FLEXIBLE	<input type="checkbox"/> 10. RIGID PLASTIC
<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):	

SECONDARY CONTAINMENT 464a

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 8. FLEXIBLE	<input type="checkbox"/> 10. RIGID PLASTIC
<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):	

PIPING/TURBINE CONTAINMENT SUMP TYPE 464b

<input checked="" type="checkbox"/> 1. SINGLE WALL	<input type="checkbox"/> 2. DOUBLE WALL	<input type="checkbox"/> 90. NONE
--	---	-----------------------------------

464c

VI. VENT, VAPOR RECOVERY (VR) AND RISER/FILL PIPE PIPING CONSTRUCTION

VENT PRIMARY CONTAINMENT 464e

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)
-----------------------------------	---	--	-----------------------------------	--

VENT SECONDARY CONTAINMENT 464e1

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input checked="" type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)
-----------------------------------	--	--	--	--

VR PRIMARY CONTAINMENT 464f

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)
-----------------------------------	---	--	-----------------------------------	--

VR SECONDARY CONTAINMENT 464g

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input checked="" type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)
-----------------------------------	--	--	--	--

VENT PIPING TRANSITION SUMP TYPE 464h

<input type="checkbox"/> 1. SINGLE WALL	<input type="checkbox"/> 2. DOUBLE WALL	<input checked="" type="checkbox"/> 90. NONE
---	---	--

RISER PRIMARY CONTAINMENT 464i

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)
-----------------------------------	--	--	-----------------------------------	--

RISER SECONDARY CONTAINMENT 464j

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)
-----------------------------------	--	--	-----------------------------------	--

FILL COMPONENTS INSTALLED 464k

<input checked="" type="checkbox"/> 1. SPILL BUCKET	<input type="checkbox"/> 3. STRIKER PLATE/BOTTOM PROTECTOR	<input type="checkbox"/> 4. CONTAINMENT SUMP
---	--	--

464k1

VII. UNDER-DISPENSER CONTAINMENT (UDC)

CONSTRUCTION TYPE 469a

<input checked="" type="checkbox"/> 1. SINGLE WALL	<input type="checkbox"/> 2. DOUBLE WALL	<input type="checkbox"/> 3. NO DISPENSERS	<input type="checkbox"/> 90. NONE
--	---	---	-----------------------------------

CONSTRUCTION MATERIAL 469b-c

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 99. OTHER (Specify)
-----------------------------------	---	--	--

VIII. CORROSION PROTECTION

STEEL COMPONENT PROTECTION 448

<input type="checkbox"/> 2. SACRIFICIAL ANODE(S)	<input type="checkbox"/> 4. IMPRESSED CURRENT	<input type="checkbox"/> 6. ISOLATION
--	---	---------------------------------------

IX. APPLICANT SIGNATURE

CERTIFICATION: I certify that this UST system is compatible with the hazardous substance stored and that the information provided herein is true, accurate, and in full compliance with legal requirements.

APPLICANT SIGNATURE Johnny Quick	DATE 4-20-13	470
APPLICANT NAME (print) JOHNNY QUICK	APPLICANT TITLE OWNER	472

Handwritten scribbles and illegible marks at the top left of the page.

Handwritten scribbles and illegible marks at the top right of the page.

OPERATING PERMIT APPLICATION - TANK INFORMATION (One form per UST)

KERN COUNTY ENVIRONMENTAL HEALTH SERVICES DIVISION
 2700 M STREET, SUITE 300
 BAKERSFIELD, CA 93301
 (661) 862-8700 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
 UNDERGROUND STORAGE TANKS

(one page per tank) Page of

TYPE OF ACTION (Check one item only. For an UST permanent closure or removal, complete only this section and Sections I, II, III, IV, and IX below) 430

<input type="checkbox"/> 1. NEW PERMIT	<input type="checkbox"/> 3. RENEWAL PERMIT	<input type="checkbox"/> 5. CHANGE OF INFORMATION
<input type="checkbox"/> 6. TEMPORARY UST CLOSURE	<input type="checkbox"/> 7. UST PERMANENT CLOSURE ON SITE	<input type="checkbox"/> 8. UST REMOVAL

DATE UST PERMANENTLY CLOSED: 430a DATE EXISTING UST DISCOVERED: 430b

I. FACILITY INFORMATION

FACILITY ID # (Agency Use Only) FA 000 2091

BUSINESS NAME (Same as FACILITY NAME or DBA-Doing Business As) Johnny Quick #143

BUSINESS SITE ADDRESS 2122 TART HURRY 103 CITY BEKED CA 93313 104

II. TANK DESCRIPTION

TANK ID # 432	TANK MANUFACTURER 433	TANK CONFIGURATION: THIS TANK IS COMPARTMENTED UNIT 434
DATE UST SYSTEM INSTALLED <u>1988</u> 435	TANK CAPACITY IN GALLONS <u>10,000</u> 436	NUMBER OF COMPARTMENTS IN THE UNIT <u>1</u> 437

III. TANK USE AND CONTENTS

TANK USE

<input checked="" type="checkbox"/> 1a. MOTOR VEHICLE FUELING	<input type="checkbox"/> 1b. MARINA FUELING	<input type="checkbox"/> 1c. AVIATION FUELING	439
<input type="checkbox"/> 3. CHEMICAL PRODUCT STORAGE	<input type="checkbox"/> 4. HAZARDOUS WASTE (Includes Used Oil)	<input type="checkbox"/> 5. EMERGENCY GENERATOR FUEL [HSC §25281.5(c)]	439a
<input type="checkbox"/> 6. OTHER GENERATOR FUEL	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):	439a

CONTENTS

PETROLEUM:	<input checked="" type="checkbox"/> 1a. REGULAR UNLEADED	<input type="checkbox"/> 1c. MIDGRADE UNLEADED	<input type="checkbox"/> 1b. PREMIUM UNLEADED	440
	<input type="checkbox"/> 3. DIFSEL	<input type="checkbox"/> 5. JET FUEL	<input type="checkbox"/> 6. AVIATION GAS	440a
	<input type="checkbox"/> 8. PETROLEUM BLEND FUEL	<input type="checkbox"/> 9. OTHER PETROLEUM (Specify):		440a
NON-PETROLEUM:	<input type="checkbox"/> 7. USED OIL	<input type="checkbox"/> 10. ETHANOL		440b
	<input type="checkbox"/> 11. OTHER NON-PETROLEUM (Specify):			440b

IV. TANK CONSTRUCTION

TYPE OF TANK

<input type="checkbox"/> 1. SINGLE WALL	<input checked="" type="checkbox"/> 2. DOUBLE WALL	<input type="checkbox"/> 95. UNKNOWN	443
---	--	--------------------------------------	-----

PRIMARY CONTAINMENT

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 3. FIBERGLASS	<input type="checkbox"/> 6. INTERNAL BLADDER	444
<input type="checkbox"/> 7. STEEL + INTERNAL LINING	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):	444a

SECONDARY CONTAINMENT

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 3. FIBERGLASS	<input type="checkbox"/> 6. EXTERIOR MEMBRANE LINER	<input type="checkbox"/> 7. JACKETED	445
<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):		445a

OVERFILL PREVENTION

<input checked="" type="checkbox"/> 1. AUDIBLE & VISUAL ALARMS	<input type="checkbox"/> 2. BALL FLOAT	<input type="checkbox"/> 3. FILL TUBE SHUT-OFF VALVE	452
<input type="checkbox"/> 4. TANK MEETS REQUIREMENTS FOR EXEMPTION FROM OVERFILL PREVENTION EQUIPMENT			

V. PRODUCT/WASTE PIPING CONSTRUCTION

PIPING CONSTRUCTION

<input type="checkbox"/> 1. SINGLE-WALLED	<input checked="" type="checkbox"/> 2. DOUBLE-WALLED	<input type="checkbox"/> 99. OTHER	460
---	--	------------------------------------	-----

SYSTEM TYPE

<input checked="" type="checkbox"/> 1. PRESSURE	<input type="checkbox"/> 2. GRAVITY	<input type="checkbox"/> 3. CONVENTIONAL SUCTION	<input type="checkbox"/> 4. SAFE SUCTION [23 CCR §2636(a)(3)]	458
---	-------------------------------------	--	---	-----

PRIMARY CONTAINMENT

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 8. FLEXIBLE	<input type="checkbox"/> 10. RIGID PLASTIC	464
<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):		464a

SECONDARY CONTAINMENT

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 8. FLEXIBLE	<input type="checkbox"/> 10. RIGID PLASTIC	464b
<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):		464c

PIPING/TURBINE CONTAINMENT SUMP TYPE

<input checked="" type="checkbox"/> 1. SINGLE WALL	<input type="checkbox"/> 2. DOUBLE WALL	<input type="checkbox"/> 90. NONE	464d
--	---	-----------------------------------	------

VI. VENT, VAPOR RECOVERY (VR) AND RISER/FILL PIPE PIPING CONSTRUCTION

VENT PRIMARY CONTAINMENT

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)	464e
					464e1

VENT SECONDARY CONTAINMENT

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input checked="" type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)	464f
					464f1

VR PRIMARY CONTAINMENT

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)	464g
					464g1

VR SECONDARY CONTAINMENT

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input checked="" type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)	464h
					464h1

VENT PIPING TRANSITION SUMP TYPE

<input type="checkbox"/> 1. SINGLE WALL	<input type="checkbox"/> 2. DOUBLE WALL	<input checked="" type="checkbox"/> 90. NONE	464i
---	---	--	------

RISER PRIMARY CONTAINMENT

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)	464j
					464j1

RISER SECONDARY CONTAINMENT

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify)	464k
					464k1

FILL COMPONENTS INSTALLED

<input checked="" type="checkbox"/> 1. SPILL BUCKET	<input type="checkbox"/> 3. STRIKER PLATE/BOTTOM PROTECTOR	<input type="checkbox"/> 4. CONTAINMENT SUMP	451a-c
---	--	--	--------

VII. UNDER-DISPENSER CONTAINMENT (UDC)

CONSTRUCTION TYPE

<input checked="" type="checkbox"/> 1. SINGLE WALL	<input type="checkbox"/> 2. DOUBLE WALL	<input type="checkbox"/> 3. NO DISPENSERS	<input type="checkbox"/> 90. NONE	469a
--	---	---	-----------------------------------	------

CONSTRUCTION MATERIAL

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 99. OTHER (Specify)	469b-c
-----------------------------------	---	--	--	--------

VIII. CORROSION PROTECTION

STEEL COMPONENT PROTECTION

<input type="checkbox"/> 2. SACRIFICIAL ANODE(S)	<input type="checkbox"/> 4. IMPRESSED CURRENT	<input type="checkbox"/> 6. ISOLATION	448.
--	---	---------------------------------------	------

IX. APPLICANT SIGNATURE

CERTIFICATION: I certify that this UST system is compatible with the hazardous substance stored and that the information provided herein is true, accurate, and in full compliance with legal requirements.

APPLICANT SIGNATURE <u>John H. Hall</u>	DATE <u>4-26-13</u>	470.
APPLICANT NAME (print) <u>John Hall</u>	APPLICANT TITLE <u>Contractor</u>	472.

CERTIFICATION OF INSTALLATION / MODIFICATION

KERN COUNTY ENVIRONMENTAL HEALTH SERVICES DIVISION
 2700 M STREET, SUITE 300
 BAKERSFIELD, CA 93301
 (661) 862-8740 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
UNDERGROUND STORAGE TANKS

(one form per project) Page ___ of ___

I. FACILITY INFORMATION

FACILITY ID # (Agency Use Only) 1.

--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

BUSINESS NAME (Same as FACILITY NAME or DBA - Doing Business As) 3.

JOHNNY QUICK #143

BUSINESS SITE ADDRESS 103. CITY 104.

2126 TART HULLY *BAKERSFIELD*

II. INSTALLATION / MODIFICATION PROJECT DESCRIPTION

TYPE OF PROJECT (Check all that apply) 483a. <ul style="list-style-type: none"> <input type="checkbox"/> 1. TANK INSTALLATION OR REPLACEMENT <input checked="" type="checkbox"/> 2. PIPING INSTALLATION OR REPLACEMENT <input checked="" type="checkbox"/> 3. SUMP INSTALLATION OR REPLACEMENT <input type="checkbox"/> 4. UNDER DISPENSER CONTAINMENT INSTALLATION OR REPLACEMENT <input type="checkbox"/> 5. OTHER 	WORK AUTHORIZED UNDER PERMIT 483b. (Number or Date):
--	--

DESCRIPTION OF WORK BEING CERTIFIED: 483c

REMOVE 1/2, REPLACE PRODUCT PIPING
1/2 (3) EXISTING TANK TULBILI SUMPS

III. CONTRACTOR INFORMATION

NAME OF CONTRACTOR WHO PERFORMED INSTALLATION / MODIFICATION 482a.

DNJ CONST INC

CONTRACTOR LICENSE # 482b. <i>792494</i>	ICC CERTIFICATION # 482c. <i>5255732</i>
---	---

IV. CERTIFICATION

I certify that the information provided herein is true, accurate, and that the following conditions have been satisfied:

- The installer has met the requirements set forth in 23 CCR §2715, subdivisions (g) and (h).
- The underground storage tank, any primary piping, and any secondary containment was installed according to applicable voluntary consensus standards and any manufacturer's written installation instructions.
- All work listed in the manufacturer's installation checklist has been completed.
- The installation has been inspected and approved by the local agency, or if required by the local agency, inspected and certified by a registered professional engineer having education and experience with underground storage tank system installations.

SIGNATURE OF TANK OWNER OR OWNER'S AGENT	DATE 484.	PHONE 487.
<i>James W. Hale</i>	<i>4-19-13</i>	<i>(661) 201 3707</i>

CERTIFIER'S NAME (print) 485.	CERTIFIER'S TITLE: 486.
<i>James Hale</i>	<i>Contractor</i>

NAME OF CERTIFIER'S EMPLOYER (DBA) 488.	CERTIFIER'S RELATIONSHIP TO TANK OWNER 489.
<i>DNJ CONST INC</i>	<ul style="list-style-type: none"> <input type="checkbox"/> 1. TANK OWNER <input type="checkbox"/> 2. TANK OPERATOR <input checked="" type="checkbox"/> 3. CONTRACTOR <input type="checkbox"/> 4. PROPERTY OWNER <input type="checkbox"/> 5. OTHER AUTHORIZED AGENT OF TANK OWNER

UST Certification of Installation / Modification Form Instructions

This Certification form must be submitted upon the completion of installation or upgrading of tanks and/or piping associated with a UST system. Installation or upgrading of multiple tank systems may be addressed on one form. The UST owner or an authorized representative of the owner must complete this form. Please number all pages of your submittal. This helps the Kern County Environmental Health Services Division (KCEHSD) identify whether the submittal is complete and if any pages are separated. (Note: Numbering of these instructions matches the data element numbers on the form.)

- 1 FACILITY ID NUMBER – Leave this blank. This number is assigned by KCEHSD. This is the unique number which identifies your facility.
- 3 BUSINESS NAME – Enter the complete Facility Name.
- 103 BUSINESS SITE ADDRESS – Enter the street address of the facility, including building number, if applicable. This address must be the physical location of the facility. Post office box numbers are not acceptable.
- 104 CITY – Enter the city or unincorporated area in which the facility is located.
- 482a NAME OF CONTRACTOR WHO PERFORMED INSTALLATION / MODIFICATION – Enter the name of the contractor who performed the work as registered with the Contractors State License Board (CSLB).
- 482b CONTRACTOR LICENSE # – For the contractor named above, enter the license number assigned by the Contractors State License Board (license information is available online at www.cslb.ca.gov).
- 482c ICC CERTIFICATION # – Enter the International Code Council (ICC) “UST Installation/Retrofitting” certification number possessed by the contractor.
- 483a TYPE OF PROJECT – Check the appropriate box(es) to indicate the type of work performed. Address each system component individually (i.e., for installation of a complete motor vehicle fueling UST system, check boxes 1 through 4).
- 483b WORK AUTHORIZED UNDER PERMIT (Number or Date) – Enter the number of the permit issued by the KCEHSD, or if no permit number, the date the permit or project approval was issued for the work being certified.
- 483c DESCRIPTION OF WORK BEING CERTIFIED – In the space provided, briefly describe the work performed. Include the number and type of UST systems installed or upgraded and the scope of work (e.g., “Installation of piping sumps and under dispenser containment, and replacement of product and vapor recovery piping associated with one 12,000 gallon regular unleaded and one 8,000 gallon premium unleaded motor vehicle fuel tank.”).

SIGNATURE OF TANK OWNER OR OWNER’S AGENT – The tank owner or an authorized agent of the owner shall sign in the space provided. This signature certifies that the signer believes that all the information submitted is true and accurate.

- 484 DATE CERTIFIED – Enter the date the form was signed.
- 485 CERTIFIER’S NAME – Enter the full printed name of the person signing the form.
- 486 CERTIFIER’S TITLE – Enter the title of the person signing the form.
- 487 PHONE – Enter the phone number of the person signing the certification. Include the area code and any extension number.
- 488 NAME OF CERTIFIER’S EMPLOYER – Enter the name (DBA) of the employer of the person signing the form. If the tank owner is an individual, and the owner signs the Certification, note “N/A” (Not Applicable) in this space.
- 489 CERTIFIER’S RELATIONSHIP TO TANK OWNER – Check the appropriate box to indicate the nature of the relationship between the person signing the form and the tank owner.

UNDERGROUND STORAGE TANK SYSTEM
 NEW CONSTRUCTION -OR- MODIFICATION

EQUIPMENT DESCRIPTION CHECKLIST

(Complete all applicable sections)

1. TANK CONSTRUCTION

- Double Wall Fiberglass
- Double Wall Steel with Fiberglass coating
- Double Wall Steel primary/ Fiberglass secondary
- Other _____

Tank Manufacturer: _____

2. LEAK MONITORING SYSTEM

Console Manufacturer: _____ Console Model #: _____

3. SENSORS

Sensors	Positive Shut Down	Manufacturer	Model #
Tank Annular Space Sensor	<input type="checkbox"/> Yes <input type="checkbox"/> No		
Tank Turbine Sumps Sensor	<input type="checkbox"/> Yes <input type="checkbox"/> No		
Tank Fill Sumps Sensor	<input type="checkbox"/> Yes <input type="checkbox"/> No		
Dispenser Pan Sumps Sensor	<input type="checkbox"/> Yes <input type="checkbox"/> No		
Sump Annular Space Sensor	<input type="checkbox"/> Yes <input type="checkbox"/> No		
Piping Annular Space Sensor	<input type="checkbox"/> Yes <input type="checkbox"/> No		
Positive Shut Down w/ Failsafe for system disconnection	<input type="checkbox"/> Yes <input type="checkbox"/> No		

4. PIPELINE SYSTEM

- Pressure
- Suction
- Gravity

5. LINE LEAK DETECTOR

- Mechanical Manufacturer: _____ Model #: _____
- Electronic Manufacturer: _____ Model #: _____

6. PIPING CONSTRUCTION PRODUCT ~~AND VENTILATION LINES~~

- Double Wall Fiberglass
- Double Wall Flex Pipe
- Other: _____

Manufacturer: Smith Model #: _____

7. AUTOMATIC TANK GAUGE

Manufacturer: _____ Model #: _____

8. OVERSPILL CONTAINER WITH DRAIN VALVE

Manufacturer: _____ Model #: _____

9. OVERFILL PREVENTION

External Alarm with Audible and Visual Alarm
Manufacturer: _____ Model #: _____ Product Level: _____

Flow Restrictor with Ball Float
Manufacturer: _____ Model #: _____ Product Level: _____

Flow Restrictor with Ball Float and External Alarm
Manufacturer: _____ Model #: _____ Product Level: _____

Positive shut off valve with Flapper
Manufacturer: _____ Model #: _____ Product Level: _____

10. DISPENSER CONTAINMENT

Manufacturer: _____ Model #: _____

11. TANK TOP SUMPS

Manufacturer: _____ Model #: _____ WESTERN FIBERGLASS

12. AUXILLARY SUMPS (TANK GAUGE RISERS, VENT BOXES, ETC)

Manufacturer: _____ Model #: _____

13. PENETRATION FITTINGS

Manufacturer: _____ Model #: _____ AO SMITH BULK HEAD

14. PENETRATION SEALANT


Manufacturer: _____ Model #: _____ AO SMITH GLUE

15. BEDDING AND BACKFILL MATERIAL

Sand Pea Gravel

JOHNNY QUICK # 143
 2120 TAPP AWY
 BKSFD CA 93313

11 TYPES OF (3) TANKS 11



NEW 42" SINGLEWHL
 WESTERN FIBERGLASS TURBIN
 SUMPS

NEW 3 1/2" D. WALL FRP
 DIESEL AT RES # 91
 PREMIUM PIPER LINES. AD. SMITH 11

EXISTING 3+0
 GILBARED MPD's
 DIESEL LINE
 CAPPED INSIDE
 OF UDD 11

DND CONST. INC
 3430-4 GILMORE AVE
 BKSFD CA 93302
 CA CONTRACTORS LIC # 792494

MONITORING PLAN

Kern County Environmental Health Services Department
 2700 M Street, Suite 300
 Bakersfield, CA 93301
 (661) 862-8740 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
 UNDERGROUND STORAGE TANK

TYPE OF ACTION 1. NEW PLAN 2. CHANGE OF INFORMATION 490-1

PLAN TYPE 1. MONITORING IS IDENTICAL FOR ALL USTs AT THIS FACILITY 490-2
 (Check one item only) 2. THIS PLAN COVERS ONLY THE FOLLOWING UST SYSTEM(S) **1 - REGULAR UNLEADED**

I. FACILITY INFORMATION

FACILITY ID# (Agency Use Only) **FA0002691** 1

BUSINESS NAME (Same as FACILITY NAME) **JOHNNY QUIK #143** 3

BUSINESS SITE ADDRESS **2126 TAFT HWY** 103 CITY **BAKERSFIELD** 104

II. EQUIPMENT TESTING AND PREVENTIVE MAINTENANCE

Testing, preventive maintenance, and calibration of monitoring equipment (e.g., sensors, probes, line leak detectors, etc.) must be performed at the frequency specified by the equipment manufacturers' instructions, or annually, whichever is more frequent, and that such work must be performed by qualified personnel. (23 CCR 2632, 2634, 2638, 2641)

MONITORING EQUIPMENT IS SERVICED 1. ANNUALLY 99. OTHER (Specify) 490-3a-b

III. MONITORING LOCATIONS

1. NEW SITE PLOT PLAN/MAP SUBMITTED WITH THIS PLAN. 2. SITE PLOT PLAN/MAP PREVIOUSLY SUBMITTED. 490-4
 (23 CCR 2632, 2634)

IV. TANK MONITORING IS PERFORMED USING THE FOLLOWING METHOD(S):

1. CONTINUOUS ELECTRONIC TANK MONITORING OF ANNULAR (INTERSTITIAL) SPACE(S) OR SECONDARY CONTAINMENT 490-5
 VAULT(S) WITH AUDIBLE AND VISUAL ALARMS. (23 CCR 2632, 2634)

SECONDARY CONTAINMENT IS: a. DRY b. LIQUID FILLED c. PRESSURIZED d. UNDER VACUUM 490-6

PANEL MANUFACTURER: **VEEDER ROOT** 490-7 MODEL #: **TLS 350** 490-8

LEAK SENSOR MANUFACTURER: **VEEDER ROOT** 490-9 MODEL #(S): **420** 490-10

2. AUTOMATIC TANK GAUGING (ATG) SYSTEM USED TO MONITOR SINGLE WALL TANK(S). (23 CCR 2643) 490-11

PANEL MANUFACTURER: 490-12 MODEL #: 490-13

IN-TANK PROBE MANUFACTURER: 490-14 MODEL #(S): 490-15

LEAK TEST FREQUENCY: a. CONTINUOUS b. DAILY/NIGHTLY c. WEEKLY 490-16

d. MONTHLY e. OTHER (Specify): 490-17

PROGRAMMED TESTS: a. 0.1 g.p.h. b. 0.2 g.p.h. c. OTHER (Specify): 490-18-19

3. MONTHLY STATISTICAL INVENTORY RECONCILIATION (23 CCR 2646.1): 490-20

4. WEEKLY MANUAL TANK GAUGING (MTG) (23 CCR 2645). TESTING PERIOD: a. 36 HOURS b. 60 HOURS 490-21-22

5. TANK INTEGRITY TESTING (23 CCR 2643.1): 490-23

TEST FREQUENCY: a. ANNUALLY b. BIENNIALY c. OTHER (Specify): 490-24-25

99. OTHER (Specify): 490-26-27

V. PIPE MONITORING IS PERFORMED USING THE FOLLOWING METHOD(S) (Check all that apply)

1. CONTINUOUS MONITORING OF PIPE/PIPING SUMP(S) AND OTHER SECONDARY CONTAINMENT WITH AUDIBLE AND VISUAL 490-28
 ALARMS. (23 CCR 2636)

SECONDARY CONTAINMENT IS: a. DRY b. LIQUID FILLED c. PRESSURIZED d. UNDER VACUUM 490-29

PANEL MANUFACTURER: **VEEDER ROOT** 490-30 MODEL #: **TLS 350** 490-31

LEAK SENSOR MANUFACTURER: **VEEDER ROOT** 490-32 MODEL #(S): **208** 490-33

PIPING LEAK ALARM TRIGGERS AUTOMATIC PUMP (i.e., TURBINE) SHUTDOWN a. YES b. NO 490-34

FAILURE/DISCONNECTION OF THE MONITORING SYSTEM TRIGGERS AUTOMATIC PUMP SHUTDOWN a. YES b. NO 490-35

2. MECHANICAL LINE LEAK DETECTOR (MLLD) THAT ROUTINELY PERFORMS 3.0 g.p.h. LEAK TESTS AND RESTRICTS OR SHUTS 490-36
 OFF PRODUCT FLOW WHEN A LEAK IS DETECTED (23 CCR 2636)

MLLD MANUFACTURER(S): **RED JACKET** 490-37 MODEL #(S): **FX 1V** 490-38

3. ELECTRONIC LINE LEAK DETECTOR (ELLD) THAT ROUTINELY PERFORMS 3.0 g.p.h. LEAK TESTS (23 CCRR 2636) 490-39

ELLD MANUFACTURER(S): 490-40 MODEL #(S): 490-41

PROGRAMMED IN LINE LEAK TEST: 1. MINIMUM MONTHLY 0.2 g.p.h. 2. MINIMUM ANNUAL 0.1 g.p.h. 490-42

ELLD DETECTION OF A PIPING LEAK TRIGGERS AUTOMATIC PUMP SHUTDOWN a. YES b. NO 490-43

ELLD FAILURE/DISCONNECTION TRIGGERS AUTOMATIC PUMP SHUTDOWN a. YES b. NO 490-44

4. PIPE INTEGRITY TESTING 490-45

TEST FREQUENCY a. ANNUALLY b. EVERY 3 YEARS c. OTHER (Specify) 490-46 490-47

5. VISUAL PIPE MONITORING 490-48

TEST FREQUENCY a. DAILY b. WEEKLY c. MIN. MONTHLY & EACH TIME SYSTEM OPERATED* 490-49

* Allowed for monitoring of unburied emergency generator fuel piping only per HSC 25281.5 (b)(3)

6. SUCTION PIPING MEETS EXEMPTION CRITERIA [23 CCR 2636(a)(3)]. 490-50

7. NO REGULATED PIPING PER HEALTH AND SAFETY CODE, DIVISION 20, CHAPTER 6.7 IS CONNECTED TO THE TANK SYSTEM 490-51

99. OTHER (Specify) 490-52-53

MONITORING PLAN

VI. UNDER DISPENSER CONTAINMENT (UDC) MONITORING

1. UDC MONITORING IS PERFORMED USING THE FOLLOWING METHOD			490-54a
<input type="checkbox"/> 1. CONTINUOUS ELECTRONIC MONITORING	<input type="checkbox"/> 2. FLOAT AND CHAIN ASSEMBLY	<input checked="" type="checkbox"/> 3. ELECTRONIC STAND-ALONE	490-54b
<input type="checkbox"/> 4. NO DISPENSERS <input type="checkbox"/> 99. OTHER (Specify)			
PANEL MANUFACTURER:	490-55	MODEL #:	490-56
LEAK SENSOR MANUFACTURER: BEAUDREAU	490-57	MODEL #(S): 406	490-58
DETECTION OF A LEAK INTO THE UDC TRIGGERS AUDIBLE AND VISUAL ALARMS	<input type="checkbox"/> a. YES	<input checked="" type="checkbox"/> b. NO	490-59
UDC LEAK ALARM TRIGGERS AUTOMATIC PUMP SHUTDOWN	<input type="checkbox"/> a. YES	<input checked="" type="checkbox"/> b. NO	490-60
FAILURE/DISCONNECTION OF UDC MONITORING SYSTEM TRIGGERS AUTOMATIC PUMP SHUTDOWN	<input type="checkbox"/> a. YES	<input checked="" type="checkbox"/> b. NO	490-61
LEAK SENSOR MANUFACTURER:	<input checked="" type="checkbox"/> a. YES	<input type="checkbox"/> b. NO	490-62
2. UDC CONSTRUCTION IS			490-63
<input checked="" type="checkbox"/> 1. SINGLE-WALLED <input type="checkbox"/> 2. DOUBLE-WALLED			
IF DOUBLE WALLED:			490-64a
UDC INTERSTITIAL SPACE IS MONITORED BY: <input type="checkbox"/> 1. LIQUID <input type="checkbox"/> 2. PRESSURE <input type="checkbox"/> 3. VACCUM			
A LEAK WITHIN THE SECONDARY CONTAINMENT OF THE UDC TRIGGERS AUDIBLE AND VISUAL ALARMS			490-64b
<input type="checkbox"/> a. YES <input type="checkbox"/> b. NO			

VII. PERIODIC SYSTEM TESTING

<input type="checkbox"/> 1. ELD TESTING: THIS FACILITY HAS BEEN NOTIFIED BY THE STATE WATER RESOURCES CONTROL BOARD THAT ENHANCED LEAK DETECTION DETECTION (ELD) MUST BE PERFORMED. PERIODIC ELD IS PERFORMED EVERY 36 MONTHS AS REQUIRED. (23 CCR 2644.1)	490-65
<input checked="" type="checkbox"/> 2. SECONDARY CONTAINMENT COMPONENTS ARE TESTED EVERY 36 MONTHS.	490-66
<input checked="" type="checkbox"/> 3. SPILL BUCKETS ARE TESTED ANNUALLY.	490-67

VIII. RECORDKEEPING

The following monitoring/maintenance records are kept for this facility:

<input checked="" type="checkbox"/> Alarm logs 490-68a	<input checked="" type="checkbox"/> Visual inspection records 490-68b	<input type="checkbox"/> Tank integrity testing results 490-68c
<input type="checkbox"/> SIR testing results (and supporting documentation records) 490-68d	<input type="checkbox"/> Tank gauging results (and supporting documentation records) 490-68e	
<input type="checkbox"/> ATG Testing results (and supporting documentation records) 490-68f	<input type="checkbox"/> Corrosion protection 60-day logs 490-68g	
<input checked="" type="checkbox"/> Equipment maintenance and calibration records 490-68h		

IX. TRAINING

<input checked="" type="checkbox"/> Personnel with UST monitoring responsibilities are familiar with all of the following documents relevant to their job duties.	490-69a
REFERENCE DOCUMENTS MAINTAINED AT FACILITY (Check all that apply)	
<input checked="" type="checkbox"/> THIS UNDERGROUND STORAGE TANK MONITORING PLAN (Required)	490-69b
<input checked="" type="checkbox"/> OPERATING MANUALS FOR ELECTRONIC MONITORING EQUIPMENT (Required)	490-69c
<input type="checkbox"/> CALIFORNIA UNDERGROUND STORAGE TANK REGULATIONS	490-69d
<input type="checkbox"/> CALIFORNIA UNDERGROUND STORAGE TANK LAW	490-69e
<input type="checkbox"/> STATE WATER RESOURCES CONTROL BOARD (SWRCB) PUBLICATION: "HANDBOOK FOR TANK OWNERS-MANUAL AND STATISTICAL INVENTORY RECONCILLIATION"	490-69f
<input type="checkbox"/> SWRCB PUBLICATION: "UNDERSTANDING AUTOMATIC TANK GAUGING SYSTEMS"	490-69g
<input type="checkbox"/> OTHER (Specify):	490-69h-69i
<input checked="" type="checkbox"/> This facility has a "Designated UST Operator" who has passed the California UST System Operator Exam administered by the International Code Council (ICC). The "Designated UST Operator" will train facility employees in the proper operation and maintenance of the UST systems annually, and within 30 days of hire. This training will include, but is not limited to, the following:	490-70
<ul style="list-style-type: none"> - Operation of the UST systems in a manner consistent with the facility's best management practices - The facility employee's role with regard to the monitoring equipment as specified in this UST Monitoring Plan - The facility employee's role with regard to spills and overfills as specified in the UST Response Plan - Names of contact person(s) for emergencies and monitoring alarms. 	

X. COMMENTS/ADDITIONAL INFORMATION

Provide additional comments here or indicate how many pages with additional information on specific monitoring procedures are attached to this plan.	490-71
--	--------

XI. PERSONNEL RESPONSIBILITIES

The UST Owner/Operator is responsible for ensuring that: 1) the daily/routine UST monitoring activities and maintenance of UST leak detection equipment covered by this plan occurs, 2) all conditions that indicate a possible release are investigated, and 3) all monitoring records are maintained properly.

The following person(s) are responsible for performing the monitoring and equipment maintenance:

NAME	490-72	TITLE	490-73
NAME	490-74	TITLE	490-75

The Designated Operator shall perform a monthly visual inspection of the facility, provide a report to the owner/operator, and inform the owner/operator of any conditions that need follow-up action.

XII. OWNER/OPERATOR SIGNATURE

CERTIFICATION: I certify that the informatino provided herein is true and accurate to the best of my knowledge.

APPLICANT SIGNATURE	490-76	DATE:	490-77
REPRESENTING: <input type="checkbox"/> 1. Tank Owner/Operator <input type="checkbox"/> 2. Facility Owner/Operator <input type="checkbox"/> 3. Authorized Representative of Owner			
APPLICANT NAME (print):	490-78	APPLICANT TITLE:	490-79

(Agency Use Only) This plan has been reviewed and: Approved Approved With Conditions

Local Agency Signature: *Vicki Furr* Date: JAN 17 2013

Comments or Special Conditions: _____

MONITORING PLAN

Kern County Environmental Health Services Department
 2700 M Street, Suite 300
 Bakersfield, CA 93301
 (661) 862-8740 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
 UNDERGROUND STORAGE TANK

TYPE OF ACTION 1. NEW PLAN 2. CHANGE OF INFORMATION 490-1
 PLAN TYPE 1. MONITORING IS IDENTICAL FOR ALL USTs AT THIS FACILITY 490-2
 (Check one item only) 2. THIS PLAN COVERS ONLY THE FOLLOWING UST SYSTEM(S) **2 - PREMIUM UNLEADED**

I. FACILITY INFORMATION

FACILITY ID# (Agency Use Only) **FA0002691** 1
 BUSINESS NAME (Same as FACILITY NAME) **JOHNNY QUIK #143** 3
 BUSINESS SITE ADDRESS **2126 TAFT HWY** 103 | CITY **BAKERSFIELD** 104

II. EQUIPMENT TESTING AND PREVENTIVE MAINTENANCE

Testing, preventive maintenance, and calibration of monitoring equipment (e.g., sensors, probes, line leak detectors, etc.) must be performed at the frequency specified by the equipment manufacturers' instructions, or annually, whichever is more frequent, and that such work must be performed by qualified personnel. (23 CCR 2632, 2634, 2638, 2641)

MONITORING EQUIPMENT IS SERVICED 1. ANNUALLY 99. OTHER (Specify) 490-3a-b

III. MONITORING LOCATIONS

1. NEW SITE PLOT PLAN/MAP SUBMITTED WITH THIS PLAN. 2. SITE PLOT PLAN/MAP PREVIOUSLY SUBMITTED. 490-4
 (23 CCR 2632, 2634)

IV. TANK MONITORING IS PERFORMED USING THE FOLLOWING METHOD(S):

1. CONTINUOUS ELECTRONIC TANK MONITORING OF ANNULAR (INTERSTITIAL) SPACE(S) OR SECONDARY CONTAINMENT 490-5
 VAULT(S) WITH AUDIBLE AND VISUAL ALARMS. (23 CCR 2632, 2634)
 SECONDARY CONTAINMENT IS: a. DRY b. LIQUID FILLED c. PRESSURIZED d. UNDER VACUUM 490-6
 PANEL MANUFACTURER: **VEEDER ROOT** 490-7 | MODEL #: **TLS 350** 490-8
 LEAK SENSOR MANUFACTURER: **VEEDER ROOT** 490-9 | MODEL #(S): **420** 490-10
 2. AUTOMATIC TANK GAUGING (ATG) SYSTEM USED TO MONITOR SINGLE WALL TANK(S). (23 CCR 2643) 490-11
 PANEL MANUFACTURER: 490-12 | MODEL #: 490-13
 IN-TANK PROBE MANUFACTURER: 490-14 | MODEL #(S): 490-15
 LEAK TEST FREQUENCY: a. CONTINUOUS b. DAILY/NIGHTLY c. WEEKLY 490-16
 d. MONTHLY e. OTHER (Specify): 490-17
 PROGRAMMED TESTS: a. 0.1 g.p.h. b. 0.2 g.p.h. c. OTHER (Specify): 490-18-19
 3. MONTHLY STATISTICAL INVENTORY RECONCILIATION (23 CCR 2646.1): 490-20
 4. WEEKLY MANUAL TANK GAUGING (MTG) (23 CCR 2645). TESTING PERIOD: a. 36 HOURS b. 60 HOURS 490-21-22
 5. TANK INTEGRITY TESTING (23 CCR 2643.1): 490-23
 TEST FREQUENCY: a. ANNUALLY b. BIENNIALLY c. OTHER (Specify): 490-24-25
 99. OTHER (Specify): 490-26-27

V. PIPE MONITORING IS PERFORMED USING THE FOLLOWING METHOD(S) (Check all that apply)

1. CONTINUOUS MONITORING OF PIPE/PIPING SUMP(S) AND OTHER SECONDARY CONTAINMENT WITH AUDIBLE AND VISUAL 490-28
 ALARMS. (23 CCR 2636)
 SECONDARY CONTAINMENT IS: a. DRY b. LIQUID FILLED c. PRESSURIZED d. UNDER VACUUM 490-29
 PANEL MANUFACTURER: **VEEDER ROOT** 490-30 | MODEL #: **TLS 350** 490-31
 LEAK SENSOR MANUFACTURER: **VEEDER ROOT** 490-32 | MODEL #(S): **208** 490-33
 PIPING LEAK ALARM TRIGGERS AUTOMATIC PUMP (i.e., TURBINE) SHUTDOWN a. YES b. NO 490-34
 FAILURE/DISCONNECTION OF THE MONITORING SYSTEM TRIGGERS AUTOMATIC PUMP SHUTDOWN a. YES b. NO 490-35
 2. MECHANICAL LINE LEAK DETECTOR (MLLD) THAT ROUTINELY PERFORMS 3.0 g.p.h. LEAK TESTS AND RESTRICTS OR SHUTS 490-36
 OFF PRODUCT FLOW WHEN A LEAK IS DETECTED (23 CCR 2636)
 MLLD MANUFACTURER(S): **RED JACKET** 490-37 | MODEL #(S): **FX 1V** 490-38
 3. ELECTRONIC LINE LEAK DETECTOR (ELLD) THAT ROUTINELY PERFORMS 3.0 g.p.h. LEAK TESTS (23 CCR 2636) 490-39
 ELLD MANUFACTURER(S): 490-40 | MODEL #(S): 490-41
 PROGRAMMED IN LINE LEAK TEST: 1. MINIMUM MONTHLY 0.2 g.p.h. 2. MINIMUM ANNUAL 0.1 g.p.h. 490-42
 ELLD DETECTION OF A PIPING LEAK TRIGGERS AUTOMATIC PUMP SHUTDOWN a. YES b. NO 490-43
 ELLD FAILURE/DISCONNECTION TRIGGERS AUTOMATIC PUMP SHUTDOWN a. YES b. NO 490-44
 4. PIPE INTEGRITY TESTING 490-45
 TEST FREQUENCY a. ANNUALLY b. EVERY 3 YEARS c. OTHER (Specify) 490-46 490-47
 5. VISUAL PIPE MONITORING 490-48
 TEST FREQUENCY a. DAILY b. WEEKLY c. MIN. MONTHLY & EACH TIME SYSTEM OPERATED* 490-49
 * Allowed for monitoring of unburied emergency generator fuel piping only per HSC 25281.5 (b)(3)
 6. SUCTION PIPING MEETS EXEMPTION CRITERIA [23 CCR 2636(a)(3)]. 490-50
 7. NO REGULATED PIPING PER HEALTH AND SAFETY CODE, DIVISION 20, CHAPTER 6.7 IS CONNECTED TO THE TANK SYSTEM 490-51
 99. OTHER (Specify) 490-52-53

MONITORING PLAN

VI. UNDER DISPENSER CONTAINMENT (UDC) MONITORING

1. UDC MONITORING IS PERFORMED USING THE FOLLOWING METHOD 490-54a

1. CONTINUOUS ELECTRONIC MONITORING 2. FLOAT AND CHAIN ASSEMBLY 3. ELECTRONIC STAND-ALONE 490-54b
 4. NO DISPENSERS 99. OTHER (Specify)

PANEL MANUFACTURER: 490-55 MODEL #: 490-56

LEAK SENSOR MANUFACTURER: **BEAUDREAU** 490-57 MODEL #(S): **406** 490-58

DETECTION OF A LEAK INTO THE UDC TRIGGERS AUDIBLE AND VISUAL ALARMS a. YES b. NO 490-59

UDC LEAK ALARM TRIGGERS AUTOMATIC PUMP SHUTDOWN a. YES b. NO 490-60

FAILURE/DISCONNECTION OF UDC MONITORING SYSTEM TRIGGERS AUTOMATIC PUMP SHUTDOWN a. YES b. NO 490-61

LEAK SENSOR MANUFACTURER: a. YES b. NO 490-62

2. UDC CONSTRUCTION IS 1. SINGLE-WALLED 2. DOUBLE-WALLED 490-63

IF DOUBLE WALLED: 490-64a

UDC INTERSTITIAL SPACE IS MONITORED BY: 1. LIQUID 2. PRESSURE 3. VACCUM

A LEAK WITHIN THE SECONDARY CONTAINMENT OF THE UDC TRIGGERS AUDIBLE AND VISUAL ALARMS a. YES b. NO 490-64b

VII. PERIODIC SYSTEM TESTING

1. ELD TESTING: THIS FACILITY HAS BEEN NOTIFIED BY THE STATE WATER RESOURCES CONTROL BOARD THAT ENHANCED LEAK DETECTION (ELD) MUST BE PERFORMED. PERIODIC ELD IS PERFORMED EVERY 36 MONTHS AS REQUIRED. (23 CCR 2644.1) 490-65

2. SECONDARY CONTAINMENT COMPONENTS ARE TESTED EVERY 36 MONTHS. 490-66

3. SPILL BUCKETS ARE TESTED ANNUALLY. 490-67

VIII. RECORDKEEPING

The following monitoring/maintenance records are kept for this facility:

- Alarm logs 490-68a Visual inspection records 490-68b Tank integrity testing results 490-68c
 SIR testing results (and supporting documentation records) 490-68d Tank gauging results (and supporting documentation records) 490-68e
 ATG Testing results (and supporting documentation records) 490-68f Corrosion protection 60-day logs 490-68g
 Equipment maintenance and calibration records 490-68h

IX. TRAINING

Personnel with UST monitoring responsibilities are familiar with all of the following documents relevant to their job duties. 490-69a

REFERENCE DOCUMENTS MAINTAINED AT FACILITY (Check all that apply)

- THIS UNDERGROUND STORAGE TANK MONITORING PLAN (Required) 490-69b
 OPERATING MANUALS FOR ELECTRONIC MONITORING EQUIPMENT (Required) 490-69c
 CALIFORNIA UNDERGROUND STORAGE TANK REGULATIONS 490-69d
 CALIFORNIA UNDERGROUND STORAGE TANK LAW 490-69e
 STATE WATER RESOURCES CONTROL BOARD (SWRCB) PUBLICATION: "HANDBOOK FOR TANK OWNERS-MANUAL AND STATISTICAL INVENTORY RECONCILIATION" 490-69f
 SWRCB PUBLICATION: "UNDERSTANDING AUTOMATIC TANK GAUGING SYSTEMS" 490-69g
 OTHER (Specify): 490-69h-69i

This facility has a "Designated UST Operator" who has passed the California UST System Operator Exam administered by the International Code Council (ICC). 490-70
 The "Designated UST Operator" will train facility employees in the proper operation and maintenance of the UST systems annually, and within 30 days of hire.
 This training will include, but is not limited to, the following:
 - Operation of the UST systems in a manner consistent with the facility's best management practices
 - The facility employee's role with regard to the monitoring equipment as specified in this UST Monitoring Plan
 - The facility employee's role with regard to spills and overfills as specified in the UST Response Plan
 - Names of contact person(s) for emergencies and monitoring alarms.

X. COMMENTS/ADDITIONAL INFORMATION

Provide additional comments here or indicate how many pages with additional information on specific monitoring procedures are attached to this plan. 490-71

XI. PERSONNEL RESPONSIBILITIES

The UST Owner/Operator is responsible for ensuring that: 1) the daily/routine UST monitoring activities and maintenance of UST leak detection equipment covered by this plan occurs, 2) all conditions that indicate a possible release are investigated, and 3) all monitoring records are maintained properly.

The following person(s) are responsible for performing the monitoring and equipment maintenance:

NAME	490-72	TITLE	490-73
NAME	490-74	TITLE	490-75

The Designated Operator shall perform a monthly visual inspection of the facility, provide a report to the owner/operator, and inform the owner/operator of any conditions that need follow-up action.

XII. OWNER/OPERATOR SIGNATURE

CERTIFICATION: I certify that the informatino provided herein is true and accurate to the best of my knowledge.

APPLICANT SIGNATURE 490-76 DATE: 490-77

REPRESENTING: 1. Tank Owner/Operator 2. Facility Owner/Operator 3. Authorized Representative of Owner

APPLICANT NAME (print): 490-78 APPLICANT TITLE: 490-79

(Agency Use Only) This plan has been reviewed and: Approved Approved With Conditions

Local Agency Signature: *Vicky Fuernberg* Date: JAN 17 2013

Comments or Special Conditions:

MONITORING PLAN

Kern County Environmental Health Services Department
 2700 M Street, Suite 300
 Bakersfield, CA 93301
 (661) 862-8740 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
UNDERGROUND STORAGE TANK

(Page 1 of 2)

TYPE OF ACTION	<input type="checkbox"/> 1. NEW PLAN	<input type="checkbox"/> 2. CHANGE OF INFORMATION	490-1
PLAN TYPE	<input type="checkbox"/> 1. MONITORING IS IDENTICAL FOR ALL USTs AT THIS FACILITY (Check one item only) <input checked="" type="checkbox"/> 2. THIS PLAN COVERS ONLY THE FOLLOWING UST SYSTEM(S) 3 - DIESEL		490-2

I. FACILITY INFORMATION										
FACILITY ID# (Agency Use Only)	FA0002691			-						1
BUSINESS NAME (Same as FACILITY NAME)	JOHNNY QUIK #143									3
BUSINESS SITE ADDRESS	2126 TAFT HWY	103	CITY	BAKERSFIELD						104

II. EQUIPMENT TESTING AND PREVENTIVE MAINTENANCE			
Testing, preventive maintenance, and calibration of monitoring equipment (e.g., sensors, probes, line leak detectors, etc.) must be performed at the frequency specified by the equipment manufacturers' instructions, or annually, whichever is more frequent, and that such work must be performed by qualified personnel. (23 CCR 2632, 2634, 2638, 2641)			
MONITORING EQUIPMENT IS SERVICED	<input checked="" type="checkbox"/> 1. ANNUALLY	<input type="checkbox"/> 99. OTHER (Specify)	490-3a-b

III. MONITORING LOCATIONS			
<input type="checkbox"/> 1. NEW SITE PLOT PLAN/MAP SUBMITTED WITH THIS PLAN.	<input checked="" type="checkbox"/> 2. SITE PLOT PLAN/MAP PREVIOUSLY SUBMITTED.		490-4
			(23 CCR 2632, 2634)

IV. TANK MONITORING IS PERFORMED USING THE FOLLOWING METHOD(S):			
<input checked="" type="checkbox"/> 1. CONTINUOUS ELECTRONIC TANK MONITORING OF ANNULAR (INTERSTITIAL) SPACE(S) OR SECONDARY CONTAINMENT VAULT(S) WITH AUDIBLE AND VISUAL ALARMS. (23 CCR 2632, 2634)			490-5
SECONDARY CONTAINMENT IS:	<input checked="" type="checkbox"/> a. DRY	<input type="checkbox"/> b. LIQUID FILLED	490-6
PANEL MANUFACTURER:	VEEDER ROOT	490-7	MODEL #: TLS 350
LEAK SENSOR MANUFACTURER:	VEEDER ROOT	490-9	MODEL #(S): 420

<input type="checkbox"/> 2. AUTOMATIC TANK GAUGING (ATG) SYSTEM USED TO MONITOR SINGLE WALL TANK(S). (23 CCR 2643)	490-11
PANEL MANUFACTURER:	490-12
IN-TANK PROBE MANUFACTURER:	490-14
LEAK TEST FREQUENCY:	<input type="checkbox"/> a. CONTINUOUS <input type="checkbox"/> b. DAILY/NIGHTLY <input type="checkbox"/> c. WEEKLY <input type="checkbox"/> d. MONTHLY <input type="checkbox"/> e. OTHER (Specify):
PROGRAMMED TESTS:	<input type="checkbox"/> a. 0.1 g.p.h. <input type="checkbox"/> b. 0.2 g.p.h. <input type="checkbox"/> c. OTHER (Specify):

<input type="checkbox"/> 3. MONTHLY STATISTICAL INVENTORY RECONCILIATION (23 CCR 2646.1):	490-20
<input type="checkbox"/> 4. WEEKLY MANUAL TANK GAUGING (MTG) (23 CCR 2645). TESTING PERIOD:	<input type="checkbox"/> a. 36 HOURS <input type="checkbox"/> b. 60 HOURS
<input type="checkbox"/> 5. TANK INTEGRITY TESTING (23 CCR 2643.1):	490-23
TEST FREQUENCY:	<input type="checkbox"/> a. ANNUALLY <input type="checkbox"/> b. BIENNIALY <input type="checkbox"/> c. OTHER (Specify):
<input type="checkbox"/> 99. OTHER (Specify):	490-26-27

V. PIPE MONITORING IS PERFORMED USING THE FOLLOWING METHOD(S) (Check all that apply)			
<input checked="" type="checkbox"/> 1. CONTINUOUS MONITORING OF PIPE/PIPING SUMP(S) AND OTHER SECONDARY CONTAINMENT WITH AUDIBLE AND VISUAL ALARMS. (23 CCR 2636)			490-28
SECONDARY CONTAINMENT IS:	<input checked="" type="checkbox"/> a. DRY	<input type="checkbox"/> b. LIQUID FILLED	490-29
PANEL MANUFACTURER:	VEEDER ROOT	490-30	MODEL #: TLS 350
LEAK SENSOR MANUFACTURER:	VEEDER ROOT	490-32	MODEL #(S): 208
PIPING LEAK ALARM TRIGGERS AUTOMATIC PUMP (i.e., TURBINE) SHUTDOWN	<input checked="" type="checkbox"/> a. YES	<input type="checkbox"/> b. NO	490-34
FAILURE/DISCONNECTION OF THE MONITORING SYSTEM TRIGGERS AUTOMATIC PUMP SHUTDOWN	<input checked="" type="checkbox"/> a. YES	<input type="checkbox"/> b. NO	490-35

<input checked="" type="checkbox"/> 2. MECHANICAL LINE LEAK DETECTOR (MLLD) THAT ROUTINELY PERFORMS 3.0 g.p.h. LEAK TESTS AND RESTRICTS OR SHUTS OFF PRODUCT FLOW WHEN A LEAK IS DETECTED (23 CCR 2636)	490-36
MLLD MANUFACTURER(S):	RED JACKET 490-37 MODEL #(S): FX1DV
<input type="checkbox"/> 3. ELECTRONIC LINE LEAK DETECTOR (ELLD) THAT ROUTINELY PERFORMS 3.0 g.p.h. LEAK TESTS (23 CCR 2636)	490-39
ELLD MANUFACTURER(S):	490-40 MODEL #(S):
PROGRAMMED IN LINE LEAK TEST:	<input type="checkbox"/> 1. MINIMUM MONTHLY 0.2 g.p.h. <input type="checkbox"/> 2. MINIMUM ANNUAL 0.1 g.p.h.
ELLD DETECTION OF A PIPING LEAK TRIGGERS AUTOMATIC PUMP SHUTDOWN	<input type="checkbox"/> a. YES <input checked="" type="checkbox"/> b. NO
ELLD FAILURE/DISCONNECTION TRIGGERS AUTOMATIC PUMP SHUTDOWN	<input type="checkbox"/> a. YES <input checked="" type="checkbox"/> b. NO

<input type="checkbox"/> 4. PIPE INTEGRITY TESTING	490-45
TEST FREQUENCY	<input type="checkbox"/> a. ANNUALLY <input type="checkbox"/> b. EVERY 3 YEARS <input type="checkbox"/> c. OTHER (Specify):
<input type="checkbox"/> 5. VISUAL PIPE MONITORING	490-48
TEST FREQUENCY	<input type="checkbox"/> a. DAILY <input type="checkbox"/> b. WEEKLY <input type="checkbox"/> c. MIN. MONTHLY & EACH TIME SYSTEM OPERATED*
* Allowed for monitoring of unburied emergency generator fuel piping only per HSC 25281.5 (b)(3)	
<input type="checkbox"/> 6. SUCTION PIPING MEETS EXEMPTION CRITERIA [23 CCR 2636(a)(3)].	490-50
<input type="checkbox"/> 7. NO REGULATED PIPING PER HEALTH AND SAFETY CODE, DIVISION 20, CHAPTER 6.7 IS CONNECTED TO THE TANK SYSTEM	490-51
<input type="checkbox"/> 99. OTHER (Specify)	490-52-53

MONITORING PLAN

VI. UNDER DISPENSER CONTAINMENT (UDC) MONITORING

1. UDC MONITORING IS PERFORMED USING THE FOLLOWING METHOD

490-54a

- 1. CONTINUOUS ELECTRONIC MONITORING
2. FLOAT AND CHAIN ASSEMBLY
3. ELECTRONIC STAND-ALONE
4. NO DISPENSERS
99. OTHER (Specify)

490-54b

PANEL MANUFACTURER: 490-55 MODEL #: 490-56

LEAK SENSOR MANUFACTURER: BEAUDREAU 490-57 MODEL #(S): 406 490-58

DETECTION OF A LEAK INTO THE UDC TRIGGERS AUDIBLE AND VISUAL ALARMS [] a. YES [x] b. NO 490-59

UDC LEAK ALARM TRIGGERS AUTOMATIC PUMP SHUTDOWN [] a. YES [x] b. NO 490-60

FAILURE/DISCONNECTION OF UDC MONITORING SYSTEM TRIGGERS AUTOMATIC PUMP SHUTDOWN [] a. YES [x] b. NO 490-61

LEAK SENSOR MANUFACTURER: [x] a. YES [] b. NO 490-62

2. UDC CONSTRUCTION IS [x] 1. SINGLE-WALLED [] 2. DOUBLE-WALLED 490-63

IF DOUBLE WALLED: 490-64a

UDC INTERSTITIAL SPACE IS MONITORED BY: [] 1. LIQUID [] 2. PRESSURE [] 3. VACCUM

A LEAK WITHIN THE SECONDARY CONTAINMENT OF THE UDC TRIGGERS AUDIBLE AND VISUAL ALARMS [] a. YES [] b. NO 490-64b

VII. PERIODIC SYSTEM TESTING

[] 1. ELD TESTING: THIS FACILITY HAS BEEN NOTIFIED BY THE STATE WATER RESOURCES CONTROL BOARD THAT ENHANCED LEAK DETECTION DETECTION (ELD) MUST BE PERFORMED. PERIODIC ELD IS PERFORMED EVERY 36 MONTHS AS REQUIRED. (23 CCR 2644.1) 490-65

[x] 2. SECONDARY CONTAINMENT COMPONENTS ARE TESTED EVERY 36 MONTHS. 490-66

[x] 3. SPILL BUCKETS ARE TESTED ANNUALLY. 490-67

VIII. RECORDKEEPING

The following monitoring/maintenance records are kept for this facility:

- [x] Alarm logs 490-68a [x] Visual inspection records 490-68b [] Tank integrity testing results 490-68c
[] SIR testing results (and supporting documentation records) 490-68d [] Tank gauging results (and supporting documentation records) 490-68e
[] ATG Testing results (and supporting documentation records) 490-68f [] Corrosion protection 60-day logs 490-68g
[x] Equipment maintenance and calibration records 490-68h

IX. TRAINING

[x] Personnel with UST monitoring responsibilities are familiar with all of the following documents relevant to their job duties. 490-69a

REFERENCE DOCUMENTS MAINTAINED AT FACILITY (Check all that apply)

- [x] THIS UNDERGROUND STORAGE TANK MONITORING PLAN (Required) 490-69b
[x] OPERATING MANUALS FOR ELECTRONIC MONITORING EQUIPMENT (Required) 490-69c
[] CALIFORNIA UNDERGROUND STORAGE TANK REGULATIONS 490-69d
[] CALIFORNIA UNDERGROUND STORAGE TANK LAW 490-69e
[] STATE WATER RESOURCES CONTROL BOARD (SWRCB) PUBLICATION: "HANDBOOK FOR TANK OWNERS-MANUAL AND STATISTICAL INVENTORY RECONCILIATION" 490-69f
[] SWRCB PUBLICATION: "UNDERSTANDING AUTOMATIC TANK GAUGING SYSTEMS" 490-69g
[] OTHER (Specify): 490-69h-69i

[x] This facility has a "Designated UST Operator" who has passed the California UST System Operator Exam administered by the International Code Council (ICC). The "Designated UST Operator" will train facility employees in the proper operation and maintenance of the UST systems annually, and within 30 days of hire. This training will include, but is not limited to, the following:
- Operation of the UST systems in a manner consistent with the facility's best management practices
- The facility employee's role with regard to the monitoring equipment as specified in this UST Monitoring Plan
- The facility employee's role with regard to spills and overfills as specified in the UST Response Plan
- Names of contact person(s) for emergencies and monitoring alarms. 490-70

X. COMMENTS/ADDITIONAL INFORMATION

Provide additional comments here or indicate how many pages with additional information on specific monitoring procedures are attached to this plan. 490-71

XI. PERSONNEL RESPONSIBILITIES

The UST Owner/Operator is responsible for ensuring that: 1) the daily/routine UST monitoring activities and maintenance of UST leak detection equipment covered by this plan occurs, 2) all conditions that indicate a possible release are investigated, and 3) all monitoring records are maintained properly.

The following person(s) are responsible for performing the monitoring and equipment maintenance:

Table with 2 columns: NAME, TITLE. Rows for 490-72 and 490-75.

The Designated Operator shall perform a monthly visual inspection of the facility, provide a report to the owner/operator, and inform the owner/operator of any conditions that need follow-up action.

XII. OWNER/OPERATOR SIGNATURE

CERTIFICATION: I certify that the informatino provided herein is true and accurate to the best of my knowledge.

APPLICANT SIGNATURE 490-76 DATE: 490-77
REPRESENTING: [] 1. Tank Owner/Operator [] 2. Facility Owner/Operator: [] 3. Authorized Representative of Owner

APPLICANT NAME (print): 490-78 APPLICANT TITLE: 490-79

(Agency Use Only) This plan has been reviewed and: [x] Approved [] Approved With Conditions

Local Agency Signature: [Signature] Date: JAN 17 2013
Comments or Special Conditions:



CERTIFICATE OF LIABILITY INSURANCE

DATE (MM/DD/YYYY)
11/28/2012

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

IMPORTANT: If the certificate holder is an ADDITIONAL INSURED, the policy(ies) must be endorsed. If SUBROGATION IS WAIVED, subject to the terms and conditions of the policy, certain policies may require an endorsement. A statement on this certificate does not confer rights to the certificate holder in lieu of such endorsement(s).

PRODUCER Wilson Paves & Associates 3636 Pegasus Drive Bakersfield CA 93308	CONTACT NAME: Adriann Gomez	
	PHONE (A/C, No, Ext): (661) 327-3111	FAX (A/C, No): (661) 327-1262
	E-MAIL ADDRESS: agomez@wilsonpaves.com	
	INSURER(S) AFFORDING COVERAGE	
	INSURER A: Great American Insurance Co.	NAIC # 16691
	INSURER B: Wesco Insurance Company	25011
	INSURER C:	
	INSURER D:	
	INSURER E:	
	INSURER F:	

COVERAGES CERTIFICATE NUMBER: **11/26/12-13** REVISION NUMBER:

THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.

INSR LTR	TYPE OF INSURANCE	ADDL INSR	SUBR WVD	POLICY NUMBER	POLICY EFF (MM/DD/YYYY)	POLICY EXP (MM/DD/YYYY)	LIMITS
A	GENERAL LIABILITY			02GL863452	11/26/2012	11/26/2013	EACH OCCURRENCE \$ 1,000,000
	<input checked="" type="checkbox"/> COMMERCIAL GENERAL LIABILITY						DAMAGE TO RENTED PREMISES (Ea occurrence) \$ 100,000
	<input type="checkbox"/> CLAIMS-MADE <input checked="" type="checkbox"/> OCCUR						MED EXP (Any one person) \$ Excluded
	<input checked="" type="checkbox"/> Pollution Liability						PERSONAL & ADV INJURY \$ 1,000,000
	<input checked="" type="checkbox"/> Professional Liability						GENERAL AGGREGATE \$ 2,000,000
	GEN'L AGGREGATE LIMIT APPLIES PER:						PRODUCTS - COMP/OP AGG \$ 2,000,000
	<input checked="" type="checkbox"/> POLICY <input type="checkbox"/> PRO-JECT <input type="checkbox"/> LOC						\$
B	AUTOMOBILE LIABILITY			WPA103011602	2/18/2013	2/18/2014	COMBINED SINGLE LIMIT (Ea accident) \$ 1,000,000
	<input checked="" type="checkbox"/> ANY AUTO						BODILY INJURY (Per person) \$
	<input type="checkbox"/> ALL OWNED AUTOS	<input type="checkbox"/> SCHEDULED AUTOS					BODILY INJURY (Per accident) \$
	<input type="checkbox"/> HIRED AUTOS	<input type="checkbox"/> NON-OWNED AUTOS					PROPERTY DAMAGE (Per accident) \$
	UMBRELLA LIAB	<input type="checkbox"/>	OCCUR				EACH OCCURRENCE \$
	EXCESS LIAB	<input type="checkbox"/>	CLAIMS-MADE				AGGREGATE \$
	DED		RETENTION \$				\$
	WORKERS COMPENSATION AND EMPLOYERS' LIABILITY						WC STATUTORY LIMITS <input type="checkbox"/> OTH-ER <input type="checkbox"/>
	ANY PROPRIETOR/PARTNER/EXECUTIVE OFFICER/MEMBER EXCLUDED? (Mandatory in NH)	<input type="checkbox"/>	N/A				E.L. EACH ACCIDENT \$
	If yes, describe under DESCRIPTION OF OPERATIONS below						E.L. DISEASE - EA EMPLOYEE \$
A	Bailee/Cargo			02IM49438	11/26/2012	11/26/2013	Limit \$ 100,000.00 Deductible \$ 1,000.00

DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES (Attach ACORD 101, Additional Remarks Schedule, if more space is required)

CERTIFICATE HOLDER

CANCELLATION

Kern County Environmental Health
Attn: Marty Brownfield
2700 M Street
Bakersfield, CA 93301

SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS.

AUTHORIZED REPRESENTATIVE

Dan Paves/AG 



CERTIFICATE OF LIABILITY INSURANCE

DATE (MM/DD/YYYY)
4/23/2013

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

IMPORTANT: If the certificate holder is an ADDITIONAL INSURED, the policy(ies) must be endorsed. If SUBROGATION IS WAIVED, subject to the terms and conditions of the policy, certain policies may require an endorsement. A statement on this certificate does not confer rights to the certificate holder in lieu of such endorsement(s).

PRODUCER Wilson Paves & Associates 3636 Pegasus Drive Bakersfield CA 93308	CONTACT NAME: Adriann Gomez	
	PHONE (A/C, No, Ext): (661) 327-3111	FAX (A/C, No): (661) 327-1262
E-MAIL ADDRESS: agomez@wilsonpaves.com		
INSURER(S) AFFORDING COVERAGE		NAIC #
INSURER A: State Compensation Ins Fund		35076
INSURER B:		
INSURER C:		
INSURER D:		
INSURER E:		
INSURER F:		

COVERAGES **CERTIFICATE NUMBER:** 13-14WC **REVISION NUMBER:**

THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.

INSR LTR	TYPE OF INSURANCE	ADDL INSR	SUBR WVD	POLICY NUMBER	POLICY EFF (MM/DD/YYYY)	POLICY EXP (MM/DD/YYYY)	LIMITS
	GENERAL LIABILITY <input type="checkbox"/> COMMERCIAL GENERAL LIABILITY <input type="checkbox"/> CLAIMS-MADE <input type="checkbox"/> OCCUR GEN'L AGGREGATE LIMIT APPLIES PER: <input type="checkbox"/> POLICY <input type="checkbox"/> PRO-JECT <input type="checkbox"/> LOC						EACH OCCURRENCE \$ DAMAGE TO RENTED PREMISES (Ea occurrence) \$ MED EXP (Any one person) \$ PERSONAL & ADV INJURY \$ GENERAL AGGREGATE \$ PRODUCTS - COMP/OP AGG \$
	AUTOMOBILE LIABILITY <input type="checkbox"/> ANY AUTO <input type="checkbox"/> ALL OWNED AUTOS <input type="checkbox"/> SCHEDULED AUTOS <input type="checkbox"/> HIRED AUTOS <input type="checkbox"/> NON-OWNED AUTOS						COMBINED SINGLE LIMIT (Ea accident) \$ BODILY INJURY (Per person) \$ BODILY INJURY (Per accident) \$ PROPERTY DAMAGE (Per accident) \$
	<input type="checkbox"/> UMBRELLA LIAB <input type="checkbox"/> OCCUR <input type="checkbox"/> EXCESS LIAB <input type="checkbox"/> CLAIMS-MADE <input type="checkbox"/> DED <input type="checkbox"/> RETENTION \$						EACH OCCURRENCE \$ AGGREGATE \$
A	WORKERS COMPENSATION AND EMPLOYERS' LIABILITY ANY PROPRIETOR/PARTNER/EXECUTIVE OFFICER/MEMBER EXCLUDED? (Mandatory in NH) If yes, describe under DESCRIPTION OF OPERATIONS below		N/A	90386272013	1/1/2013	1/1/2014	<input checked="" type="checkbox"/> WC STATU-TORY LIMITS <input type="checkbox"/> OTH-ER E.L. EACH ACCIDENT \$ 1,000,000 E.L. DISEASE - EA EMPLOYEE \$ 1,000,000 E.L. DISEASE - POLICY LIMIT \$ 1,000,000

DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES (Attach ACORD 101, Additional Remarks Schedule, if more space is required)

CERTIFICATE HOLDER**CANCELLATION**

Kern County Environmental Health
 Attn: Marty Brownfield
 2700 M Street
 Bakersfield, CA 93301

SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS.

AUTHORIZED REPRESENTATIVE

Dan Paves/ML



DEPARTMENT OF CONSUMER AFFAIRS

Contractors State License Board

Contractor's License Detail - License # 792494

⚠️ DISCLAIMER: A license status check provides information taken from the CSLB license database. Before relying on this information, you should be aware of the following limitations.

- ➔ CSLB complaint disclosure is restricted by law ([B&P 7124.6](#)) If this entity is subject to public complaint disclosure, a link for complaint disclosure will appear below. Click on the link or button to obtain complaint and/or legal action information.
- ➔ Per [B&P 7071.17](#) , only construction related civil judgments reported to the CSLB are disclosed.
- ➔ Arbitrations are not listed unless the contractor fails to comply with the terms of the arbitration.
- ➔ Due to workload, there may be relevant information that has not yet been entered onto the Board's license database.

License Number	792494	Extract Date	5/3/2013
Business Information			
D N J CONSTRUCTION INC			
Business Phone Number: (661) 864-1023			
3430-A GILMORE AVENUE BAKERSFIELD, CA 93308			
Entity	Corporation		
Issue Date	03/14/2001		
Expire Date	03/31/2015		
License Status	ACTIVE		
This license is current and active. All information below should be reviewed.			
Classifications	CLASS	DESCRIPTION	
	A	<u>GENERAL ENGINEERING CONTRACTOR</u>	
	B	<u>GENERAL BUILDING CONTRACTOR</u>	
Certifications	CERT	DESCRIPTION	
	HAZ	<u>HAZARDOUS SUBSTANCES REMOVAL</u>	
Bonding	CONTRACTOR'S BOND		
This license filed a Contractor's Bond with <u>AMERICAN CONTRACTORS INDEMNITY COMPANY</u> .			
Bond Number: 9036423			
Bond Amount: \$12,500			
Effective Date: 01/01/2007			
<u>Contractor's Bond History</u>			
BOND OF QUALIFYING INDIVIDUAL			
1. This license filed Bond of Qualifying Individual number 9036424 for WEGENER DOUGLAS EARL in the amount of \$12,500 with <u>AMERICAN CONTRACTORS INDEMNITY COMPANY</u> .			

Effective Date: 01/01/2007

BQI's Bond History

WORKERS' COMPENSATION

This license has workers compensation insurance with
STATE COMPENSATION INSURANCE FUND

Workers' Compensation

Policy Number: 9038627

Effective Date: 01/01/2013

Expire Date: 01/01/2014

Workers' Compensation History

Personnel List

[Conditions of Use](#) | [Privacy Policy](#)
Copyright © 2010 State of California



Consumer Affairs

State Of California
CONTRACTORS STATE LICENSE BOARD
ACTIVE LICENSE



License Number

792494

Entity **CORP**

Business Name

D N J CONSTRUCTION INC

Classification(s)

A B HAZ

Expiration Date

03/31/2015

www.cslb.ca.gov





International Code Council
500 New Jersey Avenue, NW
Washington, DC 20001

The individual named hereon is CERTIFIED in the categories shown, having been so certified pursuant to successful completion of the prescribed written examinations.

Not valid unless signed by certificate holder.
ICC Certification attests to competent knowledge of codes and standards.




International Code Council
500 New Jersey Avenue, NW
Washington, DC 20001

The individual named hereon is CERTIFIED in the categories shown, having been so certified pursuant to successful completion of the prescribed written examinations.


Not valid unless signed by certificate holder.
ICC Certification attests to competent knowledge of codes and standards.

Daniel D Cruz - 5255732
UST Installation/Retrofitting - Exp: 02/01/2014



ICC

Daniel D Cruz - 5255732
Vapor Recovery System Installation and Repair - Exp: 07/19/2014



ICC

Home > My ICC

Certified Professional Information:

Last, First MI: Cruz, Daniel D
 Certified under this name: Daniel D Cruz
 Address: 3430 A GILMORE AVE
 DNJ CONSTRUCTION INC
 City, State Zip: BAKERSFIELD, CA 93308
 Phone: (661)201-3708

Certification Type(s): UST Installation/Retrofitting (expires 02/01/2014)
 Vapor Recovery System Installation and Repair (expires 07/19/2014)

Listings here may not reflect today's changes, additions, exam results, or certifications from organizations other than ICC (including BOCA, ICBO, and SBCCI). Listings are updated nightly on this web site, so please allow a full 24 hours for changes to be reflected here. ICC certification for code enforcement professions attests to competent knowledge of construction codes and standards in effect on the date of certification or renewal.

ICC does its best to maintain the privacy requests of its members and constituents. If you believe that phone number or address information listed here should not be displayed please contact us at 1-888-ICC-SAFE (422-7233) between 8am and 7pm (CT) for personal assistance.

Terms of Use: This listing is provided as a service to the constituents of ICC for these purposes: locating a certified professional or contractor in your area, or confirming status for individuals. Any other use, sale, transfer, or reproduction in any form without the express written consent of ICC is strictly prohibited. ICC reserves the right to incorporate some false names to detect improper use of this service.

<p>Contact Information</p> <p>1-888-ICC-SAFE (422-7233), ext. 5524</p> <p>Contact Us</p>




SAVE™ Sustainable Attributes Verification and Evaluation Program
One Resource—Multiple Green Rating Systems

Daniel D. Cruz


Certification Type(s):
Doublewall + Retrofit

Company: D N J Construction
State: California
Expires: 10 / 31 / 2013

www.SBRAVO.com



made
in USA



*FIBERGLASS
sumps
VDC'S*

NOV Fiber Glass Systems

Daniel D. Cruz

has successfully completed Bonder Training as set forth in the
Fiber Glass Systems' Total Quality Installation Program for the
installation of UL listed primary and secondary containment
products.

3/1/2012
Date

Renewal of the bonder certification is recommended every three years
or when the specific bonding process has not been practiced for a
period of six months.

AO Smith April 6



TRAINING CERTIFICATE

PRESENTED TO:

Jerry Hale

Of: DNJ Construction.

Has successfully completed a training course for:

Single Wall Tank Sumps

CERTIFICATION DATE: 04/24/13

Valid: April 24, 2013 to April 24, 2015

CERTIFIED BY: Ron Trengove

Western Fiberglass, Inc. • 1555 Copperhill Parkway • Santa Rosa, CA 95403
Ph: (800) 688-3375 or (707) 523-2050

ANN K. BARNETT
Kern County Auditor-Controller-County Clerk
1115 Truxtun Ave, Bakersfield, CA 93301
(661) 868-3588



FICTITIOUS BUSINESS NAME STATEMENT

Fictitious Business Name (DBA) (If listing more than two DBAs, attach additional sheets as needed.)		
1	DBA #1	JOHNNY QUIK #143 2011-B3647
	DBA #2	

2	Street address of principal place of business				Mailing address of business (Write out, do not enter "same")		
	2126 TAFT HWY				2126 TAFT HWY		
	City	State	Zip	County	City	State	Zip
	BAKERSFIELD	CA	93313	KERN	BAKERSFIELD	CA	93313

3	Registrants							
	A	Last name of individual, partner, or name of Corporation, LLC, or LP					State of incorporation or organization	
		GHUMAN						
		First name of individual or partner						
	KULJIT							
	Street address (P.O. Box not acceptable)		City	State	Zip			
1001 NICKI CT		Bakersfield	CA	93307				
B	Last name of individual, partner, or name of Corporation, LLC, or LP					State of incorporation or organization		
	First name of individual or partner							
	Street address (P.O. Box not acceptable)							
		City	State	Zip				

4	Choose the option that best describes how the business is being conducted (See instructions for table of one-letter codes.)	A - Individual
---	---	----------------

5	Insert the date the business commenced (mm/dd/yyyy) If the business has not started, enter "N/A"	08/01/1996
---	--	------------

NOTICE: IN ACCORDANCE WITH SUBDIVISION (A) OF SECTION 17920, A FICTITIOUS NAME STATEMENT GENERALLY EXPIRES AT THE END OF FIVE YEARS FROM THE DATE ON WHICH IT WAS FILED IN THE OFFICE OF THE COUNTY CLERK, EXCEPT, AS PROVIDED IN SUBDIVISION (B) OF SECTION 17920, WHERE IT EXPIRES 40 DAYS AFTER ANY CHANGE IN THE FACTS SET FORTH IN THE STATEMENT PURSUANT TO SECTION 17913 OTHER THAN A CHANGE IN THE RESIDENCE ADDRESS OF A REGISTERED OWNER. A NEW FICTITIOUS BUSINESS NAME STATEMENT MUST BE FILED BEFORE THE EXPIRATION. THE FILING OF THIS STATEMENT DOES NOT OF ITSELF AUTHORIZE THE USE IN THIS STATE OF A FICTITIOUS BUSINESS NAME IN VIOLATION OF THE RIGHTS OF ANOTHER UNDER FEDERAL, STATE OR COMMON LAW (SEE SECTION 14411 ET SEQ., BUSINESS AND PROFESSIONS CODE)

I declare that all the information in this statement is true and correct. (A registrant who declares as true information which he or she knows to be false is guilty of a misdemeanor.)

Signature	<i>KSGhuman</i>
Printed name and if Corp or LLC, state title	KULJIT GHUMAN
Daytime Telephone Number	<input type="checkbox"/> Check here if you do not want your number published

DO NOT TYPE OR WRITE BELOW THIS LINE - COUNTY CLERK USE ONLY

Date Statement Filed	Date Statement Expires	ANN K. BARNETT, Auditor-Controller-County Clerk
06/09/2011	06/09/2016	By: <i>[Signature]</i> / <i>[Signature]</i>

<input checked="" type="checkbox"/>	Initial/renewal with changes - Must be published once a week for four successive weeks (publication to start within 30 days of the file date) and an affidavit of publication must be filed with the County Clerk within 30 days after publication has been completed.
<input type="checkbox"/>	Renewal - Publication is not required, pursuant to Business and Professions Code Section 17917 (c)

BANK CERTIFICATION

I hereby certify that the foregoing is a correct copy of the original filed in my office on 06/09/2011

ANN K. BARNETT, Auditor-controller-County Clerk, By: *[Signature]* / *[Signature]* Deputy Clerk.

County Clerk Copy	Bank Copy	Newspaper Copy	Registrant Copy	DBA #1
-------------------	-----------	----------------	-----------------	--------

2011-B3647

ENVIRONMENTAL HEALTH PERMIT

KERN COUNTY PUBLIC HEALTH SERVICES DEPARTMENT

ENVIRONMENTAL HEALTH SERVICES DIVISION

2700 M ST SUITE 300 BAKERSFIELD CA 93301

(661) 862-8740 www.co.kern.ca.us/eh e-mail: eh@co.kern.ca.us

REGULATED FACILITY:

JOHNNY QUIK #143
2126 TAFT HWY
BAKERSFIELD CA 93313

OWNER(S) OF RECORD:

KULJIT SINGH GHUMAN
FA ID: FA0002691

General Health Program

BUS PLAN MED LOW RISK 1 UNIT
UNDERGROUND STORAGE TANK PROGRAM
FOOD MARKET
TOBACCO RETAILER

(See tank information on back)

Permit #

Additional Information

0000313
0013545
0007207
0019019

Expiration: 06/30/2016
FOOD MARKET
TOBACCO



Permit Issued: 01/01/2012

Matthew Constantine
Public Health Services Director

This ENVIRONMENTAL HEALTH PERMIT is issued to the owner(s) and establishment shown above subject to compliance with all applicable laws and regulations. Permit is valid unless revoked or suspended for violation of applicable laws and regulations.

PERMIT IS NON-TRANSFERABLE AND MUST BE PROMINENTLY DISPLAYED IN THE PLACE OF BUSINESS

Make checks payable to:

INVOICE

COUNTY OF KERN
ENVIRONMENTAL HEALTH SERVICES DEPARTMENT
2700 M STREET, SUITE 300
BAKERSFIELD, CA 93301-2730
(661) 862-8713 Food
(661) 862-8714 Solid Waste
(661) 862-8733 Haz Mat
(661) 862-8797 Water/Housing

Invoice ID

IN0252098

Account ID

AR0002691

Date

04/19/2013

FA0002691
 JOHNNY QUIK #143



To avoid 50% Penalty, pay by:

Total Due:

Amount Paid:

We Now Accept Visa and Mastercard Payments

KULJIT SINGH GHUMAN
 JOHNNY QUIK #143
 2126 TAFT HWY
 BAKERSFIELD, CA 93313

Please return the top portion of this invoice notice with payment

County of Kern
 Environmental Health Services Department

RE: JOHNNY QUIK #143, FA0002691
 2126 TAFT HWY
 BAKERSFIELD, CA 93313

Date	Program Element	Description	Record Identifier	Amount
Invoice # IN0252098 -- Date of Invoice: 04/19/2013				
04/19/2013	CS04	UST MODIFICATION	PR0003004	1,770.00

Total For this Invoice:

Total Amount Due for this Invoice
-- Please Remit this Amount --

You must notify Environmental Health of any changes of :

- * Ownership
- * Billing Address
- * Business Name
- * Closure

FAILURE to notify Environmental Health may result in LATE PENALTIES, PERMIT DENIAL, OR REVOCATION
 Permits and Fees Paid are NOT TRANSFERABLE

OFFICIAL RECEIPT
COUNTY OF KERN

B 32671

Bakersfield, CALIF. REF. No. FA 2691 DATE 4-19 2013

RECEIVED FROM D&J Construction - Chuman

THE SUM OF Seventeen hundred seventy DOLLARS \$ 1770

ACCOUNT OF Johnny Quick #143
2126 Taft Hwy Taft, CA

ACCOUNT

HOW PAID

AMT. OF ACCOUNT \$ 1770

CASH

ENVIRONMENTAL HEALTH
DIVISION

AMT. PAID \$ 1770

CHECK 2247

BANK NO.

BALANCE DUE \$ 0

M. O.

AGENCY

BY JEN

White - Customer Copy

Canary - Accounting Copy

Pink - Book Copy

KULJIT S. GHUMAN
EVANGELINE GHUMAN
1001 NICKI CT
BAKERSFIELD, CA 93307-5194

90-7162
3222 41568

2247

DATE 04/19/13

PAY TO THE ORDER OF Kern County EHD \$ 1770
One thousand seven hundred seventy only

CHASE
JPMorgan Chase Bank, N.A.
www.Chase.com

MEMO

KS Ghuman MP

⑆ 3 2 2 2 7 1 6 2 7 ⑆

8 7 7 2 9 8 5 9 1 4 ⑆ 2 2 4 7

CERTIFICATION OF INSTALLATION / MODIFICATION

KERN COUNTY ENVIRONMENTAL HEALTH SERVICES DIVISION
 2700 M STREET, SUITE 300
 BAKERSFIELD, CA 93301
 (661) 862-8700 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
 UNDERGROUND STORAGE TANKS

(one form per project) Page ___ of ___

I. FACILITY INFORMATION

FACILITY ID # (Agency Use Only)									
BUSINESS NAME (Same as FACILITY NAME or DBA - Doing Business As) JOHNNY QUICK # 143									
BUSINESS SITE ADDRESS 2126 TAFT HWY					CITY BAKERSFIELD 93313				

II. INSTALLATION / MODIFICATION PROJECT DESCRIPTION

TYPE OF PROJECT (Check all that apply) <ul style="list-style-type: none"> <input type="checkbox"/> 1. TANK INSTALLATION OR REPLACEMENT <input checked="" type="checkbox"/> 2. PIPING INSTALLATION OR REPLACEMENT <input checked="" type="checkbox"/> 3. SUMP INSTALLATION OR REPLACEMENT <input type="checkbox"/> 4. UNDER DISPENSER CONTAINMENT INSTALLATION OR REPLACEMENT <input type="checkbox"/> 5. OTHER 	WORK AUTHORIZED UNDER PERMIT (Number or Date): FA 0002691
DESCRIPTION OF WORK BEING CERTIFIED: REPLACED: (A.O. SMITH RED THREAD II) - PRODUCT PIPING PRIMARY, SECONDARY, (3) PRODUCTS <ul style="list-style-type: none"> • 87 UNLEAD • 91 UNLEAD • DIESEL INSTALLED: (WESTERN FIBER GLASS) - (3) TURBIN 42" SINGLE WALL FIBERGLASS SUMPS	

III. CONTRACTOR INFORMATION

NAME OF CONTRACTOR WHO PERFORMED INSTALLATION / MODIFICATION DNJ CONSTRUCTION INC.	
CONTRACTOR LICENSE # 792494	ICC CERTIFICATION # 5255732

IV. CERTIFICATION


I certify that the information provided herein is true, accurate, and that the following conditions have been satisfied:

- The installer has met the requirements set forth in 23 CCR §2715, subdivisions (g) and (h).
- The underground storage tank, any primary piping, and any secondary containment was installed according to applicable voluntary consensus standards and any manufacturer's written installation instructions.
- All work listed in the manufacturer's installation checklist has been completed.
- The installation has been inspected and approved by the local agency, or if required by the local agency, inspected and certified by a registered professional engineer having education and experience with underground storage tank system installations.

SIGNATURE OF TANK OWNER OR OWNER'S AGENT <i>Daniel D. Cruz</i>	DATE 6-7-13	PHONE 661-864-1023
CERTIFIER'S NAME (print) DANIEL D. CRUZ	CERTIFIER'S TITLE: UST INSTALLATION / RETROFITTING SURV.	
NAME OF CERTIFIER'S EMPLOYER (DBA) DNJ CONST. INC.	CERTIFIER'S RELATIONSHIP TO TANK OWNER <input type="checkbox"/> 1. TANK OWNER <input type="checkbox"/> 2. TANK OPERATOR <input checked="" type="checkbox"/> 3. CONTRACTOR <input type="checkbox"/> 4. PROPERTY OWNER <input type="checkbox"/> 5. OTHER AUTHORIZED AGENT OF TANK OWNER	

A ——— N

NEW 42" WESTERN FIBERGLASS
TURBIN SUMP(S). TYPE OF (3)



(PIPING DIA.)

REVISED 6-6-13 1/8" SCALE

JOHNNY QUICK SHELL, 2126 TAFT HWY 119 / HWY 99 BAKERSFIELD, CA, 93313



MATTHEW CONSTANTINE, DIRECTOR
PUBLIC HEALTH SERVICES

ENVIRONMENTAL HEALTH DIVISION

2700 M STREET, SUITE 300, BAKERSFIELD, CA 93301-2370
VOICE: (661) 862-8740 FAX: (661) 862-8701
Web: www.co.kern.ca.us/eh E-mail: eh@co.kern.ca.us
"ONE VOICE"



CLAUDIA JONAH, MD
PUBLIC HEALTH OFFICER

PERMIT TO CONSTRUCT or MODIFY UNDERGROUND STORAGE FACILITY

Facility ID: FA0002691

NEW CONSTRUCTION MODIFICATION

<u>FACILITY NAME/ADDRESS</u>	<u>OWNER(S) NAME/ADDRESS:</u>	<u>CONTRACTOR NAME/ADDRESS</u>
Johnny Quik #143 2126 Taft Hwy Bakersfield, CA 93313	Kuljit Ghuman 2126 Taft Hwy Bakersfield, CA 93313	Rich Environmental 5643 Brooks Ct Bakersfield, CA 93308
	Phone No. (661) 363-9115	License # 1064166 Phone No. (661) 392-8687
DATE ISSUED: 11/01/2012	EXPIRES ON: 05/01/2013	APPROVED BY: Jeffrey S. Marshall

POST ON PREMISES

CONDITIONS:

- All construction to be as per facility plans approved by this department and verified by inspection by Permitting Authority.
- All equipment and materials in this construction must be installed in accordance with all manufacturers' specifications.
- Any individual installing underground storage tank systems components shall possess a current underground storage tank system installer certification from the International Code Council (ICC), which indicates that the individual has passed the ICC UST Installation/Retrofitting exam.
- Permittee must contact Permitting Authority for on-site inspection(s) with 48-hour advance notice.
- Backfill material for piping and tanks to be as per manufacturers' specifications.
- Construction inspection record card is included with permit given to Permittee. This card must be posted at job site prior to initial inspection. Permittee must contact Permitting Authority and arrange for each group of required inspections numbered as per instructions on card. Generally, inspections will be made of:
 - Piping system with secondary containment
 - Any other inspection deemed necessary by Permitting Authority.
- Primary and secondary containment of both tank(s) and underground piping must not be subject to physical or chemical deterioration due to the substance(s) stored in them. Documentation from tank, piping, and seal manufacturers of compatibility with these substance(s) must be submitted to Permitting Authority prior to construction.
- A Secondary Containment Test (SB 989) shall be conducted on all repaired equipment within six (6) months of the completed repairs.
- A Certificate of Installation/Modification shall be completed and submitted once all repairs have been completed.

ACCEPTED BY: _____

DATE: _____

11-6-12



Printed on Recycled Paper

PERMIT #: FA 0002691	OWNER: Kuljit Ghuman
FACILITY: Johnny Quik #143	CONTACT: James J. Rich
ADDRESS: 2126 Taft Hwy	ADDRESS: 2126 Taft Hwy
CITY: Bakersfield	CITY: Bakersfield
PHONE #: (661) 834-9113	PHONE #: (661) 392-8687

INSTRUCTIONS: Please call for an inspection or submit the requested information when ready. They will run in consecutive order beginning with number 1. DO NOT cover work for any numbered group or continue with the next phase of work until all items in that group are signed off by the Permitting Authority. Following these instructions will reduce the number of required inspection visits and therefore the assessment of additional fees.

INSPECTION

DATE

INSPECTOR

- TANKS & BACKFILL -

1	Backfill of tanks	N/A	
1	Copy of installation check list	N/A	
1	Spark Test Certificate	N/A	

- PIPING SYSTEM -

1	Primary piping, vapor, and vent lines pressure/soap test	N/A	
2	Corrosion protection of piping & fill pipe	N/A	

- SECONDARY CONTAINMENT -

2	Secondary piping, vapor and vent lines pressure/soap test		
2	Sump and UDC test		
2	Electrical Conduits	N/A	

Please contact the Fire Department at (661) 391-7082 and Building (electrical) Department at (661) 862-8661 to schedule final inspections with them before calling this department for the final inspection.

- FINAL -

3	Overspill boxes / Drop tube valves	N/A	
3	Line Leak Detectors and Positive Shut Down	N/A	
3	Electrical Seal Offs and Sealed Field Connections	N/A	
3	Monitor System Check	N/A	
3	Enhanced Leak Detection (ELD) test of system	N/A	
3	As-built drawings (if required)	N/A	
3	Monitoring Requirements	N/A	
3	Submittal of owner information and Form C	N/A	

CONTRACTOR: Rich Environmental
CONTACT: James J Rich

LICENSE #: 1064166
PHONE #: (661) 392-8687

CR-3201
FA-2691 EV-166

OPERATING PERMIT APPLICATION - FACILITY INFORMATION

KERN COUNTY ENVIRONMENTAL HEALTH SERVICES DIVISION
2700 M STREET, SUITE 300
BAKERSFIELD, CA 93301
(661) 862-8700 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
UNDERGROUND STORAGE TANK

(one page per site) Page _____ of _____

TYPE OF ACTION 1. NEW PERMIT 5. CHANGE OF INFORMATION 7. PERMANENT FACILITY CLOSURE 400.
(Check one item only) 3. RENEWAL PERMIT 6. TEMPORARY FACILITY CLOSURE 9. TRANSFER PERMIT

I. FACILITY INFORMATION

TOTAL NUMBER OF USTs AT FACILITY ⁴⁰⁴ **3** FACILITY ID # **-** 1.

BUSINESS NAME (Same as FACILITY NAME or DBA - Doing Business As) **JOHNNY QUICK #143** 3.

BUSINESS SITE ADDRESS ¹⁰³ **2126 TAFT HWY** CITY ¹⁰⁴ **BAKERSFIELD**

FACILITY TYPE 1. MOTOR VEHICLE FUELING 2. FUEL DISTRIBUTION ⁴⁰³ Is the facility located on Indian Reservation or Trust lands? Yes No ⁴⁰⁵
 3. FARM 4. PROCESSOR 6. OTHER

II. PROPERTY OWNER INFORMATION

PROPERTY OWNER NAME ⁴⁰⁷ **KULJIT GHUMAN** PHONE ⁴⁰⁸ **(661) 834-9113**

MAILING ADDRESS ⁴⁰⁹ **2126 TAFT HWY**

CITY ⁴¹⁰ **BAKERSFIELD** STATE ⁴¹¹ **CA** ZIP CODE ⁴¹² **93313**

III. TANK OPERATOR INFORMATION Check if same as Property Owner

TANK OPERATOR NAME ⁴²⁸⁻¹ PHONE ⁴²⁸⁻² ()

MAILING ADDRESS ⁴²⁸⁻³

CITY ⁴²⁸⁻⁴ STATE ⁴²⁸⁻⁵ ZIP CODE ⁴²⁸⁻⁶

IV. TANK OWNER INFORMATION Check if same as Property Owner

TANK OWNER NAME ⁴¹⁴ PHONE ⁴¹⁵ ()

MAILING ADDRESS ⁴¹⁶ **OCT - 8 2012**

CITY ⁴¹⁷ STATE ⁴¹⁸ ZIP CODE ⁴¹⁹ **KERN COUNTY**

OWNER TYPE: 4. LOCAL AGENCY/DISTRICT 5. COUNTY AGENCY 6. STATE AGENCY ⁴²⁰
 7. FEDERAL AGENCY 8. NON-GOVERNMENT

V. BOARD OF EQUALIZATION UST STORAGE FEE ACCOUNT NUMBER

TY (TK) HQ 44- _____ Call the State Board of Equalization, Fuel Tax Division, if there are questions. ⁴²¹

VI. PERMIT HOLDER INFORMATION

Issue permit and send legal notifications and mailings to: 1. FACILITY OWNER 4. TANK OPERATOR ⁴²³
 3. TANK OWNER 5. FACILITY OPERATOR

SUPERVISOR OF DIVISION, SECTION, OR OFFICE (Required For Public Agencies Only) ⁴⁰⁶

VII. APPLICANT SIGNATURE

CERTIFICATION: I certify that the information provided herein is true, accurate, and in full compliance with legal requirements.

APPLICANT SIGNATURE **[Signature]** DATE ⁴²⁴ **10-1-12** PHONE ⁴²⁵ **(661) 706-8685**

APPLICANT NAME (print) ⁴²⁶ **JAMES J REED** APPLICANT TITLE ⁴²⁷ **CONTRACTOR**

UST Operating mit Application – Facility Informat Instructions (Formerly SWRCB UST Permit Application Form A and UPCR Form hwfwr-a)

Complete this form for all new permits, permit changes, or facility information changes. This form must be submitted within 30 days of permit or facility information changes, unless approval is required prior to making the changes. For changes, submit only that form that contains the change.

Submit one UST Operating Permit Application – Facility Information form per facility, regardless of the number of USTs located at the facility. If not already on file with the Kern County Environmental Health Services Division (KCEHSD), the tank owner must submit with this form, a current UST Operating Permit Application – Tank Information form for each UST; a UST Monitoring Plan and a UST Response Plan pursuant to 23 CCR § 2632, 2634 and 2641; and, for USTs containing petroleum, a certification of financial responsibility pursuant to 23 CCR § 2807.

The following documents, at a minimum, are also required, if applicable:

- Written agreement between UST Owner and UST Operator per Health and Safety Code § 25284(a)(3);
- Letter from the Chief Financial Officer (if using State Cleanup Fund, financial test of self-insurance, guarantee, local government financial test, or Local Government Fund as a financial responsibility mechanism).

Please number all pages of your submittal. This helps the Kern County Environmental Health Services Division (KCEHSD) identify whether the submittal is complete and if any pages are separated. (Note: Numbering of these instructions matches the data element numbers on the form.)

400. TYPE OF ACTION – Check the reason this form is being submitted. CHECK ONE ITEM ONLY.
404. TOTAL NUMBER OF USTs AT SITE – Indicate the number of tanks that will remain on the site after the requested action.
1. FACILITY ID NUMBER – Leave this blank. This number is assigned by KCEHSD. This is the unique number which identifies your facility.
3. BUSINESS NAME – Enter the complete Business Name. (Same as FACILITY NAME or DBA (Doing Business As)).
103. BUSINESS SITE ADDRESS – Enter the street address of the facility, including building number, if applicable. This address must be the physical location of the facility. Post office box numbers are not acceptable.
104. CITY – Enter the city or unincorporated area in which the facility is located.
403. FACILITY TYPE – Indicate the type of facility.
405. INDIAN RESERVATION OR TRUST LANDS – Check whether the facility is located on an Indian reservation or other trust lands.

407. PROPERTY OWNER NAME – 408. PROPERTY OWNER PHONE – 409. PROPERTY OWNER MAILING ADDRESS – 410. PROPERTY OWNER CITY – 411. PROPERTY OWNER STATE – 412. PROPERTY OWNER ZIP CODE –	Complete items 407 - 412 for the property owner. Include the area code and any extension number.
---	--

428-1. TANK OPERATOR NAME – 428-2. TANK OPERATOR PHONE – 428-3. TANK OPERATOR MAILING ADDRESS – 428-4. TANK OPERATOR CITY – 428-5. TANK OPERATOR STATE – 428-6. TANK OPERATOR ZIP CODE –	Complete items 428-1 to 428-6 for the UST operator. Include the area code and any extension number.
---	---

414. TANK OWNER NAME – 415. TANK OWNER PHONE – 416. TANK OWNER MAILING ADDRESS – 417. TANK OWNER CITY – 418. TANK OWNER STATE – 419. TANK OWNER ZIP CODE –	Complete items 414 - 419 for the UST owner. Include the area code and any extension number.
---	---

420. TANK OWNER TYPE – Check the type of tank ownership.
421. BOE NUMBER – Enter your State Board of Equalization (BOE) UST storage fee account number. This fee applies to regulated USTs storing petroleum products and is required before your permit application will be processed. If you do not have an account number with the BOE, or if you have any questions regarding the fee or exemptions, contact the BOE at (916) 322-9669 or by mail at: Board of Equalization, Fuel Taxes Division, P O Box 942879, Sacramento, CA 94279-0030.
423. PERMIT HOLDER INFORMATION – Indicate the party to whom the UST operating permit is to be issued and legal notifications and mailings should be sent.
406. SUPERVISOR OF DIVISION SECTION OR OFFICE SUPERVISOR – If the facility owner is a public agency, enter the name of the supervisor of the division section or office that operates the UST. This person must have access to the UST records.
- APPLICANT SIGNATURE – The application form must be signed, in the space provided, by:
- The UST owner or operator, facility owner or operator, or a duly authorized representative of the owner; or
 - If the UST(s) is/are owned by a corporation, partnership, or public agency:
 - 1.) A principal executive officer at the level of vice-president or by an authorized representative responsible for the overall operation of the facility where the UST(s) is/are located; or
 - 2.) A general partner or proprietor; or
 - 3.) A principal executive officer, ranking elected official, or authorized representative of a public agency.
424. DATE – Enter the date the form was signed.
425. PHONE – Enter the phone number of the applicant (i.e., person signing the form). Include the area code and any extension number.
426. APPLICANT NAME – Print or type the full name of the person signing the form.
427. APPLICANT TITLE – Enter the title of the person signing the form.

OPERATING PERMIT APPLICATION - TANK INFORMATION (One form per UST)

KERN COUNTY ENVIRONMENTAL HEALTH SERVICES DIVISION
 2700 M STREET, SUITE 300
 BAKERSFIELD, CA 93301
 (661) 862-8700 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
UNDERGROUND STORAGE TANKS

(one page per tank) Page **1** of **1**

TYPE OF ACTION (Check one item only. For an UST permanent closure or removal, complete only this section and Sections I, II, III, IV, and IX below) 430

1. NEW PERMIT 3. RENEWAL PERMIT 5. CHANGE OF INFORMATION
 6. TEMPORARY UST CLOSURE 7. UST PERMANENT CLOSURE ON SITE 8. UST REMOVAL

DATE UST PERMANENTLY CLOSED: 430a DATE EXISTING UST DISCOVERED: 430b

I. FACILITY INFORMATION

FACILITY ID # (Agency Use Only) 1

BUSINESS NAME (Same as FACILITY NAME or DBA-Doing Business As) 3

BUSINESS SITE ADDRESS 103 CITY 104

JOHNNY QUICK #143 **BAKERSFIELD**
2126 TAFT Hwy

II. TANK DESCRIPTION

TANK ID # 432 TANK MANUFACTURER 433 TANK CONFIGURATION: THIS TANK IS 434

1 1. A STAND-ALONE TANK
 2. A COMPARTMENTED UNIT

DATE UST SYSTEM INSTALLED 435 TANK CAPACITY IN GALLONS 436 NUMBER OF COMPARTMENTS IN THE UNIT 437

10,000 **1**

III. TANK USE AND CONTENTS

TANK USE 439

1a. MOTOR VEHICLE FUELING 1b. MARINA FUELING 1c. AVIATION FUELING
 3. CHEMICAL PRODUCT STORAGE 4. HAZARDOUS WASTE (Includes Used Oil) 5. EMERGENCY GENERATOR FUEL (HSC §25281.5(c))
 6. OTHER GENERATOR FUEL 95. UNKNOWN 99. OTHER (Specify): 439a

CONTENTS PETROLEUM: 440

1a. REGULAR UNLEADED 1c. MIDGRADE UNLEADED 1b. PREMIUM UNLEADED
 3. DIESEL 5. JET FUEL 6. AVIATION GAS
 8. PETROLEUM BLEND FUEL 9. OTHER PETROLEUM (Specify): 440a

NON-PETROLEUM: 440b

7. USED OIL 10. ETHANOL
 11. OTHER NON-PETROLEUM (Specify):

IV. TANK CONSTRUCTION

TYPE OF TANK 443

1. SINGLE WALL 2. DOUBLE WALL 95. UNKNOWN

PRIMARY CONTAINMENT 444

1. STEEL 3. FIBERGLASS 6. INTERNAL BLADDER
 7. STEEL + INTERNAL LINING 95. UNKNOWN 99. OTHER (Specify): 444a

SECONDARY CONTAINMENT 445

1. STEEL 3. FIBERGLASS 6. EXTERIOR MEMBRANE LINER 7. JACKETED
 90. NONE 95. UNKNOWN 99. OTHER (Specify): 445a

OVERFILL PREVENTION 452

1. AUDIBLE & VISUAL ALARMS 2. BALL FLOAT 3. FILL TUBE SHUT-OFF VALVE
 4. TANK MEETS REQUIREMENTS FOR EXEMPTION FROM OVERFILL PREVENTION EQUIPMENT

V. PRODUCT / WASTE PIPING CONSTRUCTION

PIPING CONSTRUCTION 460

1. SINGLE-WALLED 2. DOUBLE-WALLED 99. OTHER

SYSTEM TYPE 458

1. PRESSURE 2. GRAVITY 3. CONVENTIONAL SUCTION 4. SAFE SUCTION [23 CCR §2636(a)(3)]

PRIMARY CONTAINMENT 464

1. STEEL 4. FIBERGLASS 8. FLEXIBLE 10. RIGID PLASTIC
 90. NONE 95. UNKNOWN 99. OTHER (Specify): 464a

SECONDARY CONTAINMENT 464b

1. STEEL 4. FIBERGLASS 8. FLEXIBLE 10. RIGID PLASTIC
 90. NONE 95. UNKNOWN 99. OTHER (Specify): 464c

PIPING/TURBINE CONTAINMENT SUMP TYPE 464d

1. SINGLE WALL 2. DOUBLE WALL 90. NONE

VI. VENT, VAPOR RECOVERY (VR) AND RISER / FILL PIPE PIPING CONSTRUCTION

VENT PRIMARY CONTAINMENT 464e

1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464e1

VENT SECONDARY CONTAINMENT 464f

1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464f1

VR PRIMARY CONTAINMENT 464g

1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464g1

VR SECONDARY CONTAINMENT 464h

1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464h1

VENT PIPING TRANSITION SUMP TYPE 464i

1. SINGLE WALL 2. DOUBLE WALL 90. NONE

RISER PRIMARY CONTAINMENT 464j

1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464j1

RISER SECONDARY CONTAINMENT 464k

1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464k1

FILL COMPONENTS INSTALLED 451a-c

1. SPILL BUCKET 3. STRIKER PLATE/BOTTOM PROTECTOR 4. CONTAINMENT SUMP

VII. UNDER DISPENSER CONTAINMENT (UDC)

CONSTRUCTION TYPE 469a

1. SINGLE WALL 2. DOUBLE WALL 3. NO DISPENSERS 90. NONE

CONSTRUCTION MATERIAL 469b-c

1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 99. OTHER (Specify)

VIII. CORROSION PROTECTION

STEEL COMPONENT PROTECTION 448

2. SACRIFICIAL ANODE(S) 4. IMPRESSED CURRENT 6. ISOLATION

IX. APPLICANT SIGNATURE

CERTIFICATION: I certify that this UST system is compatible with the hazardous substance stored and that the information provided herein is true, accurate, and in full compliance with legal requirements.

APPLICANT SIGNATURE 470 DATE 470

James J. Rich **10-1-12**

APPLICANT NAME (print) 471 APPLICANT TITLE 472

JAMES J RICH **CONTRACTOR**

UST Operating Permit Application Tank Information Instructions

(Formerly SWRCB Permit Application Form B and UPCF Form hwfwr-c-b)

Complete a separate form for each UST for all new permits, permit changes, and any UST system information changes. This form must be submitted within 30 days of permit or UST system information changes, unless approval is required prior to making changes. For a UST permanent closure or removal, complete only TYPE OF ACTION and Sections I, II, III, IV, and IX. Please number all pages of your submittal. This helps the Kern County Environmental Health Services Division (KCEHSD) identify whether the submittal is complete and if any pages are separated. (Note: Numbering of these instructions matches the data element numbers on the form.)

430. TYPE OF ACTION – Check the appropriate box to indicate why this form is being submitted.
- 430a. DATE UST PERMANENTLY CLOSED – For reporting closure only: enter the date the UST was removed or closed on site.
- 430b. DATE EXISTING UST DISCOVERED – Enter the date this UST was discovered. Leave blank if installation date is known.
1. FACILITY ID NUMBER – Leave this blank. This number is assigned by KCEHSD. This is the unique number which identifies your facility.
3. BUSINESS NAME – Enter the complete facility name.
103. BUSINESS SITE ADDRESS – Enter the street address of the facility, including building number, if applicable. This address must be the physical location of the facility. Post office box numbers are not acceptable.
104. CITY – Enter the city or unincorporated area in which the facility is located.
432. TANK ID # – Applicant may enter the owner's tank identification number or leave this space blank. The (KCEHSD) will assign the State tank identification number as the unique identifier for the tank.
433. TANK MANUFACTURER – Enter the name of the company that manufactured the tank.
434. TANK CONFIGURATION. Check the appropriate box to indicate if the tank is a stand-alone tank or a compartmented tank.
435. DATE UST SYSTEM INSTALLED – Enter the date the KCEHSD signed-off on installation of the UST system. This is the date of initial tank system installation, and does not include upgrades or retrofits which may have been performed later. If this is for a new installation, leave blank.
436. TANK CAPACITY IN GALLONS: Enter the tank capacity. For compartmentalized tanks, enter the capacity of each compartment.
437. NUMBER OF COMPARTMENTS IN THE UNIT: If the tank is a compartment, enter the total number of compartments in the unit.
439. TANK USE – Check the type of tank usage.
- 439a. If you checked "Other", specify the type of tank usage in the space provided.
440. TANK CONTENTS – Check the specific petroleum or non-petroleum substance stored.
- 440a. If you checked "Other Petroleum", specify the common name of the substance in the space provided [i.e., the name used in the facility's Hazardous Materials Business Plan (HMBP) inventory].
- 440b. If you checked "Other", under Non-petroleum, specify the common name of substance in the space provided (i.e., the name used in the HMBP inventory).
443. TYPE OF TANK – Check the box that identifies the type of tank.
444. TANK PRIMARY CONTAINMENT – Check the construction material of the primary containment (i.e., inner tank wall nearest the hazardous substance stored). If the tank material is not listed, check "Other" and specify the material in the space provided.
- 444a. If you checked "Other", specify the type of primary containment in the space provided.
445. TANK SECONDARY CONTAINMENT – Check the construction material of the secondary containment that provides containment external to, and separate from, the primary containment described above. If the tank is a single-wall tank, check "None." If the material is not listed, check "Other" and specify the material in the space provided (e.g., HDPE).
- 445a. If you checked "Other", specify the type of secondary containment in the space provided.
452. OVERFILL PREVENTION – Check the box(es) to describe the type(s) of overfill protection equipment installed.
458. PIPING SYSTEM TYPE – Check the type of product/waste piping installed in this tank system. "Safe suction" refers to piping systems meeting all requirements of 23 CCR §2636(a)(3) (also known as "European Suction" systems) (i.e., sloped suction piping systems with no valves or pumps below grade and only one check valve, located below and as close as practical to the suction pump). Title 23, California Code of Regulations is available online at www.calregs.com.
460. PIPING CONSTRUCTION – Indicate if the piping is single-walled or double-walled, or "other".
464. PIPING PRIMARY CONTAINMENT – Check the material(s) used to construct the primary (i.e., inner) underground product/waste piping.
- 464a. If you checked "Other", specify the type of primary containment in the space provided.
- 464b. PIPING SECONDARY CONTAINMENT – Check the material(s) used to construct the secondary containment system(s) (i.e., secondary piping, trench) provided for the product/waste piping. For single-wall piping systems, check "None."
- 464c. If you checked "Other", specify the type of secondary containment in the space provided.
- 464d. PIPING/TURBINE CONTAINMENT SUMP TYPE – Indicate the type of piping/turbine containment sump(s). Check "None" if not present.
- 464e-e1 VENT PRIMARY CONTAINMENT – Check the material(s) used to construct the primary (i.e., inner) vent piping. (Note: Address venting of the tank primary containment only.) Specify Other type of containment in the space provided.
- 464f-f1 VENT SECONDARY CONTAINMENT – Check the material(s) used to construct the secondary containment system(s) (e.g., secondary piping,) provided for the vent piping. For single-wall piping systems, check "None." (Note: Address venting of the tank primary containment only.) Specify Other type of containment in the space provided.
- 464g-g1 VR PRIMARY CONTAINMENT – Check the material(s) used to construct the primary (i.e., inner) vapor recovery piping. For tanks without vapor recovery piping (e.g., Diesel tanks), check "None." Specify Other type of containment in the space provided.
- 464h-h1 VR SECONDARY CONTAINMENT – Check the material(s) used to construct the secondary containment system(s) (e.g., secondary piping) provided for the vapor recovery piping. For single-wall piping systems, check "None." Specify Other type of containment in the space provided.
- 464i. VENT PIPING TRANSITION SUMP TYPE – Indicate type of transition sump(s). Check "None" if not present.
- 464j-j1 RISER PRIMARY CONTAINMENT – Check the material(s) used to construct the primary (i.e., inner) piping for all risers (not drop tubes) other than annular space risers (i.e., risers for filling or gauging of the primary tank). Specify Other type of containment in the space provided.
- 464k-k1 RISER SECONDARY CONTAINMENT – Check the material(s) used to construct secondary containment system(s) (i.e., secondary piping, sumps) provided for the riser piping. For risers without secondary containment, check "None." Specify Other type of containment in the space provided.
- 451a-c. FILL COMPONENTS INSTALLED – Check the appropriate boxes to show that spill containment, tank bottom protection, and fill containment sumps (if applicable) are installed.
- 469a. UDC CONSTRUCTION TYPE – Check the box to describe the type of dispenser containment system(s) (i.e., dispenser sumps or pans). If the system has no dispensers (e.g., standby generator tank system), check "No Dispensers." If the system has a dispenser, but no UDC, check "None".
- 469b. UDC CONSTRUCTION MATERIAL – Check the box to describe the materials used to construct the UDC.
- 469c. If you checked "Other", specify the construction material in the space provided.
448. STEEL COMPONENT PROTECTION – All systems contain some steel components. Check the appropriate box(es) to describe all corrosion protection methods used. "Isolation" means electrical isolation from soil, backfill, and groundwater. Examples include fiberglass cladding, non-metallic secondary containment systems which isolate steel components from the sub-surface environment, and insulating bushings.
- APPLICANT SIGNATURE** – The same person who signs the UST Operating Permit Application – Facility Information Form shall sign in the space provided. This signature certifies that the signer believes that all information submitted is true and accurate, and that the UST system is compatible with the hazardous substance stored.
470. DATE – Enter the date the form was signed.
471. APPLICANT NAME – Print or type the name of the person signing the form.
472. APPLICANT TITLE – Enter the title of the person signing the form.

OPERATING PERMIT APPLICATION - TANK INFORMATION (One form per UST)

KERN COUNTY ENVIRONMENTAL HEALTH SERVICES DIVISION
 2700 M STREET, SUITE 300
 BAKERSFIELD, CA 93301
 (661) 862-8700 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)
 UNDERGROUND STORAGE TANKS

(one page per tank) Page **1** of **1**

TYPE OF ACTION (Check one item only. For an UST permanent closure or removal, complete only this section and Sections I, II, III, IV, and IX below) 430

<input type="checkbox"/> 1. NEW PERMIT	<input type="checkbox"/> 3. RENEWAL PERMIT	<input type="checkbox"/> 5. CHANGE OF INFORMATION
<input type="checkbox"/> 6. TEMPORARY UST CLOSURE	<input type="checkbox"/> 7. UST PERMANENT CLOSURE ON SITE	<input type="checkbox"/> 8. UST REMOVAL

DATE UST PERMANENTLY CLOSED: 430a DATE EXISTING UST DISCOVERED: 430b

I. FACILITY INFORMATION

FACILITY ID # (Agency Use Only) 1

BUSINESS NAME (Same as FACILITY NAME or DBA-Doing Business As) 3

BUSINESS SITE ADDRESS 103 CITY 104

JOHNNY QUICK #143
2126 TAFT Hwy **BAKERSFIELD**

II. TANK DESCRIPTION

TANK ID # 432 TANK MANUFACTURER 433 TANK CONFIGURATION: THIS TANK IS 434

2 1. A STAND-ALONE TANK
 2. A COMPARTMENTED UNIT

DATE UST SYSTEM INSTALLED 435 TANK CAPACITY IN GALLONS 436 NUMBER OF COMPARTMENTS IN THE UNIT 437

10,000 **1**

III. TANK USE AND CONTENTS

TANK USE 439

<input checked="" type="checkbox"/> 1a. MOTOR VEHICLE FUELING	<input type="checkbox"/> 1b. MARINA FUELING	<input type="checkbox"/> 1c. AVIATION FUELING
<input type="checkbox"/> 3. CHEMICAL PRODUCT STORAGE	<input type="checkbox"/> 4. HAZARDOUS WASTE (Includes Used Oil)	<input type="checkbox"/> 5. EMERGENCY GENERATOR FUEL [HSC §25281.5(c)]
<input type="checkbox"/> 6. OTHER GENERATOR FUEL	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):

CONTENTS PETROLEUM: 440

<input type="checkbox"/> 1a. REGULAR UNLEADED	<input type="checkbox"/> 1c. MIDGRADE UNLEADED	<input checked="" type="checkbox"/> 1b. PREMIUM UNLEADED
<input type="checkbox"/> 3. DIESEL	<input type="checkbox"/> 5. JET FUEL	<input type="checkbox"/> 6. AVIATION GAS
<input type="checkbox"/> 8. PETROLEUM BLEND FUEL	<input type="checkbox"/> 9. OTHER PETROLEUM	(Specify):

NON-PETROLEUM: 440a

<input type="checkbox"/> 7. USED OIL	<input type="checkbox"/> 10. ETHANOL
<input type="checkbox"/> 11. OTHER NON-PETROLEUM (Specify): 440b	

IV. TANK CONSTRUCTION

TYPE OF TANK 443

<input type="checkbox"/> 1. SINGLE WALL	<input checked="" type="checkbox"/> 2. DOUBLE WALL	<input type="checkbox"/> 95. UNKNOWN
---	--	--------------------------------------

PRIMARY CONTAINMENT 444

<input checked="" type="checkbox"/> 1. STEEL	<input type="checkbox"/> 3. FIBERGLASS	<input type="checkbox"/> 6. INTERNAL BLADDER
<input type="checkbox"/> 7. STEEL + INTERNAL LINING	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):

SECONDARY CONTAINMENT 445

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 3. FIBERGLASS	<input type="checkbox"/> 6. EXTERIOR MEMBRANE LINER	<input type="checkbox"/> 7. JACKETED
<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):	

OVERFILL PREVENTION 445a

<input type="checkbox"/> 1. AUDIBLE & VISUAL ALARMS	<input type="checkbox"/> 2. BALL FLOAT	<input checked="" type="checkbox"/> 3. FILL TUBE SHUT-OFF VALVE
<input type="checkbox"/> 4. TANK MEETS REQUIREMENTS FOR EXEMPTION FROM OVERFILL PREVENTION EQUIPMENT 452		

V. PRODUCT / WASTE PIPING CONSTRUCTION

PIPING CONSTRUCTION 460

<input type="checkbox"/> 1. SINGLE-WALLED	<input checked="" type="checkbox"/> 2. DOUBLE-WALLED	<input type="checkbox"/> 99. OTHER
---	--	------------------------------------

SYSTEM TYPE 458

<input checked="" type="checkbox"/> 1. PRESSURE	<input type="checkbox"/> 2. GRAVITY	<input type="checkbox"/> 3. CONVENTIONAL SUCTION	<input type="checkbox"/> 4. SAFE SUCTION [23 CCR §2636(a)(3)]
---	-------------------------------------	--	---

PRIMARY CONTAINMENT 464

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 8. FLEXIBLE	<input type="checkbox"/> 10. RIGID PLASTIC
<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):	

SECONDARY CONTAINMENT 464a

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 8. FLEXIBLE	<input checked="" type="checkbox"/> 10. RIGID PLASTIC
<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 95. UNKNOWN	<input type="checkbox"/> 99. OTHER (Specify):	

PIPING/TURBINE CONTAINMENT SUMP TYPE 464b

<input checked="" type="checkbox"/> 1. SINGLE WALL	<input type="checkbox"/> 2. DOUBLE WALL	<input type="checkbox"/> 90. NONE
--	---	-----------------------------------

VI. VENT, VAPOR RECOVERY (VR) AND RISER / FILL PIPE PIPING CONSTRUCTION

VENT PRIMARY CONTAINMENT 464e

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify):
-----------------------------------	---	--	-----------------------------------	---

VENT SECONDARY CONTAINMENT 464e1

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input checked="" type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify):
-----------------------------------	--	--	--	---

VR PRIMARY CONTAINMENT 464f1

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify):
-----------------------------------	---	--	-----------------------------------	---

VR SECONDARY CONTAINMENT 464g1

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input checked="" type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify):
-----------------------------------	--	--	--	---

VENT PIPING TRANSITION SUMP TYPE 464h1

<input type="checkbox"/> 1. SINGLE WALL	<input type="checkbox"/> 2. DOUBLE WALL	<input checked="" type="checkbox"/> 90. NONE
---	---	--

RISER PRIMARY CONTAINMENT 464i

<input checked="" type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify):
--	--	--	-----------------------------------	---

RISER SECONDARY CONTAINMENT 464j1

<input type="checkbox"/> 1. STEEL	<input type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input checked="" type="checkbox"/> 90. NONE	<input type="checkbox"/> 99. OTHER (Specify):
-----------------------------------	--	--	--	---

FILL COMPONENTS INSTALLED 464k1

<input checked="" type="checkbox"/> 1. SPILL BUCKET	<input type="checkbox"/> 3. STRIKER PLATE/BOTTOM PROTECTOR	<input type="checkbox"/> 4. CONTAINMENT SUMP
---	--	--

VII. UNDER DISPENSER CONTAINMENT (UDC)

CONSTRUCTION TYPE 469a

<input checked="" type="checkbox"/> 1. SINGLE WALL	<input type="checkbox"/> 2. DOUBLE WALL	<input type="checkbox"/> 3. NO DISPENSERS	<input type="checkbox"/> 90. NONE
--	---	---	-----------------------------------

CONSTRUCTION MATERIAL 469b-c

<input type="checkbox"/> 1. STEEL	<input checked="" type="checkbox"/> 4. FIBERGLASS	<input type="checkbox"/> 10. RIGID PLASTIC	<input type="checkbox"/> 99. OTHER (Specify):
-----------------------------------	---	--	---

VIII. CORROSION PROTECTION

STEEL COMPONENT PROTECTION 448

<input type="checkbox"/> 2. SACRIFICIAL ANODE(S)	<input type="checkbox"/> 4. IMPRESSED CURRENT	<input type="checkbox"/> 6. ISOLATION
--	---	---------------------------------------

IX. APPLICANT SIGNATURE

CERTIFICATION: I certify that this UST system is compatible with the hazardous substance stored and that the information provided herein is true, accurate, and in full compliance with legal requirements.

APPLICANT SIGNATURE 470 DATE **10-1-12**

APPLICANT NAME (print) 471 APPLICANT TITLE 472

JAMES T RICH **CONTRACTOR**

OPERATING PERMIT APPLICATION – TANK INFORMATION (One form per UST)

KERN COUNTY ENVIRONMENTAL HEALTH SERVICES DIVISION

2700 M STREET, SUITE 300

BAKERSFIELD, CA 93301

(661) 862-8700 Fax (661) 862-8701

Unified Program Consolidated Form (UPCF)

UNDERGROUND STORAGE TANKS

(one page per tank) Page of

TYPE OF ACTION (Check one item only. For an UST permanent closure or removal, complete only this section and Sections I, II, III, IV, and IX below)			430
<input type="checkbox"/> 1. NEW PERMIT	<input type="checkbox"/> 3. RENEWAL PERMIT	<input type="checkbox"/> 5. CHANGE OF INFORMATION	
<input type="checkbox"/> 6. TEMPORARY UST CLOSURE	<input type="checkbox"/> 7. UST PERMANENT CLOSURE ON SITE	<input type="checkbox"/> 8. UST REMOVAL	

DATE UST PERMANENTLY CLOSED: _____ 430a	DATE EXISTING UST DISCOVERED: _____ 430b
---	--

I. FACILITY INFORMATION

FACILITY ID # (Agency Use Only) _____

BUSINESS NAME (Same as FACILITY NAME or DBA-Doing Business As) _____ 3

BUSINESS SITE ADDRESS 103 **JOHNNY QUICK # 143** CITY 104 **BAKERSFIELD**

2126 TAFT Hwy

II. TANK DESCRIPTION

TANK ID # 3 432 TANK MANUFACTURER 433 _____ TANK CONFIGURATION: THIS TANK IS 434

1. A STAND-ALONE TANK

2. A COMPARTMENTED UNIT

DATE UST SYSTEM INSTALLED 435 TANK CAPACITY IN GALLONS 436 **10,000** NUMBER OF COMPARTMENTS IN THE UNIT 437 **1**

III. TANK USE AND CONTENTS

TANK USE 1a. MOTOR VEHICLE FUELING 1b. MARINA FUELING 1c. AVIATION FUELING 439

3. CHEMICAL PRODUCT STORAGE 4. HAZARDOUS WASTE (Includes Used Oil) 5. EMERGENCY GENERATOR FUEL [HSC §25281.5(c)] 439a

6. OTHER GENERATOR FUEL 95. UNKNOWN 99. OTHER (Specify): _____ 439a

CONTENTS PETROLEUM: 1a. REGULAR UNLEADED 1c. MIDGRADE UNLEADED 1b. PREMIUM UNLEADED 440

3. DIESEL 5. JET FUEL 6. AVIATION GAS 440

8. PETROLEUM BLEND FUEL 9. OTHER PETROLEUM (Specify): _____ 440a

NON-PETROLEUM: 7. USED OIL 10. ETHANOL _____ 440b

11. OTHER NON-PETROLEUM (Specify): _____ 440b

IV. TANK CONSTRUCTION

TYPE OF TANK 1. SINGLE WALL 2. DOUBLE WALL 95. UNKNOWN 443

PRIMARY CONTAINMENT 1. STEEL 3. FIBERGLASS 6. INTERNAL BLADDER 444

7. STEEL + INTERNAL LINING 95. UNKNOWN 99. OTHER (Specify): _____ 444a

SECONDARY CONTAINMENT 1. STEEL 3. FIBERGLASS 6. EXTERIOR MEMBRANE LINER 7. JACKETED 445

90. NONE 95. UNKNOWN 99. OTHER (Specify): _____ 445a

OVERFILL PREVENTION 1. AUDIBLE & VISUAL ALARMS 2. BALL FLOAT 3. FILL TUBE SHUT-OFF VALVE 452

4. TANK MEETS REQUIREMENTS FOR EXEMPTION FROM OVERFILL PREVENTION EQUIPMENT

V. PRODUCT / WASTE PIPING CONSTRUCTION

PIPING CONSTRUCTION 1. SINGLE-WALLED 2. DOUBLE-WALLED 99. OTHER 460

SYSTEM TYPE 1. PRESSURE 2. GRAVITY 3. CONVENTIONAL SUCTION 4. SAFE SUCTION [23 CCR §2636(a)(3)] 458

PRIMARY CONTAINMENT 1. STEEL 4. FIBERGLASS 8. FLEXIBLE 10. RIGID PLASTIC 464

90. NONE 95. UNKNOWN 99. OTHER (Specify): _____ 464a

SECONDARY CONTAINMENT 1. STEEL 4. FIBERGLASS 8. FLEXIBLE 10. RIGID PLASTIC 464b

90. NONE 95. UNKNOWN 99. OTHER (Specify): _____ 464c

PIPING/TURBINE CONTAINMENT SUMP TYPE 1. SINGLE WALL 2. DOUBLE WALL 90. NONE 464d

VI. VENT, VAPOR RECOVERY (VR) AND RISER / FILL PIPE PIPING CONSTRUCTION

VENT PRIMARY CONTAINMENT 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464e

1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464e1

VENT SECONDARY CONTAINMENT 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464f

VR PRIMARY CONTAINMENT 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464f1

1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464g

VR SECONDARY CONTAINMENT 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464g1

VENT PIPING TRANSITION SUMP TYPE 1. SINGLE WALL 2. DOUBLE WALL 90. NONE 464h1

RISER PRIMARY CONTAINMENT 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464j

1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464j1

RISER SECONDARY CONTAINMENT 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 90. NONE 99. OTHER (Specify) 464k

FILL COMPONENTS INSTALLED 1. SPILL BUCKET 3. STRIKER PLATE/BOTTOM PROTECTOR 4. CONTAINMENT SUMP 464k1

VII. UNDER DISPENSER CONTAINMENT (UDC)

CONSTRUCTION TYPE 1. SINGLE WALL 2. DOUBLE WALL 3. NO DISPENSERS 90. NONE 469a

CONSTRUCTION MATERIAL 1. STEEL 4. FIBERGLASS 10. RIGID PLASTIC 99. OTHER (Specify) 469b-c

VIII. CORROSION PROTECTION

STEEL COMPONENT PROTECTION 2. SACRIFICIAL ANODE(S) 4. IMPRESSED CURRENT 6. ISOLATION 448

IX. APPLICANT SIGNATURE

CERTIFICATION: I certify that this UST system is compatible with the hazardous substance stored and that the information provided herein is true, accurate, and in full compliance with legal requirements.

APPLICANT SIGNATURE *James T. Rich* DATE 10-1-12 470.

APPLICANT NAME (print) 471. **JAMES T RICH** APPLICANT TITLE 472. **CONTRACTOR**

UNDERGROUND STORAGE TANKS NEW CONSTRUCTION/MODIFICATION APPLICATION

KERN COUNTY ENVIRONMENTAL HEALTH SERVICES DIVISION
2700 M STREET, SUITE 300
BAKERSFIELD, CA 93301
(661) 862-8700 Fax (661) 862-8701

(one page per site) Page of

TYPE OF ACTION 1. NEW SITE CONSTRUCTION 2. MODIFICATION 3. NEW TANK INSTALLATION AT EXISTING FACILITY A
(Check one item only)

I. FACILITY / SITE INFORMATION

FACILITY ID#	1 5 0 1 0 0 0	UST FILE NUMBER		B
BUSINESS NAME (same as FACILITY NAME or DBA - Doing Business As)				3
JOHNNY QUICK # 143				
BUSINESS SITE ADDRESS				103
2126 TAFT Hwy				
CITY	104	BUSINESS PHONE	102	
BAKERSFIELD		661-345-1356		
NEAREST CROSS STREET				401
HIGHWAY 99				

II. CONTRACTOR INFORMATION

CONTRACTOR NAME			C	CONTRACTOR PHONE	D	
RICH ENVIRONMENTAL				661-392-8687		
MAILING OR STREET ADDRESS						E
5643 BROOKS CT						
CITY	F	STATE	G	ZIP CODE	H	
BAKERSFIELD		CA		93308		
CALIFORNIA CONTRACTORS LICENSE NUMBER			I	LICENSE TYPE	J	
809850 C/61/040 HAZ A				A - HAZ (click for drop-down)		
CERTIFIED INSTALLER			K	ICC INSTALLER CERTIFICATION NUMBER	L	
JAMES J RICH				1064166		

III. SCOPE OF WORK

BRIEFLY DESCRIBE THE PROPOSED SCOPE OF WORK: M

INSTALL REPAIR PENARATION & CUT REMOVE &
REPLACE CONCRETE TO MAKE REPAIRS ON UNDERGROUND
SECONDARY PIPING

IV. TANK LIST

TANK NUMBER	PRODUCT(S)	CAPACITY
1	UNL-85	
2	PREM-91	
3	DIESEL	
(add additional on separate sheet)		

V. INTERGRITY TESTING/ENHANCED LEAK DETECTION

TESTING COMPANY	O	PHONE	P	
TEST METHOD				Q

VII. APPLICANT SIGNATURE

Certification - I certify that the information provided herein is true and accurate to the best of my knowledge.

SIGNATURE OF APPLICANT	DATE	PHONE	
	10-1-12	661-706-8687	
NAME OF APPLICANT (print)	TITLE OF APPLICANT		
JAMES J RICH	CONTRACTOR		

UST New Construction/Modification Application

Complete the UST – New Construction/Modification page for any new installations or modifications at a UST facility. This page must be submitted 30 days and a permit issued prior to beginning any work.

A Completed UST- Facility page and a UST – Tank Information Page for each tank is to be included with the application. Two sets of scaled facility plot plans and site specific detailed drawings of the proposed work are also to be submitted with this application.

Please number all pages of your submittal. This helps the Kern County Environmental Health Services Division (KCEHSD) identify whether the submittal is complete and if any pages are separated.

- A. TYPE OF ACTION - Check the reason the page is being completed. CHECK ONE ITEM ONLY.
- 1. FACILITY ID NUMBER - Leave this blank. This number is assigned by KCEHSD. This is the unique number which identifies your facility.
- B. UST FILE NUMBER - Leave this blank. This number is assigned by KCEHSD.
- 3. BUSINESS NAME - Enter the full legal name of the business.
- 103. BUSINESS SITE ADDRESS - Enter the street address where the facility is located. No post office box numbers are allowed. This information must provide a means to geographically locate the facility.
- 104. CITY - Enter the city or unincorporated area in which business site is located.
- 102. BUSINESS PHONE - Enter the phone number, area code first, and any extension.
- 401. NEAREST CROSS STREET - Enter the name of the cross street nearest to the site of the tank.
- C. CONTRACTOR NAME - Enter the name of the contracting firm performing the installation or modification of the UST system. The permit will not be issued until valid contractor information is provided.
- D. CONTRACTOR PHONE - Enter the phone number, area code first, and any extension.
- E. MAILING OR STREET ADDRESS - Enter the contractor's address information.
- F. CITY - Enter the contractor's city.
- G. STATE - Enter the contractor's state.
- H. ZIP - Enter the contractor's zip code.
- I. CALIFORNIA CONTRACTORS LICENSE NUMBER - Enter the appropriate contractor's license number.
- J. LICENSE TYPE - Enter the type of contractor's license.
- K. CERTIFIED INSTALLER - Enter the name of the ICC (International Code Council) certified installer that will be on site during construction.
- L. ICC INSTALLER CERTIFICATION NUMBER - Enter the ICC certification number.
- M. SCOPE OF WORK - Briefly describe the proposed scope of work. This is required for any modifications.
- N. TANK LIST - Enter the owner's assigned tank number, contents and capacity of all the tanks on the site including any tanks being installed.
- O. TESTING COMPANY - Enter the name of the company that will complete the post modification or construction testing, if required.
- P. PHONE - Enter the phone number of the testing company.
- Q. TEST METHOD - Enter the testing method that will be used.
- 424. DATE - Enter the date the form was signed.
- 425. PHONE - Enter the phone number of the applicant (i.e., person signing the form). Include the area code and any extension number.
- 426. APPLICANT NAME - Print or type the full name of the person signing the form.
- 427. APPLICANT TITLE - Enter the title of the person signing the form.

UNDERGROUND STORAGE TANK SYSTEM

NEW CONSTRUCTION -OR- MODIFICATION

EQUIPMENT DESCRIPTION CHECKLIST

(Complete all applicable sections)

1. TANK CONSTRUCTION

- Double Wall Fiberglass
- Double Wall Steel with Fiberglass coating
- Double Wall Steel primary/ Fiberglass secondary
- Other _____

Tank Manufacturer: _____

2. LEAK MONITORING SYSTEM

Console Manufacturer: _____ Console Model #: _____

3. SENSORS

Sensors	Positive Shut Down	Manufacturer	Model #
Tank Annular Space Sensor	<input type="checkbox"/> Yes <input type="checkbox"/> No		
Tank Turbine Sumps Sensor	<input type="checkbox"/> Yes <input type="checkbox"/> No		
Tank Fill Sumps Sensor	<input type="checkbox"/> Yes <input type="checkbox"/> No		
Dispenser Pan Sumps Sensor	<input type="checkbox"/> Yes <input type="checkbox"/> No		
Sump Annular Space Sensor	<input type="checkbox"/> Yes <input type="checkbox"/> No		
Piping Annular Space Sensor	<input type="checkbox"/> Yes <input type="checkbox"/> No		
Positive Shut Down w/ Failsafe for system disconnection	<input type="checkbox"/> Yes <input type="checkbox"/> No		

4. PIPELINE SYSTEM

- Pressure
- Suction
- Gravity

5. LINE LEAK DETECTOR

- Mechanical Manufacturer: _____ Model #: _____
- Electronic Manufacturer: _____ Model #: _____

6. PIPING CONTRUCTION PRODUCT AND VENT/VAPOR LINES

- Double Wall Fiberglass
- Double Wall Flex Pipe
- Other: _____

Manufacturer: _____ Model #: _____

7. AUTOMATIC TANK GAUGE

Manufacturer: _____ Model #: _____

8. OVERSPILL CONTAINER WITH DRAIN VALVE

Manufacturer: _____ Model #: _____

9. OVERFILL PREVENTION

External Alarm with Audible and Visual Alarm
Manufacturer: _____ Model #: _____ Product Level: _____

Flow Restrictor with Ball Float
Manufacturer: _____ Model #: _____ Product Level: _____

Flow Restrictor with Ball Float and External Alarm
Manufacturer: _____ Model #: _____ Product Level: _____

Positive shut off valve with Flapper
Manufacturer: _____ Model #: _____ Product Level: _____

10. DISPENSER CONTAINMENT

Manufacturer: _____ Model #: _____

11. TANK TOP SUMPS

Manufacturer: _____ Model #: _____

12. AUXILLARY SUMPS (TANK GAUGE RISERS, VENT BOXES, ETC)

Manufacturer: _____ Model #: _____

13. PENETRATION FITTINGS

Manufacturer: _____ Model #: _____

14. PENETRATION SEALANT


Manufacturer: _____ Model #: _____

15. BEDDING AND BACKFILL MATERIAL

Sand Pea Gravel

UST Monitoring Site Plan

Site Address: **2126 TAFT HWY. BAKERSFIELD, CA. 93313**



Date map was drawn: 2/23/10

Instructions

If you already have a diagram that shows all required information, you may include it, rather than this page, with your Monitoring System Certification. On your site plan, show the general layout of tanks and piping. Clearly identify locations of the following equipment, if installed: monitoring system control panels; sensors monitoring tank annular spaces, sumps, dispenser pans, spill containers, or other secondary containment areas; mechanical or electronic line leak detectors; and in-tank liquid level probes (if used for leak detection). In the space provided, note the date this Site Plan was prepared.

RICH ENVIRONMENTAL SERVICE STATION

5643 BROOKS CT 661-392-8687
BAKERSFIELD, CA 93308-3708

1706

90-7162 44841
3222

DATE 10/8/12

PAY
TO THE
ORDER OF

Kern County Environmental Health \$

DOLLARS  Security Features
Include
Details on Back

CHASE 

JPMorgan Chase Bank, N.A.
www.Chase.com

FOR

Johnny Quick - Staff

⑈801706⑈ ⑆322271627⑆

918227083⑈

MP

OFFICIAL RECEIPT
COUNTY OF KERN

B 33969

EXTOL, CALIF. REF. No. FA 21091 DATE 10/8 2012

RECEIVED FROM Johnny Quick #143

THE SUM OF One thousand seven hundred DOLLARS \$ 1,770-

ACCOUNT OF Security

ACCOUNT

HOW PAID

AMT. OF ACCOUNT \$ 1,770-

CASH

AMT. PAID \$ 1,770

CHECK 1770

BALANCE DUE \$ 0

M. O.

ENVIRONMENTAL HEALTH
DIVISION

BY [Signature]

White - Customer Copy

Canary - Accounting Copy

Pink - Book Copy

1706

RICH ENVIRONMENTAL SERVICE STATION

5643 BROOKS CT 661-392-8687
BAKERSFIELD, CA 93308-3708

90-7162 44841
3222

DATE 10/8/12

PAY TO THE ORDER OF Kern County Environmental Health \$ 1770.00

SEVENTEEN HUNDRED & SEVENTY DOLLAR & 00/100 DOLLARS  Security Features Included Details on Back

CHASE
JPMorgan Chase Bank, N.A.
www.Chase.com

FOR Johnny Quick - Japt

[Signature]

⑈001706⑈ ⑆322271627⑆

918227083⑈

Make checks payable to:

INVOICE

COUNTY OF KERN
ENVIRONMENTAL HEALTH SERVICES DEPARTMENT
2700 M STREET, SUITE 300
BAKERSFIELD, CA 93301-2730
(661) 862-8713 Food
(661) 862-8714 Solid Waste
(661) 862-8733 Haz Mat
(661) 862-8797 Water/Housing

Invoice ID IN0250830	Account ID AR0002691	Date 10/11/2012
--------------------------------	--------------------------------	---------------------------

FA0002691
 JOHNNY QUIK #143



To avoid 50% Penalty, pay by:
 Total Due:
 Amount Paid:

We Now Accept Visa and Mastercard Payments

KULJIT SINGH GHUMAN
 JOHNNY QUIK #143
 2126 TAFT HWY
 BAKERSFIELD, CA 93313

Please return the top portion of this invoice notice with payment

County of Kern
Environmental Health Services Department

RE: JOHNNY QUIK #143, FA0002691
2126 TAFT HWY
BAKERSFIELD, CA 93313

Date	Program Element	Description	Record Identifier	Amount
Invoice # IN0250830 -- Date of Invoice: 10/11/2012				
10/11/2012	CS04	UST MODIFICATION		1,770.00
Total For this Invoice:				1,770.00

Total Amount Due for this Invoice
-- Please Remit this Amount --

You must notify Environmental Health of any changes of :
 * Ownership * Billing Address
 * Business Name * Closure

FAILURE to notify Environmental Health may result in LATE PENALTIES, PERMIT DENIAL, OR REVOCATION
Permits and Fees Paid are NOT TRANSFERABLE

Home > My ICC

Certified Professional Information:

Last, First MI: Koop, Aaron

Certified under this name: Aaron Koop

Address: 3116 Bristol Ave

City, State Zip: Bakersfield, CA 93308

Certification Type(s): California UST Service Technician (expires 05/24/2013)
 UST Installation/Retrofitting (expires 05/24/2013)

<p>Contact Information</p> <p>1-888-ICC-SAFE (422-7233), ext. 5524</p> <p>Contact Us</p>

Listings here may not reflect today's changes, additions, exam results, or certifications from organizations other than ICC (including BOCA, ICBO, and SBCCI). Listings are updated nightly on this web site, so please allow a full 24 hours for changes to be reflected here. ICC certification for code enforcement professions attests to competent knowledge of construction codes and standards in effect on the date of certification or renewal.

ICC does its best to maintain the privacy requests of its members and constituents. If you believe that phone number or address information listed here should not be displayed please contact us at 1-888-ICC-SAFE (422-7233) between 8am and 7pm (CT) for personal assistance.

Terms of Use: This listing is provided as a service to the constituents of ICC for these purposes: locating a certified professional or contractor in your area, or confirming status for individuals. Any other use, sale, transfer, or reproduction in any form without the express written consent of ICC is strictly prohibited. ICC reserves the right to incorporate some false names to detect improper use of this service.



SAVE™ Sustainable Attributes Verification and Evaluation Program
One Resource—Multiple Green Rating Systems

Home > My ICC

Certified Professional Information:

Last, First MI: RICH, JAMES
 Certified under this name: JAMES RICH
 City, State Zip: Bakersfield, CA 93308
 Phone: (661)392-8687

Certification Type(s): California UST Service Technician (expires 05/31/2013)
 California UST System Operator (expires 11/05/2012)
 Vapor Recovery System Installation and Repair (expires 11/05/2012)
 Vapor Recovery System Testing and Repair (expires 01/11/2013)

Listings here may not reflect today's changes, additions, exam results, or certifications from organizations other than ICC (including BOCA, ICBO, and SBCCI). Listings are updated nightly on this web site, so please allow a full 24 hours for changes to be reflected here. ICC certification for code enforcement professions attests to competent knowledge of construction codes and standards in effect on the date of certification or renewal.

ICC does its best to maintain the privacy requests of its members and constituents. If you believe that phone number or address information listed here should not be displayed please contact us at 1-888-ICC-SAFE (422-7233) between 8am and 7pm (CT) for personal assistance.

Terms of Use: This listing is provided as a service to the constituents of ICC for these purposes: locating a certified professional or contractor in your area, or confirming status for individuals. Any other use, sale, transfer, or reproduction in any form without the express written consent of ICC is strictly prohibited. ICC reserves the right to incorporate some false names to detect improper use of this service.

Contact Information
 1-888-ICC-SAFE
 (422-7233), ext. 5524
[Contact Us](#)



SAVE™ Sustainable Attributes Verification and Evaluation Program
One Resource—Multiple Green Rating Systems



DEPARTMENT OF CONSUMER AFFAIRS

Contractors State License Board

Contractor's License Detail - License # 809850

⚠️ DISCLAIMER: A license status check provides information taken from the CSLB license database. Before relying on this information, you should be aware of the following limitations.

- CSLB complaint disclosure is restricted by law ([B&P 7124.6](#)) If this entity is subject to public complaint disclosure, a link for complaint disclosure will appear below. Click on the link or button to obtain complaint and/or legal action information.
- Per [B&P 7071.17](#), only construction related civil judgments reported to the CSLB are disclosed.
- Arbitrations are not listed unless the contractor fails to comply with the terms of the arbitration.
- Due to workload, there may be relevant information that has not yet been entered onto the Board's license database.

License Number	809850	Extract Date	10/15/2012
RICH ENVIRONMENTAL			
Business Information	Business Phone Number: (661) 392-8687		
	5643 BROOKS CT BAKERSFIELD, CA 93308		
Entity	Sole Ownership		
Issue Date	06/25/2002		
Expire Date	06/30/2014		
License Status	ACTIVE		
	This license is current and active. All information below should be reviewed.		
Classifications	CLASS	DESCRIPTION	
	D40	<u>SERVICE STATION EQUIPMENT AND MAINTENANCE</u>	
	A	<u>GENERAL ENGINEERING CONTRACTOR</u>	
Certifications	CERT	DESCRIPTION	
	HAZ	<u>HAZARDOUS SUBSTANCES REMOVAL</u>	
Bonding	CONTRACTOR'S BOND		
	This license filed a Contractor's Bond with <u>AMERICAN CONTRACTORS INDEMNITY COMPANY.</u>		
	Bond Number: SC6326078		
	Bond Amount: \$12,500		
	Effective Date: 03/02/2009		
	<u>Contractor's Bond History</u>		
	BOND OF QUALIFYING INDIVIDUAL		
	1. This license filed Bond of Qualifying Individual number 100202579 for KOOP AARON JESSE in the amount of \$12,500 with <u>AMERICAN CONTRACTORS INDEMNITY COMPANY.</u>		

Effective Date: 08/08/2012

BQI's Bond History

WORKERS' COMPENSATION

This license has workers compensation insurance with
STATE COMPENSATION INSURANCE FUND

Workers' Compensation

Policy Number: 661-0502267

Effective Date: 02/06/2012

Expire Date: 02/06/2013

Workers' Compensation History

Personnel listed on this license (current or disassociated) are listed on other licenses.

Personnel List	Other Licenses
----------------	----------------

[Conditions of Use](#) | [Privacy Policy](#)
Copyright © 2010 State of California



15540 Strebtor Drive
 Bakersfield, CA 93314
 (661) 387-6522

Invoice

Date	Invoice #
6/1/2005	2645

Bill To
JOHNNY QUICK #143 2126 TAFT HWY BAKERSFIELD, CA 93313

06-15-05 14:08 RCVD

P.O. No.	Terms
	Net 30

Item	Quantity	Description	Rate	Serviced	Amount
		SERVICE REQUESTED: NEED DISPENSER PAN SENSORS INSTALLED			
		SERVICE PERFORMED: INSTALLED 4 DISPENSER STAND ALONE SENSORS (BEAUDREAU CONTROLLERS AND SENSORS)			
MISCELLANE... BEAU-404-4 BEAU-406BS	1 4 4	MISC. SUPPLIES BEAUDREAU CONTROLLER BEAUDREAU SENSOR	5.00 260.00 140.00		5.00T 1,040.00T 560.00T
LBRTVL MILEAGE	3 25	LABOR/TRAVEL @ 48.00 PER HOUR Mileage @ .50 a mile.	48.00 0.50		144.00 12.50

Thank you. There will be a late payment charge of 2% per month on any unpaid balances.

Subtotal	\$1,761.50
Sales Tax (7.25%)	\$116.36
Total	\$1,877.86

100-100000-100000
100-100000-100000
100-100000-100000
100-100000-100000
100-100000-100000

100-100000-100000
100-100000-100000

100-100000-100000
100-100000-100000
100-100000-100000
100-100000-100000
100-100000-100000

500

320028

RICH ENVIRONMENTAL

5643 BROOKS CT BAKERSFIELD, CA. 93308
OFFICE (661) 392-8687 & FAX (661) 392-0621

FAX TRANSMITTAL COVER SHEET

Date: 11/22/04 Time: _____ No. of pages: 1

Attention: Janel Funk

Company: Kern County

Fax #: 862-8701

From: James J. Rich

RE: Notification to schedule

Date: 12/06/04 Time: 1:00pm

Test: Install Mechanical line leak Di

Site: Johnny Quick

2126 Taft Hwy

Bakersfield, Ca 93313

Tech: Ryan Mason

If you have questions please contact me at my office. Thank you!

* I'm sorry, I put wrong date

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT

STEVE McCALLEY, R.E.H.S., Director

2700 "M" STREET, SUITE 300
BAKERSFIELD, CA 93301-2370
Voice: (661) 862-8700
Fax: (661) 862-8701
TTY Relay: (800) 735-2929
e-mail: eh@co.kern.ca.us



RESOURCE MANAGEMENT AGENCY

DAVID PRICE III, RMA DIRECTOR

Community and Economic Development Department
Engineering & Survey Services Department
Environmental Health Services Department
Planning Department
Roads Department

**PERMIT TO MODIFY
UNDERGROUND
STORAGE FACILITY**

PERMIT NUMBER: 320028M

FACILITY

Johnny Quick #143
2126 Taft Hwy
Bakersfield, CA

OWNER(S) NAME/ADDRESS:

Kujit Ghuman
2126 Taft Hwy
Bakersfield, CA 93313

Phone No. (661) 834-9113

CONTRACTOR:

Redwine Testing Services
P O Box 1567
Bakersfield, CA 93302
License #: 532878
Phone No. (661) 834-6993

PERMIT EXPIRES February 12, 2005

APPROVAL DATE August 12, 2004

APPROVED BY

Laurel Funk
Laurel Funk

Hazardous Materials Specialist

NEW CONSTRUCTION
 MODIFICATION
 OTHER

POST ON PREMISES

CONDITIONS AS FOLLOW:

Standard Instructions

1. This permit applies only to the modification of an existing facility involving the upgrade of the EVR Phase I system.
2. All construction to be as per facility plans approved by this department and verified by inspection by Permitting Authority.
3. All equipment and materials in this construction must be installed in accordance with all manufacturers' specifications.
4. The KCEHSD may require soil samples to be collected below each sump to determine the presence of soil contamination. KCEHSD is to be notified at least 48 hours ahead of time to inspect the soil before installation is backfilled.
5. Owner is responsible for contacting the air pollution district for any of their requirements that may apply.

ACCEPTED BY: *[Signature]*

DATE: 8-16-04

PERMIT NO. <u>320028</u>
APN NUMBER _____
APPLICATION DATE: <u>8-11-04</u>

**APPLICATION FOR PERMIT TO CONSTRUCT/MODIFY
 UNDERGROUND HAZARDOUS SUBSTANCES STORAGE FACILITY**

Type Of Application (check):

- New Facility Modification of Facility New Tank Installation at Existing Facility

A. Number of Tanks To Be Installed 0 Existing Facility Permit # _____
 Type of Business GAS STATION AND MINI MART
 Facility Name JOHNNY QUICK #143
 Address 2126 TAFT HWY City BAKERSFIELD 93313
 T _____ R _____ SEC _____ (Rural Locations Only) Nearest Cross Street HWY 99

B. Tank Owner RUSIT GHUMAN Phone #: (661) 834 9113
 Address 2126 TAFT HWY City/State BAKERSFIELD, CA Zip 93313

C. Water To Facility Provided By CAL WATER
 Depth To Groundwater 500' Soil Characteristics At Facility SANDY LOAM

D. Contractor REDWIND TESTING SERVICES/CA Contractor's License No. 532878 A MAZ
 Address P.O. BOX 1567 City BAKERSFIELD Zip 93302 Phone # (661) 834-6993
 Worker's Compensation Certification # 165924503 Insurer STATE FUND
 Proposed Starting Date 8-16-04 Proposed Completion Date 8-20-04

E. If This Application Is For Modification Of An Existing Tank System, Briefly Describe Modifications Proposed (Excluding New Tank Installation at Existing Facilities) INSTALLATION OF OPW DIRECT BURY ENHANCED VAPOR RECOVERY HAVE TO BREAK CONCRETE

F. Tank(s) Storage (Check All That Apply):

Tank #	Unleaded				Other* Fuel	Waste Oil	Other* Waste	Other* Product
	Unleaded	Plus	Premium	Diesel				
<u>1</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>2</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>3</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

* Describe other products/waste: _____

G. Initial Tank Integrity Test Information:

Testing Company Name: _____ Phone # _____

Test Method: _____ Licensed Tester: _____

A tank integrity test is not required if the tank is equipped with an interstitial monitor certified to meet the performance standards of a "tank integrity test." GILBARCO # 350

This form has been completed under penalty of perjury and to the best of my knowledge is true and correct.

Signature [Signature] Title V.P. Date 8-11-04

TANK INFORMATION FORM
(Complete separate form for each tank)

Facility ID: _____
1998: <input type="checkbox"/> Yes <input type="checkbox"/> No

A Tank Information

Please Print

Tank Number 123 Contents REG, Premium; M/D Capacity 10K EACH

Tank Manufacturer: _____ Date Installed / / 88

Tank Construction: Single-Wall Double-Wall Jacketed
 Vaulted Other _____

Tank Material: Carbon Steel Fiberglass-Clad Fiberglass
 Concrete Other _____

 Methanol Compatible Yes No

Tank Interior Lining: Unlined Lined (material) FIBERGLASS

Corrosion Protection: Fiberglass-Clad Sacrificial Anode None
 Polyethylene/Vinyl Other _____
 Impressed Current (describe) _____

Spill Containment: (make & model) OPW Year Installed 88

Overfill Prevention: (make & model) OPW Year Installed 88

Tank Repairs: (dates & descriptions) UNKNOWN

B Piping Information

Please Print

Type of System: Pressure Suction Gravity None
 Approximate length of this pipe run: 25'

Pipe Construction: Single-Wall Double-Wall Liner Raceway
 PVC Sleeve Other _____

Pipe Material: Steel Fiberglass Flexible
 Other _____

Pipe Manufacturer: _____ Date Installed / / 88

C Monitoring Information

Please Print and Check All That Apply

Tank Monitoring: Primary: Auto-tank gauge Inventory Reconciliation
 Statistical Inventory Reconciliation Groundwater
 Vadose Zone Other _____
 Describe make and model GILBARCO MDD# PAB262010000

 Secondary: Liquid Sensor Vapor Sensor Hydrostatic
 Other _____
 Describe make & model TRI 8747E

 Alarm: Yes No





Pipe Monitoring: Primary: Reduced Flow Shut Down Other
 Line Leak Detector Line Leak Detector
 Describe make & model _____

 Secondary: Liquid Sensor Vapor Sensor Other _____
 Describe make & model _____

 Alarm: Yes No

 Pump Shut Down: Yes No

JOHNNY QUICK 143 C SHELL STATION
2126 TRAFF HILL BAILESFIELD CA. 93723



TRAFF HILL

22

PHASE I VAPOR RECOVERY EQUIPMENT DESCRIPTION

Component	Manufacturer	Model Number
Fill Adapter	OPW	615ALP 1020 EUR
Liquid Fill Cap	OPW	634 TT-7085
Vapor Fill Cap	OPW	1711T-7085
Vapor Adapter	OPW	61 USA 1020-EUR
Drop Tube	OPW	6150C
Extractor Assembly	N/A	
Float Vent Valve	N/A	
Pressure/Vacuum Relief Valve	HUSKY	4885
Overfill Protection		
(List Any Additional Components Required)		

EQUIPMENT TO BE INSTALLED

Please Continue on Reverse Side

INSPECTION RECORD

POST CARD AT JOBSITE

FACILITY <u>Johnny Quik</u>	PERMIT # <u>320028B</u>	OWNER <u>Johnny Quik Food Stores</u>
ADDRESS <u>2126 Taft Hwy</u>		ADDRESS <u>1715 Minnewawa St</u>
CITY <u>Bakersfield, CA</u>		CITY <u>Clouis, CA</u>
PHONE NO.		

INSTRUCTIONS: Please call for an inspector only when each group of inspections with the same number are ready. They will run in consecutive order beginning with number 1. DO NOT cover work for any numbered group until all items in that group are signed off by the Permitting Authority. Following these instructions will reduce the number of required inspection visits and therefore prevent assessment of additional fees.

- TANKS & BACKFILL -

INSPECTION	DATE	INSPECTOR
1 Backfill of Tank(s)		
1 Spark Test Certification		
Cathodic Protection of Tank(s)		

- PIPING SYSTEM -

2 Piping & Raceway w/Collection Sump		
2 Corrosion Protection of Piping, Joints, Fill Pipe		
2 Electrical Isolation of Piping From Tank(s)		
Cathodic Protection System-Piping		
2 Secondary Cont. at piping		

- SECONDARY CONTAINMENT, OVERFILL PROTECTION, LEAK DETECTION -

Liner Installation - Tank(s)		
Liner Installation - Piping		
Vault With Product Compatible Sealer		
3 Level Gauges or Sensors, Float Vent Valves		
3 Product Compatible Fill Box(es)		
3 Product Line Leak Detector(s)		
3 Leak Detector(s) for Annular Space-D.W. Tank(s)		
Monitoring Well(s)/Sump(s)		
Leak Detection Device(s) For Vadose/Groundwater		

- FINAL -

3 Monitoring Wells, Caps & Locks		
3 Fill Box Lock		
Monitoring Requirements		

CONTRACTOR Banks & Co LICENSE # 383550
 CONTACT _____ PH # (209) 299 0228

This Shipping Order must be legibly filled in Indelible Pencil or in Carbon and signed by the Agent.

Shipper's No. **13380**

MODERN WELDING CO

(Name of Carrier)

Carrier's No. _____

RECEIVED, subject to the classifications and tariffs in effect on the date of the issue of this Bill of Lading,

at **FRESNO, CALIFORNIA 93711** **Nov 30 19 88** From **MODERN WELDING COMPANY, INC.**

the property described below, in apparent good order, except as noted (contents and condition of contents of packages unknown), marked, consigned, and destined as indicated below, which said carrier (the word carrier being understood throughout this contract as meaning any person or corporation in possession of the property under the contract) agrees to carry to its usual place of delivery at said destination, if on its route, otherwise to deliver to another carrier on the route to said destination. It is mutually agreed, as to each carrier of all or any of said property over all or any portion of said route to destination, and as to each party at any time interested in all or any of said property, that every service to be performed hereunder shall be subject to all the terms and conditions of the Uniform Domestic Straight Bill of Lading set forth (1) in Official, Southern, Western and Illinois Freight Classifications in effect on the date hereof, if this is a rail or a rail-water shipment, or (2) in the applicable motor carrier classification or tariff if this is a motor carrier shipment.

Shipper hereby certifies that he is familiar with all the terms and conditions of the said bill of lading, including those on the back thereof, set forth in the classification or tariff which governs the transportation of this shipment, and the said terms and conditions are hereby agreed to by the shipper and accepted for himself and his assigns.

Consigned to **Banks & Co & Johnny Quick Station # 143** (Mail or street address of consignee—For purposes of notification only.)

Destination **Bakersfield** State **Ca** County _____ Delivery Address **★ Hwy 99 & 119**
 (★ To be filled in only when shipper desires and governing tariffs provide for delivery thereat.)

Route _____

Delivering Carrier _____ Car or Vehicle Initials **EW** No. _____

No. Packages	Kind of Package, Description of Articles, Special Marks, and Exceptions	*WEIGHT (Subject to Correction)	Class or Rate	Check Column	Subject to Section 7 of Conditions of applicable bill of lading. If this shipment is to be delivered to the consignee without recourse on the consignor, the consignor shall sign the following statement: The carrier shall not make delivery of this shipment without payment of freight and all other lawful charges.
1	10,000 gallon Double Wall Glasteel Underground tank.	19,100#			(Signature of Consignor) If charges are to be prepaid, write or stamp here, "To be Prepaid." Received \$ _____ to apply in prepayment of the charges on the property described hereon. Agent or Cashier Per _____ (The signature here acknowledges only the amount prepaid.)
	UL # J394045				
1	Glasteel field kits				
	<i>Jerry Caputo</i>				
	35,000 volt holiday test witnessed by:				

*If the shipment moves between two ports by a carrier by water, the law requires that the bill of lading shall state whether it is carrier's or shipper's weight.
 NOTE—Where the rate is dependent on value, shippers are required to state specifically in writing the agreed or declared value of the property. The agreed or declared value of the property is hereby specifically stated by the shipper to be not exceeding _____ per _____

†The fibre boxes used for this shipment conform to the specifications set forth in the box maker's certificate thereon, and all other requirements of the Consolidated Freight Classification.

Charges Advanced: _____
 \$ _____
 †Shipper's Imprint in lieu of stamp; not a part of Bill of Lading approved by the Interstate Commerce Commission.

MODERN WELDING COMPANY, INC. Shipper, Per **B. B. Butler**
 Permanent post-office address of shipper, **FRESNO, CALIFORNIA 93711**

Agent must detach and retain, this Shipping Order and must sign the Original Bill of Lading.

2

This Shipping Order must be legibly filled in Indelible Pencil or in Carbon and returned by the Agent.

Shipper's No. **13379**

MODERN WELDING CO
(Name of Carrier)

Carrier's No. _____

RECEIVED, subject to the classifications and tariffs in effect on the date of the issue of this Bill of Lading.

at **FRESNO, CALIFORNIA 93711** Nov 30 19 88 From **MODERN WELDING COMPANY, INC.**

The property described below, in apparent good order, except as noted (contents and condition of contents of packages unknown), marked, consigned, and destined as indicated below, which said carrier (the word carrier being understood throughout this contract as meaning any person or corporation in possession of the property under the contract) agrees to carry to its usual place of delivery at said destination, if on its route, otherwise to deliver to another carrier on the route to said destination. It is mutually agreed, as to each carrier of all or any of said property over all or any portion of said route to destination, and as to each party at any time interested in all or any of said property, that every service to be performed hereunder shall be subject to all the terms and conditions of the Uniform Domestic Straight Bill of Lading set forth (1) in Official, Southern, Western and Illinois Freight Classifications in effect on the date hereof, if this is a rail or a rail-water shipment, or (2) in the applicable motor carrier classification or tariff if this is a motor carrier shipment.

Shipper hereby certifies that he is familiar with all the terms and conditions of the said bill of lading, including those on the back thereof, set forth in the classification or tariff which governs the transportation of this shipment, and the said terms and conditions are hereby agreed to by the shipper and accepted for himself and his assigns.

Consigned to **Banks & Co & Johnny Quick Station #143**
(Mail or street address of consignee—For purposes of notification only.)

Destination **N Bakersfield** State **Ca** County _____ Delivery Address **★ Hwy 99 & 119**
(★ To be filled in only when shipper desires and governing tariffs provide for delivery thereat.)

Route _____

Delivering Carrier _____ Car or Vehicle Initials **Jerry** No. _____

No. Packages	Kind of Package, Description of Articles, Special Marks, and Exceptions	*WEIGHT (Subject to Correction)	Class or Rate	Check Column	Subject to Section 7 of Conditions of applicable bill of lading. If this shipment is to be delivered to the consignee without recourse on the consignor, the consignor shall sign the following statement: The carrier shall not make delivery of this shipment without payment of freight and all other lawful charges.
2	10,000 gallon Double Wall Glasteel Underground tank.	19,100#			(Signature of Consignor) If charges are to be prepaid, write or stamp here, "To be Prepaid." Received \$ _____ to apply in prepayment of the charges on the property described hereon. Agent or Cashier _____ Per _____ (The signature here acknowledges only the amount prepaid.)
	UL Label# J394048, J394049				
2	Glasteel field kits				
\$5,000 volt holiday test witnessed by: <i>[Signature]</i>					

*If the shipment moves between two ports by a carrier by water, the law requires that the bill of lading shall state whether it is carrier's or shipper's weight.
NOTE—Where the rate is dependent on value, shippers are required to state specifically in writing the agreed or declared value of the property. The agreed or declared value of the property is hereby specifically stated by the shipper to be not exceeding _____ per _____

†The fibre boxes used for this shipment conform to the specifications set forth in the box maker's certificate thereon, and all other requirements of the Consolidated Freight Classification.

MODERN WELDING COMPANY, INC. Shipper, Per **B. Bostick**
Permanent post-office address of shipper, **FRESNO, CALIFORNIA 93711**

Agent must detach and retain, this Shipping Order and must sign the Original Bill of Lading.

2

2700 M STREET
MAILING ADDRESS
1415 TRUXTUN AVENUE
BAKERSFIELD, CA 93301
(805) 861-3636

KERN COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

HEALTH OFFICER
Leon M Hebertson, M.D.

DIRECTOR OF ENVIRONMENTAL HEALTH
Vernon S. Reichard



**PERMIT TO CONSTRUCT
UNDERGROUND STORAGE FACILITY**

PERMIT NUMBER #320028B

FACILITY NAME/ADDRESS:

Johnny Quik Food Store
2126 Taft Hwy.
Bakersfield, CA

OWNER(S) NAME/ADDRESS:

Johnny Quik Food Store
1715 Minnewawa St. #104
Clovis, CA 93612

CONTRACTOR:

Bank and Company
2403 E. Belmont
Fresno, CA 93701

License #383550

<input checked="" type="checkbox"/>	NEW BUSINESS
<input type="checkbox"/>	CHANGE OWNERSHIP
<input type="checkbox"/>	RENEWAL
<input type="checkbox"/>	MODIFICATION
<input type="checkbox"/>	OTHER

PERMIT EXPIRES May 25, 1989

APPROVAL DATE May 25, 1988

APPROVED BY Joe Canas
Joe Canas

POST ON PREMISES.

CONDITIONS AS FOLLOWS:

1. All construction to be as per facility plans approved by this department and verified by inspection by Permitting Authority.
2. All equipment and materials in this construction must be installed in accordance with all manufacturers' specifications.
3. Permittee must contact Permitting Authority for on-site inspection(s) with 48 hour advance notice.
4. Backfill material for piping and tanks to be as per manufacturers' specifications.
5. Float vent valves are required on vent/vapor lines of underground tanks to prevent overfillings
6. Construction inspection record card is included with permit given to Permittee. This card must be posted at jobsite prior to initial inspection. Permittee must contact Permitting Authority and arrange for each group of required inspections numbered as per instructions on card. Generally, inspections will be made of:
 - a. Tank and backfill
 - b. Piping system with secondary containment
 - c. Overfill protection and leak detection/monitoring
 - d. Any other inspection deemed necessary by Permitting Authority

DISTRICT OFFICES

Delano • Lamont • Lake Isabella • Mojave • Ridgecrest • Shafter • Taft

THE UNIVERSITY OF CHICAGO
DEPARTMENT OF CHEMISTRY
5708 SOUTH CAMPUS DRIVE
CHICAGO, ILLINOIS 60637

RECEIVED
JAN 10 1964
FROM: [illegible]
TO: [illegible]
SUBJECT: [illegible]

RE: [illegible]

1. [illegible]
2. [illegible]
3. [illegible]

[illegible text]

UNIVERSITY OF CHICAGO
DEPT. OF CHEMISTRY

RECEIVED NUMBER [illegible]

PERMIT TO CONSTRUCT UNDERGROUND
STORAGE FACILITY

PERMIT NUMBER 320028B
ADDENDUM

7. All underground metal connections (e.g. piping, fittings, fill pipes) to tank(s) must be electrically isolated, and wrapped to a minimum 20 mil thickness with corrosion-preventive, gasoline-resistant tape or otherwise protected from corrosion.
8. Spark testing (35,000 volts) required at site prior to installation of tank(s). Test(s) must be certified by the manufacturer, and a copy of test certification supplied to the Permitting Authority.
9. No product shall be stored in tank(s) until approval is granted by the Permitting Authority.
10. Monitoring requirements for this facility will be described on final "Permit to Operate."

ACCEPTED BY

B. W. W. W.

DATE

11/10/88

Permit Application Checklist

Facility Name Johnny Quitt

Facility Address 2126 Taft Hwy

Application Category:
 Standard Design (Secondary Containment) Motor Vehicle Fuel Exemption Design (Non-Secondary Containment)

Approved _____

Permit Application Form Properly Completed

Deficiencies: _____

3 Copies of Plot Plan Depicting:

SC

Property lines _____
Area encompassed by minimum 100 foot radius around tank(s) and piping _____

SC

All tank(s) identified by a number and product to be stored _____
Tanks not shown on plot plan
Adequate scale (minimum 1"=16'0" in detail) 1"=20'
North arrow _____
All structures within 50 foot radius of tank(s) and piping _____

Location and labeling of all product piping and dispenser islands _____

Environmental sensitivity data including:
*Depth to first groundwater at site _____

*Any domestic or agricultural water well within 100 feet of tank(s) and piping _____

*Any surface water in unlined conveyance within 100 feet of tank(s) and piping _____

*All utility lines within 25 feet of tank(s) and piping (telephone, electrical, water, sewage, gas, leach lines, seepage pits, drainage systems) _____

*Asterisked items: appropriate documentation if permittee seeks a motor vehicle fuel exemption from secondary containment _____

Comments: _____

Approved

SC

3 Copies of Construction Drawings Depicting:
Side View of Tank Installation with Backfill, Raceway(s),
Secondary Containment and/or Leak Monitoring System in Place

Top View of Tank Installation with Raceway(s), Secondary
Containment and/or Leak Monitoring System in Place

A Materials List (indicating those used in the construction):

Backfill Sand
Tank(s) Modern 10,000 gal
Product Piping Ameron 2" Fiberglass
Raceway(s)

Sealer(s)
Secondary Containment Pipe Jacket 3" Telescoping pipe

Leak Detector(s) Red Jacket
MSA Tankguard #482607 Annulus space probe
Overfill Protection Emco Wheaton A1003-A
EBW # 308 Ball Float Valve

Gas or Vapor Detector(s)
Sump(s) 36" Sump for piping

Monitoring Well(s)

Additional: MSA probe in annulus and piping
Sump
Review STELL level gauge
Documentation of Product Performance

Additional Comments

Reviewed By

Joe Carter

Date

5/19/88

SITE INSPECTION:

Approved

Disapproved

Comments:

Inspector

Date

Faint, illegible text at the top of the page.

Faint, illegible text in the middle section.

Faint, illegible text in the middle section.

Faint, illegible text in the middle section.

1995-11

Faint, illegible text in the lower middle section.

Faint, illegible text in the lower middle section.

APPLICATION FOR PERMIT TO OPERATE UNDERGROUND
HAZARDOUS SUBSTANCES STORAGE FACILITY

Type of Application (check):

New Facility Modification Of Facility Existing Facility Transfer Of Ownership

A. Emergency 24-Hour Contact (name, area code, phone): Days GEORGE BEAL 209-299-0228
Nights GEORGE BEAL 209-299-0228

Facility Name JOHNNY QUIK FOOD STORE No. Of Tanks 3

Type Of Business (check): Gasoline Station Other (describe) CONVENIENCE STORE

Is Tank(s) Located On An Agricultural Farm? Yes No

Is Tank(s) Used Primarily For Agricultural Purposes? Yes No

Facility Address 2126 Taft Hwy Nearest Cross St. Hwy. 99

T _____ R _____ SEC _____ (Rural Locations Only)

Owner JOHNNY QUIK FOOD STORES Contact Person GEORGE BEAL

Address 1715 MINNEWAUA STREET #104 Zip CLOVIS, CA 93612 Telephone (209) 299-0228

Operator JOHNNY QUIK FOOD STORES Contact Person GEORGE BEAL

Address 1715 MINNEWAUA #104 Zip CLOVIS, CA 93612 Telephone (209) 299-0228

B. Water To Facility Provided By _____ Depth to Groundwater _____
Soil Characteristics At Facility _____
Basis For Soil Type and Groundwater Depth Determinations _____

C. Contractor BANKS & CO. CA Contractor's License No. 383550
Address 2403 E. BELMONT FRESNO, CA, 93701 Telephone (209) 299-0228
Proposed Starting Date _____ Proposed Completion Date _____
Worker's Compensation Certification No. NOS-084023 Insurer FARMERS INS.

D. If This Permit Is For Modification Of An Existing Facility, Briefly Describe Modifications Proposed N/A

E. Tank(s) Store (check all that apply):

Tank #	Waste	Product	Motor Vehicle Fuel	Unleaded	Regular	Premium	Diesel	Waste Oil
<u>PREM-1</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>UNL-1</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<u>REG-1</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

F. Chemical Composition Of Materials Stored (not necessary for motor vehicle fuels)
Tank # N/A Chemical Stored (non-commercial name) _____ CAS # (if known) _____ Chemical Previously Stored (if different) _____

G. Transfer Of Ownership
Date Of Transfer _____ Previous Owner _____
Previous Facility Name _____

I, _____ accept fully all obligations of Permit No. _____ issued to _____
I understand that the Permitting Authority may review and modify or terminate the transfer of the Permit to Operate this underground storage facility upon receiving this completed form.

This form has been completed under penalty of perjury and to the best of my knowledge is true and correct.

Signature Bill Moore Title BANKS & CO. Date 3/11/88

ERN COU. IN HEALTH DEPT

MAR 10 1988

RECEIVED

1. Tank is: Vaulted Non-Vaulted Double-Wall Single-Wall
2. Tank Material
 - Carbon Steel Stainless Steel Polyvinyl Chloride Fiberglass-Clad Steel
 - Fiberglass-Reinforced Plastic Concrete Aluminum Bronze Unknown
 - Other (describe): _____
3. Primary Containment

Date Installed	Thickness (Inches)	Capacity (Gallons)	Manufacturer
<u>MAY 1988</u>	<u>1/4</u>	<u>10,000</u>	<u>MODERN WELDING</u>
4. Tank Secondary Containment
 - Double-Wall Synthetic Liner Lined Vault None Unknown
 - Other (describe): _____ Manufacturer: _____
 - Material _____ Thickness (Inches) _____ Capacity (Gals.) _____
5. Tank Interior Lining
 - Rubber Alkyd Epoxy Phenolic Glass Clay Unlined Unknown
 - Other (describe): _____
6. Tank Corrosion Protection
 - Galvanized Fiberglass-Clad Polyethylene Wrap Vinyl Wrapping
 - Tar or Asphalt Unknown None Other (describe): _____
 - Cathodic Protection: None Impressed Current System Sacrificial Anode System
 - Describe System & Equipment: _____
7. Leak Detection, Monitoring, and Interception
 - a. Tank: Visual (vaulted tanks only) Groundwater Monitoring Well(s)
 - Vadose Zone Monitoring Well(s) U-Tube Without Liner
 - U-Tube with Compatible Liner Directing Flow To Monitoring Well(s)*
 - Vapor Detector* Liquid Level Sensor* Conductivity Sensor*
 - Pressure Sensor In Annular Space Of Double Wall Tank*
 - Liquid Retrieval & Inspection From U-Tube, Monitoring Well Or Annular Space
 - Daily Gauging & Inventory Reconciliation Periodic Tightness Testing
 - None Unknown Other _____
 - b. Piping: Flow-Restricting Leak Detector(s) For Pressurized Piping*
 - Monitoring Sump With Raceway Sealed Concrete Raceway
 - Half-Cut Compatible Pipe Raceway Synthetic Liner Raceway None
 - Unknown Other _____

* Describe Make & Model: USA. TANKHEAD # 481532 CONSOLE W/ # 481215
8. Tank Tightness

Has This Tank Been Tightness Tested? Yes No Unknown

Date Of Last Tightness Test N/A Results Of Test N/A

Test Name N/A Testing Company N/A
9. Tank Repair

Tank Repaired? Yes No Unknown

Date(s) Of Repair(s) _____

Describe Repairs _____
10. Overfill Protection
 - Operator Fills, Controls, & Visually Monitors Level
 - Tape Float Gauge Float Vent Valves Auto Shut-Off Controls
 - Capacitance Sensor Sealed Fill Box None Unknown
 - Other: _____ List Make & Model For Above Devices _____
11. Piping
 - a. Underground Piping: Yes No Unknown Material FIBERGLASS

Thickness (inches) 3/4" AO Diameter 2" Manufacturer AMERON

Pressure Suction Gravity Approximate Length Of Pipe Run 300'
 - b. Underground Piping Corrosion Protection:
 - Galvanized Fiberglass-Clad Impressed Current Sacrificial Anode
 - Polyethylene Wrap Electrical Isolation Vinyl Wrap Tar or Asphalt
 - Unknown None Other (describe): FIBERGLASS PIPE
 - c. Underground Piping, Secondary Containment:
 - Double-Wall Synthetic Liner System None Unknown
 - Other (describe): _____

1. Tank is: Vaulted Non-Vaulted Double-Wall Single-Wall
2. Tank Material:
 Carbon Steel Stainless Steel Polyvinyl Chloride Fiberglass-Clad Steel
 Fiberglass-Reinforced Plastic Concrete Aluminum Bronze Unknown
 Other (describe): _____

3. Primary Containment
 Date Installed MAY 1988 Thickness (Inches) 1/4 Capacity (Gallons) 10,000 Manufacturer MODERN WELDING

4. Tank Secondary Containment
 Double-Wall Synthetic Liner Lined Vault None Unknown
 Other (describe): _____ Manufacturer: _____
 Material _____ Thickness (Inches) _____ Capacity (Gals.) _____

5. Tank Interior Lining
 Rubber Alkyd Epoxy Phenolic Glass Clay Unlined Unknown
 Other (describe): _____

6. Tank Corrosion Protection
 Galvanized Fiberglass-Clad Polyethylene Wrap Vinyl Wrapping
 Tar or Asphalt Unknown None Other (describe): _____
 Cathodic Protection: None Impressed Current System Sacrificial Anode System
 Describe System & Equipment: _____

7. Leak Detection, Monitoring, and Interception
 a. Tank: Visual (vaulted tanks only) Groundwater Monitoring Well(s)
 Vadose Zone Monitoring Well(s) U-Tube Without Liner
 U-Tube with Compatible Liner Directing Flow To Monitoring Well(s)*
 Vapor Detector* Liquid Level Sensor* Conductivity Sensor*
 Pressure Sensor In Annular Space Of Double Wall Tank*
 Liquid Retrieval & Inspection From U-Tube, Monitoring Well Or Annular Space
 Daily Gauging & Inventory Reconciliation Periodic Tightness Testing
 None Unknown Other _____
 b. Piping: Flow-Restricting Leak Detector(s) For Pressurized Piping*
 Monitoring Sump With Raceway Sealed Concrete Raceway
 Half-Cut Compatible Pipe Raceway Synthetic Liner Raceway None
 Unknown Other _____
 * Describe Make & Model: N/A. TANK HAD # 481532 CONSOLE W/ # 481215 LIQUID PROBE

8. Tank Tightness
 Has This Tank Been Tightness Tested? Yes No Unknown
 Date Of Last Tightness Test N/A Results Of Test N/A
 Test Name N/A Testing Company N/A

9. Tank Repair
 Tank Repaired? Yes No Unknown
 Date(s) Of Repair(s) _____
 Describe Repairs _____

10. Overfill Protection
 Operator Fills, Controls, & Visually Monitors Level
 Tape Float Gauge Float Vent Valves Auto Shut-Off Controls
 Capacitance Sensor Sealed Fill Box None Unknown
 Other: _____ List Make & Model For Above Devices _____

11. Piping
 a. Underground Piping: Yes No Unknown Material FIBERGLASS
 Thickness (Inches) SCH. 40 Diameter 2" Manufacturer AMERON
 Pressure Suction Gravity Approximate Length Of Pipe Run 300'
 b. Underground Piping Corrosion Protection:
 Galvanized Fiberglass-Clad Impressed Current Sacrificial Anode
 Polyethylene Wrap Electrical Isolation Vinyl Wrap Tar or Asphalt
 Unknown None Other (describe): FIBERGLASS PIPE
 c. Underground Piping, Secondary Containment:
 Double-Wall Synthetic Liner System None Unknown
 Other (describe): _____

1. Tank is: Vaulted Non-Vaulted Double-Wall Single-Wall
2. Tank Material
 Carbon Steel Stainless Steel Polyvinyl Chloride Fiberglass-Clad Steel
 Fiberglass-Reinforced Plastic Concrete Aluminum Bronze Unknown
 Other (describe): _____

3. Primary Containment
 Date installed MAY 1988 Thickness (Inches) 1/4 Capacity (Gallons) 10,000 Manufacturer MODERN WELDING

4. Tank Secondary Containment
 Double-Wall Synthetic Liner Lined Vault None Unknown
 Other (describe): _____ Manufacturer: _____
 Material _____ Thickness (Inches) _____ Capacity (Gals.) _____

5. Tank Interior Lining
 Rubber Alkyd Epoxy Phenolic Glass Clay Unlined Unknown
 Other (describe): _____

6. Tank Corrosion Protection
 Galvanized Fiberglass-Clad Polyethylene Wrap Vinyl Wrapping
 Tar or Asphalt Unknown None Other (describe): _____
 Cathodic Protection: None Impressed Current System Sacrificial Anode System
 Describe System & Equipment: _____

7. Leak Detection, Monitoring, and Interception
 a. Tank: Visual (vaulted tanks only) Groundwater Monitoring Well(s)
 Vadose Zone Monitoring Well(s) U-Tube Without Liner
 U-Tube with Compatible Liner Directing Flow To Monitoring Well(s)*
 Vapor Detector * Liquid Level Sensor * Conductivity Sensor *
 Pressure Sensor In Annular Space Of Double Wall Tank *
 Liquid Retrieval & Inspection From U-Tube, Monitoring Well Or Annular Space
 Daily Gauging & Inventory Reconciliation Periodic Tightness Testing
 None Unknown Other _____
 b. Piping: Flow-Restricting Leak Detector(s) For Pressurized Piping*
 Monitoring Sump With Raceway Sealed Concrete Raceway
 Half-Cut Compatible Pipe Raceway * Synthetic Liner Raceway None
 Unknown Other _____
 * Describe Make & Model: N/A. TANKWARD # 481532 CONSOLE W/ # 481215

8. Tank Tightness
 Has This Tank Been Tightness Tested? Yes No Unknown
 Date Of Last Tightness Test N/A Results Of Test N/A
 Test Name N/A Testing Company N/A

9. Tank Repair
 Tank Repaired? Yes No Unknown
 Date(s) Of Repair(s) _____
 Describe Repairs _____

10. Overfill Protection
 Operator Fills, Controls, & Visually Monitors Level
 Tape Float Gauge Float Vent Valves Auto Shut-Off Controls
 Capacitance Sensor Sealed Fill Box None Unknown
 Other: _____ List Make & Model For Above Devices _____

11. Piping
 a. Underground Piping: Yes No Unknown Material FIBERGLASS
 Thickness (inches) 1/4 Diameter 2" Manufacturer AMERON
 Pressure Suction Gravity Approximate Length Of Pipe Run 300'
 b. Underground Piping Corrosion Protection:
 Galvanized Fiberglass-Clad Impressed Current Sacrificial Anode
 Polyethylene Wrap Electrical Isolation Vinyl Wrap Tar or Asphalt
 Unknown None Other (describe): FIBERGLASS PIPE
 c. Underground Piping, Secondary Containment:
 Double-Wall Synthetic Liner System None Unknown
 Other (describe): _____

OWNER'S CERTIFICATE


I (we), the undersigned, owner(s) of the property shown on this plan, hereby certify that I am (we are) aware of the proposals shown hereon, and I (we) hereby agree that all property dedications and improvements shown and required hereon will be completed prior to use or occupancy of the premises.

Date _____ Signature(s) of Property Owner(s) _____

PLANNING DIRECTOR'S CERTIFICATE

I hereby certify that I have conducted a public hearing on this P-D (Precise Development) Plan, pursuant to the requirements of the Ordinance Code of Kern County, and, after hearing all persons wishing to be heard, and considering all testimony, written and oral, approved this plan subject to the conditions shown hereon.


Planning Director _____ Date _____



TAFT HWY.

SITE PLAN
SCALE 1" = 20'

FUTURE TRUCK PARKING



VICINITY MAP

STATISTICS

APN: 0799-1120-120
ZONE: C2 PD

LOT AREA:	22,500 SF	
BUILDING HEIGHT:	15'-0"	
FLOOR AREA:	2240 SF	9.95% OF LOT AREA
GAS ISLAND CANOPY:	1200 SF	5.33% "
FUTURE BUILDING:	1800 SF	8.15% "
TOTAL COVERAGE:	7200 SF	32% "
LANDSCAPE AREA:	1800 SF	8.00% "
PROPOSED PARKING:	20 STALLS	

These drawings are the instrument of Service and are the property of RLC Design Progressions. All design and other information on the drawings are for the use on the specified project. Any use, reuse or disclosure of said plans, reproductions, ideas, designs and/or arrangements other than RLC Design Progressions is strictly prohibited by law without express, written permission of RLC Design Progressions.

CONTENTS **TAFT HWY.**

DRAWN _____ DATE _____

JOB **8790**

RLC DESIGN PROGRESSIONS

6222 N. FIRST, SUITE 108 FRESNO, CA 93710

PHONE (209) 435 5445

PROJECT **JOHNNY QUICK FOOD STORES**


BUILDER

SHEET NO. **1**

OF SHEETS

UNDERGROUND FUEL TANK DETAILS

SCALE: 1/2" = 1'-0"



EQUIPMENT DESCRIPTION:


- ① GILBARCO HIGHLINE III-B ELECTRONIC DISPENSERS
- ② 6" RAISED ISLAND WITH COXWELL ISLAND FORM
- ③ EBW #660-M IMPACT SAFETY VALVE
- ④ PIPE JACKET 3" ϕ FLEX PIPE Δ
- ⑤ RED JACKET #P32R1 SUB-PUMP W/ LEAK DETECTOR
- ⑥ CNI #236R 36" ϕ MANHOLE COVER + FRAME
- ⑦ EBW #300 VAPOR VALVE + #304 CAP
- ⑧ EBW #781 12" ϕ MANHOLE COVER + FRAME
- ⑨ STEEL #B-74LCT SAFETY MACE
- ⑩ EBW #777 4" FILL CAP + #778 ADAPTER
- ⑪ EMCO-WHEATON #A-1000 OVERFILL CONTAINMENT BOX
- ⑫ MSA. TANKGARD #482607 LIQUID DETECTION PROBE
- ⑬ PIPE JACKET 36" ϕ SUMP BOX Δ
- ⑭ 2" ϕ FRP PRODUCT SUPPLY LINE Δ
- ⑮ PIPE JACKET 3" ϕ TELESCOPING PIPE Δ
- ⑯ CLEAN SAND BACKFILL MATERIAL
- ⑰ U.G. ELECTRICAL CONDUITS FOR PROBES + PUMP Δ
- ⑱ MODERN WELDING ENVIRO-10 DWT. W/ GLASSSTEEL
- ⑲ 2" ϕ FRP PHASE II VAPOR RETURN LINE
- ⑳ EBW #330 EXTRACTOR VALVE
- ㉑ EBW #303 BALL FLOAT VALVE
- ㉒ EBW #782 4" ϕ FILL TUBE
- ㉓ 2" ϕ FRP PRIMARY TANK ATMOSPHERIC VENT Δ
- ㉔ 2" ϕ FRP SECONDARY TANK ATMOSPHERIC VENT Δ

MISC. NOTES:

- Δ SECONDARY CONTAINMENT SYSTEM FOR PRESSURE PIPING BY "PIPE JACKET", TOTAL CONTAINMENT
- Δ ALL FIBERGLASS REINFORCED PLASTIC (FRP) PIPING BY AMERON, DUALOY-3000. ALL PIPING TO SLOPE 1% TOWARD TANK. ALL PIPING TO CONFORM TO ALL STATE AND LOCAL CODES.
- Δ ALL ELECTRICAL TO CONFORM TO NATIONAL ELECTRICAL CODE

U.G. PLUMBING SCHEMATIC

SCALE: 1" = 10'-0"




PIPING LEGEND:

- = PRODUCT SUPPLY LINES Δ
- - - = PHASE II VAPOR RETURN LINES
- · - · - = ATMOSPHERIC VENT LINES

FUELING EQUIPMENT ELECTRICAL SCHEMATIC

NOT-TO-SCALE



ELECTRICAL DESCRIPTION:

- Δ 400 WATT SUPER METAL HALIDE LIGHTS
- Δ GILBARCO HIGHLINE III-B ELECTRONIC DISPS
- Δ TANKGARD PROBES - TANK ANNULAR SPACES
- Δ TANKGARD PROBES - PIPING SUMPS
- Δ FUTURE INVENTORY MONITOR CONDUITS
- Δ 1/3 H.P. SUBMERGED TURBINE PUMPS
- Δ INTERCOM SPEAKER + CALL BUTTON
- Δ EMERGENCY SHUT-OFF SWITCH
- Δ SUBMERGED TURBINE PUMP CONTROL RELAYS

"TYPICAL INSTALLATION DRAWING"

REVISIONS	BY

FUELING INSTALLATION DETAILS
 BY: BANKS & CO.
 2403 E. BELMONT AVE.
 FRESNO, CA. 93701
 (209) 485-3456
 FOR: JOHNNY-QUIK FOOD STORES
 SUITE #104
 1715 MINNEAPOLIS
 CLOVIS, CA 93612
 (209) 299-0223

DRAWN BILL MOORE
CHECKED
DATE OCT. 20, 1987
SCALE 1/2" = 1'-0"
JOB NO.
SHEET ONE
OF THREE SHEETS

Central Valley Regional Water Quality Control Board

5 December 2013

Kuljit Ghuman
2126 Taft Highway
Bakersfield, CA 93313

**REVIEW – SOIL ASSESSMENT REPORT, UNDERGROUND STORAGE TANK RELEASE,
JOHNNY QUICK #143, 2126 TAFT HIGHWAY, BAKERSFIELD, KERN COUNTY, RB CASE
5T15000929**

The *Soil Investigation Report* (Report) dated September 2013, was submitted by the consultant, Advanced Environmental Concepts, Inc. (AEC), in response to the Central Valley Regional Water Quality Control Board (Central Valley Water Board) staff letter dated 17 July 2013. The Report summarizes investigation to define the vertical and lateral extent of petroleum fuel constituents detected in soil during May 2013 underground storage tank (UST) system piping replacement. This letter summarizes the Report, addresses concerns and provides comments, and requests additional submittals prior to final consideration of case closure of the UST site (Site).

SUMMARY

After the UST system piping was replaced, a vertical 2-inch diameter pipe was installed at the UST release source area (dispenser), and another 10 feet to the west, as drilling guides for direct-push borings TH-1 and TH-2, respectively. The piping trench was backfilled with pea gravel and then paved with concrete. On 29 July 2013, AEC attempted to advance TH-1, but encountered drilling problems which prevented sample collection. TH-2 and an additional lateral boring, TH-3, located 15 feet north of the source area, were successfully drilled and sampled. Soil samples were collected at five-foot intervals beginning at five feet below ground surface (bgs), to a maximum depth of 30 feet bgs.

On September 9, 2013, concrete and backfill were removed from the area, and TH-1 was successfully advanced and sampled at five-foot intervals from 10 feet to 40 feet bgs. TH-4, was also sampled as an additional lateral boring five feet north of TH-3, since a low concentration of gasoline constituents was detected in the sample collected from TH-3 at 25 feet bgs. TH-4 was sampled at five-foot intervals from 25 to 40 feet bgs.

The samples were submitted to a California-certified laboratory for analysis for total petroleum hydrocarbons as gasoline (TPHg); benzene, toluene, ethylbenzene, and xylenes (BTEX); and the fuel oxygenate methyl tertiary butyl ether (MTBE). Selected samples were also analyzed for total petroleum hydrocarbons as diesel (TPHd). The sample from TH-1 at 10 feet bgs was also analyzed for volatile organic compounds, including naphthalene. TPHg and TPHd were detected at 10 feet in TH-1 at 260 and 682 milligrams per kilogram (mg/kg), respectively, and naphthalene was detected at 12 mg/kg. TPHg was detected at less than 10 mg/kg in samples from 15 and

KARL E. LONGLEY ScD, P.E., CHAIR | PAMELA C. CREEDON P.E., BCCE, EXECUTIVE OFFICER

1685 E Street, Fresno, CA 93706 | www.waterboards.ca.gov/centralvalley

DEC - 9 2013

LV

20 feet bgs, but no deeper. Benzene was not detected in samples from TH-1 or the other borings. Ethylbenzene was detected at 0.3 mg/kg at 20 feet in TH-1. Xylenes were detected to 20 feet bgs in TH-1 from 1.8 to 14 mg/kg, and at less than 1 mg/kg from 25 to 35 feet bgs.

TPHg was detected at less than 1 mg/kg at 25 feet bgs in lateral borings TH-2 and TH-3, and toluene was also detected at less than 1 mg/kg at 25 feet in TH-2. No analytes were detected in samples from lateral boring TH-4.

AEC concluded that significant concentrations of gasoline and diesel constituents did not migrate below 15 feet bgs through the permeable sandy soil, and remain within an approximate 10-foot radius of the release point. The presence of silt lenses, encountered from 20 – 24 and 32 -36 feet bgs, did not cause extensive lateral fluid migration. Groundwater was not affected by the release. AEC recommends case closure.

COMMENTS

Central Valley Water Board staff concurs that gasoline and diesel constituents are confined to shallow depths, and did not migrate to groundwater. The investigation summarized in the Report defines the vertical and lateral extent of affected soil – **additional investigation is not requested**. Little hydrocarbon mass remains, and secondary source removal is not practicable. Gasoline and diesel constituent concentrations detected in shallow soil during May and September 2013 suggest that human health risk is less than the level of concern.

Low-Threat Underground Storage Tank Case Closure Policy Evaluation

Central Valley Water Board staff is required by State Water Resources Control Board Resolution No. 2012-0062 to review UST release cases for closure in accordance with the *Low-Threat Underground Storage Tank Case Closure Policy* (Policy). The subject UST release may be eligible for closure under the Policy, based on data contained in the Report and case file. Policy criteria remaining to be satisfied are discussed below:

The following General Criteria are **not** satisfied:

- e.) Development of a Conceptual Site Model (CSM) that assesses the nature and mobility of the release. Sufficient supporting information and data for the CSM are contained in the Report and case file, with the exception of a Sensitive Receptor Survey (SRS), and an estimate of the remaining hydrocarbon mass.
 - **A SRS is requested** - provide documentation of any water wells within 1,000 feet of the release, including private domestic, irrigation, and other wells, with construction details, based on examination of DWR records and other records. Utilities and other enclosed spaces in the vicinity of the release, and any other potential receptors also need to be identified. The SRS should include a field reconnaissance.
 - **Calculate the remaining hydrocarbon mass** - include the data used, calculations, and assumptions.

The following tasks in the Policy's Low-Threat Case Closure section needs to be completed prior to closure:


- a.) Notification of the proposed case closure to water districts, water replenishment districts, special act districts with groundwater management authority, agencies with authority to issue building permits for land affected by the unauthorized release, and the owners and occupants of the property affected by the unauthorized release, and owners and occupants of all parcels adjacent to the impacted property.

- **An Off-Site Property Owner Survey (Survey) is requested** - provide a mailing list for distribution of a Public Notice to be prepared by Central Valley Water Board staff. The Survey should be conducted by obtaining the property owner names and mailing addresses, business and residences mailing addresses, and assessors' parcel maps and numbers for all properties overlying soil and groundwater historically impacted by the UST release and adjacent properties. The data should be presented in a table or spreadsheet. Central Valley Water Board staff will request will proceed with closure after a 60 day public comment period, if comments adverse to closure are not received.


b.) The removal and proper disposal of waste piles, drums, debris and other investigation derived materials in accordance with regulatory agency requirements.

By 5 February 2014, please submit the Off-Site Property Owner Survey and hydrocarbon mass calculation.

Please call me at (559) 445-5504 or email at jwhiting@waterboards.ca.gov if you have any questions, and in advance of fieldwork.



JOHN D. WHITING
Engineering Geologist
PG No. 5951



SHELTON R. GRAY
Senior Engineering Geologist

cc: Lydia V. von Sydow, Kern County Environmental Health Division, Bakersfield
Jonathon Buck, Advanced Environmental Concepts, Inc., Bakersfield

60297

MONITORING SYSTEM CERTIFICATION

For Use By All Jurisdictions Within the State of California

Authority Cited: Chapter 6.7, Health and Safety Code; Chapter 16, Division 3, Title 23, California Code of Regulations

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

A. General Information

Facility Name: JOHNNY QUICK Bldg. No.: _____
 Site Address: 2126 TAFT HWY City: BAKERSFIELD Zip: 93313
 Facility Contact Person: MR. KOOL Contact Phone No.: (661) 834-9113
 Make/Model of Monitoring System: TLS-350 Date of Testing/Service: 2/23/2015

B. Inventory of Equipment Tested/Certified

Check the appropriate boxes to indicate specific equipment inspected/serviced:

Tank ID: REG87 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: PREM91 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Tank ID: DIESEL <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input type="checkbox"/> Annular Space or Vault Sensor. Model: _____ <input type="checkbox"/> Piping Sump / Trench Sensor(s). Model: _____ <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Dispenser ID: 1/2 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 3/4 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: 5/6 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 7/8 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply):
 System set-up Alarm history report

Technician Name (print): BRANDON MASON Signature: _____
 Certification No.: 5284980-UT / B34335 License No.: C61/ D40 A HAZ 809850
 Testing Company Name: RICH ENVIRONMENTAL Phone No.: (661) 392-8687
 Testing Company Address: 5643 BROOKS CT. BAKERSFIELD, CA 93308 Date of Testing/Service: 2/23/2015

Monitoring System Certification

D. Results of Testing/Serviceing

Software Version Installed: 332.00

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the audible alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the visual alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors visually inspected, functionally tested, and confirmed operational?
<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No*	Were all sensors installed at lowest point of secondary containment and positioned so that other equipment will not interfere with their proper operation?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	If alarms are relayed to a remote monitoring station, is all communications equipment (e.g., modem) operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected? If yes: which sensors initiate positive shut-down? (Check all that apply) <input checked="" type="checkbox"/> Sump/Trench Sensors; <input type="checkbox"/> Dispenser Containment Sensors. Did you confirm positive shut-down due to leaks and sensor failure/disconnection? <input checked="" type="checkbox"/> Yes; <input type="checkbox"/> No.
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For tank systems that utilize the monitoring system as the primary tank overflow warning device (i.e., no mechanical overflow prevention valve is installed), is the overflow warning alarm visible and audible at the tank fill point(s) and operating properly? If so, at what percent of tank capacity does the alarm trigger? %
<input checked="" type="checkbox"/> Yes*	<input type="checkbox"/> No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes, or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E, below.
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was liquid found inside any secondary containment systems designed as dry systems? (Check all that apply) <input type="checkbox"/> Product; <input type="checkbox"/> Water. If yes, describe causes in Section E, below.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was monitoring system set-up reviewed to ensure proper settings? Attach set up reports, if applicable
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is all monitoring equipment operational per manufacturer's specifications?

* In Section E below, describe how and when these deficiencies were or will be corrected.

E. Comments:



Monitoring System Certification

F. In-Tank Gauging / SIR Equipment:

- Check this box if tank gauging is used only for inventory control.
- Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all tank gauging probes visually inspected for damage and residue buildup?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system product level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system water level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all probes reinstalled properly?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

G. Line Leak Detectors (LLD):

- Check this box if LLDs are not installed.

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For equipment start-up or annual equipment certification, was a leak simulated to verify LLD performance? (Check all that apply) Simulated leak rate: <input checked="" type="checkbox"/> 3 g.p.h.; <input type="checkbox"/> 0.1 g.p.h.; <input type="checkbox"/> 0.2 g.p.h.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all LLDs confirmed operational and accurate within regulatory requirements?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was the testing apparatus properly calibrated?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

H. Comments: _____



Monitoring System Certification Form: Addendum for Vacuum/Pressure Interstitial Sensors

I. Results of Vacuum/Pressure Monitoring Equipment Testing

This page should be used to document testing and servicing of vacuum and pressure interstitial sensors. A copy of this form must be included with the Monitoring System Certification Form, which must be provided to the tank system owner/operator. The owner/operator must submit a copy of the Monitoring System Certification Form to the local agency regulating UST systems within 30 days of test date.

Manufacturer: N/A		Model:	System Type: <input type="checkbox"/> Pressure; <input type="checkbox"/> Vacuum
Sensor ID			
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		
	Component(s) Monitored by this Sensor:		
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail		
How was interstitial communication verified?			
<input type="checkbox"/> Leak Introduced at Far End of Interstitial Space; ¹ <input type="checkbox"/> Gauge; <input type="checkbox"/> Visual Inspection; <input type="checkbox"/> Other (Describe in Sec. J, below)			
Was vacuum/pressure restored to operating levels in all interstitial spaces? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no, describe in Sec. J, below)			


J. Comments: N/A

¹ If the sensor successfully detects a simulated vacuum/pressure leak introduced in the interstitial space at the furthest point from the sensor, vacuum/pressure has been demonstrated to be communicating throughout the interstice.

Monitoring System Certification

UST Monitoring Site Plan

Site Address: 2126 TAFT HWY. BAKERSFIELD, CA.



Date map was drawn: 2/14/2013.

Instructions

If you already have a diagram that shows all required information, you may include it, rather than this page, with your Monitoring System Certification. On your site plan, show the general layout of tanks and piping. Clearly identify locations of the following equipment, if installed: monitoring system control panels; sensors monitoring tank annular spaces, sumps, dispenser pans, spill containers, or other secondary containment areas; mechanical or electronic line leak detectors; and in-tank liquid level probes (if used for leak detection). In the space provided, note the date this Site Plan was prepared.



RICH ENVIRONMENTAL
 5643 BROOKS CT. BAKERSFIELD, CA. 93308
 OFFICE (661)392-8687 FAX (661)392-0621
PRODUCT LINE LEAK DETECTOR TEST

WORK SHEET

W/O#: _____

FACILITY NAME: JOHNNY QUICK

FACILITY ADDRESS: 2126 TAFT HWY. BAKERSFIELD

PRODUCT LINE TYPE: PRESSURE

PRODUCT	LEAK DETECTOR TYPE SERIAL NUMBER	TEST BELOW 3 G.P.H.	TRIP P.S.I.	PASS OR FAIL
REG87	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>2347</u>	YES	10	PASS
PREM91	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>1262</u>	YES	10	PASS
DIESEL	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>3246</u>	YES	10	PASS
	L/D TYPE : <u> </u> SERIAL # <u> </u>	YES NO		PASS FAIL

I CERTIFY THE ABOVE TESTS WERE CONDUCTED ON THIS DATE ACCORDING TO RED JACKET PUMPS FIELD TEST APPARATUS TESTING PROCEDURE AND LIMITATIONS. THE MECHANICAL LEAK DETECTOR TEST PASS / FAIL IS DETERMINED BY USING A LOW FLOW THRESHOLD TRIP RATE OF 3 GALLONS PER HOUR OR LESS AT 10 P.S.I. I ACKNOWLEDGE THAT ALL DATA COLLECTED IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE.

TECHNICIAN: BRANDON MASON

SIGNATURE: _____

DATE: 2/23/15

Spill Bucket Testing Report Form

This form is intended for use by contractors performing annual testing of UST spill containment structures. The completed form and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: JOHNNY QUICK	Date of Testing: 2/23/15
Facility Address: 2126 TAFT HWY. BAKERSFIELD	
Facility Contact: MR. KOOL	Phone: (661) 834-9113
Date Local Agency Was Notified of Testing : 1/14/15	
Name of Local Agency Inspector (if present during testing): MARTY	

2. TESTING CONTRACTOR INFORMATION

Company Name: RICH ENVIRONMENTAL
Technician Conducting Test: BRANDON MASON
Credentials ¹ : <input type="checkbox"/> CSLB Contractor <input checked="" type="checkbox"/> ICC Service Tech. <input type="checkbox"/> SWRCB Tank Tester <input type="checkbox"/> Other (Specify)
License Number(s): 5284980-UT


3. SPILL BUCKET TESTING INFORMATION

Test Method Used: <input checked="" type="checkbox"/> Hydrostatic <input type="checkbox"/> Vacuum <input type="checkbox"/> Other				
Test Equipment Used: VISUAL Equipment Resolution: 0.00				
Identify Spill Bucket (By Tank Number, Stored Product, etc.)	1 REG87-FILL	2 PREM91-FILL	3 DIESEL	4
Bucket Installation Type:	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump
Bucket Diameter:	12"	12"	12"	
Bucket Depth:	12"	12"	12"	
Wait time between applying vacuum/water and start of test:	30MIN	30MIN	30MIN	
Test Start Time (T _I):	9:00	9:00	9:00	
Initial Reading (R _I):	10"	10"	10"	
Test End Time (T _F):	10:00	10:00	10:00	
Final Reading (R _F):	10"	10"	10"	
Test Duration (T _F - T _I):	60MIN	60MIN	60MIN	
Change in Reading (R _F - R _I):	0	0	0	
Pass/Fail Threshold or Criteria:	0	0	0	
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

I hereby certify that all the information contained in this report is true, accurate, and in full compliance with legal requirements.

Technician's Signature: 

Date: 2/23/15

¹ State laws and regulations do not currently require testing to be performed by a qualified contractor. However, local requirements may be more stringent.

VERSION 332.00
SOFTWARE# 346332-100-A
CREATED - 11.05.27.16.12

S-MODULE# 330160-004-a
SYSTEM FEATURES:
PERIODIC IN-TANK TESTS
ANNUAL IN-TANK TESTS
ISD/APM

SYSTEM SETUP

FEB 23 2015 11:04 AM

SYSTEM UNITS

U.S.
SYSTEM LANGUAGE
ENGLISH
SYSTEM DATE/TIME FORMAT
MON DD YYYY HH:MM:SS XM

JOHNNY QUICK 143
2126 TAFT HWY
BAKERSFIELD CA 93313
661-834-9113

SHIFT TIME 1 : 8:00 AM
SHIFT TIME 2 : DISABLED
SHIFT TIME 3 : DISABLED
SHIFT TIME 4 : DISABLED

TANK PER TST NEEDED WRN
DISABLED
TANK ANN TST NEEDED WRN
DISABLED

LINE RE-ENABLE METHOD
PASS LINE TEST

LINE PER TST NEEDED WRN
DISABLED
LINE ANN TST NEEDED WRN
DISABLED

PRINT TO VOLUMES
ENABLED

TEMP COMPENSATION
VALUE (DEG F) : 60.0
STICK HEIGHT OFFSET
DISABLED
ULLAGE: 90%

H-PROTOCOL DATA FORMAT
HEIGHT
DAYLIGHT SAVING TIME
ENABLED
START DATE
MAR WEEK 2 SUN
START TIME
2:00 AM
END DATE
NOV WEEK 1 SUN
END TIME
2:00 AM

RE-DIRECT LOCAL PRINTOUT
DISABLED

EURO PROTOCOL PREFIX
S.

COMMUNICATIONS SETUP

PORT SETTINGS:

COMM BOARD : 1 (EDIM)
RS-232 SECURITY
CODE : DISABLED

COMM BOARD : 2 (RS-232)
BAUD RATE : 9600
PARITY : NONE
STOP BIT : 1 STOP
DATA LENGTH: 8 DATA
RS-232 SECURITY
CODE : DISABLED

COMM BOARD : 3 (RS-232)
BAUD RATE : 1200
PARITY : ODD
STOP BIT : 1 STOP
DATA LENGTH: 7 DATA
RS-232 SECURITY
CODE : DISABLED

AUTO TRANSMIT SETTINGS:

AUTO LEAK ALARM LIMIT
DISABLED
AUTO HIGH WATER LIMIT
DISABLED
AUTO OVERFILL LIMIT
DISABLED
AUTO LOW PRODUCT
DISABLED
AUTO THEFT LIMIT
DISABLED
AUTO DELIVERY START
DISABLED
AUTO DELIVERY END
DISABLED
AUTO EXTERNAL INPUT ON
DISABLED
AUTO EXTERNAL INPUT OFF
DISABLED
AUTO SENSOR FUEL ALARM
DISABLED
AUTO SENSOR WATER ALARM
DISABLED
AUTO SENSOR OUT ALARM
DISABLED

RS-232 END OF MESSAGE
DISABLED

IN-TANK SETUP

T 1:UNL87
PRODUCT CODE : 1
THERMAL COEFF : .000700
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
9000
HIGH PRODUCT : 95%
9500
DELIVERY LIMIT : 10%
1000

LOW PRODUCT : 1000
LEAK-ALARM-LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
1000

LEAK MIN ANNUAL : 10%
1000

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

T 2:PREM91
PRODUCT CODE : 2
THERMAL COEFF : .000700
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
9000
HIGH PRODUCT : 95%
9500
DELIVERY LIMIT : 10%
1000

LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
1000

LEAK MIN ANNUAL : 10%
1000

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

T 3:DIESEL
PRODUCT CODE : 3
THERMAL COEFF : .000450
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
9000
HIGH PRODUCT : 95%
9500
DELIVERY LIMIT : 10%
1000

LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
1000

LEAK MIN ANNUAL : 10%
1000

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

LEAK TEST METHOD

TEST ON DATE : ALL TANK
MAY 27, 2011
START TIME : DISABLED
TEST RATE : 0.20 GAL/HR
DURATION : 2 HOURS

TST EARLY STOP:DISABLED

LEAK TEST REPORT FORMAT
NORMAL

LIQUID SENSOR SETUP

L 1:87 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE


L 2:91 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 3:DSL ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 4:87 STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 5:91 STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 6:DSL STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

60297 

ALARM HISTORY REPORT

R 1:87
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 1

LIQUID SENSOR ALMS
L 1:FUEL ALARM
L 4:FUEL ALARM
L 1:SENSOR OUT ALARM
L 4:SENSOR OUT ALARM

ISD SITE ALARMS
ISD GROSS PRES FAIL
ISD DEGRD PRES FAIL
ISD VAPOR LEAK FAIL
ISD VP PRES FAIL
ISD VP STATUS FAIL

ISD HOSE ALARMS
ALL:FLOW COLLECT FAIL

R 2:91
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 2

LIQUID SENSOR ALMS
L 2:FUEL ALARM
L 5:FUEL ALARM
L 2:SENSOR OUT ALARM
L 5:SENSOR OUT ALARM

ISD SITE ALARMS
ISD GROSS PRES FAIL
ISD VAPOR LEAK FAIL
ISD VP PRES FAIL
ISD VP STATUS FAIL

ISD HOSE ALARMS
ALL:FLOW COLLECT FAIL

R 3:DSL
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 3

LIQUID SENSOR ALMS
L 3:FUEL ALARM
L 6:FUEL ALARM
L 3:SENSOR OUT ALARM
L 6:SENSOR OUT ALARM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 1:87 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 23, 2015 9:55 AM

FUEL ALARM
FEB 23, 2015 9:44 AM

FUEL ALARM
FEB 21, 2014 10:24 AM

* * * * * END * * * * *

ALARM HISTORY REPORT

60297

----- SENSOR ALARM -----
L 4:87 STP
STP SUMP
SENSOR OUT ALARM
FEB 23, 2015 9:55 AM

FUEL ALARM
FEB 23, 2015 9:39 AM

SENSOR OUT ALARM
FEB 21, 2014 10:24 AM

* * * * * END * * * * *

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 2:91 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 23, 2015 9:55 AM

FUEL ALARM
FEB 23, 2015 9:46 AM

FUEL ALARM
FEB 21, 2014 10:24 AM

* * * * * END * * * * *

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 5:91 STP
STP SUMP
SENSOR OUT ALARM
FEB 23, 2015 9:55 AM

FUEL ALARM
FEB 23, 2015 9:38 AM

FUEL ALARM
MAR 11, 2014 3:24 PM

* * * * * END * * * * *

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 3:DSL ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 23, 2015 9:55 AM

FUEL ALARM
FEB 23, 2015 9:48 AM

FUEL ALARM
FEB 21, 2014 10:24 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 6:DSL STP
STP SUMP
SENSOR OUT ALARM
FEB 23, 2015 9:55 AM

FUEL ALARM
FEB 23, 2015 9:38 AM

SENSOR OUT ALARM
FEB 21, 2014 10:24 AM

60297
/

MONITOR CERT. FAILURE REPORT

SITE NAME: JOHNNY QUICK **DATE:** 2/23/15

ADDRESS: 2126 TAFT HWY **TECHNICIAN:** BRANDON MASON

CITY: BAKERSFIELD **SIGNATURE:** 

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS: NONE

LABOR: NONE

PARTS INSTALLED: NONE

NAME: _____ **TITLE:** _____

SIGNATURE: _____

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENCE.



HAZARDOUS MATERIALS BUSINESS PLAN (HMBP) INSPECTION REPORT

Facility Name: JOHNNY QUIK #143		Facility ID: FA0002691
Site Address: 2126 TAFT HWY BAKERSFIELD, CA 93313		CERS ID: 10233775
Phone: (661) 834-9113	Consent Granted By: KULJIT GHUMAN	Inspection Date: 04/07/2015
Inspection Type: <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Reinspection		Reinspection required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Inspection Element: BUS PLAN MED LOW RISK 1 UNIT		

File/CERS Review Violations

V	Viol #	Summary	Code
	H335	Failure to adequately complete and submit a HMBP into the California Environmental Reporting System (CERS)	HSC 6.95 25505, 25508(a)(1), 25508(d)
✓	H344	Failure to complete and submit the Business Activities Page and/or Business Owner Operator Identification Page in CERS	HSC 6.95 25508(a)(1); 19 CCR 4 2729.2(a)(1);
✓	H342	Failure to complete and submit hazardous material inventory information for all reportable hazardous materials on site in CERS	HSC 6.95 25505(a)(1), 25506, 25508(a)(1)
	H341	Failure to annually review and electronically certify that the business plan is complete, accurate, and up-to-date in CERS	HSC 6.95 25508(c), 25508.2
✓	H346	Failure to complete and submit a site map with all required content in CERS	HSC 6.95 25505(a)(2), 25508(a)(1)
✓	H347	Failure to submit an adequate emergency response plan and procedures in CERS	HSC 6.95 25505(a)(3), 25508(a)(1)
✓	H353	Failure to submit an adequate training program in CERS	HSC 6.95 25505(a)(4), 25508(a)(1)
	H340	Failure to notify property owner in writing that a HMBP is required	HSC 6.95 25505.1
	H336	Failure to provide property owner a copy of the HMBP upon request	HSC 6.95 25505.1

Onsite Inspection Violations

V	Viol #	Summary	Code
	H334	Failure to adequately establish and implement a HMBP	HSC 6.95 25507
	H343	Failure to revise HMBP in CERS within 30 days upon a substantial change in the handler's operation	HSC 6.95 25508.1(f)
	H345	Failure to update Facility Information and/or Hazardous Materials Inventory in CERS within 30 days upon a significant change	HSC 6.95 25508.1(a)-(e)
	H348	Failure to provide initial and annual safety training to all employees and/or failure to document and maintain training records for 3 years	HSC 6.95 25505(a)(4)
	H338	Failure to report a release or threatened release of a hazardous material to the CUPA and to California Office of Emergency Services	HSC 6.95 25510(a)

Inspector: MARTY A BROWNFIELD

Inspection Date: 04/07/2015

CONDITIONAL EXEMPTIONS FROM REPORTING REQUIREMENTS

Agricultural handlers are conditionally exempt from electronically submitting Emergency Response and Employee Training Plans in CERS if the following requirements are met:

- Owner/Operator annually submits the Facility Information and Hazardous Materials Inventory electronically into CERS
- Each location/building, where hazardous materials (i.e. pesticides, petroleum products, fertilizers, etc.) are stored, is posted with warning signs that meet the following requirements:
 - Shall be conspicuous and visible from any direction of probable approach
 - Shall be of such size that it is readable from 25 feet and shall be labeled as follows:

DANGER HAZARDOUS MATERIAL STORAGE AREA
 (the hazardous materials stored within shall be noted by category
 [i.e. pesticides, petroleum products, fertilizers, etc.]
 ALL UNAUTHORIZED PERSONS-KEEP OUT - IN AN EMERGENCY, CONTACT:
 (list the name and phone number of an emergency contact person(s))

- Shall be repeated in an appropriate language other than English when persons who do not understand the English language may enter the posted location/building
- Owner/Operator provides training for all new employees and annual training, including refresher courses, for all employees in safety procedures in the event of a release or threatened release of a hazardous material, including, but not limited to, familiarity with the emergency plans and procedures

Exempt Facility Violations

V	Viol #	Summary	Code
	H760	Failure to submit Emergency Response/Contingency Plan in CERS when not meeting agricultural handler exemption requirements	HSC 6.95 25507.1, 25508(a)(1); 19 CCR 4 2733, 2734
	H758	Failure to submit Employee Training Plan in CERS when not meeting agricultural handler exemption requirements	HSC 6.95 25507.1, 25508(a)(1); 19 CCR 4 2733, 2734
	H759	Failure to establish and submit a HMBP in CERS when not meeting remote unstaffed facility exemption requirements	HSC 6.95 25505, 25506, 25507, 25507.2, 25508(a)(1)

SUMMARY OF OBSERVATIONS/VIOLATIONS

- No violations of hazardous materials business plan laws/regulations were discovered. KERN CUPA greatly appreciates your efforts to comply with all the laws and regulations applicable to your facility.
- Violations were observed/discovered as listed below. **ALL VIOLATIONS MUST BE CORRECTED WITHIN 30 DAYS OR AS SPECIFIED.** CUPA must be informed in writing with a certification that compliance has been achieved. A false statement that compliance has been achieved is a violation of the law and punishable by a fine of not less than \$2,000 or more than \$25,000 for each violation. Your facility may be reinspected any time during normal business hours. If a second reinspection becomes necessary due to non compliance, a reinspection charge of \$100.00 per hour may be charged to the facility.

You may request a meeting with the Program Manager to discuss the inspection findings and/or the proposed corrective actions. The issuance of this Summary of Violations does not preclude the CUPA from taking administrative, civil, or criminal action.

VIOLATIONS

Violation Number	Violation Text	Violation Degree	Comply by
H342	Failure to complete and electronically submit hazardous material inventory information for all reportable hazardous materials on site. HSC 6.95 25506, 25505(a)(1), 25508(a)(1)	CLASS II VIOLATION	05/07/2015
Violation Details & Corrective Action Required:	PLEASE UPDATE YOUR HAZARDOUS MATERIALS INVENTORY TO SHOW THAT CARBON DIOXIDE AND LPG ARE STORED AT GREATER THAN AMBIENT PRESSURE		

H344	Failure to complete and electronically submit the Business Activities Page and/or Business Owner Operator Identification Page. HSC 6.95 25508(a)(1), 19 CCR 4 2729.2(a)(1)	CUPA MINOR VIOLATION	05/07/2015
-------------	--	-----------------------------	-------------------

Violation Details & Corrective Action Required: PLEASE UPDATE YOUR BEGINNING AND ENDING DATES ON THE BUSINESS OWNER/OPERATOR PAGE IN THE CALIFORNIA ENVIRONMENTAL REPORTING SYSTEM (CERS).

H346	Failure to complete and electronically submit an annotated site map with all required content (north orientation, loading areas, internal roads, adjacent streets, storm and sewer drains, access and exit points, emergency shutoffs, evacuation staging areas, hazardous material handling and storage areas, and emergency response equipment). Updates to existing maps to meet these requirements shall be completed by January 1, 2015. HSC 25505(a)(2), 25508(a)(1)	CLASS II VIOLATION	05/07/2015
-------------	--	---------------------------	-------------------

Violation Details & Corrective Action Required: PLEASE UPDATE YOUR SITE/FACILITY MAP TO SHOW WHERE YOUR CO2 IS BEING STORED AT.

H347	Failure to establish and electronically submit an adequate Emergency Response Plan and procedures in the event of a reportable release or threatened release of a hazardous material, including, but not limited to, all of the following: (A) Immediate notification to the appropriate local emergency rescue personnel and to the unified program agency. (B) Procedures for the mitigation of a release or threatened release to minimize any potential harm or damage to persons, property, or the environment. (C) Evacuation plans and procedures, including immediate notice, for the business site. HSC 6.95 25505(a)(3), 25508(a)(1)	CLASS II VIOLATION	05/07/2015
-------------	---	---------------------------	-------------------

Violation Details & Corrective Action Required: PLEASE COMPLETE AND UPLOAD INTO THE CALIFORNIA ENVIRONMENTAL REPORTING SYSTEM (CERS) THE CONSOLIDATED CONTINGENCY PLAN TEMPLATE FORM LAUREL FUNK E-MAILED YOU

H353	Failure to include and electronically submit an adequate training program in the Hazardous Materials Business Plan (HMBP), which is reasonable and appropriate for the size of the business and the nature of the hazardous materials handled. HSC 6.95 25505(a)(4), 25508(a)(1)	CLASS II VIOLATION	05/07/2015
-------------	--	---------------------------	-------------------

Violation Details & Corrective Action Required: PLEASE COMPLETE AND UPLOAD INTO THE CALIFORNIA ENVIRONMENTAL REPORTING SYSTEM (CERS) THE EMPLOYEE TRAINING PLAN TEMPLATE FORM LAUREL FUNK E-MAILED YOU

INSPECTION COMMENTS:

COMMENTS: Go to <http://www.co.kern.ca.us/eh/> (Hazardous Materials) for forms and information.

Inspector:  MARTY A BROWNFIELD
 Inspection Date: 04/07/2015

Signature of Facility Representative:

Certification: I certify under penalty of perjury that this facility has complied with the corrective actions listed on this inspection form.

Printed Name of Owner/Operator

Title

Signature of Owner/Operator

Date



UNDERGROUND STORAGE TANK INSPECTION REPORT

Facility Name: JOHNNY QUIK #143		Facility ID: FA0002691
Site Address: 2126 TAFT HWY BAKERSFIELD, CA 93313		CERS ID: 10233775
Phone: (661) 834-9113		BOE #:
Consent Granted By: KULJIT GHUMAN		Inspection Date: 04/07/2015
Designated Operator: RICH ENVIRONMENTAL		Testing Company: RICH ENVIRONMENTAL
Inspection Type: <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Reinspection		Reinspection required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

File/CERS Review Violations

V	Viol #	Summary	Code
	H650	FAILURE TO OBTAIN/MAINTAIN A VALID OPERATING PERMIT	23 CCR 16 2712(i); HSC 6.7 25284
✓	H651	FAILURE TO SUBMIT ACCURATE UST FACILITY/TANK INFORMATION	23 CCR 16 2711; HSC 6.7 25286(a)
✓	H653	FAILURE TO SUBMIT STATEMENT OF DESIGNATED OPERATOR/UST COMPLIANCE	23 CCR 16 2715(a), 2715(b)
	H654	FAILURE TO SUBMIT/MAINTAIN AN ACCURATE RESPONSE PLAN	23 CCR 16 2632, 2634(e), 2641(h), 2712(i)
	H655	FAILURE TO SUBMIT/MAINTAIN AN ACCURATE PLOT PLAN	23 CCR 16 2632(d)(1)(C), 2711(a)(8)
	H660	MAKING FALSE STATEMENTS/REPRESENTATION ON ANY DOCUMENT	HSC 6.7 25299
	H662	FAILURE TO COMPLETE/SUBMIT ANNUAL MONITORING CERTIFICATION	23 CCR 16 2638
	H663	FAILURE TO COMPLETE SECONDARY CONTAINMENT TESTING	23 CCR 16 2637
	H664	FAILURE TO ANNUALLY TEST SPILL CONTAINMENT	HSC 6.7 25284.2
	H665	FAILURE TO SUBMIT SECONDARY CONTAINMENT TEST RESULTS	23 CCR 16 2637(e)

General Violations

V	Viol #	Summary	Code
	H741	FAILURE TO COMPLY WITH ALL OPERATING PERMIT CONDITIONS	23 CCR 16 2712
	H680	IMPROPER PROGRAMING/OPERATION OF LEAK DETECTION EQUIPMENT	23 CCR 16 2632, 2634, 2636, 2666
	H681	FAILURE OF LEAK DETECTION EQUIPMENT TO HAVE AUDIBLE/VISUAL ALARMS	23 CCR 16 2632, 2634, 2636, 2666
	H683	FAILURE TO INSTALL CORRECT LEAK DETECTION SYSTEM	23 CCR 16 2638; HSC 6.7 25290.1, 25290.2, 2529122 CCR 12 66262.34(d)(2);
	H684	FAILURE TO PROPERLY LABEL CERTIFIED MONITORING EQUIPMENT	23 CCR 16 2638(f)
	H690	FAILURE TO PROPERLY MONITOR UNDER DISPENSER CONTAINMENT	23 CCR 16 2636(f)(1)
	H694	FAILURE OF SENSOR TO BE LOCATED IN THE PROPER POSITION	23 CCR 16 2630(d), 2641(a)
	H695	TAMPERING WITH LEAK DETECTION EQUIPMENT	HSC 6.7 25299(a)(9)
	H704	FAILURE TO INSTALL LINE LEAK DETECTORS ON PRESSURIZED PIPING	HSC 6.7 25290.1(h), 25290.2(g), 25291(f), 25292(e)
	H708	FAILURE OF LINE LEAK DETECTOR TO FUNCTION AS REQUIRED	23 CCR 16 2636(f)(2)
	H711	FAILURE TO KEEP SECONDARY CONTAINMENT FREE OF DEBRIS/ LIQUID AND IN GOOD CONDITION	HSC 6.7 25290.1, 25290.2, 25291
	H717	FAILURE TO KEEP SPILL BUCKET FREE OF DEBRIS/LIQUID AND IN GOOD CONDITION	23 CCR 16 2635(b), 2715(c)(2)
	H676	FAILURE TO OBTAIN PERMITS TO INSTALL, REPLACE, REPAIR OR MODIFY PART OF THE UST SYSTEM	23 CCR 16 2712

Inspector: MARTY A BROWNFIELD

Inspection Date: 04/07/2015

General Violations - continued

V	Viol #	Summary	Code
	H719	FAILURE TO OPERATE THE UST SYSTEM TO PREVENT SPILLS/ OVERFILLS	HSC 6.7 25292.1(a)
	H720	FAILURE OF THE OVERFILL PREVENTION SYSTEM TO FUNCTION AS REQUIRED	23 CCR 16 2635(b)(2), 2665
	H721	FAILURE OF INDIVIDUALS WORKING ON/MAINTAINING THE UST SYSTEM TO HAVE A PROPER/CURRENT ICC CERTIFICATION	23 CCR 16 2715
	H747	FAILURE TO COMPLY WITH TEMPORARY CLOSURE REQUIREMENTS	23 CCR 16 2670, 2671; HSC 6.7 25298
	H748	FAILURE TO COMPLY WITH ALL PERMANENT CLOSURE REQUIREMENTS	23 CCR 16 2670, 2672; HSC 6.7 25298

Double Walled Tank Violations

V	Viol #	Summary	Code
	H682	FAILURE TO CONTINUOUSLY MONITOR SECONDARY CONTAINMENT THAT ACTIVATES AN AUDIBLE/VISUAL ALARM	23 CCR 16 2631(g), 2632(c)(2)(A)&(B), 2633(c), 2636(f)
	H699	FAILURE TO CONTINUOUSLY MONITOR SECONDARY CONTAINMENT USING VACUUM/PRESSURE/HYDROSTATIC	HSC 6.7 25290.1(e)
	H714	FAILURE TO MAINTAIN PRODUCT TIGHT SECONDARY CONTAINMENT	23 CCR 16 2662; HSC 6.7 25290.1(c)(2), 25290.2(c)(2), 25291(a), 25292(e)

Double Walled Piping Violations

V	Viol #	Summary	Code
	H666	FAILURE TO COMPLY WITH ANNUAL LINE INTEGRITY TESTING	23 CCR 16 2636(f)(4)
	H686	FAILURE OF SECONDARY CONTAINMENT MONITORING TO PROVIDE FAIL SAFE AND POSITIVE SHUT DOWN	23 CCR 16 2636(f)(5)
	H687	FAILURE TO CONTINUOUSLY MONITOR SECONDARY CONTAINMENT THAT ACTIVATES AN AUDIBLE/VISUAL ALARM	23 CCR 16 2636(f)(1)
	H705	FAILURE TO CHECK MONITORING SYSTEM DAILY TO MAINTAIN EMERGENCY GENERATOR LINE LEAK DETECTOR EXEMPTION	23 CCR 16 2636(f)(2), 2666(c)
	H712	FAILURE TO MAINTAIN SECONDARY CONTAINMENT TO ALLOW PRODUCT TO BE DETECTED AT THE EARLIEST POSSIBLE	23 CCR 16 2630(d), 2641(a)

Single Walled Tank Violations

V	Viol #	Summary	Code
	H685	FAILURE TO USE THE AUTOMATIC TANK GAUGE AND MANUAL INVENTORY RECONCILIATION FOR LOW VOLUME TANK TESTING	23 CCR 16 2643(b)(2)
	H688	FAILURE TO CONDUCT 0.2 GALLON/HOUR CONTINUOUS IN TANK LEAK DETECTION TEST MONTHLY AND DOCUMENT	23 CCR 16 2643(b)(5)
	H689	FAILURE TO CONDUCT 0.2 GALLON/HOUR IN TANK LEAK DETECTION TEST MONTHLY AND DOCUMENT	23 CCR 16 2643(b)(1)
	H692	FAILURE TO INSTALL AUTOMATIC TANK GAUGING/LEAK DETECTION	23 CCR 16 2643; HSC 6.7 25292(a)
	H701	FAILURE TO MAINTAIN/INSPECT CORROSION PROTECTION SYSTEM AS REQUIRED	23 CCR 16 2635(a)(2), 2662(c)(1)(B)
	H755	FAILURE TO INSTALL A FUNCTIONAL CORROSION PROTECTION	23 CCR 16 2635(a)(2)(A)
	H669	FAILURE TO RECERTIFY INTERIOR LINED TANKS AS REQUIRED	23 CCR 16 2663
	H671	FAILURE TO CONDUCT ENHANCED LEAK DETECTION TESTING AS REQUIRED	23 CCR 16 2644.1(a)(3)
	H672	FAILURE TO SUBMIT ENHANCED LEAK DETECTION TEST RESULTS AS REQUIRED	23 CCR 16 2644.1(a)(5)
	H749	FAILURE TO CORRECT ANY FAILURES DETECTED DURING ENHANCED LEAK DETECTION TESTING	HSC 6.7 25292.4(d), 25292.5(c)

Inspector: MARTY A BROWNFIELD

Inspection Date: 04/07/2015

Single Walled Piping Violations

V	Viol #	Summary	Code
	H703	FAILURE TO PERFORM MONTHLY 0.2 GALLON/HOUR OR ANNUAL 0.1 GALLON/HOUR LINE INTEGRITY TESTS	23 CCR 16 2641(a), 2643(c)
	H707	FAILURE OF THE LINE LEAK DETECTOR TO PROVIDE FAIL SAFE AND POSITIVE SHUT DOWN	23 CCR 16 2666(c)

On Site Records Violations

V	Viol #	Summary	Code
	H652	FAILURE TO OBTAIN/MAINTAIN A VALID BOARD OF EQUALIZATION ACCOUNT NUMBER	HSC 6.7 25286(c)
	H661	FAILURE TO NOTIFY THE CUPA OF A CHANGE IN DESIGNATED OPERATOR	23 CCR 16 2715(a)
✓	H724	FAILURE TO SUBMIT/MAINTAIN A CURRENT CERTIFICATION OF FINANCIAL RESPONSIBILITY	23 CCR 16 2711; 23 CCR 18 2808.1, 2809-2809.2; HSC 6.7 25292.2; HSC 6.75 25299.30-25299.34
	H726	FAILURE TO MAINTAIN COPIES OF DESIGNATED OPERATOR'S INSPECTION REPORTS AND LIST OF TRAINED EMPLOYEES	23 CCR 16 2715
	H727	FAILURE OF DESIGNATED OPERATOR TO COMPLY WITH ALL MONTHLY INSPECTION REQUIREMENTS	23 CCR 16 2715
	H729	FAILURE TO MAINTAIN ALARM LOGS AND FOLLOW-UP DOCUMENTATION	23 CCR 16 2632, 2634, 2712(b)
	H731	FAILURE OF DESIGNATED OPERATOR TO PROVIDE APPROPRIATE EMPLOYEE TRAINING	23 CCR 16 2715(c)(6), 2715(f)
	H736	FAILURE TO MAINTAIN MONITORING, MAINTENANCE, AND REPAIR RECORDS	23 CCR 16 2712(b)
	H737	FAILURE TO MAINTAIN CORROSION PROTECTION RECORDS	23 CCR 16 2635, 2712(b)
	H738	FAILURE TO MAINTAIN AN APPROVED MONITORING PLAN ON SITE	23 CCR 16 2632, 2634, 2711, 2712(i)
	H739	FAILURE TO SUBMIT/MAINTAIN A WRITTEN OWNER/OPERATOR AGREEMENT	23 CCR 16 2620(b); HSC 6.7 25284(a){3}
	H740	FAILURE TO RECORD AND/OR REPORTSUSPECTED OR ACTUAL UNAUTHORIZED RELEASE CORRECTLY	HSC 6.7 29294, 29295

Inspector: MARTY A BROWNFIELD

Inspection Date: 04/07/2015

SUMMARY OF OBSERVATIONS/VIOLATIONS

- No violations of underground storage tank laws/regulations were discovered. KERN CUPA greatly appreciates your efforts to comply with all the laws and regulations applicable to your facility.
- Violations were observed/discovered as listed below. All violations must be corrected by implementing the corrective action listed by each violation. If you disagree with any of the violations or corrective actions required, please inform the CUPA in writing.

ALL VIOLATIONS MUST BE CORRECTED WITHIN 30 DAYS OR AS SPECIFIED. CUPA must be informed in writing with a certification that compliance has been achieved. A false statement that compliance has been achieved is a violation of the law and punishable by a fine of not less than \$2,000 or more than \$25,000 for each violation. Your facility may be reinspected any time during normal business hours. If a second reinspection becomes necessary due to non compliance, a reinspection charge of \$100.00 per hour may be charged to the facility.

You may request a meeting with the Program Manager to discuss the inspection findings and/or the proposed corrective actions. The issuance of this Summary of Violations does not preclude the CUPA from taking administrative, civil, or criminal action.

VIOLATIONS

Violation Number	Violation Text	Violation Degree	Comply by
H651	Failure to prepare, maintain, and submit accurate CUPA UST Operating Permit Application for Facility information and/or Tank information. 23 CCR 16 2711; HSC 6.7 25286(a)	CLASS II VIOLATION	05/07/2015
Violation Details & Corrective Action Required:	<i>USING THE INFORMATION PROVIDED BY LAUREL FUNK, PLEASE COMPLETE AND RE-SUBMIT YOUR UST OPERATOR APPLICATION AND FORMS INTO THE CALIFORNIA ENVIRONMENTAL REPORTING SYSTEM (CERS). THIS INCLUDES: 1.) UST TANK INFORMATION 2.) UST MONITORING PLAN</i>		
H653	Failure to submit statement of UST compliance and/or Designated Operator current certification. 23 CCR 16 2715(a), 2715(b)	CLASS II VIOLATION	05/07/2015
Violation Details & Corrective Action Required:	<i>USING THE FORM PROVIDED BY LAUREL FUNK, PLEASE COMPLETE AND RE-SUBMIT YOUR DESIGNATED OPERATOR FORM INTO THE CALIFORNIA ENVIRONMENTAL REPORTING SYSTEM (CERS).</i>		
H724	Failure to submit and maintain complete and current Certification of Financial Responsibility or other mechanism of financial assurance. 23 CCR 16 2711; 23 CCR 18 2808.1, 2809-2809.2; HSC 6.7 25292.2; HSC 6.75 25299.30-25299.34	CLASS II VIOLATION	05/07/2015
Violation Details & Corrective Action Required:	<i>USING THE INFORMATION PROVIDED BY LAUREL FUNK, PLEASE COMPLETE AND RE-SUBMIT THE FOLLOWING DOCUMENTS REGARDING THE UST FINANCIAL RESPONSIBILITY INTO THE CALIFORNIA ENVIRONMENTAL REPORTING SYSTEM (CERS). 1.) CERTIFICATE OF FINANCIAL RESPONSIBILITY 2.) CHIEF FINANCIAL OFFICER'S LETTER</i>		

INSPECTION COMMENTS:

THIS WAS A PAPERWORK ONLY INSPECTION - ANNUAL MONITORING CERT WAS COMPLETED ON FEBRUARY 23, 2015 BY BRANDON MASON WITH RICH ENVIRONMENTAL

Inspector: MARTY A BROWNFIELD

Inspection Date: 04/07/2015

COMMENTS: Go to <http://www.co.kern.ca.us/eh/> (Hazardous Materials) for forms and information.



Inspector: MARTY A BROWNFIELD

Signature of Facility Representative:

Inspection Date: 04/07/2015

Certification: I certify under penalty of perjury that this facility has complied with the corrective actions listed on this inspection form.

Printed Name of Owner/Operator

Title

Signature of Owner/Operator

Date

CERTIFIED UNIFIED PROGRAM AGENCY PERMIT

KERN COUNTY PUBLIC HEALTH SERVICES DEPARTMENT ENVIRONMENTAL HEALTH SERVICE DIVISION

2700 M ST, SUITE 300, BAKERSFIELD, CA 93301

(661) 862-8740 www.co.kern.ca.us/eh e-mail: hazmatprogram@co.kern.ca.us

REGULATED FACILITY:

JOHNNY QUIK #143
2126 TAFT HWY
BAKERSFIELD CA 93313

IDENTIFICATION NUMBERS:

FACILITY ID: FA0002691
CERS ID: 10233775

OWNER(S) OF RECORD:

KULJIT SINGH GHUMAN

General Health Program

BUS PLAN MED LOW RISK 1 UNIT
UNDERGROUND STORAGE TANK PROGRAM

Permit

0000313
0013545

Additional Information

PIP*

Effective Thru

06/30/2017
02/28/2017

STATE UST ID#

15-010-002691-0001
15-010-002691-0002
15-010-002691-0003

SIZE(GAL)

10,000
10,000
10,000

CONTENTS

REGULAR UNLEADED
PREMIUM UNLEADED
DIESEL



Permit Issued: 3/1/2015

UST Permit Expiration Date: 02/28/2016

Matthew Constantine
Public Health Services Director

This ENVIRONMENTAL HEALTH PERMIT is issued to the owner(s) and establishment shown above subject to compliance with all applicable laws and regulations. Permit is valid unless revoked or suspended for violation of applicable laws and regulations.

The underground storage tank portion of this permit must be renewed by: 02/28/2016

PERMIT IS NON-TRANSFERABLE AND MUST BE PROMINENTLY DISPLAYED IN THE PLACE OF BUSINESS

* **PIP - Performance Incentive Program** is a voluntary program for facilities that handle extremely hazardous material(s).

KULJIT SINGH GHUMAN
KULJIT SINGH GHUMAN
2126 TAFT HWY
BAKERSFIELD, CA 93313

Underground Storage Tank Facilities:

1. The permit holder shall comply with the monitoring, response, and plot plans as submitted in the California Environmental Reporting System (CERS) and accepted by this Division. The underground storage tank facility must also be monitored according to all the applicable requirements in the California Code of Regulations, Title 23, Division 3, Chapter 16.
2. A copy of the facility's underground storage tank leak prevention monitoring program (including facility form, tank form, monitoring plan, response plan, and plot plan), as accepted by this Division, must be accessible at the facility, either electronically or hard copy.
3. Monitoring of the tank system(s) shall be according to the Monitoring Plan(s) as submitted in CERS and accepted by this Division.
4. Monitor panel shall be inspected daily. Inspections shall be documented and maintained on site.
5. The underground storage tank system shall be operated and maintained in accordance with the manufacturer's instructions, including routine maintenance and service checks (at least once per year) for operability or running condition. Other testing shall be performed as required in the accepted monitoring plan in CERS.
6. Reports (ie. Monitoring System Certification) documenting any maintenance, testing, monitoring, and/or changes to the underground storage tanks shall be submitted to this Division within 30 days of testing and/or changes.
7. The facility owner/operator shall ensure that the facility has adequate financial responsibility insurance coverage, as mandated for all underground storage tanks, and supply proof of such coverage electronically in CERS.
8. The owner and/or operator must report any significant unauthorized release from underground storage tanks to this Division within 24 hours of discovery.
9. The underground storage tank permit will be renewed once compliance with all of the above conditions is verified and an onsite inspection is completed by this Division.

60297

MONITORING SYSTEM CERTIFICATION

For Use By All Jurisdictions Within the State of California

Authority Cited: Chapter 6.7, Health and Safety Code; Chapter 16, Division 3, Title 23, California Code of Regulations

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

A. General Information

Facility Name: JOHNNY QUICK Bldg. No.: _____
 Site Address: 2126 TAFT HWY City: BAKERSFIELD Zip: 93313
 Facility Contact Person: MR. KOOL Contact Phone No.: (661) 834-9113
 Make/Model of Monitoring System: TLS-350 Date of Testing/Service: 2/23/2015

B. Inventory of Equipment Tested/Certified

Check the appropriate boxes to indicate specific equipment inspected/serviced:

Tank ID: REG87 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: PREM91 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Tank ID: DIESEL <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input type="checkbox"/> Annular Space or Vault Sensor. Model: _____ <input type="checkbox"/> Piping Sump / Trench Sensor(s). Model: _____ <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Dispenser ID: 1/2 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 3/4 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: 5/6 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 7/8 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply):
 System set-up Alarm history report

Technician Name (print): BRANDON MASON Signature: _____
 Certification No.: 5284980-UT / B34335 License No.: C61/ D40 A HAZ 809850
 Testing Company Name: RICH ENVIRONMENTAL Phone No.: (661) 392-8687
 Testing Company Address: 5643 BROOKS CT. BAKERSFIELD, CA 93308 Date of Testing/Service: 2/23/2015

Monitoring System Certification

D. Results of Testing/Serviceing

Software Version Installed: 332.00

Complete the following checklist:

Table with 3 columns: Yes/No checkboxes, Yes/No/N/A checkboxes, and descriptive questions about alarm functionality, sensor installation, and equipment replacement.

* In Section E below, describe how and when these deficiencies were or will be corrected.

E. Comments:

Series of horizontal lines provided for handwritten comments.



Monitoring System Certification

F. In-Tank Gauging / SIR Equipment:

- Check this box if tank gauging is used only for inventory control.
- Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all tank gauging probes visually inspected for damage and residue buildup?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system product level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system water level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all probes reinstalled properly?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

G. Line Leak Detectors (LLD):

- Check this box if LLDs are not installed.

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For equipment start-up or annual equipment certification, was a leak simulated to verify LLD performance? (Check all that apply) Simulated leak rate: <input checked="" type="checkbox"/> 3 g.p.h.; <input type="checkbox"/> 0.1 g.p.h.; <input type="checkbox"/> 0.2 g.p.h.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all LLDs confirmed operational and accurate within regulatory requirements?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was the testing apparatus properly calibrated?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

H. Comments: _____



Monitoring System Certification Form: Addendum for Vacuum/Pressure Interstitial Sensors

I. Results of Vacuum/Pressure Monitoring Equipment Testing

This page should be used to document testing and servicing of vacuum and pressure interstitial sensors. A copy of this form must be included with the Monitoring System Certification Form, which must be provided to the tank system owner/operator. The owner/operator must submit a copy of the Monitoring System Certification Form to the local agency regulating UST systems within 30 days of test date.

Manufacturer: N/A	Model:	System Type: <input type="checkbox"/> Pressure; <input type="checkbox"/> Vacuum
Sensor ID		
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
How was interstitial communication verified?		
<input type="checkbox"/> Leak Introduced at Far End of Interstitial Space; ¹ <input type="checkbox"/> Gauge; <input type="checkbox"/> Visual Inspection; <input type="checkbox"/> Other (Describe in Sec. J, below)		
Was vacuum/pressure restored to operating levels in all interstitial spaces? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no, describe in Sec. J, below)		


J. Comments: N/A

¹ If the sensor successfully detects a simulated vacuum/pressure leak introduced in the interstitial space at the furthest point from the sensor, vacuum/pressure has been demonstrated to be communicating throughout the interstice.

Monitoring System Certification

UST Monitoring Site Plan

Site Address: 2126 TAFT HWY. BAKERSFIELD, CA.



Date map was drawn: 2/14/2013.

Instructions

If you already have a diagram that shows all required information, you may include it, rather than this page, with your Monitoring System Certification. On your site plan, show the general layout of tanks and piping. Clearly identify locations of the following equipment, if installed: monitoring system control panels; sensors monitoring tank annular spaces, sumps, dispenser pans, spill containers, or other secondary containment areas; mechanical or electronic line leak detectors; and in-tank liquid level probes (if used for leak detection). In the space provided, note the date this Site Plan was prepared.

RICH ENVIRONMENTAL
 5643 BROOKS CT. BAKERSFIELD, CA. 93308
 OFFICE (661)392-8687 FAX (661)392-0621
PRODUCT LINE LEAK DETECTOR TEST

WORK SHEET

W/O#: _____

FACILITY NAME: JOHNNY QUICK

FACILITY ADDRESS: 2126 TAFT HWY. BAKERSFIELD

PRODUCT LINE TYPE: PRESSURE

PRODUCT	LEAK DETECTOR TYPE SERIAL NUMBER	TEST BELOW 3 G.P.H.	TRIP P.S.I.	PASS OR FAIL
REG87	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>2347</u>	YES	10	PASS
PREM91	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>1262</u>	YES	10	PASS
DIESEL	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>3246</u>	YES	10	PASS
	L/D TYPE : <u> </u> SERIAL # <u> </u>	YES		PASS
		NO		FAIL

I CERTIFY THE ABOVE TESTS WERE CONDUCTED ON THIS DATE ACCORDING TO RED JACKET PUMPS FIELD TEST APPARATUS TESTING PROCEDURE AND LIMITATIONS. THE MECHANICAL LEAK DETECTOR TEST PASS / FAIL IS DETERMINED BY USING A LOW FLOW THRESHOLD TRIP RATE OF 3 GALLONS PER HOUR OR LESS AT 10 P.S.I. I ACKNOWLEDGE THAT ALL DATA COLLECTED IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE.

TECHNICIAN: BRANDON MASON

SIGNATURE: _____

DATE: 2/23/15

Spill Bucket Testing Report Form

This form is intended for use by contractors performing annual testing of UST spill containment structures. The completed form and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: JOHNNY QUICK	Date of Testing: 2/23/15
Facility Address: 2126 TAFT HWY. BAKERSFIELD	
Facility Contact: MR. KOOL	Phone: (661) 834-9113
Date Local Agency Was Notified of Testing : 1/14/15	
Name of Local Agency Inspector (if present during testing): MARTY	

2. TESTING CONTRACTOR INFORMATION

Company Name: RICH ENVIRONMENTAL
Technician Conducting Test: BRANDON MASON
Credentials ¹ : <input type="checkbox"/> CSLB Contractor <input checked="" type="checkbox"/> ICC Service Tech. <input type="checkbox"/> SWRCB Tank Tester <input type="checkbox"/> Other (Specify)
License Number(s): 5284980-UT


3. SPILL BUCKET TESTING INFORMATION

Test Method Used: <input checked="" type="checkbox"/> Hydrostatic <input type="checkbox"/> Vacuum <input type="checkbox"/> Other				
Test Equipment Used: VISUAL Equipment Resolution: 0.00				
Identify Spill Bucket (By Tank Number, Stored Product, etc.)	1 REG87-FILL	2 PREM91-FILL	3 DIESEL	4
Bucket Installation Type:	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump
Bucket Diameter:	12"	12"	12"	
Bucket Depth:	12"	12"	12"	
Wait time between applying vacuum/water and start of test:	30MIN	30MIN	30MIN	
Test Start Time (T _I):	9:00	9:00	9:00	
Initial Reading (R _I):	10"	10"	10"	
Test End Time (T _F):	10:00	10:00	10:00	
Final Reading (R _F):	10"	10"	10"	
Test Duration (T _F - T _I):	60MIN	60MIN	60MIN	
Change in Reading (R _F - R _I):	0	0	0	
Pass/Fail Threshold or Criteria:	0	0	0	
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

I hereby certify that all the information contained in this report is true, accurate, and in full compliance with legal requirements.

Technician's Signature: 

Date: 2/23/15

¹ State laws and regulations do not currently require testing to be performed by a qualified contractor. However, local requirements may be more stringent.

VERSION 332.00
SOFTWARE# 346332-100-A
CREATED - 11.05.27.16.12

S-MODULE# 330160-004-a
SYSTEM FEATURES:
PERIODIC IN-TANK TESTS
ANNUAL IN-TANK TESTS
ISD/APM

SYSTEM SETUP

FEB 23 2015 11:04 AM

SYSTEM UNITS

U.S.
SYSTEM LANGUAGE
ENGLISH
SYSTEM DATE/TIME FORMAT
MON DD YYYY HH:MM:SS XM

JOHNNY QUICK 143
2126 TAFT HWY
BAKERSFIELD CA 93313
661-834-9113

SHIFT TIME 1 : 8:00 AM
SHIFT TIME 2 : DISABLED
SHIFT TIME 3 : DISABLED
SHIFT TIME 4 : DISABLED

TANK PER TST NEEDED WRN
DISABLED
TANK ANN TST NEEDED WRN
DISABLED

LINE RE-ENABLE METHOD
PASS LINE TEST

LINE PER TST NEEDED WRN
DISABLED
LINE ANN TST NEEDED WRN
DISABLED

PRINT TO VOLUMES
ENABLED

TEMP COMPENSATION
VALUE (DEG F) : 60.0
STICK HEIGHT OFFSET
DISABLED
ULLAGE: 90%

H-PROTOCOL DATA FORMAT
HEIGHT
DAYLIGHT SAVING TIME
ENABLED
START DATE
MAR WEEK 2 SUN
START TIME
2:00 AM
END DATE
NOV WEEK 1 SUN
END TIME
2:00 AM

RE-DIRECT LOCAL PRINTOUT
DISABLED

EURO PROTOCOL PREFIX
S.

COMMUNICATIONS SETUP

PORT SETTINGS:

COMM BOARD : 1 (EDIM)
RS-232 SECURITY
CODE : DISABLED

COMM BOARD : 2 (RS-232)
BAUD RATE : 9600
PARITY : NONE
STOP BIT : 1 STOP
DATA LENGTH: 8 DATA
RS-232 SECURITY
CODE : DISABLED

COMM BOARD : 3 (RS-232)
BAUD RATE : 1200
PARITY : ODD
STOP BIT : 1 STOP
DATA LENGTH: 7 DATA
RS-232 SECURITY
CODE : DISABLED

AUTO TRANSMIT SETTINGS:

AUTO LEAK ALARM LIMIT
DISABLED
AUTO HIGH WATER LIMIT
DISABLED
AUTO OVERFILL LIMIT
DISABLED
AUTO LOW PRODUCT
DISABLED
AUTO THEFT LIMIT
DISABLED
AUTO DELIVERY START
DISABLED
AUTO DELIVERY END
DISABLED
AUTO EXTERNAL INPUT ON
DISABLED
AUTO EXTERNAL INPUT OFF
DISABLED
AUTO SENSOR FUEL ALARM
DISABLED
AUTO SENSOR WATER ALARM
DISABLED
AUTO SENSOR OUT ALARM
DISABLED

RS-232 END OF MESSAGE
DISABLED

IN-TANK SETUP

T 1:UNL87
PRODUCT CODE : 1
THERMAL COEFF : .000700
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
9000
HIGH PRODUCT : 95%
9500
DELIVERY LIMIT : 10%
1000

LOW PRODUCT : 1000
LEAK-ALARM-LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
1000

LEAK MIN ANNUAL : 10%
1000

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

T 2:PREM91
PRODUCT CODE : 2
THERMAL COEFF : .000700
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
9000
HIGH PRODUCT : 95%
9500
DELIVERY LIMIT : 10%
1000

LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
: 1000

LEAK MIN ANNUAL : 10%
: 1000

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

T 3:DIESEL
PRODUCT CODE : 3
THERMAL COEFF : .000450
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
9000
HIGH PRODUCT : 95%
9500
DELIVERY LIMIT : 10%
1000

LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
: 1000

LEAK MIN ANNUAL : 10%
: 1000

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

LEAK TEST METHOD

TEST ON DATE : ALL TANK
MAY 27, 2011
START TIME : DISABLED
TEST RATE : 0.20 GAL/HR
DURATION : 2 HOURS

TST EARLY STOP:DISABLED

LEAK TEST REPORT FORMAT
NORMAL

LIQUID SENSOR SETUP

L 1:87 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE


L 2:91 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 3:DSL ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 4:87 STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 5:91 STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 6:DSL STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

60297 

ALARM HISTORY REPORT

R 1:87
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 1

LIQUID SENSOR ALMS
L 1:FUEL ALARM
L 4:FUEL ALARM
L 1:SENSOR OUT ALARM
L 4:SENSOR OUT ALARM

ISD SITE ALARMS
ISD GROSS PRES FAIL
ISD DEGRD PRES FAIL
ISD VAPOR LEAK FAIL
ISD VP PRES FAIL
ISD VP STATUS FAIL

ISD HOSE ALARMS
ALL:FLOW COLLECT FAIL

R 2:91
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 2

LIQUID SENSOR ALMS
L 2:FUEL ALARM
L 5:FUEL ALARM
L 2:SENSOR OUT ALARM
L 5:SENSOR OUT ALARM

ISD SITE ALARMS
ISD GROSS PRES FAIL
ISD VAPOR LEAK FAIL
ISD VP PRES FAIL
ISD VP STATUS FAIL

ISD HOSE ALARMS
ALL:FLOW COLLECT FAIL

R 3:DSL
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 3

LIQUID SENSOR ALMS
L 3:FUEL ALARM
L 6:FUEL ALARM
L 3:SENSOR OUT ALARM
L 6:SENSOR OUT ALARM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 1:87 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 23, 2015 9:55 AM

FUEL ALARM
FEB 23, 2015 9:44 AM

FUEL ALARM
FEB 21, 2014 10:24 AM

* * * * * END * * * * *

ALARM HISTORY REPORT

60297

----- SENSOR ALARM -----
L 4:87 STP
STP SUMP
SENSOR OUT ALARM
FEB 23, 2015 9:55 AM

FUEL ALARM
FEB 23, 2015 9:39 AM

SENSOR OUT ALARM
FEB 21, 2014 10:24 AM

* * * * * END * * * * *

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 2:91 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 23, 2015 9:55 AM

FUEL ALARM
FEB 23, 2015 9:46 AM

FUEL ALARM
FEB 21, 2014 10:24 AM

* * * * * END * * * * *

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 5:91 STP
STP SUMP
SENSOR OUT ALARM
FEB 23, 2015 9:55 AM

FUEL ALARM
FEB 23, 2015 9:38 AM

FUEL ALARM
MAR 11, 2014 3:24 PM

* * * * * END * * * * *

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 3:DSL ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 23, 2015 9:55 AM

FUEL ALARM
FEB 23, 2015 9:48 AM

FUEL ALARM
FEB 21, 2014 10:24 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 6:DSL STP
STP SUMP
SENSOR OUT ALARM
FEB 23, 2015 9:55 AM

FUEL ALARM
FEB 23, 2015 9:38 AM

SENSOR OUT ALARM
FEB 21, 2014 10:24 AM

60297
/

MONITOR CERT. FAILURE REPORT

SITE NAME: JOHNNY QUICK **DATE:** 2/23/15

ADDRESS: 2126 TAFT HWY **TECHNICIAN:** BRANDON MASON

CITY: BAKERSFIELD **SIGNATURE:** 

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS: NONE

LABOR: NONE

PARTS INSTALLED: NONE

NAME: _____ **TITLE:** _____

SIGNATURE: _____

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENENCE.



MATTHEW CONSTANTINE, DIRECTOR
PUBLIC HEALTH SERVICES

ENVIRONMENTAL HEALTH DIVISION

2700 M STREET, SUITE 300, BAKERSFIELD, CA 93301-2370
VOICE: (661) 862-8740 FAX: (661) 862-8701
Web: www.co.kern.ca.us/eh E-mail: eh@co.kern.ca.us

"ONE VOICE"



CLAUDIA JONAH, MD
PUBLIC HEALTH OFFICER

CERTIFIED UNIFIED PROGRAM AGENCY (CUPA) HAZARDOUS MATERIAL INSPECTION FORM

Report Date: 02/15/2013

Facility ID: FA0002691

File #: 003201

Facility Name: JOHNNY QUIK #143				Inspection Type <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint	
Site Address: 2126 TAFT HWY BAKERSFIELD, CA 93313					
Phone: (661)834-9113					
PROGRAMS INSPECTED:	<input type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input checked="" type="checkbox"/> UST	<input type="checkbox"/> APSA	
REINSPECTION REQUIRED:	<input type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input type="checkbox"/> UST	<input type="checkbox"/> APSA	

INSPECTOR: JEFFREY MARSHALL

INSPECTION DATE: 02/14/2013

FACILITY NAME: JOHNNY QUIK #143

ADDRESS: 2126 TAFT HWY
 BAKERSFIELD, CA
 93313

FA ID: FA0002691
 FILE ID: 003201

VIOLATION	VIOLATION NUMBER	UNDERGROUND STORAGE TANK REQUIREMENTS
	UT01	Facility has a site certificate of financial responsibility for underground storage tanks on file with regulatory agency [HSC 25292.2(a)].
	UT02	Facility has an approved designated operator and that operator is performing the required inspections and training [Title 23, CCR 2715].
	UT03	Facility has a written monitoring and response plan for USTs on site and on file with regulatory agency [Title 23, CCR 2632(d)(1) & 2641(h)].
	UT05	Facility completed an annual monitoring system certification for an underground storage tank system and submitted it to the regulatory agency [Title 23, CCR 2630(d) 2641(j)].
	UT06	Cathodic protection systems for underground storage tank systems (where appropriate) certified every three years. Facility provided certification results to regulatory agency [Title 23, CCR 2635(a) 2662(b)].
✓	UT07	Secondary containment systems for underground storage tank systems tested every three years. Facility provided results to the agency [Title 23, CCR 2637(a)].
	UT08	Underground storage tank systems (with single walled components) within 1000' of a drinking well must be tested with enhanced leak detection methods (ELD) every three years. Facility provided results to regulatory agency [Title 23, CCR 2640(e) & 2644.1].
	UT11	Facility's underground storage tank monitoring system is functioning as designed [Title 23, CCR 2632].
	UT12	The underground storage system at the facility is monitored according to site's monitoring plan or permit [HSC 25293].
	UT13	Monitoring records for the underground storage tank system are available upon request [Title 23, CCR 2712(b)].
	UT14	Overspill and overflow equipment for underground storage tank(s) is present, properly installed, and functioning [Title 23, CCR 2635].
	UT16	Change of ownership or monitoring method reported to the permitting agency within 30 days of change [HSC 25284(c); Title 23, CCR 2712].
	UT22	Under Dispenser Containment (UDC) installed [HSC 25284.1 (a)(5)(c)].
	UT23	Under Dispenser Containment (UDC) has approved and functional monitoring equipment [Title 23, CCR 2636(f)(1) and (g)].
	UT24	Leak detection sensors are properly secured at lowest point in sumps and annular spaces [Title 23, CRR 2641(a)].
	UT25	Monitoring system shuts down the pump if a release is detected or the monitor fails or is disconnected [Positive Shut Down (PSD)]. Annual line integrity testing completed if no PSD [Title 23, CCR 2636(f)] .
	UT26	Automatic line leak detectors installed on pressurized piping that detects a 3.0 gph leak [Title 23, CCR 2636(f)(2)].
✓	UT27	Secondary containment and overspill containers are liquid/debris free [Title 23, CCR 2631(d)(4) & 2635(b)(1)].

INSPECTOR: JEFFREY MARSHALL

INSPECTION DATE: 02/14/2013

VIOLATION	VIOLATION NUMBER	UNDERGROUND STORAGE TANK REQUIREMENTS (Continued)
	UT28	No liquid leaks visible [Title 23, CCR 2632].
	UT29	Fuel filters managed properly [HSC 25189(a)].
	UT30	Documentation of hazardous and designated waste disposal [Title 22, CCR 66262.23].

FACILITY NAME: JOHNNY QUIK #143

ADDRESS: 2126 TAFT HWY
BAKERSFIELD, CA
93313

FA ID: FA0002691
FILE ID: 003201

SUMMARY OF OBSERVATIONS/VIOLATIONS

- No violations of underground storage tank, hazardous materials, or hazardous waste laws/regulations were discovered. KERN CUPA greatly appreciates your efforts to comply with all the laws and regulations applicable to your facility.
- Violations were observed/discovered as listed below. All violations must be corrected by implementing the corrective action listed by each violation. If you disagree with any of the violations or corrective actions required, please inform the CUPA in writing.

ALL VIOLATIONS MUST BE CORRECTED WITHIN 30 DAYS OR AS SPECIFIED. CUPA must be informed in writing with a certification that compliance has been achieved. A false statement that compliance has been achieved is a violation of the law and punishable by a fine of not less than \$2,000 or more than \$25,000 for each violation. Your facility may be reinspected any time during normal business hours. If a second reinspection becomes necessary due to non compliance, a reinspection charge of \$100.00 per hour may be charged to the facility.

You may request a meeting with the Program Manager to discuss the inspection findings and/or the proposed corrective actions. The issuance of this Summary of Violations does not preclude the CUPA from taking administrative, civil, or criminal action.

VIOLATIONS

VIOLATION #	DEGREE OF VIOLATION	CORRECTIVE ACTION REQUIRED
UT27	CLASS II VIOLATION	Clean out containment and properly handle any hazardous waste. LIQUID WAS OBSERVED IN THE UNDER DISPENSER CONTAINMENT (UDC) FOR DISPENSER #5/6 AND IN THE DIESEL TURBINE SUMP. THE ON-SITE SERVICE TECHNICIAN REMOVED AND DISPOSED OF ALL LIQUID.

INSPECTOR: JEFFREY MARSHALL

INSPECTION DATE: 02/14/2013

UT07

CLASS II
VIOLATION

Test secondary containment system or if recently tested provide written results to regulatory agency.

A SECONDARY CONTAINMENT TEST (SB 989) WAS CONDUCTED AT THE FACILITY ON JUNE 19, 2012. FAILURES WERE OBSERVED FOR THE 87 OCTANE, 91 OCTANE AND DIESEL SECONDARY PIPING; THE 87 OCTANE AND 91 OCTANE TURBINE SUMP; AND THE UNDER DISPENSER CONTAINMENT #3/4. AN UNDERGROUND STORAGE TANK MODIFICATION PERMIT WAS ISSUED TO THE FACILITY ON NOVEMBER 01, 2012 AND A PRODUCT LINE TEST WAS CONDUCTED ON DECEMBER 04, 2012. THESE FAILURES HAVE NOT BEEN CORRECTED AND THE MODIFICATION PERMIT EXPIRES ON MAY 01, 2013.

INSPECTION COMMENTS:

AN INSPECTION WAS CONDUCTED AT THE FACILITY ON FEBRUARY 14, 2013. FOR ANY QUESTIONS, PLEASE CONTACT JEFFREY MARSHALL AT 1-661-862-8775.

COMMENTS: Go to <http://www.co.kern.ca.us/eh/cupaprogram.asp> for forms and information.

INSPECTOR: JEFFREY MARSHALL

SIGNATURE OF FACILITY REP:

INSPECTION DATE: 02/14/2013

FA ID: FA0002691

FACILITY NAME: JOHNNY QUIK #143

FILE ID: 003201

Certification: I certify under penalty of perjury that this facility has complied with the corrective actions listed on this inspection form.

Printed Name of Owner/Operator

Title

Signature of Owner/Operator

Date



MATTHEW CONSTANTINE, DIRECTOR
PUBLIC HEALTH SERVICES

ENVIRONMENTAL HEALTH DIVISION

2700 M STREET, SUITE 300, BAKERSFIELD, CA 93301-2370
VOICE: (661) 862-8740 FAX: (661) 862-8701
Web: www.co.kern.ca.us/eh E-mail: eh@co.kern.ca.us

"ONE VOICE"



CLAUDIA JONAH, MD
PUBLIC HEALTH OFFICER

CERTIFIED UNIFIED PROGRAM AGENCY (CUPA) HAZARDOUS MATERIAL INSPECTION FORM

Report Date: 02/15/2013

Facility ID: FA0002691

File #: 003201

Facility Name: JOHNNY QUIK #143				<u>Inspection Type</u> <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint	
Site Address: 2126 TAFT HWY BAKERSFIELD, CA 93313					
Phone: (661)834-9113					
PROGRAMS INSPECTED:	<input type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input checked="" type="checkbox"/> UST	<input type="checkbox"/> APSA	
REINSPECTION REQUIRED:	<input type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input type="checkbox"/> UST	<input type="checkbox"/> APSA	

INSPECTOR: JEFFREY MARSHALL

INSPECTION DATE: 02/14/2013

FACILITY NAME: JOHNNY QUIK #143

ADDRESS: 2126 TAFT HWY
 BAKERSFIELD, CA
 93313

FA ID: FA0002691
 FILE ID: 003201

VIOLATION	VIOLATION NUMBER	UNDERGROUND STORAGE TANK REQUIREMENTS
	UT01	Facility has a site certificate of financial responsibility for underground storage tanks on file with regulatory agency [HSC 25292.2(a)].
	UT02	Facility has an approved designated operator and that operator is performing the required inspections and training [Title 23, CCR 2715].
	UT03	Facility has a written monitoring and response plan for USTs on site and on file with regulatory agency [Title 23, CCR 2632(d)(1) & 2641(h)].
	UT05	Facility completed an annual monitoring system certification for an underground storage tank system and submitted it to the regulatory agency [Title 23, CCR 2630(d) 2641(j)].
	UT06	Cathodic protection systems for underground storage tank systems (where appropriate) certified every three years. Facility provided certification results to regulatory agency [Title 23, CCR 2635(a) 2662(b)].
✓	UT07	Secondary containment systems for underground storage tank systems tested every three years. Facility provided results to the agency [Title 23, CCR 2637(a)].
	UT08	Underground storage tank systems (with single walled components) within 1000' of a drinking well must be tested with enhanced leak detection methods (ELD) every three years. Facility provided results to regulatory agency [Title 23, CCR 2640(e) & 2644.1].
	UT11	Facility's underground storage tank monitoring system is functioning as designed [Title 23, CCR 2632].
	UT12	The underground storage system at the facility is monitored according to site's monitoring plan or permit [HSC 25293].
	UT13	Monitoring records for the underground storage tank system are available upon request [Title 23, CCR 2712(b)].
	UT14	Overspill and overflow equipment for underground storage tank(s) is present, properly installed, and functioning [Title 23, CCR 2635].
	UT16	Change of ownership or monitoring method reported to the permitting agency within 30 days of change [HSC 25284(c); Title 23, CCR 2712].
	UT22	Under Dispenser Containment (UDC) installed [HSC 25284.1 (a)(5)(c)].
	UT23	Under Dispenser Containment (UDC) has approved and functional monitoring equipment [Title 23, CCR 2636(f)(1) and (g)].
	UT24	Leak detection sensors are properly secured at lowest point in sumps and annular spaces [Title 23, CRR 2641(a)].
	UT25	Monitoring system shuts down the pump if a release is detected or the monitor fails or is disconnected [Positive Shut Down (PSD)]. Annual line integrity testing completed if no PSD [Title 23, CCR 2636(f)] .
	UT26	Automatic line leak detectors installed on pressurized piping that detects a 3.0 gph leak [Title 23, CCR 2636(f)(2)].
✓	UT27	Secondary containment and overspill containers are liquid/debris free [Title 23, CCR 2631(d)(4) & 2635(b)(1)].

INSPECTOR: JEFFREY MARSHALL

INSPECTION DATE: 02/14/2013

VIOLATION	VIOLATION NUMBER	UNDERGROUND STORAGE TANK REQUIREMENTS (Continued)
	UT28	No liquid leaks visible [Title 23, CCR 2632].
	UT29	Fuel filters managed properly [HSC 25189(a)].
	UT30	Documentation of hazardous and designated waste disposal [Title 22, CCR 66262.23].

FACILITY NAME: JOHNNY QUIK #143

ADDRESS: 2126 TAFT HWY
BAKERSFIELD, CA
93313

FA ID: FA0002691
FILE ID: 003201

SUMMARY OF OBSERVATIONS/VIOLATIONS

- No violations of underground storage tank, hazardous materials, or hazardous waste laws/regulations were discovered. KERN CUPA greatly appreciates your efforts to comply with all the laws and regulations applicable to your facility.
- Violations were observed/discovered as listed below. All violations must be corrected by implementing the corrective action listed by each violation. If you disagree with any of the violations or corrective actions required, please inform the CUPA in writing.

ALL VIOLATIONS MUST BE CORRECTED WITHIN 30 DAYS OR AS SPECIFIED. CUPA must be informed in writing with a certification that compliance has been achieved. A false statement that compliance has been achieved is a violation of the law and punishable by a fine of not less than \$2,000 or more than \$25,000 for each violation. Your facility may be reinspected any time during normal business hours. If a second reinspection becomes necessary due to non compliance, a reinspection charge of \$100.00 per hour may be charged to the facility.

You may request a meeting with the Program Manager to discuss the inspection findings and/or the proposed corrective actions. The issuance of this Summary of Violations does not preclude the CUPA from taking administrative, civil, or criminal action.

VIOLATIONS

VIOLATION #	DEGREE OF VIOLATION	CORRECTIVE ACTION REQUIRED
UT27	CLASS II VIOLATION	Clean out containment and properly handle any hazardous waste. LIQUID WAS OBSERVED IN THE UNDER DISPENSER CONTAINMENT (UDC) FOR DISPENSER #5/6 AND IN THE DIESEL TURBINE SUMP. THE ON-SITE SERVICE TECHNICIAN REMOVED AND DISPOSED OF ALL LIQUID.

INSPECTOR: JEFFREY MARSHALL

INSPECTION DATE: 02/14/2013

UT07

CLASS II
VIOLATION

Test secondary containment system or if recently tested provide written results to regulatory agency.

A SECONDARY CONTAINMENT TEST (SB 989) WAS CONDUCTED AT THE FACILITY ON JUNE 19, 2012. FAILURES WERE OBSERVED FOR THE 87 OCTANE, 91 OCTANE AND DIESEL SECONDARY PIPING; THE 87 OCTANE AND 91 OCTANE TURBINE SUMP; AND THE UNDER DISPENSER CONTAINMENT #3/4. AN UNDERGROUND STORAGE TANK MODIFICATION PERMIT WAS ISSUED TO THE FACILITY ON NOVEMBER 01, 2012 AND A PRODUCT LINE TEST WAS CONDUCTED ON DECEMBER 04, 2012. THESE FAILURES HAVE NOT BEEN CORRECTED AND THE MODIFICATION PERMIT EXPIRES ON MAY 01, 2013.

INSPECTION COMMENTS:

AN INSPECTION WAS CONDUCTED AT THE FACILITY ON FEBRUARY 14, 2013. FOR ANY QUESTIONS, PLEASE CONTACT JEFFREY MARSHALL AT 1-661-862-8775.

COMMENTS: Go to <http://www.co.kern.ca.us/eh/cupaprogram.asp> for forms and information.

INSPECTOR: JEFFREY MARSHALL

SIGNATURE OF FACILITY REP:

INSPECTION DATE: 02/14/2013

FA ID: FA0002691

FACILITY NAME: JOHNNY QUIK #143

FILE ID: 003201

Certification: I certify under penalty of perjury that this facility has complied with the corrective actions listed on this inspection form.

Printed Name of Owner/Operator

Title

Signature of Owner/Operator

Date



MATTHEW CONSTANTINE, DIRECTOR
PUBLIC HEALTH SERVICES

ENVIRONMENTAL HEALTH

DIVISION

2700 M STREET, SUITE 300, BAKERSFIELD, CA 93301-2370

VOICE: (661) 862-8740 FAX: (661) 862-8701

Web: www.co.kern.ca.us/eh E-mail: eh@co.kern.ca.us

"ONE VOICE"



CLAUDIA JONAH, MD
PUBLIC HEALTH OFFICER

CERTIFIED UNIFIED PROGRAM AGENCY (CUPA) HAZARDOUS MATERIAL INSPECTION FORM

Report Date: 02/13/2012

Facility ID: FA0002691

File #: 003201

Facility Name: JOHNNY QUIK #143			Inspection Type <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint	
Site Address: 2126 TAFT HWY BAKERSFIELD, CA 93313				
Phone: (661)834-9113				
PROGRAMS INSPECTED:	<input checked="" type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input checked="" type="checkbox"/> UST	<input type="checkbox"/> APSA
REINSPECTION REQUIRED:	<input type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input type="checkbox"/> UST	<input type="checkbox"/> APSA

VIOLATION	VIOLATION NUMBER	BUSINESS PLAN REQUIREMENTS
	BP01	Inventory of hazardous materials is accurate, up to date, and complete [HSC 6.95, 25504, Title 19 CCR 2729].
	BP02	Site layout/facility maps are accurate [HSC 6.95,25504; Title 19 CCR 2729].
	BP03	Hazardous materials are stored in properly labeled and non-deteriorated containers [HSC 25124(b)(3)(A & B)].
	BP04	The hazardous materials inventory shall be submitted annually on or before March 1 [Title 19 CCR 2729.4(b)].
	ER01	Contingency Plan is complete, updated, and maintained on site [HSC 6.95, 25504; Title 19 CCR 2731 Title 22 CCR 66265.53-54].
	ER02	Facility is operated and maintained to prevent/mitigate fire, explosion, or release of hazardous material or waste which could threaten human health or the environment [Title 22 CCR 66265.31; Title 19 CCR 2731].
	ER03	Business has equipment required to, or appropriate for, safe handling of hazardous materials [Title 22 CCR 66265.32 & .34].
	TR01	Facility has a training program appropriate for the size and complexity of business and nature of hazardous materials handled [Title 19 CCR 2732; Title 22 CCR 66265.16].
	TR02	Training documentation is maintained on site for current personnel [Title 19 CCR 2732; Title 22 CCR 66265.16].

INSPECTOR: ALEXANDRA FRAIRE

INSPECTION DATE: 02/13/2012

FACILITY NAME: JOHNNY QUIK #143

ADDRESS: 2126 TAFT HWY
 BAKERSFIELD, CA
 93313

FA ID: FA0002691
 FILE ID: 003201

VIOLATION	VIOLATION NUMBER	UNDERGROUND STORAGE TANK REQUIREMENTS
	UT01	Facility has a site certificate of financial responsibility for underground storage tanks on file with regulatory agency [HSC 25292.2(a)].
	UT02	Facility has an approved designated operator and that operator is performing the required inspections and training [Title 23, CCR 2715].
	UT03	Facility has a written monitoring and response plan for USTs on site and on file with regulatory agency [Title 23, CCR 2632(d)(1) & 2641(h)].
	UT05	Facility completed an annual monitoring system certification for an underground storage tank system and submitted it to the regulatory agency [Title 23, CCR 2630(d) 2641(j)].
	UT06	Cathodic protection systems for underground storage tank systems (where appropriate) certified every three years. Facility provided certification results to regulatory agency [Title 23, CCR 2635(a) 2662(b)].
	UT07	Secondary containment systems for underground storage tank systems tested every three years. Facility provided results to the agency [Title 23, CCR 2637(a)].
	UT08	Underground storage tank systems (with single walled components) within 1000' of a drinking well must be tested with enhanced leak detection methods (ELD) every three years. Facility provided results to regulatory agency [Title 23, CCR 2640(e) & 2644.1].
	UT11	Facility's underground storage tank monitoring system is functioning as designed [Title 23, CCR 2632].
	UT12	The underground storage system at the facility is monitored according to site's monitoring plan or permit [HSC 25293].
	UT13	Monitoring records for the underground storage tank system are available upon request [Title 23, CCR 2712(b)].
	UT14	Overspill and overfill equipment for underground storage tank(s) is present, properly installed, and functioning [Title 23, CCR 2635].
	UT16	Change of ownership or monitoring method reported to the permitting agency within 30 days of change [HSC 25284(c); Title 23, CCR 2712].
	UT22	Under Dispenser Containment (UDC) installed [HSC 25284.1 (a)(5)(c)].
	UT23	Under Dispenser Containment (UDC) has approved and functional monitoring equipment [Title 23, CCR 2636(f)(1) and (g)].
	UT24	Leak detection sensors are properly secured at lowest point in sumps and annular spaces [Title 23, CCR 2641(a)].
	UT25	Monitoring system shuts down the pump if a release is detected or the monitor fails or is disconnected [Positive Shut Down (PSD)]. Annual line integrity testing completed if no PSD [Title 23, CCR 2636(f)] .
	UT26	Automatic line leak detectors installed on pressurized piping that detects a 3.0 gph leak [Title 23, CCR 2636(f)(2)].
	UT27	Secondary containment and overspill containers are liquid/debris free [Title 23, CCR 2631(d)(4) & 2635(b)(1)].

INSPECTOR: ALEXANDRA FRAIRE

INSPECTION DATE: 02/13/2012

VIOLATION	VIOLATION NUMBER	UNDERGROUND STORAGE TANK REQUIREMENTS (Continued)
	UT28	No liquid leaks visible [Title 23, CCR 2632].
	UT29	Fuel filters managed properly [HSC 25189(a)].
	UT30	Documentation of hazardous and designated waste disposal [Title 22, CCR 66262.23].

FACILITY NAME: JOHNNY QUIK #143

ADDRESS: 2126 TAFT HWY
BAKERSFIELD, CA
93313

FA ID: FA0002691
FILE ID: 003201

SUMMARY OF OBSERVATIONS/VIOLATIONS

- No violations of underground storage tank, hazardous materials, or hazardous waste laws/regulations were discovered. KERN CUPA greatly appreciates your efforts to comply with all the laws and regulations applicable to your facility.
- Violations were observed/discovered as listed below. All violations must be corrected by implementing the corrective action listed by each violation. If you disagree with any of the violations or corrective actions required, please inform the CUPA in writing.

ALL VIOLATIONS MUST BE CORRECTED WITHIN 30 DAYS OR AS SPECIFIED. CUPA must be informed in writing with a certification that compliance has been achieved. A false statement that compliance has been achieved is a violation of the law and punishable by a fine of not less than \$2,000 or more than \$25,000 for each violation. Your facility may be reinspected any time during normal business hours. If a second reinspection becomes necessary due to non compliance, a reinspection charge of \$100.00 per hour may be charged to the facility.

You may request a meeting with the Program Manager to discuss the inspection findings and/or the proposed corrective actions. The issuance of this Summary of Violations does not preclude the CUPA from taking administrative, civil, or criminal action.

VIOLATIONS

VIOLATION #	DEGREE OF VIOLATION	CORRECTIVE ACTION REQUIRED

INSPECTION COMMENTS:

PLEASE CALL ME AT (661) 862-8727 IF YOU HAVE ANY QUESTIONS REGARDING THIS REPORT.

COMMENTS: Go to <http://www.co.kern.ca.us/eh/cupaprogram.asp> for forms and information.

INSPECTOR: ALEXANDRA FRAIRE
INSPECTION DATE: 02/13/2012

SIGNATURE OF FACILITY REP:

Certification: I certify under penalty of perjury that this facility has complied with the corrective actions listed on this inspection form.

Printed Name of Owner/Operator

Title

Signature of Owner/Operator

Date



MATTHEW CONSTANTINE, DIRECTOR
PUBLIC HEALTH SERVICES

ENVIRONMENTAL HEALTH DIVISION

2700 M STREET, SUITE 300, BAKERSFIELD, CA 93301-2370
VOICE: (661) 862-8740 FAX: (661) 862-8701
Web: www.co.kern.ca.us/eh E-mail: eh@co.kern.ca.us
"ONE VOICE"



CLAUDIA JONAH, MD
PUBLIC HEALTH OFFICER

CERTIFIED UNIFIED PROGRAM AGENCY (CUPA) HAZARDOUS MATERIAL INSPECTION FORM

Report Date: 04/28/2011

Facility ID: FA0002691

File #: 003201

Facility Name: JOHNNY QUIK #143			Inspection Type <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint	
Site Address: 2126 TAFT HWY BAKERSFIELD, CA 93313				
Phone: (661)834-9113				
PROGRAMS INSPECTED:	<input type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input checked="" type="checkbox"/> UST	<input type="checkbox"/> APSA
REINSPECTION REQUIRED:	<input type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input type="checkbox"/> UST	<input type="checkbox"/> APSA

INSPECTOR: LYDIA VON SYDOW

INSPECTION DATE: 04/27/2011

FACILITY NAME: JOHNNY QUIK #143

ADDRESS: 2126 TAFT HWY
 BAKERSFIELD, CA
 93313

FA ID: FA0002691
 FILE ID: 003201

VIOLATION	VIOLATION NUMBER	UNDERGROUND STORAGE TANK REQUIREMENTS
	UT01	Facility has a site certificate of financial responsibility for underground storage tanks on file with regulatory agency [HSC 25292.2(a)].
	UT02	Facility has an approved designated operator and that operator is performing the required inspections and training [Title 23, CCR 2715].
	UT03	Facility has a written monitoring and response plan for USTs on site and on file with regulatory agency [Title 23, CCR 2632(d)(1) & 2641(h)].
	UT05	Facility completed an annual monitoring system certification for an underground storage tank system and submitted it to the regulatory agency [Title 23, CCR 2630(d) 2641(j)].
	UT06	Cathodic protection systems for underground storage tank systems (where appropriate) certified every three years. Facility provided certification results to regulatory agency [Title 23, CCR 2635(a) 2662(b)].
	UT07	Secondary containment systems for underground storage tank systems tested every three years. Facility provided results to the agency [Title 23, CCR 2637(a)].
	UT08	Underground storage tank systems (with single walled components) within 1000' of a drinking well must be tested with enhanced leak detection methods (ELD) every three years. Facility provided results to regulatory agency [Title 23, CCR 2640(e) & 2644.1].
	UT11	Facility's underground storage tank monitoring system is functioning as designed [Title 23, CCR 2632].
	UT12	The underground storage system at the facility is monitored according to site's monitoring plan or permit [HSC 25293].
	UT13	Monitoring records for the underground storage tank system are available upon request [Title 23, CCR 2712(b)].
	UT14	Overspill and overfill equipment for underground storage tank(s) is present, properly installed, and functioning [Title 23, CCR 2635].
	UT16	Change of ownership or monitoring method reported to the permitting agency within 30 days of change [HSC 25284(c); Title 23, CCR 2712].
	UT22	Under Dispenser Containment (UDC) installed [HSC 25284.1 (a)(5)(c)].
	UT23	Under Dispenser Containment (UDC) has approved and functional monitoring equipment [Title 23, CCR 2636(f)(1) and (g)].
	UT24	Leak detection sensors are properly secured at lowest point in sumps and annular spaces [Title 23, CCR 2641(a)].
	UT25	Monitoring system shuts down the pump if a release is detected or the monitor fails or is disconnected [Positive Shut Down (PSD)]. Annual line integrity testing completed if no PSD [Title 23, CCR 2636(f)].
	UT26	Automatic line leak detectors installed on pressurized piping that detects a 3.0 gph leak [Title 23, CCR 2636(f)(2)].
	UT27	Secondary containment and overspill containers are liquid/debris free [Title 23, CCR 2631(d)(4) & 2635(b)(1)].

INSPECTOR: LYDIA VON SYDOW

INSPECTION DATE: 04/27/2011

VIOLATION	VIOLATION NUMBER	UNDERGROUND STORAGE TANK REQUIREMENTS (Continued)
	UT28	No liquid leaks visible [Title 23, CCR 2632].
	UT29	Fuel filters managed properly [HSC 25189(a)].
	UT30	Documentation of hazardous and designated waste disposal [Title 22, CCR 66262.23].

FACILITY NAME: JOHNNY QUIK #143

ADDRESS: 2126 TAFT HWY
BAKERSFIELD, CA
93313

FA ID: FA0002691
FILE ID: 003201

SUMMARY OF OBSERVATIONS/VIOLATIONS

- No violations of underground storage tank, hazardous materials, or hazardous waste laws/regulations were discovered. KERN CUPA greatly appreciates your efforts to comply with all the laws and regulations applicable to your facility.
- Violations were observed/discovered as listed below. All violations must be corrected by implementing the corrective action listed by each violation. If you disagree with any of the violations or corrective actions required, please inform the CUPA in writing.

ALL VIOLATIONS MUST BE CORRECTED WITHIN 30 DAYS OR AS SPECIFIED. CUPA must be informed in writing with a certification that compliance has been achieved. A false statement that compliance has been achieved is a violation of the law and punishable by a fine of not less than \$2,000 or more than \$25,000 for each violation. Your facility may be reinspected any time during normal business hours. If a second reinspection becomes necessary due to non compliance, a reinspection charge of \$100.00 per hour may be charged to the facility.

You may request a meeting with the Program Manager to discuss the inspection findings and/or the proposed corrective actions. The issuance of this Summary of Violations does not preclude the CUPA from taking administrative, civil, or criminal action.

VIOLATIONS

VIOLATION #	DEGREE OF VIOLATION	CORRECTIVE ACTION REQUIRED

INSPECTION COMMENTS:

COMMENTS: Go to <http://www.co.kern.ca.us/eh/cupaprogram.asp> for forms and information.

INSPECTOR: LYDIA VON SYDOW
INSPECTION DATE: 04/27/2011

SIGNATURE OF FACILITY REP:

Certification: I certify under penalty of perjury that this facility has complied with the corrective actions listed on this inspection form.

Printed Name of Owner/Operator

Title

Signature of Owner/Operator

Date

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT

MATTHEW CONSTANTINE, R.E.H.S., Director

2700 "M" STREET, SUITE 300
BAKERSFIELD, CA 93301-2370
Voice: (661) 862-8700
Fax: (661) 862-8701
TTY Relay: (800) 735-2929
Web: www.co.kern.ca.us/eh
E-mail: eh@co.kern.ca.us



RESOURCE MANAGEMENT AGENCY

TED JAMES, AICP, INTERIM RMA DIRECTOR

Animal Control Department
Community and Economic Development Department
Engineering and Survey Services Department
Environmental Health Services Department
Planning Department
Roads Department

February 23, 2010

**CERTIFIED UNIFIED PROGRAM AGENCY (CUPA)
HAZARDOUS MATERIAL INSPECTION FORM**

Date: 02/23/2010

Facility ID: FA0002691

File #: 003201

Facility Name: JOHNNY QUIK #143		<u>Inspection Type</u>		
Site Address: 2126 TAFT HWY BAKERSFIELD, CA 93313		<input checked="" type="checkbox"/> Routine <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint		
Phone: (661)834-9113				
PROGRAMS INSPECTED:	<input type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input checked="" type="checkbox"/> UST	<input type="checkbox"/> APSA
REINSPECTION REQUIRED:	<input type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input type="checkbox"/> UST	<input type="checkbox"/> APSA

INSPECTOR: LYDIA VON SYDOW

INSPECTION DATE: 02/23/2010

VIOLATION	VIOLATION NUMBER	
	UT01	Facility has a site certificate of financial responsibility for underground storage tanks on file with regulatory agency [HSC 25292.2(a)].
	UT02	Facility has an approved designated operator and that operator is performing the required inspections and training [Title 23, CCR 2715].
	UT03	Facility has a written monitoring and response plan for USTs on site and on file with regulatory agency [Title 23, CCR 2632(d)(1) & 2641(h)].
	UT05	Facility completed an annual monitoring system certification for an underground storage tank system and submitted it to the regulatory agency [Title 23, CCR 2630(d) 2641(j)].
	UT06	Cathodic protection systems for underground storage tank systems (where appropriate) certified every three years. Facility provided certification results to regulatory agency [Title 23, CCR 2635(a) 2662(b)].
	UT07	Secondary containment systems for underground storage tank systems tested every three years. Facility provided results to the agency [Title 23, CCR 2637(a)].
	UT08	Underground storage tank systems (with single walled components) within 1000' of a drinking well must be tested with enhanced leak detection methods (ELD) every three years. Facility provided results to regulatory agency [Title 23, CCR 2635(a) & 2662(a)].
	UT11	Facility's underground storage tank monitoring system is functioning as designed [Title 23, CCR 2632].
	UT12	The underground storage system at the facility is monitored according to site's monitoring plan or permit [HSC 25293].
	UT13	Monitoring records for the underground storage tank system are available upon request [Title 23, CCR 2712(b)].
	UT14	Overspill and overfill equipment for underground storage tank(s) is present, properly installed, and functioning [Title 23, CCR 2635].
	UT16	Change of ownership or monitoring method reported to the permitting agency within 30 days of change [HSC 25284(c); Title 23, CCR 2712].
	UT22	Under Dispenser Containment (UDC) installed [HSC 25284.1 (a)(5)(c)].
	UT23	Under Dispenser Containment (UDC) has approved and functional monitoring equipment [Title 23, CCR 2636(f)(1) and (g)].
	UT24	Leak detection sensors are properly secured at lowest point in sumps and annular spaces [Title 23, CCR 2641(a)].
	UT25	Monitoring system shuts down the pump if a release is detected or the monitor fails or is disconnected [Positive Shut Down (PSD)]. Annual line integrity testing completed if no PSD [Title 23, CCR 2636(f)] .
	UT26	Automatic line leak detectors installed on pressurized piping that detects a 3.0 gph leak [Title 23, CCR 2636(f)(2)].
	UT27	Secondary containment and overspill containers are liquid/debris free [Title 23, CCR 2631(d)(4) & 2635(b)(1)].

VIOLATION	VIOLATION NUMBER	
	UT28	No liquid leaks visible [Title 23, CCR 2632].
	UT29	Fuel filters managed properly [HSC 25189(a)].
	UT30	Documentation of hazardous and designated waste disposal [Title 22, CCR 66262.23].

FACILITY NAME: JOHNNY QUIK #143

ADDRESS: 2126 TAFT HWY
BAKERSFIELD, CA
93313

FA ID: FA0002691
FILE ID: 003201

SUMMARY OF OBSERVATIONS/VIOLATIONS

- No violations of underground storage tank, hazardous materials, or hazardous waste laws/regulations were discovered. KERN CUPA greatly appreciates your efforts to comply with all the laws and regulations applicable to your facility.
- Violations were observed/discovered as listed below. All violations must be corrected by implementing the corrective action listed by each violation. If you disagree with any of the violations or corrective actions required, please inform the CUPA in writing.

ALL VIOLATIONS MUST BE CORRECTED WITHIN 30 DAYS OR AS SPECIFIED. CUPA must be informed in writing with a certification that compliance has been achieved. A false statement that compliance has been achieved is a violation of the law and punishable by a fine of not less than \$2,000 or more than \$25,000 for each violation. Your facility may be reinspected any time during normal business hours. If a second reinspection becomes necessary due to non compliance, a reinspection charge of \$100.00 per hour may be charged to the facility.

You may request a meeting with the Program Manager to discuss the inspection findings and/or the proposed corrective actions. The issuance of this Summary of Violations does not preclude the CUPA from taking administrative, civil, or criminal action.

VIOLATIONS

VIOLATION #	DEGREE OF VIOLATION	CORRECTIVE ACTION REQUIRED

INSPECTION COMMENTS:

COMMENTS: Go to <http://www.co.kern.ca.us/eh/cupaprogram.asp> for forms and information.

INSPECTOR: LYDIA VON SYDOW
INSPECTION DATE: 02/23/2010

SIGNATURE OF FACILITY REP:

Certification: I certify under penalty of perjury that this facility has complied with the corrective actions listed on this inspection form.

Printed Name of Owner/Operator

Title

Signature of Owner/Operator

Date

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT

MATTHEW CONSTANTINE, R.E.H.S., Director

2700 "M" STREET, SUITE 300
 BAKERSFIELD, CA 93301-2370
 Voice: (661) 862-8700
 Fax: (661) 862-8701
 TTY Relay: (800) 735-2929
 Web: www.co.kern.ca.us/eh
 E-mail: eh@co.kern.ca.us



RESOURCE MANAGEMENT AGENCY

DAVID PRICE III, RMA DIRECTOR

Animal Control Department
 Community and Economic Development Department
 Engineering and Survey Services Department
 Environmental Health Services Department
 Planning Department
 Roads Department

February 13, 2009

**CERTIFIED UNIFIED PROGRAM AGENCY (CUPA)
 HAZARDOUS MATERIAL INSPECTION FORM**

Date: 02/13/2009

Facility ID: FA0002691

File #: 003201

Facility Name: JOHNNY QUIK #143			Inspection Type <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint		
Site Address: 2126 TAFT HWY BAKERSFIELD, CA 93313					
Phone: (661)834-9113					
PROGRAMS INSPECTED:	<input checked="" type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input checked="" type="checkbox"/> UST	<input type="checkbox"/> AGT	<input type="checkbox"/> CalARP
REINSPECTION REQUIRED:	<input type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input type="checkbox"/> UST	<input type="checkbox"/> AGT	<input type="checkbox"/> CalARP

VIOLATION

<u>YES</u>	<u>NO/NA</u>	<u>VIOL. #</u>	<u>BUSINESS PLAN REQUIREMENTS</u>
<input type="checkbox"/>	<input checked="" type="checkbox"/>	BP01	Inventory of hazardous materials is accurate, up to date, and complete [HSC 6.95, 25504, Title 19 CCR 2729].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	BP02	Site layout/facility maps are accurate [HSC 6.95,25504; Title 19 CCR 2729].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	BP03	Hazardous materials are stored in properly labeled and non-deteriorated containers [HSC 25124(b)(3)(A & B)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	BP04	The hazardous materials inventory shall be submitted annually on or before March 1 [Title 19 CCR 2729.4(b)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	ER01	Contingency Plan is complete, updated, and maintained on site [HSC 6.95, 25504; Title 19 CCR 2731 Title 22 CCR 66265.53-54].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	ER02	Facility is operated and maintained to prevent/mitigate fire, explosion, or release of hazardous material or waste which could threaten human health or the environment [Title 22 CCR 66265.31; Title 19 CCR 2731].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	ER03	Business has equipment required to, or appropriate for, safe handling of hazardous materials [Title 22 CCR 66265.32 & .34].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	TR01	Facility has a training program appropriate for the size and complexity of business and nature of hazardous materials handled [Title 19 CCR 2732; Title 22 CCR 66265.16].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	TR02	Training documentation is maintained on site for current personnel. [Title 19 CCR 2732; Title 22 CCR 66265.16].

COMMENTS: Go to <http://www.co.kern.ca.us/eh/cupaprogram.asp> for forms and information.

GPS Coordinates: Latitude: 35.2670840000

Longitude: -119.0257700000

INSPECTOR: LAUREL D FUNK

DATE: 02/13/2009

VIOLATION

<u>YES</u>	<u>NO/NA</u>	<u>VIOL. #</u>	<u>UNDERGROUND STORAGE TANK (UST) INSPECTION REQUIREMENTS</u>
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT01	Facility has a site certificate of financial responsibility for Underground Storage Tanks on file with regulatory agency [HSC 25292.2(a)]
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT02	Facility has an approved designated operator and that operator is performing the required inspections and training [CCR 2715].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT03	Facility has a written monitoring and response plan for USTs on site and on file with regulatory agency [CCR 2632(d)(1) & 2641(h)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT05	Facility completed an annual monitoring system certification for an underground storage tank system and submitted it to the regulatory agency [CCR 2630(d) 2641(j)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT06	Cathodic Protection systems for underground storage tank systems (where appropriate) certified every three years. Facility provided certification results to regulatory agency [CCR 2635(a) 2662(b)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT07	Secondary containment systems for underground storage tank systems tested every three years. Facility provided results to the agency [CCR 2637(a)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT08	Underground storage tank systems (with single walled components) within 1000' of a drinking well must be tested with enhanced leak detection methods (ELD) every three years. Facility provided results to regulatory agency [CCR 2635(a) & 2662(a)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT11	Facility's underground storage tank monitoring system is functioning as designed [CCR 2632].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT12	The underground storage system at the facility is monitored according to site's monitoring plan or permit [HSC 25293].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT13	Monitoring records for the underground storage tank system are available upon request [CCR 2712(b)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT14	Overspill and overfill equipment for underground storage tank(s) is present, properly installed, and functioning [CCR 2635].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT16	Change of ownership or monitoring method reported to the permitting agency within 30 days of change (HSC 25284(c); CCR 2712).
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT22	Under Dispenser Containment (UDC) installed. [HSC 25284.1 (a)(5)(c)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT23	Under Dispenser Containment (UDC) has approved and functional monitoring equipment. [CCR 2636(f)(1) and (g)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT24	Leak detection sensors are properly secured at lowest point in sumps and annular spaces. [CRR 2641(a)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT25	Monitoring system shuts down the pump if a release is detected or the monitor fails or is disconnected (Positive Shut Down (PSD)). Annual line integrity testing completed if no PSD. [CCR 2636(f)] .
<input checked="" type="checkbox"/>	<input type="checkbox"/>	UT26	Automatic line leak detectors installed on pressurized piping that detects a 3.0 gph leak. [CCR 2636(f)(2)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT27	Secondary containment & overspill containers are liquid/debris free. [CCR 2631(d)(4) & 2635(b)(1)]
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT28	No liquid leaks visible. [CCR 2632]
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT29	Fuel filters managed properly. [HSC 25189 (a)]
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT30	Documentation of hazardous and designated waste disposal. [Title 22 CCR 66262.23]

SUMMARY OF OBSERVATIONS/VIOLATIONS

- No violations of underground storage tank, hazardous materials, or hazardous waste laws/regulations were discovered. KERN CUPA greatly appreciates your efforts to comply with all the laws and regulations
- Violations were observed/discovered as listed below. All violations must be corrected by implementing the corrective action listed by each violation. If you disagree with any of the violations or corrective actions required, please inform the CUPA in writing.

ALL VIOLATIONS MUST BE CORRECTED WITHIN 30 DAYS OR AS SPECIFIED. CUPA must be informed in writing with a certification that compliance has been achieved. A false statement that compliance has been achieved is a violation of the law and punishable by a fine of not less than \$2,000 or more than \$25,000 for each violation. Your facility may be reinspected any time during normal business hours. If a second reinspection becomes necessary due to non compliance, a reinspection charge of \$100.00 per hour may be charged to the facility.

You may request a meeting with the Program Manager to discuss the inspection findings and/or the proposed corrective actions. The issuance of this Summary of Violations does not preclude the CUPA from taking administrative, civil, or criminal action.

FACILITY NAME: JOHNNY QUIK #143

ADDRESS: 2126 TAFT HWY
BAKERSFIELD, CA 93313

FA ID: FA0002691
FILE ID: 003201

VIOLATIONS

VIOL. NO	VIOL. TYPE	CORRECTIVE ACTION REQUIRED
UT26	MINOR VIOLATION	Install automatic line leak detectors that detect a 3.0 gph leak. Line leak detectors failed on the gas tanks. The contractor replace the LLDs and retested. The violations was corrected on site.

INSPECTION COMMENTS:

INSPECTOR: LAUREL D FUNK

SIGNATURE OF FACILITY REP:

DATE: 02/13/2009

Certification: I certify under penalty of perjury that this facility has complied with the corrective actions listed on this inspection form.

Signature of Owner/Operator: _____ Title: _____ Date: _____

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT

MATTHEW CONSTANTINE, R.E.H.S., Director

2700 "M" STREET, SUITE 300
BAKERSFIELD, CA 93301-2370
Voice: (661) 862-8700
Fax: (661) 862-8701
TTY Relay: (800) 735-2929
e-mail: eh@co.kern.ca.us



RESOURCE MANAGEMENT AGENCY

DAVID PRICE III, RMA DIRECTOR

Community and Economic Development Department
Engineering & Survey Services Department
Environmental Health Services Department
Planning Department
Roads Department

February 15, 2008

**CERTIFIED UNIFIED PROGRAM AGENCY (CUPA)
HAZARDOUS MATERIAL INSPECTION FORM**

Date: 02/12/2008

Facility ID: FA0002691

File #: 003201

Facility Name: JOHNNY QUIK #143			Inspection Type		
Site Address: 2126 TAFT HWY BAKERSFIELD, CA 93313			<input checked="" type="checkbox"/> Routine		
Phone: (661)834-9113			<input type="checkbox"/> Reinspection		
PROGRAMS INSPECTED:			<input type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input checked="" type="checkbox"/> UST
			<input type="checkbox"/> AGT	<input type="checkbox"/> CalARP	
REINSPECTION REQUIRED:			<input type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input type="checkbox"/> UST
			<input type="checkbox"/> AGT	<input type="checkbox"/> CalARP	

COMMENTS: Go to <http://www.co.kern.ca.us/eh/HazMatPage.asp> for forms and information.

GPS Coordinates: Latitude: 35.2670840000

Longitude: -119.0257700000

INSPECTOR: LAUREL D FUNK

DATE: 02/12/2008

VIOLATION

<u>YES</u>	<u>NO/NA</u>	<u>VIOL. #</u>	<u>UNDERGROUND STORAGE TANK (UST) INSPECTION REQUIREMENTS</u>
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT01	Facility has a site certificate of financial responsibility for Underground Storage Tanks on file with regulatory agency [HSC 25292.2(a)]
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT02	Facility has an approved designated operator and that is performing the required inspections and training [CCR 2715].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT03	Facility has a written monitoring and response plan for USTs on site and on file with regulatory agency [CCR 2632(d)(1) & 2641(h)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT05	Facility completed an annual monitoring system certification for an underground storage tank system and submitted it to the regulatory agency [CCR 2630(d) 2641(j)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT06	Cathodic Protection systems for underground storage tank systems (where appropriate) certified every three years. Facility provided certification results to regulatory agency [CCR 2635(a) 2662(b)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT07	Secondary containment systems for underground storage tank systems tested every three years. Facility provided results to the agency [CCR 2637(a)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT08	Underground storage tank systems (with single walled components) within 1000' of a drinking well must be tested with enhanced leak detection methods (ELD) every three years. Facility provided results to regulatory agency [CCR 2635(a) & 2662(a)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT11	Facility's underground storage tank monitoring system is functioning as designed [CCR 2632].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT12	The underground storage system at the facility is monitored according to site's monitoring plan or permit [HSC 25293].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT13	Monitoring records for the underground storage tank system are available upon request [CCR 2712(b)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT14	Overspill and overfill equipment for underground storage tank(s) is present, properly installed, and functioning [CCR 2635].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT16	Change of ownership or monitoring method reported to the permitting agency within 30 days of change (HSC 25284(c); CCR 2712).
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT22	Under Dispenser Containment (UDC) installed. [HSC 25284.1 (a)(5)(c)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT23	Under Dispenser Containment (UDC) has approved and functional monitoring equipment. [CCR 2636(f)(1) and (g)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT24	Leak detection sensors are properly secured at lowest point in sumps and annular spaces. [CCR 2641(a)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT25	Monitoring system shuts down the pump if a release is detected or the monitor fails or is disconnected (Positive Shut Down (PSD)). Annual line integrity testing completed if no PSD. [CCR 2636(f)] .
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT26	Automatic line leak detectors installed on pressurized piping that detects a 3.0 gph leak. [CCR 2636(f)(2)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT27	Secondary containment & overspill containers are liquid/debris free. [CCR 2631(d)(4) & 2635(b)(1)]
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT28	No liquid leaks visible. [CCR 2632]
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT29	Fuel filters managed properly. [HSC 25189 (a)]
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT30	Documentation of hazardous and designated waste disposal. [Title 22 CCR 66262.23]

SUMMARY OF OBSERVATIONS/VIOLATIONS

- No violations of underground storage tank, hazardous materials, or hazardous waste laws/regulations were discovered. KERN CUPA greatly appreciates your efforts to comply with all the laws and regulations
- Violations were observed/discovered as listed below. All violations must be corrected by implementing the corrective action listed by each violation. If you disagree with any of the violations or corrective actions required, please inform the CUPA in writing.

ALL VIOLATIONS MUST BE CORRECTED WITHIN 30 DAYS OR AS SPECIFIED. CUPA must be informed in writing with a certification that compliance has been achieved. A false statement that compliance has been achieved is a violation of the law and punishable by a fine of not less than \$2,000 or more than \$25,000 for each violation. Your facility may be reinspected any time during normal business hours. If a reinspection becomes necessary due to non compliance, a reinspection charge of \$85.00 per hour may be charged to the facility.

You may request a meeting with the Program Manager to discuss the inspection findings and/or the proposed corrective actions. The issuance of this Summary of Violations does not preclude the CUPA from taking administrative, civil, or criminal action.

FACILITY NAME: JOHNNY QUIK #143

ADDRESS: 2126 TAFT HWY
BAKERSFIELD, CA 93313

FA ID: FA0002691
FILE ID: 003201

VIOLATIONS

VIOL. NO	VIOL. TYPE	CORRECTIVE ACTION REQUIRED
----------	------------	----------------------------

INSPECTION COMMENTS:

INSPECTOR: LAUREL D FUNK
DATE: 02/12/2008

SIGNATURE OF FACILITY REP:

Certification: I certify under penalty of perjury that this facility has complied with the corrective actions listed on this inspection form.

Signature of Owner/Operator: _____ Title: _____ Date: _____

ENVIRONMENTAL HEALTH SERVICES DEPARTMENT**MATTHEW CONSTANTINE, R.E.H.S., Director**

2700 "M" STREET, SUITE 300
 BAKERSFIELD, CA 93301-2370
 Voice: (661) 862-8700
 Fax: (661) 862-8701
 TTY Relay: (800) 735-2929
 e-mail: eh@co.kern.ca.us

**RESOURCE MANAGEMENT AGENCY****DAVID PRICE III, RMA DIRECTOR**

Community and Economic Development Department
 Engineering & Survey Services Department
 Environmental Health Services Department
 Planning Department
 Roads Department

May 25, 2007

**CERTIFIED UNIFIED PROGRAM AGENCY (CUPA)
 HAZARDOUS MATERIAL INSPECTION FORM**

Date: 05/24/2007

Facility ID: FA0002691

File #: 003201

Facility Name: JOHNNY QUIK #143			Inspection Type <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint		
Site Address: 2126 TAFT HWY BAKERSFIELD, CA 93313					
Phone: (661)834-9113					
PROGRAMS INSPECTED:	<input checked="" type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input checked="" type="checkbox"/> UST	<input type="checkbox"/> AGT	<input type="checkbox"/> CalARP
REINSPECTION REQUIRED:	<input type="checkbox"/> Business Plan	<input type="checkbox"/> HW Generator	<input type="checkbox"/> UST	<input type="checkbox"/> AGT	<input type="checkbox"/> CalARP

VIOLATION

<u>YES</u>	<u>NO/NA</u>	<u>VIOL. #</u>	<u>BUSINESS PLAN REQUIREMENTS</u>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	BP01	Inventory of hazardous materials is accurate, up to date, and complete [HSC 6.95, 25504, Title 19 CCR 2729].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	BP02	Site layout/facility maps are accurate [HSC 6.95,25504; Title 19 CCR 2729].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	BP03	Hazardous materials are stored in properly labeled and non-deteriorated containers [HSC 25124(b)(3)(A & B)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	BP04	The hazardous materials inventory shall be submitted annually on or before March 1 [Title 19 CCR 2729.4(b)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	ER01	Contingency Plan is complete, updated, and maintained on site [HSC 6.95, 25504; Title 19 CCR 2731 Title 22 CCR 66265.53-54].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	ER02	Facility is operated and maintained to prevent/mitigate fire, explosion, or releases of hazardous material or waste which could threaten human health or the environment [Title 22 CCR 66265.31; Title 19 CCR 2731].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	ER03	Business has equipment required to, or appropriate for, safely handling hazardous materials [Title 22 CCR 66265.32 & .34].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	TR01	Facility has a training program appropriate for the size and complexity of business and nature of hazardous materials handled [Title 19 CCR 2732; Title 22 CCR 66265.16].
<input checked="" type="checkbox"/>	<input type="checkbox"/>	TR02	Training documentation is maintained on site for current personnel. [Title 19 CCR 2732;22 CCR 66265.16].

COMMENTS: Go to <http://www.co.kern.ca.us/eh/HazMatPage.asp> for forms and information.**GPS Coordinates: Latitude:****Longitude:****INSPECTOR:** LAUREL D FUNK**DATE:** 05/24/2007

VIOLATION

<u>YES</u>	<u>NO/NA</u>	<u>VIOL. #</u>	<u>UNDERGROUND STORAGE TANK (UST) INSPECTION REQUIREMENTS</u>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	UT01	Facility has a site certificate of financial responsibility for Underground Storage Tanks on file with regulatory agency [HSC 25292.2(a)]
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT02	Facility has an approved designated operator and that is performing the required inspections and training [CCR 2715].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT03	Facility has a written monitoring and response plan for USTs on site and on file with regulatory agency [CCR 2632(d)(1) & 2641(h)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT05	Facility completed an annual monitoring system certification for an underground storage tank system and submitted it to the regulatory agency [CCR 2630(d) 2641(j)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT06	Cathodic Protection systems for underground storage tank systems (where appropriate) certified every three years. Facility provided certification results to regulatory agency [CCR 2635(a) 2662(b)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT07	Secondary containment systems for underground storage tank systems tested every three years. Facility provided results to the agency [CCR 2637(a)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT08	Underground storage tank systems (with single walled components) within 1000' of a drinking well must be tested with enhanced leak detection methods (ELD) every three years. Facility provided results to regulatory agency [CCR 2635(a) & 2662(a)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT11	Facility's underground storage tank monitoring system is functioning as designed [CCR 2632].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT12	The underground storage system at the facility is monitored according to site's monitoring plan or permit [HSC 25293].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT13	Monitoring records for the underground storage tank system are available upon request [CCR 2712(b)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT14	Overspill and overfill equipment for underground storage tank(s) is present, properly installed, and functioning [CCR 2635].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT16	Change of ownership or monitoring method reported to the permitting agency within 30 days of change (HSC 25284(c); CCR 2712).
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT22	Under Dispenser Containment (UDC) installed. [HSC 25284.1 (a)(5)(c)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT23	Under Dispenser Containment (UDC) has approved and functional monitoring equipment. [CCR 2636(f)(1) and (g)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT24	Leak detection sensors are properly secured at lowest point in sumps and annular spaces. [CCR 2641(a)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT25	Monitoring system shuts down the pump if a release is detected or the monitor fails or is disconnected (Positive Shut Down (PSD)). Annual line integrity testing completed if no PSD. [CCR 2636(f)] .
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT26	Automatic line leak detectors installed on pressurized piping that detects a 3.0 gph leak. [CCR 2636(f)(2)].
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT27	Secondary containment & overspill containers are liquid/debris free. [CCR 2631(d)(4) & 2635(b)(1)]
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT28	No liquid leaks visible. [CCR 2632]
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT29	Fuel filters managed properly. [HSC 25189 (a)]
<input type="checkbox"/>	<input checked="" type="checkbox"/>	UT30	Documentation of hazardous and designated waste disposal. [Title 22 CCR 66262.23]

SUMMARY OF OBSERVATIONS/VIOLATIONS

- No violations of underground storage tank, hazardous materials, or hazardous waste laws/regulations were discovered. KERN CUPA greatly appreciates your efforts to comply with all the laws and regulations
- Violations were observed/discovered as listed below. All violations must be corrected by implementing the corrective action listed by each violation. If you disagree with any of the violations or corrective actions required, please inform the CUPA in writing.

ALL VIOLATIONS MUST BE CORRECTED WITHIN 30 DAYS OR AS SPECIFIED. CUPA must be informed in writing with a certification that compliance has been achieved. A false statement that compliance has been achieved is a violation of the law and punishable by a fine of not less than \$2,000 or more than \$25,000 for each violation. Your facility may be reinspected any time during normal business hours. If a second reinspection becomes necessary due to non compliance, a reinspection charge of \$85.00 per hour may be charged to the facility.

You may request a meeting with the Program Manager to discuss the inspection findings and/or the proposed corrective actions. The issuance of this Summary of Violations does not preclude the CUPA from taking administrative, civil, or criminal action.

FACILITY NAME: JOHNNY QUIK #143

ADDRESS: 2126 TAFT HWY
BAKERSFIELD, CA 93313

FA ID: FA0002691
FILE ID: 003201

VIOLATIONS

VIOL. NO	VIOL. TYPE	CORRECTIVE ACTION REQUIRED
BP01	MINOR	Update inventory of hazardous materials. Complete a new business plan packet
TR02	MINOR	Document training. Update employee training yearly
UT01	MINOR	File certificate of financial responsibility for Underground Storage Tanks at facility.

INSPECTION COMMENTS:

INSPECTOR: LAUREL D FUNK
DATE: 05/24/2007

SIGNATURE OF FACILITY REP:

<p>Certification: I certify under penalty of perjury that this facility has complied with the corrective actions listed on this inspection form.</p> <p>Signature of Owner/Operator: _____ Title: _____ Date: _____</p>



ENVIRONMENTAL HEALTH DIVISION INSPECTION CONSENT AND ACKNOWLEDGEMENT CERTIFICATION

Facility Name: Johnny Air # 413 Inspection Date: 2/4/16
Facility ID: _____ CERS ID: 10233775

Consent: By signing this document, you are consenting to an inspection of the above referenced facility by the Kern County Public Health Services Department, Environmental Health Division, Certified Unified Program Agency (CUPA) for the county of Kern. The State of California has authorized the CUPA to conduct business facility inspections for compliance with the programs listed below. These inspections may include the inspection of all business areas on the property, the review and copying of records, the taking of photographs, and the taking of samples to evaluate compliance with CUPA requirements. The following Health and Safety Code (HSC) sections give the CUPA the authority to inspect:

- Hazardous Waste (Health & Safety Code [HSC § 25185, subd. (a)]);
- California Accidental Release Prevention (HSC § 25534.5);
- Hazardous Materials Release Response Plans [HSC § 25508, subd. (a)];
- Underground Storage Tanks – (HSC § 25289); and
- Aboveground Storage Tanks – [HSC § 25270.5, subd. (a)].

[Signature] LEON VITICHUNIAN OWNER 02/04/16
Signature Facility Representative Print Name and Title Date Signed

Declined to sign, verbal consent to inspect given. Inspection Refused

Acknowledgement of Method to Receive Inspection Report:

E-mail to: A.Ghuzman@ath.net Mail to: _____

Fax to: _____

[Signature] Brenda Selan 2/4/16
Signature Inspector Print Name and Title Date Signed



**ENVIRONMENTAL HEALTH DIVISION
CERTIFIED UNIFIED PROGRAM AGENCY (CUPA)**

MATTHEW CONSTANTINE
DIRECTOR

2700 M STREET, SUITE 300 BAKERSFIELD, CALIFORNIA 93301-2370 VOICE: 661-862-8740 FAX: 661-862-8701 WWW.CO.KERN.CA.US/EH

UNDERGROUND STORAGE TANK INSPECTION REPORT

Facility Name: JOHNNY QUIK #143		Facility ID: FA0002691
Site Address: 2126 TAFT HWY BAKERSFIELD, CA 93313		CERS ID: 10233775
Phone: (661) 834-9113		BOE #:
Consent Granted By: Kuljit Ghuman		Inspection Date: 02/04/2016
Designated Operator: Rich Env.		Testing Company: Rich Env.
Inspection Type: <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Reinspection		Reinspection required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

File/CERS Review Violations

V	Viol #	Summary	Code
	H650	FAILURE TO OBTAIN/MAINTAIN A VALID OPERATING PERMIT	23 CCR 16 2712(i); HSC 6.7 25284
	H651	FAILURE TO SUBMIT ACCURATE UST FACILITY/TANK INFORMATION	23 CCR 16 2711; HSC 6.7 25286(a)
	H653	FAILURE TO SUBMIT STATEMENT OF DESIGNATED OPERATOR/UST COMPLIANCE	23 CCR 16 2715(a), 2715(b)
	H654	FAILURE TO SUBMIT/MAINTAIN AN ACCURATE RESPONSE PLAN	23 CCR 16 2632, 2634(e), 2641(h), 2712(i)
	H655	FAILURE TO SUBMIT/MAINTAIN AN ACCURATE PLOT PLAN	23 CCR 16 2632(d)(1)(C), 2711(a)(8)
	H660	MAKING FALSE STATEMENTS/REPRESENTATION ON ANY DOCUMENT	HSC 6.7 25299
	H662	FAILURE TO COMPLETE/SUBMIT ANNUAL MONITORING CERTIFICATION	23 CCR 16 2638
	H663	FAILURE TO COMPLETE SECONDARY CONTAINMENT TESTING	23 CCR 16 2637
	H664	FAILURE TO ANNUALLY TEST SPILL CONTAINMENT	HSC 6.7 25284.2
	H665	FAILURE TO SUBMIT SECONDARY CONTAINMENT TEST RESULTS	23 CCR 16 2637(e)

General Violations

V	Viol #	Summary	Code
	H741	FAILURE TO COMPLY WITH ALL OPERATING PERMIT CONDITIONS	23 CCR 16 2712
	H680	IMPROPER PROGRAMING/OPERATION OF LEAK DETECTION EQUIPMENT	23 CCR 16 2632, 2634, 2636, 2666
	H681	FAILURE OF LEAK DETECTION EQUIPMENT TO HAVE AUDIBLE/VISUAL ALARMS	23 CCR 16 2632, 2634, 2636, 2666
	H683	FAILURE TO INSTALL CORRECT LEAK DETECTION SYSTEM	23 CCR 16 2638; HSC 6.7 25290.1, 25290.2, 2529122 CCR 12 66262.34(d)(2);
	H684	FAILURE TO PROPERLY LABEL CERTIFIED MONITORING EQUIPMENT	23 CCR 16 2638(f)
	H690	FAILURE TO PROPERLY MONITOR UNDER DISPENSER CONTAINMENT	23 CCR 16 2636(f)(1)
	H694	FAILURE OF SENSOR TO BE LOCATED IN THE PROPER POSITION	23 CCR 16 2630(d), 2641(a)
	H695	TAMPERING WITH LEAK DETECTION EQUIPMENT	HSC 6.7 25299(a)(9)
	H704	FAILURE TO INSTALL LINE LEAK DETECTORS ON PRESSURIZED PIPING	HSC 6.7 25290.1(h), 25290.2(g), 25291(f), 25292(e)
	H708	FAILURE OF LINE LEAK DETECTOR TO FUNCTION AS REQUIRED	23 CCR 16 2636(f)(2)
	H711	FAILURE TO KEEP SECONDARY CONTAINMENT FREE OF DEBRIS/ LIQUID AND IN GOOD CONDITION	HSC 6.7 25290.1, 25290.2, 25291
	H717	FAILURE TO KEEP SPILL BUCKET FREE OF DEBRIS/LIQUID AND IN GOOD CONDITION	23 CCR 16 2635(b), 2715(c)(2)
	H676	FAILURE TO OBTAIN PERMITS TO INSTALL, REPLACE, REPAIR OR MODIFY PART OF THE UST SYSTEM	23 CCR 16 2712

Inspector: Brody Saleen

Inspection Date: 02/04/2016

General Violations - continued

V	Viol #	Summary	Code
	H719	FAILURE TO OPERATE THE UST SYSTEM TO PREVENT SPILLS/ OVERFILLS	HSC 6.7 25292.1(a)
	H720	FAILURE OF THE OVERFILL PREVENTION SYSTEM TO FUNCTION AS REQUIRED	23 CCR 16 2635(b)(2), 2665
	H721	FAILURE OF INDIVIDUALS WORKING ON/MAINTAINING THE UST SYSTEM TO HAVE A PROPER/CURRENT ICC CERTIFICATION	23 CCR 16 2715
	H747	FAILURE TO COMPLY WITH TEMPORARY CLOSURE REQUIREMENTS	23 CCR 16 2670, 2671; HSC 6.7 25298
	H748	FAILURE TO COMPLY WITH ALL PERMANENT CLOSURE REQUIREMENTS	23 CCR 16 2670, 2672; HSC 6.7 25298

Double Walled Tank Violations

V	Viol #	Summary	Code
	H682	FAILURE TO CONTINUOUSLY MONITOR SECONDARY CONTAINMENT THAT ACTIVATES AN AUDIBLE/VISUAL ALARM	23 CCR 16 2631(g), 2632(c)(2)(A)&(B), 2633(c), 2636(f)
	H699	FAILURE TO CONTINUOUSLY MONITOR SECONDARY CONTAINMENT USING VACUUM/PRESSURE/HYDROSTATIC	HSC 6.7 25290.1(e)
	H714	FAILURE TO MAINTAIN PRODUCT TIGHT SECONDARY CONTAINMENT	23 CCR 16 2662; HSC 6.7 25290.1(c)(2), 25290.2(c)(2), 25291(a), 25292(e)

Double Walled Piping Violations

V	Viol #	Summary	Code
	H666	FAILURE TO COMPLY WITH ANNUAL LINE INTEGRITY TESTING	23 CCR 16 2636(f)(4)
	H686	FAILURE OF SECONDARY CONTAINMENT MONITORING TO PROVIDE FAIL SAFE AND POSITIVE SHUT DOWN	23 CCR 16 2636(f)(5)
	H687	FAILURE TO CONTINUOUSLY MONITOR SECONDARY CONTAINMENT THAT ACTIVATES AN AUDIBLE/VISUAL ALARM	23 CCR 16 2636(f)(1)
	H705	FAILURE TO CHECK MONITORING SYSTEM DAILY TO MAINTAIN EMERGENCY GENERATOR LINE LEAK DETECTOR EXEMPTION	23 CCR 16 2636(f)(2), 2666(c)
	H712	FAILURE TO MAINTAIN SECONDARY CONTAINMENT TO ALLOW PRODUCT TO BE DETECTED AT THE EARLIEST POSSIBLE	23 CCR 16 2630(d), 2641(a)

Single Walled Tank Violations

V	Viol #	Summary	Code
	H685	FAILURE TO USE THE AUTOMATIC TANK GAUGE AND MANUAL INVENTORY RECONCILIATION FOR LOW VOLUME TANK TESTING	23 CCR 16 2643(b)(2)
	H688	FAILURE TO CONDUCT 0.2 GALLON/HOUR CONTINUOUS IN TANK LEAK DETECTION TEST MONTHLY AND DOCUMENT	23 CCR 16 2643(b)(5)
	H689	FAILURE TO CONDUCT 0.2 GALLON/HOUR IN TANK LEAK DETECTION TEST MONTHLY AND DOCUMENT	23 CCR 16 2643(b)(1)
	H692	FAILURE TO INSTALL AUTOMATIC TANK GAUGING/LEAK DETECTION	23 CCR 16 2643; HSC 6.7 25292(a)
	H701	FAILURE TO MAINTAIN/INSPECT CORROSION PROTECTION SYSTEM AS REQUIRED	23 CCR 16 2635(a)(2), 2662(c)(1)(B)
	H755	FAILURE TO INSTALL A FUNCTIONAL CORROSION PROTECTION	23 CCR 16 2635(a)(2)(A)
	H669	FAILURE TO RECERTIFY INTERIOR LINED TANKS AS REQUIRED	23 CCR 16 2663
	H671	FAILURE TO CONDUCT ENHANCED LEAK DETECTION TESTING AS REQUIRED	23 CCR 16 2644.1(a)(3)
	H672	FAILURE TO SUBMIT ENHANCED LEAK DETECTION TEST RESULTS AS REQUIRED	23 CCR 16 2644.1(a)(5)
	H749	FAILURE TO CORRECT ANY FAILURES DETECTED DURING ENHANCED LEAK DETECTION TESTING	HSC 6.7 25292.4(d), 25292.5(c)

Inspector: Brody Saleen

Inspection Date: 02/04/2016

Single Walled Piping Violations

V	Viol #	Summary	Code
	H703	FAILURE TO PERFORM MONTHLY 0.2 GALLON/HOUR OR ANNUAL 0.1 GALLON/HOUR LINE INTEGRITY TESTS	23 CCR 16 2641(a), 2643(c)
	H707	FAILURE OF THE LINE LEAK DETECTOR TO PROVIDE FAIL SAFE AND POSITIVE SHUT DOWN	23 CCR 16 2666(c)

On Site Records Violations

V	Viol #	Summary	Code
	H652	FAILURE TO OBTAIN/MAINTAIN A VALID BOARD OF EQUALIZATION ACCOUNT NUMBER	HSC 6.7 25286(c)
	H661	FAILURE TO NOTIFY THE CUPA OF A CHANGE IN DESIGNATED OPERATOR	23 CCR 16 2715(a)
	H724	FAILURE TO SUBMIT/MAINTAIN A CURRENT CERTIFICATION OF FINANCIAL RESPONSIBILITY	23 CCR 16 2711; 23 CCR 18 2808.1, 2809-2809.2; HSC 6.7 25292.2; HSC 6.75 25299.30-25299.34
	H726	FAILURE TO MAINTAIN COPIES OF DESIGNATED OPERATOR'S INSPECTION REPORTS AND LIST OF TRAINED EMPLOYEES	23 CCR 16 2715
	H727	FAILURE OF DESIGNATED OPERATOR TO COMPLY WITH ALL MONTHLY INSPECTION REQUIREMENTS	23 CCR 16 2715
	H729	FAILURE TO MAINTAIN ALARM LOGS AND FOLLOW-UP DOCUMENTATION	23 CCR 16 2632, 2634, 2712(b)
	H731	FAILURE OF DESIGNATED OPERATOR TO PROVIDE APPROPRIATE EMPLOYEE TRAINING	23 CCR 16 2715(c)(6), 2715(f)
	H736	FAILURE TO MAINTAIN MONITORING, MAINTENANCE, AND REPAIR RECORDS	23 CCR 16 2712(b)
	H737	FAILURE TO MAINTAIN CORROSION PROTECTION RECORDS	23 CCR 16 2635, 2712(b)
	H738	FAILURE TO MAINTAIN AN APPROVED MONITORING PLAN ON SITE	23 CCR 16 2632, 2634, 2711, 2712(i)
	H739	FAILURE TO SUBMIT/MAINTAIN A WRITTEN OWNER/OPERATOR AGREEMENT	23 CCR 16 2620(b); HSC 6.7 25284(a)(3)
	H740	FAILURE TO RECORD AND/OR REPORTSUSPECTED OR ACTUAL UNAUTHORIZED RELEASE CORRECTLY	HSC 6.7 29294, 29295

Inspector: Brody Saleen

Inspection Date: 02/04/2016

SUMMARY OF OBSERVATIONS/VIOLATIONS

- No violations of underground storage tank laws/regulations were discovered. KERN CUPA greatly appreciates your efforts to comply with all the laws and regulations applicable to your facility.
- Violations were observed/discovered as listed below. All violations must be corrected by implementing the corrective action listed by each violation. If you disagree with any of the violations or corrective actions required, please inform the CUPA in writing.

ALL VIOLATIONS MUST BE CORRECTED WITHIN 30 DAYS OR AS SPECIFIED. CUPA must be informed in writing with a certification that compliance has been achieved. A false statement that compliance has been achieved is a violation of the law and punishable by a fine of not less than \$2,000 or more than \$25,000 for each violation. Your facility may be reinspected any time during normal business hours. If a second reinspection becomes necessary due to non compliance, a reinspection charge of \$100.00 per hour may be charged to the facility.

You may request a meeting with the Program Manager to discuss the inspection findings and/or the proposed corrective actions. The issuance of this Summary of Violations does not preclude the CUPA from taking administrative, civil, or criminal action.

INSPECTION COMMENTS:

COMMENTS: Go to <http://www.co.kern.ca.us/eh/> (Hazardous Materials) for forms and information.



Inspector: Brody Saleen
 Inspection Date: 02/04/2016

Signature of Facility Representative:

64156

MONITORING SYSTEM CERTIFICATION

For Use By All Jurisdictions Within the State of California

Authority Cited: Chapter 6.7, Health and Safety Code; Chapter 16, Division 3, Title 23, California Code of Regulations

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

A. General Information

Facility Name: JOHNNY QUICK Bldg. No.: _____
 Site Address: 2126 TAFT HWY City: BAKERSFIELD Zip: 93313
 Facility Contact Person: MR. KOOL Contact Phone No.: (661) 834-9113
 Make/Model of Monitoring System: TLS-350 Date of Testing/Serviceing: 2/4/2016

B. Inventory of Equipment Tested/Certified

Check the appropriate boxes to indicate specific equipment inspected/serviced:

Tank ID: REG87 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: PREM91 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Tank ID: DIESEL <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input type="checkbox"/> Annular Space or Vault Sensor. Model: _____ <input type="checkbox"/> Piping Sump / Trench Sensor(s). Model: _____ <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Dispenser ID: 1/2 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 3/4 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: 5/6 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 7/8 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply):
 System set-up Alarm history report

Technician Name (print): RICHARD MASON Signature: _____
 Certification No.: 5297857-UT / B36880 License No.: C61/ D40 A 809850
 Testing Company Name: RICH ENVIRONMENTAL Phone No.: (661) 392-8687
 Testing Company Address: 5643 BROOKS CT. BAKERSFIELD, CA 93308 Date of Testing/Serviceing: 2/4/2016

64156
JL

D. Results of Testing/Serviceing

Software Version Installed: 332.00

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the audible alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is the visual alarm operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors visually inspected, functionally tested, and confirmed operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all sensors installed at lowest point of secondary containment and positioned so that other equipment will not interfere with their proper operation?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	If alarms are relayed to a remote monitoring station, is all communications equipment (e.g., modem) operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected? If yes: which sensors initiate positive shut-down? <i>(Check all that apply)</i> <input checked="" type="checkbox"/> Sump/Trench Sensors; <input type="checkbox"/> Dispenser Containment Sensors. Did you confirm positive shut-down due to leaks <u>and</u> sensor failure/disconnection? <input checked="" type="checkbox"/> Yes; <input type="checkbox"/> No.
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For tank systems that utilize the monitoring system as the primary tank overfill warning device (i.e., no mechanical overfill prevention valve is installed), is the overfill warning alarm visible and audible at the tank fill point(s) and operating properly? If so, at what percent of tank capacity does the alarm trigger? %
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes, or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E, below.
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was liquid found inside any secondary containment systems designed as dry systems? <i>(Check all that apply)</i> <input type="checkbox"/> Product; <input type="checkbox"/> Water. If yes, describe causes in Section E, below.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was monitoring system set-up reviewed to ensure proper settings? Attach set up reports, if applicable
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is all monitoring equipment operational per manufacturer's specifications?

* In Section E below, describe how and when these deficiencies were or will be corrected.

E. Comments:

K

Monitoring System Certification

F. In-Tank Gauging / SIR Equipment:

- Check this box if tank gauging is used only for inventory control.
- Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all tank gauging probes visually inspected for damage and residue buildup?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system product level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system water level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all probes reinstalled properly?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

G. Line Leak Detectors (LLD):

- Check this box if LLDs are not installed.

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For equipment start-up or annual equipment certification, was a leak simulated to verify LLD performance? (Check all that apply) Simulated leak rate: <input checked="" type="checkbox"/> 3 g.p.h.; <input type="checkbox"/> 0.1 g.p.h; <input type="checkbox"/> 0.2 g.p.h.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all LLDs confirmed operational and accurate within regulatory requirements?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was the testing apparatus properly calibrated?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

H. Comments:

6415 M

I. Results of Vacuum/Pressure Monitoring Equipment Testing

This page should be used to document testing and servicing of vacuum and pressure interstitial sensors. A copy of this form must be included with the Monitoring System Certification Form, which must be provided to the tank system owner/operator. The owner/operator must submit a copy of the Monitoring System Certification Form to the local agency regulating UST systems within 30 days of test date.

Manufacturer: N/A	Model:	System Type: <input type="checkbox"/> Pressure; <input type="checkbox"/> Vacuum
Sensor ID		
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
	Component(s) Monitored by this Sensor:	
	Sensor Functionality Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail Interstitial Communication Test Result: <input type="checkbox"/> Pass; <input type="checkbox"/> Fail	
How was interstitial communication verified?		
<input type="checkbox"/> Leak Introduced at Far End of Interstitial Space; ¹ <input type="checkbox"/> Gauge; <input type="checkbox"/> Visual Inspection; <input type="checkbox"/> Other (Describe in Sec. J, below)		
Was vacuum/pressure restored to operating levels in all interstitial spaces? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no, describe in Sec. J, below)		


J. Comments: N/A

¹ If the sensor successfully detects a simulated vacuum/pressure leak introduced in the interstitial space at the furthest point from the sensor, vacuum/pressure has been demonstrated to be communicating throughout the interstice.

64156
4/2

UST Monitoring Site Plan

Site Address: 2126 TAFT HWY. BAKERSFIELD, CA.



Date map was drawn: 2/14/2013.

Instructions

If you already have a diagram that shows all required information, you may include it, rather than this page, with your Monitoring System Certification. On your site plan, show the general layout of tanks and piping. Clearly identify locations of the following equipment, if installed: monitoring system control panels; sensors monitoring tank annular spaces, sumps, dispenser pans, spill containers, or other secondary containment areas; mechanical or electronic line leak detectors; and in-tank liquid level probes (if used for leak detection). In the space provided, note the date this Site Plan was prepared.

Spill Bucket Testing Report Form

This form is intended for use by contractors performing annual testing of UST spill containment structures. The completed form and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: JOHHNY QUICK	Date of Testing: 2/4/16
Facility Address: 2126 TAFT HWY. BAKERSFIELD	
Facility Contact: MR. KOOL	Phone: (661) 834-9113
Date Local Agency Was Notified of Testing :	
Name of Local Agency Inspector (if present during testing):	

2. TESTING CONTRACTOR INFORMATION

Company Name: RICH ENVIRONMENTAL
Technician Conducting Test: RICHARD MASON
Credentials ¹ : <input type="checkbox"/> CSLB Contractor <input checked="" type="checkbox"/> ICC Service Tech. <input type="checkbox"/> SWRCB Tank Tester <input type="checkbox"/> Other (Specify) _____
License Number(s): 5297857-UT

3. SPILL BUCKET TESTING INFORMATION

Test Method Used: <input checked="" type="checkbox"/> Hydrostatic <input type="checkbox"/> Vacuum <input type="checkbox"/> Other				
Test Equipment Used: VISUAL Equipment Resolution: 0.00				
Identify Spill Bucket (By Tank Number, Stored Product, etc.)	1 REG87-FILL	2 PREM91-FILL	3 DIESEL	4
Bucket Installation Type:	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump
Bucket Diameter:	12"	12"	12"	
Bucket Depth:	12"	12"	12"	
Wait time between applying vacuum/water and start of test:	30MIN	30MIN	30MIN	
Test Start Time (T _I):	9:00	9:00	9:00	
Initial Reading (R _I):	10"	10"	10"	
Test End Time (T _F):	10:00	10:00	10:00	
Final Reading (R _F):	10"	10"	10"	
Test Duration (T _F - T _I):	60MIN	60MIN	60MIN	
Change in Reading (R _F - R _I):	0	0	0	
Pass/Fail Threshold or Criteria:	0	0	0	
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

I hereby certify that all the information contained in this report is true, accurate, and in full compliance with legal requirements.

Technician's Signature: _____

Date: 2/4/16

¹ State laws and regulations do not currently require testing to be performed by a qualified contractor. However, local requirements may be more stringent.

64156
R

RICH ENVIRONMENTAL
5643 BROOKS CT. BAKERSFIELD, CA. 93308
OFFICE (661)392-8687 FAX (661)392-0621
PRODUCT LINE LEAK DETECTOR TEST

WORK SHEET

W/O#: _____

FACILITY NAME: JOHNNY QUICK

FACILITY ADDRESS: 2126 TAFT HWY. BAKERSFIELD

PRODUCT LINE TYPE: PRESSURE

PRODUCT	LEAK DETECTOR TYPE SERIAL NUMBER	TEST BELOW 3 G.P.H.	TRIP P.S.I.	PASS OR FAIL
REG87	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>2347</u>	YES	10	PASS
PREM91	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>1262</u>	YES	10	PASS
DIESEL	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>3246</u>	YES	10	PASS
	L/D TYPE : <u> </u> SERIAL # <u> </u>	YES NO		PASS FAIL

I CERTIFY THE ABOVE TESTS WERE CONDUCTED ON THIS DATE ACCORDING TO RED JACKET PUMPS FIELD TEST APPARATUS TESTING PROCEDURE AND LIMITATIONS. THE MECHANICAL LEAK DETECTOR TEST PASS / FAIL IS DETERMINED BY USING A LOW FLOW THRESHOLD TRIP RATE OF 3 GALLONS PER HOUR OR LESS AT 10 P.S.I. I ACKNOWLEDGE THAT ALL DATA COLLECTED IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE.

TECHNICIAN: RICHARD MASON

SIGNATURE: 

DATE: 2/4/16

6452
M

IN-TANK SETUP

T 1:UNLB7
PRODUCT CODE : 1
THERMAL COEFF : .000700
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
: 9000
HIGH PRODUCT : 95%
: 9500
DELIVERY LIMIT : 10%
: 1000

LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
: 1000
LEAK MIN ANNUAL : 10%
: 1000

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

COMMUNICATIONS SETUP

PORT SETTINGS:

COMM BOARD : 1 (EDIM)
RS-232 SECURITY
CODE : DISABLED

COMM BOARD : 2 (RS-232)
BAUD RATE : 9600
PARITY : NONE
STOP BIT : 1 STOP
DATA LENGTH: 8 DATA
RS-232 SECURITY
CODE : DISABLED

COMM BOARD : 3 (RS-232)
BAUD RATE : 1200
PARITY : ODD
STOP BIT : 1 STOP
DATA LENGTH: 7 DATA
RS-232 SECURITY
CODE : DISABLED

AUTO TRANSMIT SETTINGS:

AUTO LEAK ALARM LIMIT
DISABLED
AUTO HIGH WATER LIMIT
DISABLED
AUTO OVERFILL LIMIT
DISABLED
AUTO LOW PRODUCT
DISABLED
AUTO THEFT LIMIT
DISABLED
AUTO DELIVERY START
DISABLED
AUTO DELIVERY END
DISABLED
AUTO EXTERNAL INPUT ON
DISABLED
AUTO EXTERNAL INPUT OFF
DISABLED
AUTO SENSOR FUEL ALARM
DISABLED
AUTO SENSOR WATER ALARM
DISABLED
AUTO SENSOR OUT ALARM
DISABLED

RS-232 END OF MESSAGE
DISABLED

SYSTEM SETUP

FEB 4, 2016 9:21 AM

SYSTEM UNITS

U.S.
SYSTEM LANGUAGE
ENGLISH
SYSTEM DATE/TIME FORMAT
MON DD YYYY HH:MM:SS XM

JOHNNY QUICK 143
2126 TAFT HWY
BAKERSFIELD CA 93313
661-834-9113

SHIFT TIME 1 : 8:00 AM
SHIFT TIME 2 : DISABLED
SHIFT TIME 3 : DISABLED
SHIFT TIME 4 : DISABLED

TANK PER TST NEEDED WRN
DISABLED
TANK ANN TST NEEDED WRN
DISABLED

LINE RE-ENABLE METHOD
PASS LINE TEST

LINE PER TST NEEDED WRN
DISABLED
LINE ANN TST NEEDED WRN
DISABLED

PRINT TC VOLUMES
ENABLED

TEMP COMPENSATION
VALUE (DEG F): 60.0
STICK HEIGHT OFFSET
DISABLED
ULLAGE: 90%

H-PROTOCOL DATA FORMAT
HEIGHT
DAYLIGHT SAVING TIME
ENABLED
START DATE
MAR WEEK 2 SUN
START TIME
2:00 AM
END DATE
NOV WEEK 1 SUN
END TIME
2:00 AM

RE-DIRECT LOCAL PRINTOUT
DISABLED

EURO PROTOCOL PREFIX
S

SYSTEM SECURITY
CODE : 000000

MAINTENANCE HISTORY
DISABLED

TANK CHART SECURITY
DISABLED

64156
M

EVR/ISD SETUP

EVR TYPE: BALANCE
BALANCE NOZZLE TYPE
VST
VAPOR PROCESSOR TYPE
VEEDER-ROOT POLISHER

ANALYSIS TIMES
TIME: 10:00 AM
DELAY MINUTES: 1

ACCEPT HIGH ORVR:
DISABLED

ISD HOSE TABLE

ID	FP	FL	HL	AA	RR
01	01	01	02	01	02
02	02	02	02	01	02
03	03	03	02	02	02
04	04	04	02	02	02
05	05	05	02	03	02
06	06	06	02	03	02
07	07	07	02	04	02
08	08	08	02	04	02

ISD AIRFLOW METER MAP

ID	SERIAL	NUM	LABEL
1	54184	DISP	1-2 A
2	64654	DISP	3-4 A
3	54186	DISP	5-6 A
4	54207	DISP	7-8 A

ISD FUEL GRADE HOSE MAP

FP	MHH	MHH	MHH	MHH	AA
01	201	101	901	3	U 1
02	202	102	902	3	U 1
03	203	103	903	3	U 2
04	204	104	904	3	U 2
05	305	105	205	U	U 3
06	306	106	206	U	U 3
07	307	107	207	U	U 4
08	308	108	208	U	U 4

LABEL TABLE

- 1: UNASSIGNED
- 2: BLEND3
- 3: REGULAR
- 4: MID GRADE
- 5: PREMIUM
- 6: GOLD
- 7: BRONZE
- 8: SILVER
- 9: BLEND2
- 10: BLEND4

OUTPUT RELAY SETUP

R 1:87
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 1

LIQUID SENSOR ALMS
L 1:FUEL ALARM
L 4:FUEL ALARM
L 1:SENSOR OUT ALARM
L 4:SENSOR OUT ALARM

ISD SITE ALARMS
ISD GROSS PRES FAIL
ISD DEGRD PRES FAIL
ISD VAPOR LEAK FAIL
ISD VP PRES FAIL
ISD VP STATUS FAIL

ISD HOSE ALARMS
ALL:FLOW COLLECT FAIL

R 2:91
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 2

LIQUID SENSOR ALMS
L 2:FUEL ALARM
L 5:FUEL ALARM
L 2:SENSOR OUT ALARM
L 5:SENSOR OUT ALARM

ISD SITE ALARMS
ISD GROSS PRES FAIL
ISD VAPOR LEAK FAIL
ISD VP PRES FAIL
ISD VP STATUS FAIL

ISD HOSE ALARMS
ALL:FLOW COLLECT FAIL

R 3:DSL
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 3

LIQUID SENSOR ALMS
L 3:FUEL ALARM
L 6:FUEL ALARM
L 3:SENSOR OUT ALARM
L 6:SENSOR OUT ALARM

LEAK TEST METHOD

TEST ON DATE : ALL TANK
MAY 27, 2011
START TIME : DISABLED
TEST RATE : 0.20 GAL/HR
DURATION : 2 HOURS

TST EARLY STOP:DISABLED

LEAK TEST REPORT FORMAT
NORMAL

LIQUID SENSOR SETUP

L 1:87 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 2:91 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 3:DSL ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 4:87 STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 5:91 STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 6:DSL STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

----- SENSOR ALARM -----
L 4:87 STP
STP SUMP
SENSOR OUT ALARM
FEB 4, 2016 10:30 AM

FUEL ALARM
FEB 4, 2016 10:16 AM

SENSOR OUT ALARM
FEB 23, 2015 9:55 AM

* * * * * END * * * * *

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 5:91 STP
STP SUMP
SENSOR OUT ALARM
FEB 4, 2016 10:30 AM

FUEL ALARM
FEB 4, 2016 10:15 AM

SENSOR OUT ALARM
FEB 23, 2015 9:55 AM

* * * * * END * * * * *

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 6:DSL STP
STP SUMP
SENSOR OUT ALARM
FEB 4, 2016 10:30 AM

FUEL ALARM
FEB 4, 2016 10:14 AM

SENSOR OUT ALARM
FEB 23, 2015 9:55 AM

ALARM HISTORY REPORT
----- SENSOR ALARM -----
L 1:87 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 4, 2016 10:30 AM

FUEL ALARM
FEB 4, 2016 10:20 AM

FUEL ALARM
FEB 23, 2015 9:55 AM

* * * * * END * * * * *

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 2:91 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 4, 2016 10:30 AM

FUEL ALARM
FEB 4, 2016 10:20 AM

FUEL ALARM
FEB 23, 2015 9:55 AM

* * * * * END * * * * *

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 3:DSL ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 4, 2016 10:30 AM

FUEL ALARM
FEB 4, 2016 10:21 AM

FUEL ALARM
FEB 23, 2015 9:55 AM

64156
M

SMARTSENSOR SETUP

- § 1: CARBON CANISTOR
CATEGORY VAPOR VALVE
- § 2: VAPOR PRESSURE
CATEGORY VAPOR PRESSURE
- § 3: DISP 1-2 AFM
CATEGORY AIR FLOW METER
- § 4: DISP 3-4 AFM
CATEGORY AIR FLOW METER
- § 5: DISP 5-6 AFM
CATEGORY AIR FLOW METER
- § 6: DISP 7-8 AFM
CATEGORY AIR FLOW METER
- § 8: ATM
CATEGORY ATM P SENSOR

64156
K

MONITOR CERT. FAILURE REPORT

SITE NAME: JOHNNY QUICK **DATE: 2/4/16**

ADDRESS: 2126 TAFT HWY **TECHNICIAN: RICHARD MASON**

CITY: BAKERSFIELD **SIGNATURE:** 

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS: NONE

LABOR: NONE

PARTS INSTALLED: NONE

NAME: _____ **TITLE:** _____

SIGNATURE: _____

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENENCE.

Secondary Containment Testing Report Form

This form is intended for use by contractors performing periodic testing of UST secondary containment systems. Use the appropriate pages of this form to report results for all components tested. The completed form, written test procedures, and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name: JOHNNY QUICK	Date of Testing: 6/13/16
Facility Address: 2126 TAFT HWY, BAKERSFIELD	
Facility Contact: MR. KOOL	Phone:
Date Local Agency Was Notified of Testing :	
Name of Local Agency Inspector (if present during testing):	

2. TESTING CONTRACTOR INFORMATION

Company Name: Rich Environmental		
Technician Conducting Test: JAMES J RICH		
Credentials: <input checked="" type="checkbox"/> CSLB Licensed Contractor	<input type="checkbox"/> SWRCB Licensed Tank Tester	
License Type: C61/D40 A	License Number: 809850	
Manufacturer Training		
Manufacturer	Component(s)	Date Training Expires
INCON	TS-ST5	11/17/16


3. SUMMARY OF TEST RESULTS

Component	Pass	Fail	Not Tested	Repairs Made	Component	Pass	Fail	Not Tested	Repairs Made
87 ANNULAR	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	UDC #7/8	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
91 ANNULAR	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	87 SPILL BUCKET	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DIESEL ANNULAR	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	91 SPILL BUCKET	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
87 SECONDARY PIPE	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	DIESEL SPILL BUCKET	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
91 SECONDARY PIPE	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	87 VPR SPILL BUCKET	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DIESEL SEC PIPE	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	91 VPR SPILL BUCKET	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
87 STP	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	DSL EXTRA SPILL BKT	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
91 STP	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DIESEL STP	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
UDC #1/2	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
UDC #3/4	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
UDC #5/6	X	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

If hydrostatic testing was performed, describe what was done with the water after completion of tests:

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

To the best of my knowledge, the facts stated in this document are accurate and in full compliance with legal requirements

Technician's Signature: 

Date: 6/13/16

4. TANK ANNULAR TESTING

Test Method Developed By:	<input type="checkbox"/> Tank Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer	
	<input type="checkbox"/> Other (Specify)			
Test Method Used:	<input type="checkbox"/> Pressure	<input checked="" type="checkbox"/> Vacuum	<input type="checkbox"/> Hydrostatic	
	<input type="checkbox"/> Other (Specify)			
Test Equipment Used: 4" DIAL GAUGE	Equipment Resolution:			
	Tank # 87	Tank # 91	Tank # DSL	Tank #
Is Tank Exempt From Testing? ¹	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Tank Capacity:	10K	10K	10K	
Tank Material:	STEEL	STEEL	STEEL	
Tank Manufacturer:	UNKNOWN	UNKNOWN	UNKNOWN	
Product Stored:	UNL-87	UNL-91	DIESEL	
Wait time between applying pressure/vacuum/water and starting test:	30MIN	30MIN	30MIN	
Test Start Time:	1:00	2:00	2:30	
Initial Reading (R _I):	10.4	10.0	10.0	
Test End Time:	2:00	3:00	3:30	
Final Reading (R _F):	10.4	10.0	10.0	
Test Duration:	60MIN	60MIN	60MIN	
Change in Reading (R _F -R _I):	0	0	0	
Pass/Fail Threshold or Criteria:	0	0	0	
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ Secondary containment systems where the continuous monitoring automatically monitors both the primary and secondary containment, such as systems that are hydrostatically monitored or under constant vacuum, are exempt from periodic containment testing. {California Code of Regulations, Title 23, Section 2637(a)(6)}

6. PIPING SUMP TESTING

Test Method Developed By:	<input type="checkbox"/> Sump Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
	<input type="checkbox"/> Other (Specify)		
Test Method Used:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic
	<input type="checkbox"/> Other (Specify)		
Test Equipment Used: INCON TS-ST5	Equipment Resolution:		
	Sump # 87	Sump # 91	Sump # DSL
	Sump #		
Sump Diameter:	40"	40"	40"
Sump Depth:	43"	43"	43"
Sump Material:	FIBERGLASS	FIBERGLASS	FIBERGLASS
Height from Tank Top to Top of Highest Piping Penetration:	12"	12"	12"
Height from Tank Top to Lowest Electrical Penetration:	30"	30"	30"
Condition of sump prior to testing:	GOOD	GOOD	GOOD
Portion of Sump Tested ¹	14"	14"	14"
Does turbine shut down when sump sensor detects liquid (both product and water)?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Turbine shutdown response time	N/A	N/A	N/A
Is system programmed for fail-safe shutdown?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Was fail-safe verified to be operational?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Wait time between applying pressure/vacuum/water and starting test:	30MIN	30MIN	30MIN
Test Start Time:	10:20	10:38	10:20 10:38
Initial Reading (R _I):	5.313	5.312	4.101 4.093 4.096 4.095
Test End Time:	10:35	10:53	10:35 11:20 10:35 10:53
Final Reading (R _F):	5.313	5.312	4.100 4.091 4.095 4.094
Test Duration:	15MIN	15MIN	15MIN 15MIN 15MIN 15MIN
Change in Reading (R _F -R _I):	.000	.000	.001 .001 .000 .001
Pass/Fail Threshold or Criteria:	.002	-.002	-.002 -.002 -.002 -.002
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ If the entire depth of the sump is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire sump must be tested. (See SWRCB LG-160)

7. UNDER-DISPENSER CONTAINMENT (UDC) TESTING

Test Method Developed By:	<input type="checkbox"/> UDC Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer					
	<input type="checkbox"/> Other (Specify)							
Test Method Used:	<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic					
	<input type="checkbox"/> Other (Specify)							
Test Equipment Used: INCON TS-ST5	Equipment Resolution:							
	UDC # 1/2	UDC # 3/4	UDC # 5/6	UDC # 7/8				
UDC Manufacturer:	UNKNOWN	UNKNOWN	UNKNOWN	UNKNOWN				
UDC Material:	FIBERGLASS	FIBERGLASS	FIBERGLASS	FIBERGLASS				
UDC Depth:	26"	26"	26"	26"				
Height from UDC Bottom to Top of Highest Piping Penetration:	12"	12"	12"	12"				
Height from UDC Bottom to Lowest Electrical Penetration:	14"	14"	14"	14"				
Condition of UDC prior to testing:	GOOD	GOOD	GOOD	GOOD				
Portion of UDC Tested ¹	14"	14"	14"	14"				
Does turbine shut down when UDC sensor detects liquid (both product and water)?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA				
Turbine shutdown response time	N/A	N/A	N/A	N/A				
Is system programmed for fail-safe shutdown?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA				
Was fail-safe verified to be operational?*	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA				
Wait time between applying pressure/vacuum/water and starting test	30MIN	30MIN	30MIN	30MIN				
Test Start Time:	11:38	12:13	11:38	11:55	1:03	1:21	11:38	11:55
Initial Reading (R _I):	2.668	2.663	3.936	3.936	5.007	5.007	7.151	7.153
Test End Time:	11:53	12:28	11:53	12:10	1:18	1:36	11:53	12:10
Final Reading (R _F):	2.667	2.662	3.936	3.939	5.007	5.007	7.152	7.153
Test Duration:	15MIN	15MIN	15MIN	15MIN	15MIN	15MIN	15MIN	15MIN
Change in Reading (R _F -R _I):	.000	.001	.000	.000	.000	.000	.001	.000
Pass/Fail Threshold or Criteria:	.002	.002	.002	.002	.002	.002	.002	.002
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail
Was sensor removed for testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments -- (include information on repairs made prior to testing, and recommended follow-up for failed tests)

¹ If the entire depth of the UDC is not tested, specify how much was tested. If the answer to any of the questions indicated with an asterisk (*) is "NO" or "NA", the entire UDC must be tested. (See SWRCB LG-160)

8. FILL RISER CONTAINMENT SUMP TESTING

Facility is Not Equipped With Fill Riser Containment Sumps <input type="checkbox"/>				
Fill Riser Containment Sumps are Present, but were Not Tested <input type="checkbox"/>				
Test Method Developed By:		<input type="checkbox"/> Sump Manufacturer	<input checked="" type="checkbox"/> Industry Standard	<input type="checkbox"/> Professional Engineer
		<input type="checkbox"/> Other (Specify)		
Test Method Used:		<input type="checkbox"/> Pressure	<input type="checkbox"/> Vacuum	<input checked="" type="checkbox"/> Hydrostatic
		<input type="checkbox"/> Other (Specify)		
Test Equipment Used: INCON TS-ST5			Equipment Resolution:	
	Fill Sump #	Fill Sump #	Fill Sump #	Fill Sump #
Sump Diameter:				
Sump Depth:				
Height from Tank Top to Top of Highest Piping Penetration:				
Height from Tank Top to Lowest Electrical Penetration:				
Condition of sump prior to testing:				
Portion of Sump Tested				
Sump Material:				
Wait time between applying pressure/vacuum/water and starting test:				
Test Start Time:				
Initial Reading (R _I):				
Test End Time:				
Final Reading (R _F):				
Test Duration:				
Change in Reading (R _F -R _I):				
Pass/Fail Threshold or Criteria:				
Test Result:	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Is there a sensor in the sump?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Does the sensor alarm when either product or water is detected?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor removed for testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Was sensor properly replaced and verified functional after testing?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

NO FILL SUMPS AT THIS SITE

RICH ENVI.
JOHNNY QUIK
2126 TAFT HWY
BAKERSFIELD CA 93313

06/13/2016 11:53 AM

SUMP LEAK TEST REPORT

DSP 1-2

TEST STARTED 11:38 AM
TEST STARTED 06/13/2016
BEGIN LEVEL 2.6684 IN
END TIME 11:53 AM
END DATE 06/13/2016
END LEVEL 2.6675 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

DSP 7-8

TEST STARTED 11:38 AM
TEST STARTED 06/13/2016
BEGIN LEVEL 7.1516 IN
END TIME 11:53 AM
END DATE 06/13/2016
END LEVEL 7.1528 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

DSP 3-4

TEST STARTED 11:38 AM
TEST STARTED 06/13/2016
BEGIN LEVEL 3.9362 IN
END TIME 11:53 AM
END DATE 06/13/2016
END LEVEL 3.9362 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

DSP 5-6

TEST STARTED 11:38 AM
TEST STARTED 06/13/2016
BEGIN LEVEL 6.9028 IN
END TIME 11:53 AM
END DATE 06/13/2016
END LEVEL 6.8791 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

JOHNNY QUIK
2126 TAFT HWY
BAKERSFIELD CA 93313

06/13/2016 10:53 AM

SUMP LEAK TEST REPORT

DSL STP

TEST STARTED 10:38 AM
TEST STARTED 06/13/2016
BEGIN LEVEL 4.0955 IN
END TIME 10:53 AM
END DATE 06/13/2016
END LEVEL 4.0944 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

91 STP

TEST STARTED 10:38 AM
TEST STARTED 06/13/2016
BEGIN LEVEL 4.1005 IN
END TIME 10:53 AM
END DATE 06/13/2016
END LEVEL 4.0981 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

87 STP

TEST STARTED 10:38 AM
TEST STARTED 06/13/2016
BEGIN LEVEL 5.3129 IN
END TIME 10:53 AM
END DATE 06/13/2016
END LEVEL 5.3126 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

JOHNNY QUIK
2126 TAFT HWY
BAKERSFIELD CA 93313

06/13/2016 10:35 AM

SUMP LEAK TEST REPORT

DSL STP

TEST STARTED 10:20 AM
TEST STARTED 06/13/2016
BEGIN LEVEL 4.0960 IN
END TIME 10:35 AM
END DATE 06/13/2016
END LEVEL 4.0956 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

91 STP

TEST STARTED 10:20 AM
TEST STARTED 06/13/2016
BEGIN LEVEL 4.1018 IN
END TIME 10:35 AM
END DATE 06/13/2016
END LEVEL 4.1007 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

87 STP

TEST STARTED 10:20 AM
TEST STARTED 06/13/2016
BEGIN LEVEL 5.3131 IN
END TIME 10:35 AM
END DATE 06/13/2016
END LEVEL 5.3130 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

Handwritten mark

RICH ENVI.
JDHNNY QUIK
2126 TAFT HWY
BAKERSFIELD CA 93313

06/13/2016 1:18 PM

SUMP LEAK TEST REPORT

DSP 5-6

TEST STARTED 1:03 PM
TEST STARTED 06/13/2016
BEGIN LEVEL 5.0073 IN
END TIME 1:18 PM
END DATE 06/13/2016
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

RICH ENVI.
JDHNNY QUIK
2126 TAFT HWY
BAKERSFIELD CA 93313

06/13/2016 12:29 PM

SUMP LEAK TEST REPORT

DSP 1-2

TEST STARTED 12:13 PM
TEST STARTED 06/13/2016
BEGIN LEVEL 2.6637 IN
END TIME 12:28 PM
END DATE 06/13/2016
END LEVEL 2.6626 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

DSP 7-8

TEST STARTED 12:13 PM
TEST STARTED 06/13/2016
BEGIN LEVEL 7.1627 IN
END TIME 12:28 PM
END DATE 06/13/2016
END LEVEL 7.1640 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

DSP 3-4

TEST STARTED 12:13 PM
TEST STARTED 06/13/2016
BEGIN LEVEL 3.9316 IN
END TIME 12:28 PM
END DATE 06/13/2016
END LEVEL 3.9302 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

DSP 5-6

TEST STARTED 12:13 PM
TEST STARTED 06/13/2016
BEGIN LEVEL 6.8449 IN
END TIME 12:28 PM
END DATE 06/13/2016
END LEVEL 6.8016 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

RICH ENVI.
JDHNNY QUIK
2126 TAFT HWY
BAKERSFIELD CA 93313

06/13/2016 12:10 PM

SUMP LEAK TEST REPORT

DSP 1-2

TEST STARTED 11:55 AM
TEST STARTED 06/13/2016
BEGIN LEVEL 2.6670 IN
END TIME 12:10 PM
END DATE 06/13/2016
END LEVEL 2.6648 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

DSP 7-8

TEST STARTED 11:55 AM
TEST STARTED 06/13/2016
BEGIN LEVEL 7.1535 IN
END TIME 12:10 PM
END DATE 06/13/2016
END LEVEL 7.1539 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

DSP 3-4

TEST STARTED 11:55 AM
TEST STARTED 06/13/2016
BEGIN LEVEL 3.9360 IN
END TIME 12:10 PM
END DATE 06/13/2016
END LEVEL 3.9358 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

DSP 5-6

TEST STARTED 11:55 AM
TEST STARTED 06/13/2016
BEGIN LEVEL 6.8626 IN
END TIME 12:10 PM
END DATE 06/13/2016
END LEVEL 6.8461 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT FAILED

RICH ENVI.
JDHNNY QUIK
2126 TAFT HWY
BAKERSFIELD CA 93313

06/13/2016 1:18 PM

SUMP LEAK TEST REPORT

DSP 5-6

TEST STARTED 1:21 PM
TEST STARTED 06/13/2016
BEGIN LEVEL 5.0073 IN
END TIME 1:36 PM
END DATE 06/13/2016
END LEVEL 5.0073 IN
LEAK THRESHOLD 0.002 IN
TEST RESULT PASSED

SB989 TESTING FAILURE REPORT

SITE NAME: JOHNNY QUICK **DATE:** 6/13/16

ADDRESS: 2126 TAFT HWY **TECHNICIAN:** JAMES RICH

CITY: BAKERSFIELD **SIGNATURE:** _____

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS: NONE

LABOR: NONE

PARTS INSTALLED: NONE

NAME: _____ **TITLE:** _____

SIGNATURE: _____

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENENCE.



UNDERGROUND STORAGE TANK INSPECTION REPORT

Facility Name: K & S Food Store		Facility ID: FA0002691
Site Address: 2126 TAFT HWY BAKERSFIELD, CA 93313		CERS ID: 10233775
Phone: (661) 834-9113		BOE #:
Consent Granted By:		Inspection Date: 06/16/2017
Designated Operator:		Testing Company:
Inspection Type: <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Reinspection	Reinspection required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

File/CERS Review Violations

V	Viol #	Summary	Code
	H650	Failure to obtain a valid Permit to Operate	HSC 6.7 25284
	H651	Failure to submit accurate UST Facility and Tank Information	HSC 6.7 25284, 25286; 23 CCR 16 2711
	H779	Failure to have an approved UST Monitoring Plan	23 CCR 16 2632(d)(1), 2634(d), 2641(h)
	H655	Failure to submit or update a UST Monitoring Site Plan	23 CCR 16 2632(d)(1)(C), 2641(h), 2711(a)(8)
	H724	Failure to submit/maintain a current Certification of Financial Responsibility and/or mechanism of financial assurance	HSC 6.7 25292.2; HSC 6.75 25299.30-25299.34; 23 CCR 16 2711; 23 CCR 18 2808.1, 2809-2809.2
	H780	Failure to have an approved UST Response Plan	23 CCR 16 2632(d)(2), 2634(e), 2641(h)
	H739	Failure to implement/maintain an Owner/Operator Written Agreement	HSC 6.7 25284(a)(3)(A) & (B); 23 CCR 16 2620(b)
	H661	Failure to notify the CUPA of a change in designated operator (DO)	23 CCR 16 2715(a)
	H662	Failure to complete the annual Monitoring System Certification	23 CCR 16 2638(a) & (b), 2641(i), 2715(i)
	H664	Failure to test all spill bucket(s) annually	HSC 6.7 25284.2
	H663	Failure to complete secondary containment testing as required	23 CCR 16 2637
	H669	Failure to inspect an interior lined tank as required	23 CCR 16 2663
	H675	Failure to conduct the required enhanced leak detection (ELD) testing for tanks within 1,000 feet of a public well	HSC 6.7 25292.4(a), 25292.5(a); 23 CCR 16 2640(e), 2644.1

General Violations

V	Viol #	Summary	Code
	H741	Failure to comply with all Permit to Operate requirements	23 CCR 16 2712
	U001	Failure of individuals installing/maintaining/inspecting UST systems to possess current/proper licenses and certifications	23 CCR 16 2715
	H680	Improper installation/programming/operation of leak detection equipment	23 CCR 16 2638(a), 2641(i)
	H694	Failure of leak detection equipment to be located in the proper position	23 CCR 16 2630(d), 2641(a)
	H716	Failure to maintain spill bucket(s) according to requirements	23 CCR 16 2635(b)(1), 2665
	H720	Failure of overflow prevention system to function as required	23 CCR 16 2635(b)(2), 2665
	H681	Failure of leak detection equipment to have continuous monitoring and audible/visual alarms	23 CCR 16 2632(c)(2)(B), 2634(d)(1)(A), 2636(f)(1)
	H704	Failure to install line leak detectors (LLD) on pressurized piping	HSC 6.7 25290.1(h), 25290.2(g), 25291(f), 25292(e); 23 CCR 16 2636(f)(2)
	H708	Failure of line leak detector(s) to function as required	23 CCR 16 2636(f)(2)
	U687	Failure of UDC monitoring to activate audible/visual alarm or stop the flow of product at the dispenser	23 CCR 16 2636(f)(1)

Inspector: WAQAR RUSTAM

Inspection Date: 06/16/2017

General Violations - continued

V	Viol #	Summary	Code
	H711	Failure to keep water out of the secondary containment of UST systems installed on or after July 1, 2003	HSC 6.7 25290.1(c)(3), 25290.2(c)(3)
	H795	Failure to construct/operate/maintain primary containment as product-tight	HSC 6.7 25290.1(c)(1), 25290.2(c)(1), 25291(a)(1); 23 CCR 16 2631(a)
	H719	Failure to operate the UST system to prevent unauthorized releases including leaks, spills, and/or overfills	HSC 6.7 25292.1(a)
	H684	Failure to properly affix tag/sticker on certified monitoring equipment	23 CCR 16 2638(f)
	H695	Tampering with leak detection equipment	HSC 6.7 25299(a)(9)

Double Walled Tank Violations

V	Viol #	Summary	Code
	H682	Failure to have continuous monitoring of the secondary containment that activates an audible/visual alarm	23 CCR 16 2631(g), 2632(c)(2)(A)&(B)
	H699	Failure to continuously monitor secondary containment using vacuum, pressure, or hydrostatic (VPH)	HSC 6.7 25290.1(e)
	H714	Failure to maintain product-tight secondary containment	HSC 6.7 25290.1(c), 25290.2(c), 25291(a)(2), 25292(e)

Double Walled Piping Violations

V	Viol #	Summary	Code
	H687	Failure to continuously monitor the secondary containment that activates an audible/visual alarm and stops the flow at the dispenser	23 CCR 16 2636(f)(1)
	H686	Failure of secondary containment monitoring to provide fail safe and positive shutdown in lieu of annual line integrity testing	23 CCR 16 2636(f)(5)
	H666	Failure to comply with annual line integrity testing	HSC 6.7 25290.2(g), 25291(f), 25292(e); 23 CCR 16 2636(f)(4)
	H712	Failure to maintain secondary containment to allow product to be detected at the earliest possible opportunity	23 CCR 16 2630(d), 2641(a)

Single Walled Tank Violations

V	Viol #	Summary	Code
	H692	Failure to install automatic tank gauge (ATG) or continuous in tank leak detection (CITLD)	HSC 6.7 25292(a); 23 CCR 16 2643
	H689	Failure of ATG to conduct monthly 0.2 gph leak test and print results	23 CCR 16 2643(b)(1)
	H688	Failure of CITLD to conduct monthly 0.2 gph leak test and print results	23 CCR 16 2643(b)(5)
	H685	Failure to use ATG to conduct 0.1 gallon-per-hour monthly leak test and manual inventory reconciliation for low volume tanks	23 CCR 16 2643(b)(2)
	H755	Failure to install a corrosion protection system that meets the consensus standards	23 CCR 16 2635(a)(2)(A), 2662(c)(1)(B)
	H701	Failure to have cathodic protection system turned on, maintained, and inspected as required	23 CCR 16 2635(a)(2)(A), 2662(c)(1)(B)

Single Walled Piping Violations

V	Viol #	Summary	Code
	H703	Failure to perform monthly 0.2 gph or annual 0.1 gph line integrity tests	HSC 6.7 25292(e); 23 CCR 16 2643(c)
	H707	Failure of the line leak detector to provide fail safe and positive shut down	23 CCR 16 2666(c)
	H709	Failure of safe suction piping to be installed (proper slope and check valve) and inspected as required	23 CCR 16 2636(a)(3), 2641(b)
	H667	Failure to perform 0.1 gph line integrity tests every three years on conventional suction piping	23 CCR 16 2643(d)

Inspector: WAQAR RUSTAM

Inspection Date: 06/16/2017

On Site Records Violations

V	Viol #	Summary	Code
	H792	Failure to retain a copy of the Permit to Operate at the facility	23 CCR 16 2712(i)
	H726	Failure to maintain copies of the designated operator's monthly inspection reports on site as required	23 CCR 16 2715(e)
	H727	Failure of designated operator to comply with all monthly inspection requirements	23 CCR 16 2715(c)
	H781	Failure to maintain a list of employees trained by the designated operator on site	23 CCR 16 2715(f)(3)
	H729	Failure to maintain alarm logs, maintenance records, and response follow-up documentation	23 CCR 16 2632, 2634, 2712(b)
	H736	Failure to maintain records of repairs, linings, and upgrades for the life of the UST	23 CCR 16 2712(b)
	H737	Failure to maintain corrosion protection records as required	23 CCR 16 2712(b)
	H738	Failure to have an approved UST Monitoring Plan on site	23 CCR 16 2712(i)
	H654	Failure to have an approved UST Response Plan on site	23 CCR 16 2712(i)
	H740	Failure to record any unauthorized release from the primary containment	HSC 6.7 29294

Compliance/Enforcement Violations

V	Viol #	Summary	Code
	H674	Failure to notify the CUPA 48 hours prior to testing	23 CCR 16 2637(f), 2638(e), 2643(g), 2644.1(a)(4)
	H788	Failure to submit annual Monitoring System Certification results within 30 days of completion of the test	23 CCR 16 2638(d)
	H665	Failure to submit secondary containment test results within 30 days of the test	23 CCR 16 2637(e)
	H670	Failure to complete tank lining certification/testing as required	23 CCR 16 2663
	H672	Failure to submit enhanced leak detection test results as required	23 CCR 16 2644.1(a)(5)
	H787	Failure to correct previous violations within 30 days of receiving the inspection report	23 CCR 16 2712(f)
	H660	Making false statements/representation on any document	HSC 6.7 25299
	U002	Failure to obtain a permit from the CUPA before beginning any work that requires a permit	KCOC 8.48.050
	H791	Failure to properly report an unauthorized release	HSC 6.7 25295(a)(1); 23 CCR 16 2650(e), 2652
	H749	Failure to repair and/or retest any failures detected during enhanced leak detection testing	HSC 6.7 25292.4(d), 25292.5(c)
	H747	Failure to comply with all temporary closure requirements	HSC 6.7 25298; 23 CCR 16 2670, 2671
	H748	Failure to comply with all permanent closure requirements	HSC 6.7 25298; 23 CCR 16 2670, 2672
	H746	Facility allowed the deposit of petroleum into a UST that has a red tag affixed to the fill	23 CCR 16 2717.1(f)
	H745	Red Tag has been removed, defaced, altered, or otherwise tampered with	23 CCR 16 2717.1(g)

Inspector: WAQAR RUSTAM

Inspection Date: 06/16/2017

SUMMARY OF OBSERVATIONS/VIOLATIONS

- No violations of underground storage tank laws/regulations were discovered. Kern County CUPA greatly appreciates your efforts to comply with all the laws and regulations applicable to your facility.
- Violations were observed/discovered as listed below. All violations must be corrected by implementing the corrective action listed below each violation. If you disagree with any of the violations or corrective actions required, please inform the CUPA in writing.

ALL VIOLATIONS MUST BE CORRECTED WITHIN 30 DAYS OR AS OTHERWISE SPECIFIED. Kern County CUPA must be informed in writing with a certification that compliance has been achieved. A false statement that compliance has been achieved is a violation of the law and punishable by a fine of not less than \$2,000 or more than \$25,000 for each violation. Your facility may be reinspected any time during normal business hours. If a second reinspection becomes necessary due to non-compliance, a reinspection charge of \$125.00 per hour may be charged to the facility.

You may request a meeting with the inspector and/or the CUPA Program Supervisor to discuss the inspection findings and/or the proposed corrective actions. The issuance of this Summary of Violations does not preclude the CUPA from taking administrative, civil, or criminal action.

Facility Name: K & S Food Store

Facility ID: FA0002691

CERS ID: 10233775

INSPECTION COMMENTS:



Inspector: WAQAR RUSTAM

Signature of Facility Representative:

Inspection Date: 06/16/2017

Inspector: WAQAR RUSTAM

Inspection Date: 06/16/2017

Printed: 06/26/2017

Page 4 of 4

68215

MONITORING SYSTEM CERTIFICATION

For Use By All Jurisdictions Within the State of California

Authority Cited: Chapter 6.7, Health and Safety Code; Chapter 16, Division 3, Title 23, California Code of Regulations

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

A. General Information

Facility Name: K&S FOOD STORE Bldg. No.: _____
 Site Address: 2126 TAFT HWY City: BAKERSFIELD Zip: 93313
 Facility Contact Person: MR. KOOL Contact Phone No.: (661) 834-9113
 Make/Model of Monitoring System: TLS-350 Date of Testing/Servicing: 2/8/2017

B. Inventory of Equipment Tested/Certified

Check the appropriate boxes to indicate specific equipment inspected/serviced:

Tank ID: REG87 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: PREM91 <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Tank ID: DIESEL <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>420</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>RED JACKET</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	Tank ID: _____ <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input type="checkbox"/> Annular Space or Vault Sensor. Model: _____ <input type="checkbox"/> Piping Sump / Trench Sensor(s). Model: _____ <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
Dispenser ID: 1/2 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 3/4 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: 5/6 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: 7/8 <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>406</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
Dispenser ID: _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	Dispenser ID: _____ <input type="checkbox"/> Dispenser Containment Sensor(s). Model: _____ <input type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).

*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply):

System set-up Alarm history report

Technician Name (print): DONNY BROCK Signature: _____
 Certification No.: 8325570-UT / B46599 License No.: C61/D40 A 809850
 Testing Company Name: RICH ENVIRONMENTAL Phone No.: (661) 392-8687
 Testing Company Address: 5643 BROOKS CT. BAKERSFIELD, CA 93308 Date of Testing/Servicing: 2/8/2017

Monitoring System Certification

F. In-Tank Gauging / SIR Equipment:

- Check this box if tank gauging is used only for inventory control.
- Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Complete the following checklist:

<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all tank gauging probes visually inspected for damage and residue buildup?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system product level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system water level readings tested?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all probes reinstalled properly?
<input type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

* In Section H, below, describe how and when these deficiencies were or will be corrected.

G. Line Leak Detectors (LLD):

- Check this box if LLDs are not installed.

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For equipment start-up or annual equipment certification, was a leak simulated to verify LLD performance? (Check all that apply) Simulated leak rate: <input checked="" type="checkbox"/> 3 g.p.h.; <input type="checkbox"/> 0.1 g.p.h ; <input type="checkbox"/> 0.2 g.p.h.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all LLDs confirmed operational and accurate within regulatory requirements?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was the testing apparatus properly calibrated?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?


* In Section H, below, describe how and when these deficiencies were or will be corrected.

H. Comments:

Monitoring System Certification

UST Monitoring Site Plan

Site Address: 2126 TAFT HWY. BAKERSFIELD, CA.



Date map was drawn: 2/14/2013.

Instructions

If you already have a diagram that shows all required information, you may include it, rather than this page, with your Monitoring System Certification. On your site plan, show the general layout of tanks and piping. Clearly identify locations of the following equipment, if installed: monitoring system control panels; sensors monitoring tank annular spaces, sumps, dispenser pans, spill containers, or other secondary containment areas; mechanical or electronic line leak detectors; and in-tank liquid level probes (if used for leak detection). In the space provided, note the date this Site Plan was prepared.

Spill Bucket Testing Report Form

This form is intended for use by contractors performing annual testing of UST spill containment structures. The completed form and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

Facility Name:	K&S FOOD STORE	Date of Testing:	2/8/17
Facility Address:	2126 TAFT HWY. BAKERSFIELD		
Facility Contact:	MR. KOOL	Phone:	(661) 834-9113
Date Local Agency Was Notified of Testing :	1/19/17		
Name of Local Agency Inspector (if present during testing):			

2. TESTING CONTRACTOR INFORMATION

Company Name:	RICH ENVIRONMENTAL		
Technician Conducting Test:	DONNY BROCK		
Credentials ¹ :	<input type="checkbox"/> CSLB Contractor <input checked="" type="checkbox"/> ICC Service Tech. <input type="checkbox"/> SWRCB Tank Tester <input type="checkbox"/> Other (Specify) _____		
License Number(s):	8325570-UT		

3. SPILL BUCKET TESTING INFORMATION

Test Method Used:	<input checked="" type="checkbox"/> Hydrostatic <input type="checkbox"/> Vacuum <input type="checkbox"/> Other			
Test Equipment Used:	VISUAL	Equipment Resolution: 0.00		
Identify Spill Bucket (By Tank Number, Stored Product, etc.)	1 REG87-FILL	2 PREM91-FILL	3 DIESEL	4
Bucket Installation Type:	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump	<input type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump
Bucket Diameter:	12"	12"	12"	
Bucket Depth:	12"	12"	12"	
Wait time between applying vacuum/water and start of test:	30MIN	30MIN	30MIN	
Test Start Time (T _I):	9:00	9:00	9:00	
Initial Reading (R _I):	10"	10"	10"	
Test End Time (T _F):	10:00	10:00	10:00	
Final Reading (R _F):	10"	10"	10"	
Test Duration (T _F - T _I):	60MIN	60MIN	60MIN	
Change in Reading (R _F - R _I):	0	0	0	
Pass/Fail Threshold or Criteria:	0	0	0	
Test Result:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

I hereby certify that all the information contained in this report is true, accurate, and in full compliance with legal requirements.

Technician's Signature: 

Date: 2/8/17

¹ State laws and regulations do not currently require testing to be performed by a qualified contractor. However, local requirements may be more stringent.

68215

M

RICH ENVIRONMENTAL
 5643 BROOKS CT. BAKERSFIELD, CA. 93308
 OFFICE (661)392-8687 FAX (661)392-0621
PRODUCT LINE LEAK DETECTOR TEST

WORK SHEET

W/O#: _____

FACILITY NAME: K&S FOOD STORE


FACILITY ADDRESS: 2126 TAFT HWY. BAKERSFIELD

PRODUCT LINE TYPE: PRESSURE

PRODUCT	LEAK DETECTOR TYPE SERIAL NUMBER	TEST BELOW 3 G.P.H.	TRIP P.S.I.	PASS OR FAIL
REG87	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>2347</u>	YES	10	PASS
PREM91	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>1262</u>	YES	10	PASS
DIESEL	L/D TYPE : <u>RED JACKET</u> SERIAL # <u>3246</u>	YES	10	PASS
	L/D TYPE : <u> </u> SERIAL # <u> </u>	YES NO		PASS FAIL

I CERTIFY THE ABOVE TESTS WERE CONDUCTED ON THIS DATE ACCORDING TO RED JACKET PUMPS FIELD TEST APPARATUS TESTING PROCEDURE AND LIMITATIONS. THE MECHANICAL LEAK DETECTOR TEST PASS / FAIL IS DETERMINED BY USING A LOW FLOW THRESHOLD TRIP RATE OF 3 GALLONS PER HOUR OR LESS AT 10 P.S.I. I ACKNOWLEDGE THAT ALL DATA COLLECTED IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE.

TECHNICIAN: DONNY BROCK

SIGNATURE: 

DATE: 2/8/17

6825

M

SENSOR ALARM
L 2:91 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 8. 2017 10:26 AM

----- SENSOR ALARM -----
L 5:91 STP
STP SUMP
SENSOR OUT ALARM
FEB 8. 2017 10:12 AM

SENSOR OUT ALARM
FEB 8. 2017 10:25 AM
FUEL ALARM
FEB 8. 2017 10:25 AM

SENSOR OUT ALARM
FEB 8. 2017 10:04 AM
FUEL ALARM
FEB 8. 2017 9:54 AM

LIQUID SENSOR SETUP

L 1:87 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 2:91 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

* * * * * END * * * * *

* * * * * END * * * * *

L 3:DSL ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 4:87 STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 3:DSL ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 8. 2017 10:26 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 6:DSL STP
STP SUMP
SENSOR OUT ALARM
FEB 8. 2017 10:12 AM

L 6:DSL STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

SENSOR OUT ALARM
FEB 8. 2017 10:26 AM
FUEL ALARM
FEB 8. 2017 10:25 AM

SENSOR OUT ALARM
FEB 8. 2017 10:04 AM
FUEL ALARM
FEB 8. 2017 9:53 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 1:87 ANNULAR
ANNULAR SPACE
FUEL ALARM
FEB 8. 2017 10:26 AM

* * * * * END * * * * *

* * * * * END * * * * *

SENSOR OUT ALARM
FEB 8. 2017 10:25 AM

FUEL ALARM
FEB 8. 2017 10:25 AM

ALARM HISTORY REPORT

----- SENSOR ALARM -----
L 4:87 STP
STP SUMP
SENSOR OUT ALARM
FEB 8. 2017 10:12 AM

SENSOR OUT ALARM
FEB 8. 2017 10:04 AM

FUEL ALARM
FEB 8. 2017 9:55 AM

CUSTOM ALARMS
DISABLED

AUTO LEAK ALARM LIMIT
DISABLED
AUTO HIGH WATER LIMIT
DISABLED
AUTO OVERFILL LIMIT
DISABLED
AUTO LOW PRODUCT
DISABLED
AUTO THEFT LIMIT
DISABLED
AUTO DELIVERY START
DISABLED
AUTO DELIVERY END
DISABLED
AUTO EXTERNAL INPUT ON
DISABLED
AUTO EXTERNAL INPUT OFF
DISABLED
AUTO SENSOR FUEL ALARM
DISABLED
AUTO SENSOR WATER ALARM
DISABLED
AUTO SENSOR OUT ALARM
DISABLED

SYSTEM SETUP

FEB 8. 2017 8:32 AM

SERVICE NOTICE
DISABLED

ISO 3166 COUNTRY
CODE:

VAPOR MONITORING TYPE
CARB ISD

MASS/DENSITY
DISABLED

FISCAL HEIGHT SECURITY
DISABLED

SYSTEM UNITS
U.S.
SYSTEM LANGUAGE
ENGLISH
SYSTEM DATE/TIME FORMAT
MON DD YYYY HH:MM:SS XM

JOHNNY QUICK 143
2126 TAFT HWY
BAKERSFIELD CA 93313
661-834-9113

SHIFT TIME 1 : 8:00 AM
SHIFT TIME 2 : DISABLED
SHIFT TIME 3 : DISABLED
SHIFT TIME 4 : DISABLED

TANK PER TST NEEDED WRN
DISABLED
TANK ANN TST NEEDED WRN
DISABLED

LINE RE-ENABLE METHOD
PASS LINE TEST

LINE PER TST NEEDED WRN
DISABLED
LINE ANN TST NEEDED WRN
DISABLED

PRINT TO VOLUMES
ENABLED

TEMP COMPENSATION
VALUE (DEG F): 60.0
STICK HEIGHT OFFSET
DISABLED
ULLAGE: 90%

H-PROTOCOL DATA FORMAT
HEIGHT
DAYLIGHT SAVING TIME
ENABLED
START DATE
MAR WEEK 2 SUN
START TIME
2:00 AM
END DATE
NOV WEEK 1 SUN
END TIME
2:00 AM

RE-DIRECT LOCAL PRINTOUT
DISABLED

EURO PROTOCOL PREFIX
S

SYSTEM SECURITY
CODE : 000000

MAINTENANCE HISTORY
DISABLED

TANK CHART SECURITY
DISABLED

COMMUNICATIONS SETUP

PORT SETTINGS:

COMM BOARD : 1 (EDIM)
RS-232 SECURITY
CODE : DISABLED

COMM BOARD : 2 (RS-232)
BAUD RATE : 9600
PARITY : NONE
STOP BIT : 1 STOP
DATA LENGTH: 8 DATA
RS-232 SECURITY
CODE : DISABLED

COMM BOARD : 5 (S-SAT)
BAUD RATE : 9600
PARITY : NONE
STOP BIT : 1 STOP
DATA LENGTH: 8 DATA
RS-232 SECURITY
CODE : DISABLED
DTR NORMAL STATE: HIGH

AUTO TRANSMIT SETTINGS:

RECEIVER SETUP:

NONE

AUTO DIAL TIME SETUP:

NONE

RS-232 END OF MESSAGE
DISABLED

AUTO DIAL ALARM SETUP

T 1:UNL87
PRODUCT CODE : 1
THERMAL COEFF : .000700
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
9000
HIGH PRODUCT : 95%
9500
DELIVERY LIMIT : 10%
1000

LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
1000

LEAK MIN ANNUAL : 10%
1000

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

PRODUCT CODE : 2
THERMAL COEFF : .000700
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
9000
HIGH PRODUCT : 95%
9500
DELIVERY LIMIT : 10%
1000

LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
1000

LEAK MIN ANNUAL : 10%
1000

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

T 3:DIESEL
PRODUCT CODE : 3
THERMAL COEFF : .000450
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 10000
72.0 INCH VOL : 8192
48.0 INCH VOL : 5091
24.0 INCH VOL : 1991

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0
WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10000
OVERFILL LIMIT : 90%
9000
HIGH PRODUCT : 95%
9500
DELIVERY LIMIT : 10%
1000

LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 10%
1000

LEAK MIN ANNUAL : 10%
1000

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN
PUMP THRESHOLD : 10.00%

68215

11

LEAK TEST METHOD

TEST ON DATE : ALL TANK
MAY 27, 2011
START TIME : DISABLED
TEST RATE : 0.20 GAL/HR
DURATION : 2 HOURS

TST EARLY STOP:DISABLED

LEAK TEST REPORT FORMAT
NORMAL

LIQUID SENSOR SETUP

L 1:87 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 2:91 ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 3:DSL ANNULAR
NORMALLY CLOSED
CATEGORY : ANNULAR SPACE

L 4:87 STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 5:91 STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

L 6:DSL STP
TRI-STATE (SINGLE FLOAT)
CATEGORY : STP SUMP

OUTPUT RELAY SETUP

R 1:87
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 1

LIQUID SENSOR ALMS
L 4:FUEL ALARM
L 4:SENSOR OUT ALARM

ISD SITE ALARMS
ISD GROSS PRES FAIL
ISD DEGRD PRES FAIL
ISD VAPOR LEAK FAIL
ISD VP PRES FAIL
ISD VP STATUS FAIL

ISD HOSE ALARMS
ALL:FLOW COLLECT FAIL

R 2:91
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 2

LIQUID SENSOR ALMS
L 5:FUEL ALARM
L 5:SENSOR OUT ALARM

ISD SITE ALARMS
ISD GROSS PRES FAIL
ISD VAPOR LEAK FAIL
ISD VP PRES FAIL
ISD VP STATUS FAIL

ISD HOSE ALARMS
ALL:FLOW COLLECT FAIL

R 3:DSL
TYPE:
STANDARD
NORMALLY CLOSED

TANK #: 3

LIQUID SENSOR ALMS
L 6:FUEL ALARM
L 6:SENSOR OUT ALARM

SMARTSENSOR SETUP

§ 1:CARBON CANISTOR
CATEGORY VAPOR VALVE

§ 2:VAPOR PRESSURE
CATEGORY VAPOR PRESSURE

§ 3:DISP 1-2 AFM
CATEGORY AIR FLOW METER

§ 4:DISP 3-4 AFM
CATEGORY AIR FLOW METER

§ 5:DISP 5-6 AFM
CATEGORY AIR FLOW METER

§ 6:DISP 7-8 AFM
CATEGORY AIR FLOW METER

§ 8:ATM
CATEGORY ATM P SENSOR

EVR/ISD SETUP

EVR TYPE: BALANCE

BALANCE NOZZLE TYPE
VST

VAPOR PROCESSOR TYPE
VEEDER-ROOT POLISHER

ANALYSIS TIMES
TIME: 10:00 AM
DELAY MINUTES: 1

ACCEPT HIGH ORVR:
DISABLED

ISD HOSE TABLE

ID	FP	FL	HL	AA	RR
01	01	01	02	01	02
02	02	02	02	01	02
03	03	03	02	02	02
04	04	04	02	02	02
05	05	05	02	03	02
06	06	06	02	03	02
07	07	07	02	04	02
08	08	08	02	04	02

68215 M

ISD AIRFLOW METER MAP
ID SERIAL NUM LABEL

1 54184 DISP 1-2 A
2 64654 DISP 3-4 A
3 54186 DISP 5-6 A
4 54207 DISP 7-8 A

ISD FUEL GRADE HOSE MAP
1 2 3 4
FP MHH MHH MHH MHH AA

01 201 101 901 3 U 1
02 202 102 902 3 U 1
03 203 103 903 3 U 2
04 204 104 904 3 U 2
05 305 105 205 U U 3
06 306 106 206 U U 3
07 307 107 207 U U 4
08 308 108 208 U U 4

LABEL TABLE

1: UNASSIGNED
2: BLEND3
3: REGULAR
4: MID GRADE
5: PREMIUM
6: GOLD
7: BRONZE
8: SILVER
9: BLEND2
10: BLEND4



MONITOR CERT. FAILURE REPORT

SITE NAME: K&S FOOD STORE **DATE:** 2/8/17

ADDRESS: 2126 TAFT HWY **TECHNICIAN:** DONNY BROCK

CITY: BAKERSFIELD **SIGNATURE:** 

THE FOLLOWING COMPONENTS WERE REPLACED/REPAIRED TO COMPLETE TESTING.

REPAIRS: NONE

PARTS INSTALLED: NONE

NAME: _____ **TITLE:** _____

SIGNATURE: _____

THE ABOVE NAMED PERSON TAKES FULL RESPONSIBILITY OF NOTIFYING THE APPROPRIATE PARTY TO HAVE CORRECTIVE ACTION TAKEN TO REPAIR THE ABOVE LISTED PROBLEMS AND NOTIFYING RICH ENVIRONMENTAL FOR ANY NEEDED RETESTING. THIS ALSO RELEASES RICH ENVIRONMENTAL OF ANY FINES OR PENALTIES OCCURING FROM NON-COMPLIANCE. A COPY OF THIS DOCUMENT HAS BEEN LEFT ON-SITE FOR YOUR CONVIENENCE.



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

Central Valley Regional Water Quality Control Board

31 December 2013

LR# 3201
FA0002691

RECEIVED

Kuljit Ghuman
2126 Taft Highway
Bakersfield, CA 93313

JAN - 2 2014

KERN COUNTY
ENVIRONMENTAL HEALTH SERVICES

PRECLOSURE NOTIFICATION, UNDERGROUND STORAGE TANK RELEASE, JOHNNY QUICK #143, 2126 TAFT HIGHWAY, BAKERSFIELD, KERN COUNTY, RB CASE 5T15000929

Based on the information contained in the case file, it appears that closure may be appropriate for the underground storage tank release case. In accordance with the State Water Resources Control Board's *Low-Threat Underground Storage Tank Case Closure Policy*, the Central Valley Regional Water Quality Control Board (Central Valley Water Board) is required to provide the opportunity to interested parties in the vicinity, to participate in the case closure process.

The enclosed Public Notice has been transmitted to the parties listed on the attachment. Public comments will be accepted regarding the case closure **until 3 March 2014**. You will be notified of any comments that are received. Unless comments adverse to closure are received, Central Valley Water Board staff will mail a closure letter and case summary.

If you have any questions regarding this letter, please contact John Whiting at (559) 445-5504 or by email at jwhiting@waterboards.ca.gov.


JOHN D. WHITING
Engineering Geologist
PG 5951

SHELTON R. GRAY
Senior Engineering Geologist

Enclosure

- cc w/attachment:
- Juergen Vespermann, California Department of Transportation, Hazardous Waste Branch, Fresno
 - City of Bakersfield Public Works Department, Bakersfield
 - City of Bakersfield Building Division, Bakersfield
 - City of Bakersfield Planning Division, Bakersfield
 - Kern County Engineering, Surveying and Permit Services, Bakersfield
 - Kern County Planning and Community Development, Bakersfield
 - California Water Service, Bakersfield District, Bakersfield
 - Jonathon Buck, Advanced Environmental Concepts, Inc., Bakersfield

LA



Central Valley Regional Water Quality Control Board

PUBLIC NOTICE

CONSIDERATION OF CASE CLOSURE, UNDERGROUND STORAGE TANK RELEASE, JOHNNY QUICK #143, 2126 TAFT HIGHWAY, BAKERSFIELD, KERN COUNTY, RB CASE 5T15000929

To: Offsite Property Owners and Other Interested Persons

This letter is to inform interested parties of the Central Valley Regional Water Quality Control Board (Central Valley Water Board) consideration of closing the case, and to request comments from interested parties. After discovery of a release from the underground storage tank system in May 2013, the responsible party conducted an investigation to determine the extent of affected soil and groundwater during September 2013. The investigation determined that a small mass of gasoline and diesel range petroleum hydrocarbons remains in soil. The proposed case closure is based on Central Valley Water Board staff's conclusion that the site satisfies the State Water Resources Control Board (State Water Board) *Low-Threat Underground Storage Tank Case Closure Policy*. All technically and economically feasible cleanup has been completed. The remaining petroleum hydrocarbons should continue to degrade naturally, and should not threaten public health or groundwater.

You may participate in the case closure process by reviewing technical reports, asking questions, and providing comments. Details of the site assessment and cleanup are available to interested parties through the State Water Board GeoTracker website (<http://geotracker.waterboards.ca.gov/>) by searching for case number 5T15000929. This information may also be reviewed at the Central Valley Water Board office at 1685 "E" Street in Fresno, California. Comments regarding the proposed closure need to be submitted to the Central Valley Water Board office **by 3 March 2014**.

Interested parties with questions or comments regarding the site or the proposed action should contact John Whiting, at the above address, by e-mail at jwhiting@waterboards.ca.gov, or by telephone at (559) 445-5504.

Attachment: Distribution List (*Offsite Property Owner Survey*) prepared by Advanced Environmental Concepts, Inc.

KARL E. LONGLEY ScD, P.E., CHAIR | PAMELA C. CREEDON P.E., BCEE, EXECUTIVE OFFICER

1685 E Street, Fresno, CA 93706 | www.waterboards.ca.gov/centralvalley

Offsite Property Owner Survey

Johnny Quik #143
2126 Taft Highway
Bakersfield, CA 93313

	Owner	Site Address	Mailing Address	APN
1.	Peie Chuun – Chevron Food Mart	1999 Taft Highway, Bakersfield, CA 93313	1999 Taft Highway, Bakersfield, CA 93313	184-160-21
2.	Riddhi Inc. – AM/PM Market	2051 Taft Highway, Bakersfield, CA 93313	7012 Frog Meadow Street, Bakersfield, CA 93313	184-160-19
3.	Jack In The Box Company	2011 Taft Highway, Bakersfield, CA 93313	2011 Taft Highway, Bakersfield, CA 93313	184-160-25
4.	Fong Chung – E-Z Mart Mobil	2106 Taft Highway, Bakersfield, CA 93313	2106 Taft Highway, Bakersfield, CA 93313	514-060-20