



T. PRESTON GILLESPIE, JR.
Vice President
Oconee Nuclear Station

January 31, 2013

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Duke Energy
ON01VP / 7800 Rochester Hwy.
Seneca, SC 29672

864-873-4478
864-873-4208 fax
T.Gillespie@duke-energy.com

Subject: Duke Energy Carolinas, LLC
Oconee Nuclear Station Unit 1
Docket No. 50-269
Fourth Ten-Year Inservice Inspection Plan
Request for Relief No. 12-ON-001


Pursuant to 10 CFR 50.55a(g)(5)(iii), attached is a Request for Relief from the requirement to examine 100% of the volume specified by the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code), Section XI, Rules for Inservice Inspection of Nuclear Power Plant Components, 1998 Edition with 2000 Addenda (as modified by Code Case N-460).

The attached Request for Relief 12-ON-001 is to allow Duke Energy to take credit for the enclosed Table 1 list of limited ultrasonic examinations on welds associated with various systems and components during Unit 1 EOC26 refueling outage. The ultrasonic examination coverage of the subject Unit 1 welds did not meet the 90% examination requirements of Code Case N-460. The obtainable volume coverage for weld examination is indicated on Attachment A of the relief request. Achievement of greater examination coverage for these welds is impractical due to piping/valve geometry and interferences. Therefore, Duke Energy requests that the NRC grant relief as authorized under 10 CFR 50.55(g)(6)(i).

This submittal document contains no regulatory commitments.

If there are any questions or further information is needed you may contact Corey Gray at (864)-873-6325.

Sincerely,


T. Preston Gillespie Jr.,
Site Vice President

Enclosure: Oconee Nuclear Station - Unit 1 Relief Request 12-ON-001

A 047
NRR

U. S. Nuclear Regulatory Commission
January 31, 2013
Page 2

Xc w/att: Victor Mcree
Region II Administrator
U. S. Nuclear Regulatory Commission
Marquis One Tower
245 Peachtree Center Ave., NE, Suite 1200
Atlanta, GA 30303-1257

John Boska
Project Manager
(by electronic mail only)
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
11555 Rockville Pike
Mail Stop O-8G9A
Rockville, MD 20852-2746

Xc w/o attachment

NRC Senior Resident Inspector
Oconee Nuclear Station

Susan Jenkins
Section Manager
Division of Waste Management
Bureau of Land and Waste Management
SC Dept. of Health & Environment Control
2600 Bull St.
Columbia, SC 29201

Enclosure

Oconee Nuclear Station - Unit 1
Relief Request 12-ON-001

Oconee Relief Request 12-ON-001

1.0 Scope of Relief Request

Relief is requested pursuant to 10 CFR 50.55a(g)(5)(iii) for welds listed in Table 1. These welds were required to be examined in accordance with Inservice Inspection Plans for the following Units.

Oconee Nuclear Station - Unit 1
 Fourth 10-Year Inservice Inspection Interval
 Interval Start Date: January 01, 2004

Table 1					
<u>Relief Request Section Number</u>	<u>Oconee Unit Number</u>	<u>Examination Performed (Refueling Outage)</u>	<u>Weld ID Number</u>	<u>Item/Summary Number</u>	<u>Examination Data</u>
2.0	1	1EOC26	1-PZR-WP26-3	O1.B3.110.0011	See Attachment A Pages 1-10
3.0	1	1EOC26	1-PZR-WP26-7	O1.B3.110.0012	See Attachment A Pages 11-20
4.0	1	1EOC26	1-PIB1-9	O1.B9.11.0029	See Attachment A Pages 21-32
5.0	1	1EOC26	1-PDB1-1	O1.B9.11.0072	See Attachment A Pages 33-44
6.0	1	1EOC26	1LP-128-80	O1.C5.11.0029	See Attachment A Pages 45-51
7.0	1	1EOC26	1LP-209-17	O1.C5.11.0084	See Attachment A Pages 52-57
8.0	1	1EOC26	1LP-209-18	O1.C5.11.0085	See Attachment A Pages 58-63
9.0	1	1EOC26	1HP-192-15	O1.C5.21.0006	See Attachment A Pages 64-72
10.0	1	1EOC26	1-51A-01-91A	O1.C5.21.0024	See Attachment A Pages 73-78

Oconee Relief Request 12-ON-001

11.0	1	1EOC26	1HP-324-118B	O1.C5.21.0041	See Attachment A Pages 79-84
12.0	1	1EOC26	1-51A-02-34B	O1.C5.21.0053	See Attachment A Pages 85-91
13.0	1	1EOC26	1HP-193-12	O1.C5.21.0057	See Attachment A Pages 92-98
14.0	1	1EOC26	1-51A-01-103A	O1.C5.21.0066	See Attachment A Pages 99-106
15.0	1	1EOC26	1LPS-563-14	O1.C5.51.0050	See Attachment A Pages 107-115
16.0	1	1EOC26	1LPS-702-50	O1.C5.51.0053	See Attachment A Pages 116-124
17.0	1	1EOC26	WJ-32	PSI	See Attachment A Pages 125-133
18.0	1	1EOC26	WJ-33	PSI	See Attachment A Pages 134-144
19.0	1	1EOC26	WJ-35	PSI	See Attachment A Pages 145-153
20.0	1	1EOC26	WJ-36	PSI	See Attachment A Pages 154-162

Duke Energy procedures require ASME Code, Section XI examinations that do not meet the requirements of Code Case N-460 to be marked "reject" for tracking purposes, regardless of whether indications were noted. Therefore, the limited exams in 12-ON-001 without indications were marked "reject".

2.0 Weld #1-PZR-WP26-3

2.1. ASME Code Component(s) Affected

Unit 1 Pressurizer Heater Belt Shell to Sampling Nozzle Weld #1-PZR-WP26-3, Summary Number O1.B3.110.0011 and ASME Code Class 1.

2.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

2.3. Applicable Code Requirement

IWB-2500, Table IWB-2500-1, Examination Category B-D, Item Number B3.110 Fig. IWB-2500-7 (a), 100% Volume Coverage of Examination Volume A-B-C-D-E-F-G-H-I.

2.4. Impracticality of Compliance

Component configuration:

- Surface 1: Shell - Carbon steel
- Surface 2: Sampling nozzle - Carbon steel
- Diameter: 5.750 in.
- Thickness: 6.187 in.

This component was scanned manually with conventional methods. Scanning requirements are described in ASME Section V, Article 4, T-441.1.2(a), T-441.1.3, T-441.1.4, T-441.1.5 and T-441.1.6. These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following:

- Weld coverage using 45° & 60° shear waves for axial scans (S1, S2), and 45° & 60° shear waves for circumferential scans (CW, CCW) obtained 15.4% coverage.
- Base material coverage using 45° & 60° shear wave for axial scans (S1) and 45° & 60° shear waves for circumferential scans (CW, CCW) obtained 54.8% coverage.
- 0° scan coverage obtained 33.8% coverage.
- The aggregate coverage was calculated to be $(15.4\% + 54.8\% + 33.8\%)/3 = 34.7\%$.

The impracticality was caused by the weld taper configuration of the sampling nozzle to the shell that does not allow meaningful interrogation from Surface 2, the sampling nozzle side. In order to scan all of the required volume for this weld, the shell to sampling nozzle weld would have to be redesigned or replaced to allow scanning from both sides of the weld, which is impractical.

Oconee Relief Request 12-ON-001

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. The achieved coverage did not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were recorded during this examination. The reject box on the UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

2.5. Proposed Alternative and Basis for Use

No substitution alternative for this weld is available which would provide better coverage. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws. Use of other manual or automated UT techniques, whether conventional or phased array, were considered, but would not increase coverage due to the limitation created by the component configuration. The use of any other UT technique available would incur the same physical scanning limitations.

2.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

2.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number O1.B3.110.0011 was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each refueling outage in accordance with Table IWB-2500-1, Examination Category B-P requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), Reactor Building Normal Sump monitoring and other leakage detection systems provide additional assurance that, in the event that leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the leakage monitoring, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

2.8. References

Duke Energy Relief Request 04-ON-005 was approved by the NRC during the last inspection interval. The previous approved SE is documented in Accession Number ML050340377, TAC No.MC4527 dated March 8, 2005.

3.0 Weld #1-PZR-WP26-7

3.1. ASME Code Component(s) Affected

Unit 1 Pressurizer Heater Belt Shell to Sampling Nozzle Weld #1-PZR-WP26-7, Summary Number O1.B3.110.0012, and ASME Code Class 1.

3.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

3.3. Applicable Code Requirement

IWB-2500, Table IWB-2500-1, Examination Category B-D, Item Number B3.110 Fig. IWB-2500-7 (a), 100% Volume Coverage of Examination Volume A-B-C-D-E-F-G-H-I.

3.4. Impracticality of Compliance

Component configuration:

- Surface 1: Shell - Carbon steel
- Surface 2: Sampling nozzle - Carbon steel
- Diameter: 5.750 in.
- Thickness: 6.187 in.

This component was scanned manually with conventional methods. Scanning requirements are described in ASME Section V, Article 4, T-441.1.2(a), T-441.1.3, T-441.1.4, T-441.1.5 and T-441.1.6. These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following:

- Weld coverage using 45° & 60° shear waves for axial scans (S1, S2), and 45° & 60° shear waves for circumferential scans (CW, CCW) obtained 15.4% coverage.
- Base material coverage using 45° & 60° shear wave for axial scans (S1) and 45° & 60° shear waves for circumferential scans (CW, CCW) obtained 54.8% coverage.
- 0° scan coverage obtained 33.8% coverage.
- The aggregate coverage was calculated to be $(15.4\% + 54.8\% + 33.8\%)/3 = 34.7\%$.

The impracticality was caused by the weld taper configuration of the sampling nozzle to the shell that does not allow meaningful interrogation from Surface 2, the sampling nozzle side. In order to scan all of the required volume for this weld, the shell to sampling nozzle weld would have to be redesigned or replaced to allow scanning from both sides of the weld, which is impractical.

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. The achieved coverage did not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were recorded during this examination. The reject box on the UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

3.5. Proposed Alternative and Basis for Use

No substitution alternative for this weld is available which would provide better coverage. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws. Use of other manual or automated UT techniques, whether conventional or phased array, were considered, but would not increase coverage due to the limitation created by the component configuration. The use of any other UT technique available would incur the same physical scanning limitations.

3.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

3.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number O1.B3.110.00012 was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each refueling outage in accordance with Table IWB-2500-1, Examination Category B-P requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), Reactor Building Normal Sump monitoring and other leakage detection systems provide additional assurance that, in the event that leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the leakage monitoring, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

Oconee Relief Request 12-ON-001

3.8. References

Duke Energy Relief Request 04-ON-005 was approved by the NRC during the last inspection interval. The previous approved SE is documented in Accession Number ML050340377, TAC No.MC4527 dated March 8, 2005.

4.0 Weld #1-PIB1-9

4.1. ASME Code Component(s) Affected

Unit 1 Reactor Coolant Pump 1B1 Casing Nozzle to Safe-End Piping Weld, Weld #1-PIB1-9, Summary Number O1.B9.11.0029 and ASME Code Class 1.

4.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

4.3. Applicable Code Requirement

IWB-2500, Table IWB-2500-1, Examination Category B-J, Item Number B9.11 Figure IWB-2500-8 (c), 100% Volume Coverage of Examination Volume C-D-E-F.

4.4. Impracticality of Compliance

Component configuration:

- Surface 1: Cast Stainless Steel Nozzle
- Surface 2: Forged Stainless Steel Safe End
- NPS: 36.5 in.
- Thickness: 2.330 in.

This component was scanned manually with conventional methods. Scanning requirements are described in 10 CFR 50.55a(b)(2)(xv)(A)(1). These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following:

- 60° shear waves obtained 0% coverage in one axial direction (S1 – nozzle)
- 60° shear waves obtained 50% coverage in one axial direction (S2 – safe end)
- 45° shear waves obtained 50% coverage in one circumferential direction (CW).
- 45° shear waves obtained 50% coverage in one circumferential direction (CCW).
- The aggregate coverage was calculated to be $(0\% + 50\% + 50\% + 50\%)/4 = 37.5\%$.

In addition, best effort supplemental scanning was performed using 60° and 70° refracted longitudinal waves from the S2 pump casing side for interrogation of the upper 2/3 area within the cast material.

Oconee Relief Request 12-ON-001

Best effort supplemental scanning was also performed using 60° refracted longitudinal waves for interrogation of the lower 1/3 nozzle far side of the weld from the S1 safe-end side, but is not qualified to be calculated into the above claimed coverage. The supplemental refracted longitudinal scan was only used for interrogation in the axial direction per procedural direction. Supplemental scanning is not performed in the circumferential direction.

The impracticality was caused by the nozzle taper configuration and cast stainless steel material which cannot be effectively interrogated by ultrasound. There are currently no examination techniques that have been qualified for cast stainless steel through Appendix VIII for cast stainless steel. Therefore, coverage could not be obtained by scanning from the nozzle side. In order to scan all of the required volume for this weld, the nozzle would have to be redesigned and replaced, which is impractical.

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were recorded during this examination. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

4.5 Proposed Alternative and Basis for Use

This weld was examined using procedures, equipment and personnel qualified in accordance with ASME Section XI, Appendix VIII. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws and has not been qualified through performance demonstration. Use of other manual or automated UT techniques, whether conventional or phased array, qualified under ASME Section XI, Appendix VIII would not increase coverage due to the limitation created by the cast stainless material. The use of any other UT technique available would incur the same physical scanning limitations.

4.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

4.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number O1.B9.11.0029 was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each refueling outage in accordance with Table IWB-2500-1, Examination Category B-P requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

Oconee Relief Request 12-ON-001

In addition to the above Code required examinations (volumetric and pressure test), Reactor Building Normal Sump monitoring and other leakage detection systems provide additional assurance that, in the event that leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the leakage monitoring, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

4.8 References

None

5.0 Weld #1-PDB1-1

5.1. ASME Code Component(s) Affected

Unit 1 Reactor Coolant Pump 1B1 Casing Nozzle to Safe-End Weld,
Weld #1-PDB1-1, Summary Number O1.B9.11.0072 and ASME Code Class 1.

5.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the
2000 Addenda.

5.3. Applicable Code Requirement

IWB-2500, Table IWB-2500-1, Examination Category B-J, Item Number B9.11
Figure IWB-2500-8 (c), 100% Volume Coverage of Examination Volume
C-D-E-F.

5.4. Impracticality of Compliance

Component configuration:

- Surface 1: Forged Stainless Steel Safe End
- Surface 2: Cast Stainless Steel Nozzle
- NPS: 33.5 in.
- Thickness: 2.330 in.

This component was scanned manually with conventional methods. Scanning requirements are described in 10 CFR 50.55a(b)(2)(xv)(A)(1). These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following:

- 60° shear waves obtained 50% coverage in one axial direction (S1 – safe end)
- 60° shear waves obtained 0% coverage in one axial direction (S2 – nozzle)
- 45° shear waves obtained 50% coverage in one circumferential direction (CW).
- 45° shear waves obtained 50% coverage in one circumferential direction (CCW).
- The aggregate coverage was calculated to be $(50\% + 0\% + 50\% + 50\%)/4 = 37.5\%$.

In addition, best effort supplemental scanning was performed using 60° and 70° refracted longitudinal waves from the S2 pump casing side for interrogation of the upper 2/3 area within the cast material.

Best effort supplemental scanning was also performed using 60° refracted longitudinal waves for interrogation of the lower 1/3 nozzle on the far side of the weld from the S1 safe-end side, but is not qualified to be calculated into the above claimed coverage. The supplemental refracted longitudinal scan was only used for interrogation in the axial direction per procedural direction. Supplemental scanning is not performed in the circumferential direction.

The impracticality was caused by the nozzle taper configuration due to cast stainless steel material which cannot be effectively interrogated by ultrasound. There are currently no examination techniques that have been qualified through Appendix VIII for cast stainless steels. Therefore, coverage could not be obtained by scanning from the nozzle side. In order to scan all of the required volume for this weld, the nozzle would have to be redesigned and replaced, which is impractical.

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were recorded during this examination. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

5.5. Proposed Alternative and Basis for Use

This weld was examined using procedures, equipment and personnel qualified in accordance with ASME Section XI, Appendix VIII. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws and has not been qualified through performance demonstration. Use of other manual or automated UT techniques, whether conventional or phased array, qualified under ASME Section XI, Appendix VIII would not increase coverage due to the limitation created by the cast stainless material. The use of any other UT technique available would incur the same physical scanning limitations.

5.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

5.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number O1.B9.11.0072 was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each refueling outage in accordance with Table IWB-2500-1, Examination Category B-P requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

Oconee Relief Request 12-ON-001

In addition to the above Code required examinations (volumetric and pressure test), Reactor Building Normal Sump monitoring and other leakage detection systems provide additional assurance that, in the event that leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the leakage monitoring, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

5.8 References None

6.0 Weld #1LP-128-80

6.1. ASME Code Component(s) Affected

Unit 1 Reducer to Valve 1LP-18 Weld, Weld #1LP-128-80, Summary Number O1.C5.11.0029 and ASME Code Class 2.

6.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

6.3. Applicable Code Requirement

IWC-2500, Table IWC-2500-1, Examination Category C-F-1, Item Number C5.11 Figure IWC-2500-7(a), 100% Volume Coverage of Examination Volume C-D-E-F.

6.4. Impracticality of Compliance

Component configuration:

- Surface 1: Forged Stainless Steel Reducer
- Surface 2: Cast Stainless Steel Valve
- Diameter: 12.0 in.
- Thickness: 1.168 in.

This component was scanned manually with conventional methods. Scanning requirements are described in 10 CFR 50.55a(b)(2)(xv)(A)(1). These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following:

- 60° shear waves obtained 50% coverage in one axial direction (S1 - reducer)
- 60° shear waves obtained 0% coverage in one axial direction (S2 - valve)
- 45° shear waves obtained 50% coverage in one axial direction (S3 - CW)
- 45° shear waves obtained 50% coverage in one axial direction (S4 - CCW)
- The aggregate coverage was calculated to be $(50\% + 0 + 50\% + 50\%)/4 = 37.5\%$.

Best effort supplemental scanning was also performed using 60° refracted longitudinal waves for interrogation of the lower 1/3 valve far side of the weld from the S1 reducer side, but is not qualified to be calculated into the above claimed coverage. The supplemental refracted longitudinal scan was only used for interrogation in the axial direction per procedural direction. Supplemental scanning is not performed in the circumferential direction.

Oconee Relief Request 12-ON-001

The impracticality was caused by the cast stainless steel material which cannot be effectively interrogated by ultrasound. There are currently no examination techniques that have been qualified through Appendix VIII for cast stainless steels. Therefore, coverage could not be obtained by scanning from the valve side. In order to scan all of the required volume for this weld, the valve would have to be redesigned and replaced, which is impractical.

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were recorded during this examination. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

6.5. Proposed Alternative and Basis for Use

This weld was examined using procedures, equipment and personnel qualified in accordance with ASME Section XI, Appendix VIII. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws and has not been qualified through performance demonstration. Use of other manual or automated UT techniques, whether conventional or phased array, qualified under ASME Section XI, Appendix VIII would not increase coverage due to the limitation created by the cast stainless material. The use of any other UT technique available would incur the same physical scanning limitations.

6.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

6.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number O1.C5.11.0029 was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each inspection period in accordance with Table IWC-2500-1, Examination Category C-H requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), visual observations performed during operator rounds provide additional assurance that in the event leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable

Oconee Relief Request 12-ON-001

results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the continuing periodic leakage inspections, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

6.8 References

None

7.0 Weld #1LP-209-17

7.1. ASME Code Component(s) Affected

Unit 1 Pipe to Flow Restrictor Weld, Weld #1LP-209-17, Summary Number O1.C5.11.0084 and ASME Code Class 2.

7.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

7.3. Applicable Code Requirement

IWC-2500, Table IWC-2500-1, Examination Category C-F-1, Item Number C5.11 Figure IWC-2500-7(a), 100% Volume Coverage of Examination Volume C-D-E-F.

7.4. Impracticality of Compliance

Component configuration:

- Surface 1: Forged Stainless Pipe
- Surface 2: Cast Stainless Flow Restrictor
- Diameter: 10.0 in.
- Thickness: 1.0 in.

This component was scanned manually with conventional methods. Scanning requirements are described in 10 CFR 50.55a(b)(2)(xv)(A)(1). These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following:

- 60° shear waves obtained 50% coverage in one axial direction (S1 - pipe)
- 60° shear waves obtained 0% coverage in one axial direction (S2 – flow restrictor)
- 45° shear waves obtained 50% coverage in one axial direction (S3 - CW)
- 45° shear waves obtained 50% coverage in one axial direction (S4 - CCW)
- The aggregate coverage was calculated to be $(50\% + 0 + 50\% + 50\%)/4 = 37.5\%$.

Best effort supplemental scanning was also performed using 60° refracted longitudinal waves for interrogation of the lower 1/3 flow restrictor far side of the weld from the S1 pipe side, but is not qualified to be calculated into the above claimed coverage. The supplemental refracted longitudinal scan was only used for interrogation in the axial direction per procedural direction. Supplemental scanning is not performed in the circumferential direction.

The impracticality was caused by the cast stainless steel material which cannot be effectively interrogated by ultrasound. There are currently no examination techniques that have been qualified through Appendix VIII for cast stainless steel. Therefore, coverage could not be obtained by scanning from the flow restrictor side. In order to scan all of the required volume for this weld, the valve would have to be redesigned and replaced, which is impractical.

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were recorded during this examination. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

7.5. Proposed Alternative and Basis for Use

This weld was examined using procedures, equipment and personnel qualified in accordance with ASME Section XI, Appendix VIII. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws and has not been qualified through performance demonstration. Use of other manual or automated UT techniques, whether conventional or phased array, qualified under ASME Section XI, Appendix VIII would not increase coverage due to the limitation created by the cast stainless material. The use of any other UT technique available would incur the same physical scanning limitations.

7.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

7.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number O1.C5.11.0084 was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each inspection period in accordance with Table IWC-2500-1, Examination Category C-H requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), Reactor Building Normal Sump monitoring and other leakage detection systems provide additional assurance that, in the event that leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable

Oconee Relief Request 12-ON-001

results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the leakage monitoring, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

7.8 References

None

8.0 Weld #1LP-209-18

8.1. ASME Code Component(s) Affected

Unit 1 Pipe to Flow Restrictor Piping Weld, Weld #1LP-209-18, Summary Number O1.C5.11.0085 and ASME Code Class 2.

8.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

8.3. Applicable Code Requirement

IWC-2500, Table IWC-2500-1, Examination Category C-F-1, Item Number C5.11 Figure IWC-2500-7(a), 100% Volume Coverage of Examination Volume C-D-E-F.

8.4. Impracticality of Compliance

Component configuration:

- Surface 1: Cast Stainless Flow Restrictor
- Surface 2: Forged Stainless Pipe
- Diameter: 10.0 in.
- Thickness: 1.0 in.

This component was scanned manually with conventional methods. Scanning requirements are described in 10 CFR 50.55a(b)(2)(xv)(A)(1). These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following:

- 60° shear waves obtained 0% coverage in one axial direction (S1 – flow restrictor)
- 60° shear waves obtained 50% coverage in one axial direction (S2 - pipe)
- 45° shear waves obtained 50% coverage in one axial direction (S3 - CW)
- 45° shear waves obtained 50% coverage in one axial direction (S4 - CCW)
- The aggregate coverage was calculated to be $(0\% + 50 + 50\% + 50\%)/4 = 37.5\%$.

Best effort supplemental scanning was also performed using 60° refracted longitudinal waves for interrogation of the lower 1/3 flow restrictor far side of the weld from the S1 pipe side, but is not qualified to be calculated into the above claimed coverage. The supplemental refracted longitudinal scan was only used for interrogation in the axial direction per procedural direction. Supplemental scanning is not performed in the circumferential direction.

Oconee Relief Request 12-ON-001

The impracticality was caused by the cast stainless steel material which cannot be effectively interrogated by ultrasound. There are currently no examination techniques that have been qualified through Appendix VIII for cast stainless steel. Therefore, coverage could not be obtained by scanning from the flow restrictor side. In order to scan all of the required volume for this weld, the valve would have to be redesigned and replaced, which is impractical.

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were recorded during this examination. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

8.5. Proposed Alternative and Basis for Use

This weld was examined using procedures, equipment and personnel qualified in accordance with ASME Section XI, Appendix VIII. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws and has not been qualified through performance demonstration. Use of other manual or automated UT techniques, whether conventional or phased array, qualified under ASME Section XI, Appendix VIII would not increase coverage due to the limitation created by the cast stainless material. The use of any other UT technique available would incur the same physical scanning limitations.

8.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

8.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number O1.C5.11.0085 was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each inspection period in accordance with Table IWC-2500-1, Examination Category C-H requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), Reactor Building Normal Sump monitoring and other leakage detection systems provide additional assurance that, in the event that leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure

Oconee Relief Request 12-ON-001

testing (VT-2) examinations required by Section XI, and the leakage monitoring, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

8.8 References

None

9.0 Weld #1HP-192-15

9.1. ASME Code Component(s) Affected

Unit 1 Flange Orifice to Pipe Weld, Weld #1HP-192-15, Summary Number O1.C5.21.0006 and ASME Code Class 2.

9.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

9.3. Applicable Code Requirement

IWC-2500, Table IWC-2500-1, Examination Category C-F-1, Item Number C5.21 Figure IWC-2500-7(a), 100% Volume Coverage of Examination Volume C-D-E-F.

9.4. Impracticality of Compliance

Component configuration:

- Surface 1: Forged Stainless Steel Flange
- Surface 2: Forged Stainless Steel Pipe
- Diameter: 4.0 in.
- Thickness: 0.531 in.

This component was scanned manually with conventional methods. Scanning requirements are described in 10 CFR 50.55a(b)(2)(xv)(A)(1). These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following:

- 60° shear waves obtained 0% coverage in one axial direction (S1 –flange)
- 60° shear waves obtained 50% coverage in one axial direction (S2 - pipe)
- 45° shear waves obtained 50% coverage in one axial direction (S3 - CW)
- 45° shear waves obtained 50% coverage in one axial direction (S4 - CCW)
- The aggregate coverage was calculated to be $(0\% + 50 + 50\% + 50\%)/4 = 37.5\%$.

Best effort supplemental scanning was also performed using 70° refracted longitudinal waves for interrogation of the lower 1/3 flange far side of the weld from the S1 pipe side, but is not qualified to be calculated into the above claimed coverage. The supplemental refracted longitudinal scan was only used for interrogation in the axial direction per procedural direction. Supplemental scanning is not performed in the circumferential direction.

Oconee Relief Request 12-ON-001

The impracticality was caused by the tapered configuration of the flange, which did not allow access to the full volume of the weld. Therefore coverage could not be obtained by scanning from the flange side. In order to scan all of the required volume for this weld, the flange would have to be redesigned and replaced, which is impractical.

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

The indication detected during the examination was the result of component geometry and was not associated with flaws in the component weld. The indication was acceptable without further evaluation. The indication was dispositioned using procedure guidance on probe skewing, use of higher angles and indication plotting. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

9.5. Proposed Alternative and Basis for Use

This weld was examined using procedures, equipment and personnel qualified in accordance with ASME Section XI, Appendix VIII. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws and has not been qualified through performance demonstration. Use of other manual or automated UT techniques, whether conventional or phased array, qualified under ASME Section XI, Appendix VIII would not increase coverage due to the limitation created by the component configuration. The use of any other UT technique available would incur the same physical scanning limitations.

9.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

9.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number O1.C5.21.0006 was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each inspection period in accordance with Table IWC-2500-1, Examination Category C-H requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), visual observations performed during operator rounds provide additional assurance that in the event leakage did occur through this weld, it would be detected and proper action taken.

Oconee Relief Request 12-ON-001

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the continuing periodic leakage inspections, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

9.8. References

Duke Energy Relief Requests 02-ON-005 and 02-ON-004 were approved by the NRC during the last inspection interval. The previous approved SE's are documented in Accession Number ML32721404, TAC No.MB5815 and MC5830 dated September 29, 2003.

10.0 Weld #1-51A-01-91A

10.1. ASME Code Component(s) Affected

Unit 1 Pipe to Valve 1HP-128 Weld, Weld #1-51A-01-91A, Summary Number O1.C5.21.0024 and ASME Code Class 2.

10.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

10.3. Applicable Code Requirement

IWC-2500, Table IWC-2500-1, Examination Category C-F-1, Item Number C5.21 Figure IWC-2500-7(a), 100% Volume Coverage of Examination Volume C-D-E-F.

10.4. Impracticality of Compliance

Component configuration:

- Surface 1: Forged Stainless Steel Pipe
- Surface 2: Forged Stainless Steel Valve
- Diameter: 4.0 in.
- Thickness: 0.531 in.

This component was scanned manually with conventional methods. Scanning requirements are described in 10 CFR 50.55a(b)(2)(xv)(A)(1). These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following:

- 60° shear waves obtained 100% coverage in one axial direction (S1 – pipe)
- 60° shear waves obtained 100% coverage in one axial direction (S2 - valve)
- 45° shear waves obtained 50% coverage in one axial direction (S3 - CW)
- 45° shear waves obtained 50% coverage in one axial direction (S4 - CCW)
- The aggregate coverage was calculated to be $(100\% + 100 + 50\% + 50\%)/4 = 75.0\%$.

Best effort supplemental scanning was not applied since the requirements of the ASME Code, Section XI, Supplement 2 pertaining to refracted longitudinal wave or 70 degree shear wave methods are to be applied during single sided exams when axial scanning can only be performed from one side of the weld. 100% coverage was obtained in each axial scan direction.

Oconee Relief Request 12-ON-001

The impracticality was caused by the tapered configuration of the valve, which did not allow access to the full volume of the weld in the circumferential direction. Therefore coverage could not be obtained by scanning from the valve side. In order to scan all of the required volume for this weld, the valve would have to be redesigned and replaced, which is impractical.

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were recorded during this examination. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

10.5. Proposed Alternative and Basis for Use

This weld was examined using procedures, equipment and personnel qualified in accordance with ASME Section XI, Appendix VIII. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws and has not been qualified through performance demonstration. Use of other manual or automated UT techniques, whether conventional or phased array, qualified under ASME Section XI, Appendix VIII would not increase coverage due to the limitation created by the component configuration. The use of any other UT technique available would incur the same physical scanning limitations.

10.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

10.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number O1.C5.21.0024 was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each inspection period in accordance with Table IWC-2500-1, Examination Category C-H requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), visual observations performed during operator rounds provide additional assurance that in the event leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure

Oconee Relief Request 12-ON-001

testing (VT-2) examinations required by Section XI, and the continuing periodic leakage inspections, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

10.8. References

Duke Energy Relief Requests 02-ON-005 and 02-ON-004 were approved by the NRC during the last inspection interval. The previous approved SE's are documented in Accession Number ML32721404, TAC No.MB5815 and MC5830 dated September 29, 2003.

11.0 Weld #1HP-324-118B

11.1. ASME Code Component(s) Affected

Unit 1 Tee to Valve 1HP-119 Weld, Weld #1HP-324-118B, Summary Number O1.C5.21.0041 and ASME Code Class 2.

11.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

11.3. Applicable Code Requirement

IWC-2500, Table IWC-2500-1, Examination Category C-F-1, Item Number C5.21 Figure IWC-2500-7(a), 100% Volume Coverage of Examination Volume C-D-E-F.

11.4. Impracticality of Compliance

Component configuration:

- Surface 1: Forged Stainless Steel Valve
- Surface 2: Forged Stainless Steel Tee
- Diameter: 2.5 in.
- Thickness: 0.375 in.

This component was scanned manually with conventional methods. Scanning requirements are described in 10 CFR 50.55a(b)(2)(xv)(A)(1). These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following:

- 60° shear waves obtained 77.850% coverage in one axial direction (S1 - valve)
- 60° shear waves obtained 88.925% coverage in one axial direction (S2 - tee)
- 45° shear waves obtained 50% coverage in one axial direction (S3 - CW)
- 45° shear waves obtained 50% coverage in one axial direction (S4 - CCW)
- The aggregate coverage was calculated to be $(77.850\% + 88.925 + 50\% + 50\%)/4 = 66.694\%$.

Best effort supplemental scanning was performed using 70° shear waves for interrogation of the lower 1/3 valve far side of the weld from the S2 tee side, but is not qualified to be calculated into the above claimed coverage. The supplemental shear was only used for interrogation in the axial direction per procedural direction. Supplemental scanning is not performed in the circumferential direction. The 70° shear wave was selected to supplement the 60° shear waves as the component is less than 0.500" in thickness.

The impracticality was caused by the tapered configuration of the valve, which did not allow access to the full volume of the weld in the circumferential direction. Welded attachments prevented complete scanning from the valve side in the axial direction. Therefore coverage could not be obtained by scanning from the valve side. In order to scan all of the required volume for this weld, the valve would have to be redesigned and replaced, which is impractical.

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were recorded during this examination. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

11.5. Proposed Alternative and Basis for Use

This weld was examined using procedures, equipment and personnel qualified in accordance with ASME Section XI, Appendix VIII. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws and has not been qualified through performance demonstration. Use of other manual or automated UT techniques, whether conventional or phased array, qualified under ASME Section XI, Appendix VIII would not increase coverage due to the limitation created by the component configuration. The use of any other UT technique available would incur the same physical scanning limitations.

11.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

11.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number O1.C5.21.0041 was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each inspection period in accordance with Table IWC-2500-1, Examination Category C-H requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), visual observations performed during operator rounds provide additional assurance that in the event leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable

Oconee Relief Request 12-ON-001

results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the continuing periodic leakage inspections, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

11.8. References

Duke Energy Relief Requests 02-ON-005 and 02-ON-004 were approved by the NRC during the last inspection interval. The previous approved SE's are documented in Accession Number ML32721404, TAC No.MB5815 and MC5830 dated September 29, 2003.

12.0 Weld #1-51A-02-34B

12.1. ASME Code Component(s) Affected

Unit 1 Elbow to Valve 1HP-134, Weld #1-51A-02-34B, Summary Number O1.C5.21.0053 and ASME Code Class 2.

12.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

12.3. Applicable Code Requirement

IWC-2500, Table IWC-2500-1, Examination Category C-F-1, Item Number C5.21 Figure IWC-2500-7(a), 100% Volume Coverage of Examination Volume C-D-E-F.

12.4. Impracticality of Compliance

Component configuration:

- Surface 1: Forged Stainless Steel Elbow
- Surface 2: Forged Stainless Steel Valve
- Diameter: 4.0 in.
- Thickness: 0.531 in.

This component was scanned manually with conventional methods. Scanning requirements are described in 10 CFR 50.55a(b)(2)(xv)(A)(1). These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following:

- 60° shear waves obtained 100% coverage in one axial direction (S1 – elbow)
- 45° shear waves obtained 46.1% coverage in one axial direction (S2 - valve)
- 45° shear waves obtained 50% coverage in one axial direction (S3 - CW)
- 45° shear waves obtained 50% coverage in one axial direction (S4 - CCW)
- The aggregate coverage was calculated to be $(100\% + 46.1 + 50\% + 50\%)/4 = 61.525\%$.

Best effort supplemental scanning was also performed using 60° refracted longitudinal waves for interrogation of the lower 1/3 valve far side of the weld from the S1 elbow side, but is not qualified to be calculated into the above claimed coverage. The supplemental refracted longitudinal scan was only used for interrogation in the axial direction per procedural direction. Supplemental scanning is not performed in the circumferential direction.

The impracticality was caused by the tapered configuration of the valve, which did not allow access to the full volume of the weld. Therefore coverage could not be obtained by scanning from the valve side. In order to scan all of the required volume for this weld, the valve would have to be redesigned and replaced, which is impractical.

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were recorded during this examination. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

12.5. Proposed Alternative and Basis for Use

This weld was examined using procedures, equipment and personnel qualified in accordance with ASME Section XI, Appendix VIII. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws and has not been qualified through performance demonstration. Use of other manual or automated UT techniques, whether conventional or phased array, qualified under ASME Section XI, Appendix VIII would not increase coverage due to the limitation created by the component configuration. The use of any other UT technique available would incur the same physical scanning limitations.

12.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

12.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number O1.C5.21.0053 was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

In addition to the volumetric examination with limited coverage, Duke Energy performed a surface examination (code required) on this C5.21 item. The result from the surface examination was acceptable.

The system leakage test performed each inspection period in accordance with Table IWC-2500-1, Examination Category C-H requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric, surface, and pressure test), visual observations performed during operator rounds provide additional assurance that in the event leakage did occur through this weld, it would be detected and proper action taken.

Oconee Relief Request 12-ON-001

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the acceptable results of the surface examinations performed during this outage, the pressure testing (VT-2) examinations required by Section XI, and the continuing periodic leakage inspections, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

12.8. References

Duke Energy Relief Requests 02-ON-005 and 02-ON-004 were approved by the NRC during the last inspection interval. The previous approved SE's are documented in Accession Number ML32721404, TAC No.MB5815 and MC5830 dated September 29, 2003.

13.0 Weld #1HP-193-12

13.1. ASME Code Component(s) Affected

Unit 1 Tee to Valve 1HP-26 Weld, Weld #1HP-193-12, Summary Number O1.C5.21.0057 and ASME Code Class 2.

13.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

13.3. Applicable Code Requirement

IWC-2500, Table IWC-2500-1, Examination Category C-F-1, Item Number C5.21 Figure IWC-2500-7(a), 100% Volume Coverage of Examination Volume C-D-E-F.

13.4. Impracticality of Compliance

Component configuration:

- Surface 1: Cast Stainless Steel Valve
- Surface 2: Forged Stainless Steel Tee
- Diameter: 4.0 in.
- Thickness: 0.531 in.

This component was scanned manually with conventional methods. Scanning requirements are described in 10 CFR 50.55a(b)(2)(xv)(A)(1). These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following:

- 60° shear waves obtained 0% coverage in one axial direction (S1 - valve)
- 60° shear waves obtained 50% coverage in one axial direction (S2 - tee)
- 45° shear waves obtained 50% coverage in one axial direction (S3 - CW)
- 45° shear waves obtained 50% coverage in one axial direction (S4 - CCW)
- The aggregate coverage was calculated to be $(0\% + 50\% + 50\% + 50\%)/4 = 37.5\%$.

Best effort supplemental scanning was also performed using 70° refracted longitudinal waves for interrogation of the lower 1/3 valve far side of the weld from the S1 tee side, but is not qualified to be calculated into the above claimed coverage. The supplemental refracted longitudinal scan was only used for interrogation in the axial direction per procedural direction. Supplemental scanning is not performed in the circumferential direction.

The impracticality was caused by the cast stainless steel material which cannot be effectively interrogated by ultrasound. There are currently no examination

Oconee Relief Request 12-ON-001

techniques that have been qualified through Appendix VIII for cast stainless steel. Therefore, coverage could not be obtained by scanning from the valve side. In order to scan all of the required volume for this weld, the valve would have to be redesigned and replaced, which is impractical.

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were recorded during this examination. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

13.5. Proposed Alternative and Basis for Use

This weld was examined using procedures, equipment and personnel qualified in accordance with ASME Section XI, Appendix VIII. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws and has not been qualified through performance demonstration. Use of other manual or automated UT techniques, whether conventional or phased array, qualified under ASME Section XI, Appendix VIII would not increase coverage due to the limitation created by the cast stainless material. The use of any other UT technique available would incur the same physical scanning limitations.

13.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

13.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number O1.C5.21.0057 was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each inspection period in accordance with Table IWC-2500-1, Examination Category C-H requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), visual observations performed during operator rounds provide additional assurance that in the event leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the continuing periodic

Oconee Relief Request 12-ON-001

leakage inspections, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

13.8. References

Duke Energy Relief Requests 02-ON-005 and 02-ON-004 were approved by the NRC during the last inspection interval. The previous approved SE's are documented in Accession Number ML32721404, TAC No.MB5815 and MC5830 dated September 29, 2003.

14.0 Weld #1-51A-01-103A

14.1. ASME Code Component(s) Affected

Unit 1 Pipe to Valve 1HP-109 Weld, Weld #1-51A-01-103A, Summary Number O1.C5.21.0066 and ASME Code Class 2.

14.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

14.3. Applicable Code Requirement

IWC-2500, Table IWC-2500-1, Examination Category C-F-1, Item Number C5.21 Figure IWC-2500-7(a), 100% Volume Coverage of Examination Volume C-D-E-F.

14.4. Impracticality of Compliance

Component configuration:

- Surface 1: Forged Stainless Steel Valve
- Surface 2: Forged Stainless Steel Pipe
- Diameter: 3.0 in.
- Thickness: 0.438 in.

This component was scanned manually with conventional methods. Scanning requirements are described in 10 CFR.50.55a(b)(2)(xv)(A)(1). These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following:

- 60° shear waves obtained 100% coverage in one axial direction (S1 - valve)
- 60° shear waves obtained 100% coverage in one axial direction (S2 - pipe)
- 45° shear waves obtained 50% coverage in one axial direction (S3 - CW)
- 45° shear waves obtained 50% coverage in one axial direction (S4 - CCW)
- The aggregate coverage was calculated to be $(100\% + 100\% + 50\% + 50\%)/4 = 75.0\%$.

Best effort supplemental scanning was not applied since the requirements of the ASME Code, Section XI, Supplement 2 pertaining to refracted longitudinal wave or 70 degree shear wave methods are to be applied during single sided exams when axial scanning can only be performed from one side of the weld. 100% coverage was obtained in each axial scan direction.

The impracticality was caused by the tapered configuration of the valve, which did not allow access to the full volume of the weld in the circumferential direction. Therefore coverage could not be obtained by scanning from the valve side. In order to scan all of the required volume for this weld, the valve would have to be redesigned and replaced, which is impractical.

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were recorded during this examination. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

14.5. Proposed Alternative and Basis for Use

This weld was examined using procedures, equipment and personnel qualified in accordance with ASME Section XI, Appendix VIII. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws and has not been qualified through performance demonstration. Use of other manual or automated UT techniques, whether conventional or phased array, qualified under ASME Section XI, Appendix VIII would not increase coverage due to the limitation created by the component configuration. The use of any other UT technique available would incur the same physical scanning limitations.

14.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

14.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number O1.C5.21.0066 was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each inspection period in accordance with Table IWC-2500-1, Examination Category C-H requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), visual observations performed during operator rounds provide additional assurance that in the event leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure

Oconee Relief Request 12-ON-001

testing (VT-2) examinations required by Section XI, and the continuing periodic leakage inspections, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

14.8. References

Duke Energy Relief Requests 02-ON-005 and 02-ON-004 were approved by the NRC during the last inspection interval. The previous approved SE's are documented in Accession Number ML32721404, TAC No.MB5815 and MC5830 dated September 29, 2003.

15.0 Weld #1LPS-563-14

15.1. ASME Code Component(s) Affected

Unit 1 Valve 1LPS-022 to Pipe Weld, Weld #1LPS-563-14, Summary Number O1.C5.51.0050, Low Pressure Service Water System, and ASME Code Class 2.

15.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

15.3. Applicable Code Requirement

IWC-2500, Table IWC-2500-1, Examination Category C-F-2, Item Number C5.51 Figure IWC-2500-7(a), 100% Volume Coverage of Examination Volume C-D-E-F.

15.4. Impracticality of Compliance

Component configuration:

- Surface 1: Carbon Steel Pipe
- Surface 2: Cast Stainless Steel Valve
- Diameter: 8.0 in.
- Thickness: 0.50 in.

This component was scanned manually with conventional methods. Scanning requirements are described in 10CFR.50.55a(b)(2)(xv)(A)(1). These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following:

- 60° shear waves obtained 50% coverage in one axial direction (S1 - pipe)
- 60° shear waves obtained 0% coverage in one axial direction (S2 - valve)
- 45° shear waves obtained 50% coverage in one axial direction (S3 - CW)
- 45° shear waves obtained 50% coverage in one axial direction (S4 - CCW)
- The aggregate coverage was calculated to be $(50\% + 0\% + 50\% + 50\%)/4 = 37.5\%$.

The impracticality was caused by the cast stainless steel material which cannot be effectively interrogated by ultrasound. There are currently no examination techniques that have been qualified through Appendix VIII for cast stainless steel. Therefore, coverage could not be obtained by scanning from the valve side. In order to scan all of the required volume for this weld, the valve would have to be redesigned and replaced, which is impractical.

Oconee Relief Request 12-ON-001

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were recorded during this examination. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

15.5. Proposed Alternative and Basis for Use

This weld was examined using procedures, equipment and personnel qualified in accordance with ASME Section XI, Appendix VIII. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws and has not been qualified through performance demonstration. Use of other manual or automated UT techniques, whether conventional or phased array, qualified under ASME Section XI, Appendix VIII would not increase coverage due to the limitation created by the cast stainless material. The use of any other UT technique available would incur the same physical scanning limitations.

15.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

15.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number O1.C5.51.0050 was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each inspection period in accordance with Table IWC-2500-1, Examination Category C-H requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), visual observations performed during operator rounds provide additional assurance that in the event leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the continuing periodic leakage inspections, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

15.8 References

None

16.0 Weld #1LPS-702-50

16.1. ASME Code Component(s) Affected

Unit 1 Valve 1LPSW-016 to Pipe Weld, Weld #1LPS-702-50, Summary Number O1.C5.51.0053, Low Pressure Service Water System, and ASME Code Class 2.

16.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

16.3. Applicable Code Requirement

IWC-2500, Table IWC-2500-1, Examination Category C-F-2, Item Number C5.51 Figure IWC-2500-7(a), 100% Volume Coverage of Examination Volume C-D-E-F.

16.4. Impracticality of Compliance

Component configuration:

- Surface 1: Carbon Steel Pipe
- Surface 2: Cast Stainless Steel Valve
- Diameter: 8.0 in.
- Thickness: 0.50 in.

This component was scanned manually with conventional methods. Scanning requirements are described in 10CFR.50.55a(b)(2)(xv)(A)(1). These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following:

- 60° shear waves obtained 50% coverage in one axial direction (S1 - pipe)
- 60° shear waves obtained 0% coverage in one axial direction (S2 - valve)
- 45° shear waves obtained 50% coverage in one axial direction (S3 - CW)
- 45° shear waves obtained 50% coverage in one axial direction (S4 - CCW)
- The aggregate coverage was calculated to be $(50\% + 0\% + 50\% + 50\%)/4 = 37.5\%$.

The impracticality was caused by the cast stainless steel material which cannot be effectively interrogated by ultrasound. There are currently no examination techniques that have been qualified through Appendix VIII for cast stainless steel. Therefore, coverage could not be obtained by scanning from the valve side. In order to scan all of the required volume for this weld, the valve would have to be redesigned and replaced, which is impractical.

Oconee Relief Request 12-ON-001

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were recorded during this examination. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

16.5. Proposed Alternative and Basis for Use

This weld was examined using procedures, equipment and personnel qualified in accordance with ASME Section XI, Appendix VIII. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws and has not been qualified through performance demonstration. Use of other manual or automated UT techniques, whether conventional or phased array, qualified under ASME Section XI, Appendix VIII would not increase coverage due to the limitation created by the cast stainless material. The use of any other UT technique available would incur the same physical scanning limitations.

16.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

16.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number O1.C5.51.0053 was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each inspection period in accordance with Table IWC-2500-1, Examination Category C-H requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), visual observations performed during operator rounds provide additional assurance that in the event leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the continuing periodic leakage inspections, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

16.8. References

None

17.0 Weld WJ32 (Serial #N-32389-1)

17.1. ASME Code Component(s) Affected

Unit 1 Letdown Cooler SN# N-32389-1 Inlet Channel Body to Chemical Connector Weld # WJ32, Summary Number PSI and ASME Code Class 1.

17.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

17.3. Applicable Code Requirement

IWB-2500, Table IWB-2500-1, Examination Category B-B, Item Number B2.51 Figure IWB-2500-1, 100% Volume Coverage of Examination Volume A-B-C-D.

17.4. Impracticality of Compliance

Component configuration:

- Surface 1: Stainless Steel Inlet Channel Body
- Surface 2: Stainless Steel Chemical Connector
- Diameter: 8.620 in.
- Thickness: 0.875 in.

This component was scanned manually using conventional methods. Scanning requirements are described in ASME Section XI, Appendix III, III-4420 and III-4430. These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following.

- Axial scan coverage: 45° shear waves and 45°, 60° and 70° longitudinal waves in the S1 and S2 direction obtained an aggregate coverage of 97.2%
- Circumferential scan coverage: 45° shear waves obtained an aggregate coverage of 78.1%
- The total aggregate coverage was calculated to be $(97.2\% + 78.1\%) / 2 = 87.7\%$
- In addition, a best effort examination was performed using 60° and 70° longitudinal waves to the extent possible in the upper 2/3 area of interest.

The impracticality was caused by the taper configuration of the chemical connector and the proximity of a nozzle within the scan area from the inlet channel body. In order to scan all of the volume for this weld, the chemical connector and location of the adjacent nozzle would have to be redesigned and replaced, which is impractical.

Oconee Relief Request 12-ON-001

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

Four indications were detected during the examinations that were determined to be all from component geometry. The indications were not associated with flaws in the component weld. The indications were acceptable without further evaluation. The dispositions for the indications were by procedure guidance on the use of probe skewing, use of higher angles and indication plotting. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

17.5. Proposed Alternative and Basis for Use

No substitution alternative for this weld is available which would provide better coverage. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws. Use of other manual or automated UT techniques, whether conventional or phased array, were considered, but would not increase coverage due to the limitation created by the component configuration. The use of any other UT technique available would incur the same physical scanning limitations.

17.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

17.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number PSI was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each refueling outage in accordance with Table IWB-2500-1, Examination Category B-P requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), Reactor Building Normal Sump monitoring and other leakage detection systems provide additional assurance that, in the event that leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the leakage monitoring, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

17.8 References

None

18.0 Weld WJ33 (Serial #N-32389-1)

18.1. ASME Code Component(s) Affected

Unit 1 Letdown Cooler SN# N-32389-1 Inlet Nozzle to Channel Body Weld WJ33, Summary Number PSI and ASME Code Class 1.

18.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

18.3. Applicable Code Requirement

IWB-2500, Table IWB-2500-1, Examination Category B-D, Item Number B3.150 Figure IWB-2500-7(a), 100% Volume Coverage of Examination Volume A-B-C-D-E-F-G-H-I.

18.4. Impracticality of Compliance

Component configuration:

- Surface 1: Stainless Steel Channel Body
- Surface 2: Stainless Steel Inlet Nozzle
- Diameter: 3.0 in.
- Thickness: 0.875 in.

This component was scanned manually using conventional methods. Scanning requirements are described in ASME Section XI, Appendix III, III-4420 and III-4430. These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following.

- Base metal coverage using circumferential and axial scan coverage: 45° shear waves and 45°, 60° and 70° longitudinal waves in the S1 and S2 direction obtained an aggregate coverage of 60.1%
- Weld Material coverage using axial and circumferential scan coverage: 45° shear waves obtained an aggregate coverage of 49.1%
- The total aggregate coverage was calculated to be $(60.1\% + 49.1\%)/2 = 54.6\%$
- In addition, a best effort examination was performed using 60° and 70° longitudinal waves to the extent possible in the upper 2/3 area of interest.

The impracticality was caused by the weld taper configuration of the inlet nozzle to channel body that does not allow meaningful interrogation from Surface 2 the inlet nozzle side. In order to scan the required volume for this weld, the channel body to inlet nozzle weld would have to be redesigned and replaced, which is impractical.

Oconee Relief Request 12-ON-001

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were detected during this examination. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

18.5. Proposed Alternative and Basis for Use

No substitution alternative for this weld is available which would provide better coverage. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws. Use of other manual or automated UT techniques, whether conventional or phased array, were considered, but would not increase coverage due to the limitation created by the component configuration. The use of any other UT technique available would incur the same physical scanning limitations.

18.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

18.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number PSI was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each refueling outage in accordance with Table IWB-2500-1, Examination Category B-P requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), Reactor Building Normal Sump monitoring and other leakage detection systems provide additional assurance that, in the event that leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the leakage monitoring, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

18.8 References

None

19.0 Weld WJ35 (Serial #N-32389-1)

19.1. ASME Code Component(s) Affected

Unit 1 Letdown Cooler SN# N-32389-1 Outlet Channel Body to Chemical Connector Weld # WJ35, Summary Number PSI and ASME Code Class 1.

19.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

19.3. Applicable Code Requirement

IWB-2500, Table IWB-2500-1, Examination Category B-B, Item Number B2.51 Figure IWB-2500-1, 100% Volume Coverage of Examination Volume A-B-C-D.

19.4. Impracticality of Compliance

Component configuration:

- Surface 1: Stainless Steel Outlet Channel Body
- Surface 2: Stainless Steel Chemical Connector
- Diameter: 8.620 in.
- Thickness: 0.875 in.

This component was scanned manually using conventional methods. Scanning requirements are described in ASME Section XI, Appendix III, III-4420 and III-4430. These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following.

- Axial scan coverage: 45° shear waves and 45°, 60° and 70° longitudinal waves in the S1 and S2 direction obtained an aggregate coverage of 97.2%
- Circumferential scan coverage: 45° shear waves obtained an aggregate coverage of 78.1%
- The total aggregate coverage was calculated to be $(97.2\% + 78.1\%)/2 = 87.7\%$
- In addition, a best effort examination was performed using 60° and 70° longitudinal waves to the extent possible in the upper 2/3 area of interest.

The impracticality was caused by the taper configuration of the chemical connector and the proximity of a nozzle within the scan area from the outlet channel body. In order to scan all of the volume for this weld, the chemical connector and location of the adjacent nozzle would have to be redesigned and replaced, which is impractical.

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

Three indications were detected during the examinations that were determined to be all from component geometry. The indications were not associated with flaws in the component weld. All were acceptable without further evaluation. The dispositions of all indications were by procedure guidance on the use of probe skewing, use of higher angles and indication plotting. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

19.5. Proposed Alternative and Basis for Use

No substitution alternative for this weld is available which would provide better coverage. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws. Use of other manual or automated UT techniques, whether conventional or phased array, were considered, but would not increase coverage due to the limitation created by the component configuration. The use of any other UT technique available would incur the same physical scanning limitations,

19.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

19.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number PSI was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each refueling outage in accordance with Table IWB-2500-1, Examination Category B-P requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), Reactor Building Normal Sump monitoring and other leakage detection systems provide additional assurance that, in the event that leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the leakage monitoring, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

19.8 References

None

20.0 Weld WJ36 (Serial #N-32389-1)

20.1. ASME Code Component(s) Affected

Unit 1 Letdown Cooler SN# N-32389-1 Outlet Nozzle to Channel Body Weld #WJ36, Summary Number PSI and ASME Code Class 1.

20.2. Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

20.3. Applicable Code Requirement

IWB-2500, Table IWB-2500-1, Examination Category B-D, Item Number B3.150 Figure IWB-2500-7(a), 100% Volume Coverage of Examination Volume A-B-C-D-E-F-G-H-I.

20.4. Impracticality of Compliance

Component configuration:

- Surface 1: Stainless Steel Channel Body
- Surface 2: Stainless Steel Outlet Nozzle
- Diameter: 3.0 in.
- Thickness: 0.875 in.

This component was scanned manually using conventional methods. Scanning requirements are described in ASME Section XI, Appendix III, III-4420 and III-4430. These requirements describe and are specific to scanning components in two axial and two circumferential directions. This component was scanned to the extent possible to meet these requirements. The aggregate coverage that was obtained is described and calculated from the following.

- Base metal coverage using circumferential and axial scan coverage: 45° shear waves and 45°, 60° and 70° longitudinal waves in the S1 and S2 direction obtained an aggregate coverage of 60.1%
- Weld Material coverage using axial and circumferential scan coverage: 45° shear waves obtained an aggregate coverage of 49.1%
- The total aggregate coverage was calculated to be $(49.1\% + 60.1\%)/2 = 54.6\%$
- In addition, a best effort examination was performed using 60° and 70° longitudinal waves to the extent possible in the upper 2/3 area of interest.

The impracticality was caused by the weld taper configuration of the outlet nozzle to channel body that does not allow meaningful interrogation from Surface 2, the outlet nozzle side. In order to scan the required volume for this weld, the channel body to outlet nozzle weld would have to be redesigned and replaced, which is impractical.

The Oconee Inservice Inspection Plan allows the use of Code Case N-460, which requires greater than 90% volumetric coverage. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

This relief request is specific to examination volume coverage limitations only. All other Code requirements were satisfied.

No indications were detected during this examination. The reject box on each UT Calibration/Examination sheet is marked for internal tracking of the coverage limitation only.

20.5. Proposed Alternative and Basis for Use

No substitution alternative for this weld is available which would provide better coverage. Radiography (RT) is not a desired option because RT is limited in the ability to detect service induced flaws. Use of other manual or automated UT techniques, whether conventional or phased array, were considered, but would not increase coverage due to the limitation created by the component configuration. The use of any other UT technique available would incur the same physical scanning limitations.

20.6. Duration of Proposed Alternative

This request is for the duration of the fourth inservice inspection interval, currently scheduled to end on July 15, 2014.

20.7. Justification for Granting Relief

Ultrasonic examination of the weld for the item number PSI was conducted using personnel, equipment, and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each refueling outage in accordance with Table IWB-2500-1, Examination Category B-P requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provides additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), Reactor Building Normal Sump monitoring and other leakage detection systems provide additional assurance that, in the event that leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the leakage monitoring, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

20.8 References

None

Attachment A


to Relief Request

12-ON-001

UT Detail Data sheets from

1EOC-26

Limited Exam Coverage



UT Calibration a nation

Site/Unit: Oconee / 1
 Summary No.: 01.B3.110.0011
 Workscope: ISI

Procedure: NDE-640
 Procedure Rev.: 5
 Work Order No.: 01897577

Outage No.: 01-26
 Report No.: UT-11-770
 Page: 1 of 1

Code: 1999/2009A Cat./Item: B-D /B3.110 Location: _____
 Drawing No.: ISI-OCN1-002 Description: Nozzle to Shell
 System ID: 50
 Component ID: 1-PZR-WP26-3 Size/Length: N/A Thickness/Diameter: C8/6.187/5.75
 Limitations: See attached sheets Start Time: 1200 Finish Time: 1207

Instrument Settings
 Serial No.: 05TJXT
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 1.0359 Range: 10.0
 M's Cal/Vol: 233 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 31.3 Circ. Gain (dB): N/A
1 Screen Div. = 1.0 In. of Sound Path
 Linearity Report No.: L-11-136

Search Unit
 Serial No.: C120048P
 Manufacturer: KBA
 Size: 1.0 Shape: Round
 Freq.: 2.25 MHz Style: Gamma
 Exam Angle: 0 # of Elements: Single
 Mode: Long
 Measured Angle: N/A
 Wedge Style: Integral
Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1050	4/18/2011
Inter. Cal.	1200	4/18/2011
Inter. Cal.		
Inter. Cal.	1215	4/18/2011
Final Cal	1305	4/18/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1/8	80	1.58	1.54
2/8	70	3.3	3.3
3/8	65	5.0	5.08

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Calibration Block
 Cal. Block No. 40338
 Thickness 6.187 Dia.: 5.750
 Cal. Blk. Temp. 71 Temp. Tool: MCNDE40127
 Comp. Temp. 78 Temp. Tool: MCNDE40128
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info

Scan Coverage
 Upstream Downstream Scan dB: 37.3
 CW CCW Scan dB: N/A
 Exam Surface: OD
 Surface Condition: As Ground

Reference Block
 Serial No.: 90-6522
 Type: ROMPAS

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
14.9	BW	80	1.0	1.0

Comments: N/A

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewed	Signature	Date
Mauldin, Larry E.	II-N	<i>Larry E. Mauldin</i>	4/18/2011	<i>Sam Mors</i>		4-20-11
Multhead, Barry A.	II-N	<i>Barry Multhead</i>	4/18/2011	<i>N/A</i>		
Other	Level: N/A	Signature	Date	ANN Review	Signature	Date
N/A				<i>Doreen C. Ritchie Slaughter</i>		4/20/11

UT Calibrator Calibration

Site/Unit: Oconee / 1
 Summary No.: 01.B3.110.0011
 Workscope: ISI

Procedure: NDE-820
 Procedure Rev.: 6
 Work Order No.: 01897577

Outage No.: 01-26
 Report No.: UT-11-771
 Page: 1 of 9

Code: 1998/2000A Cal/Item: B-D /B3.110 Location: _____
 Drawing No.: 181-OCN1-002 Description: Nozzle to Shell
 System ID: 60
 Component ID: 1-PZR-WP26-3 Size/Length: N/A Thickness/Diameter: C8/6.187/3.75
 Limitations: Yes - See attached sheets Start Time: 1216 Finish Time: 1222

Instrument Settings

Serial No.: 60TJKT Search Unit: G14818
 Manufacturer: KRAUTKRAMER Manufacturer: KBA
 Model: USN-60 Size: .5x1.0 Shape: Rect.
 Delay: 11.31 Range: 15.0 Freq.: 2.25 MHz Style: Gamma
 M's Cal/Vol: .1268 Pulsar: High Exam Angle: 45 # of Elements: Single
 Damping: 1K Reject: 0% Mode: Shear
 Rep. Rate: Autohigh Freq.: 2.25 MHz Measured Angle: 45
 Filter: Fixed Mode: PE Wedge Style: SWB
 Voltage: Fixed Other: Pulswave
 Ax. Gain (dB): 46.1/52.1 Ctr. Gain (dB): N/A Search Unit Cable: _____
1 Screen Div. = 1.5 In. of Sound Path Type: RG - 174
 Linearity Report No.: L-11-138 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1055	4/18/2011
Inter. Cal.	1216	4/18/2011
Inter. Cal.		
Inter. Cal.	1230	4/18/2011
Final Cal	1300	4/18/2011

Couplant

Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1/8	80	1.4	2.24
2/8	35	3.0	4.70
3/8	20/40	4.8	6.89
Notch	35	6.6	9.81
5/8	15	8.1	12.19

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Calibration Block

Cal. Block No. 40338 Upstream Downstream Scan dB: 58.1
 Thickness 7 Dia.: 5.750 CW CCW Scan dB: 58.1
 Cal. Blk. Temp. 71 Temp. Tool: MCNDE40127 Exam Surface: OD
 Comp. Temp. 78 Temp. Tool: MCNDE40128 Surface Condition: As Ground
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Reference Block

Serial No.: 99-6522
 Type: ROMPAS

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
32.2	2" Radius	60	1.3	2.0

Results: Accept Reject Info Comments: _____
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	ID-N	Signature	Date	Reviews	Signature	Date
Mauldin, Larry E.			<i>Larry E. Mauldin</i>	4/18/2011	<i>Larry E. Mauldin</i>		4-20-11
Murthead, Barry A.			<i>Barry A. Murthead</i>	4/18/2011	N/A		
Other	Level	N/A	Signature	Date	ANIT Review	Signature	Date
N/A			<i>Nancy C. Ritchie-Smyth</i>				4/20/11



UT Calibrator Certification

Site/Unit: Oconee / 1
 Summary No.: O1.B3.110.0011
 Workscope: ISI

Procedure: NDE-820
 Procedure Rev.: 6
 Work Order No.: 01897577

Outage No.: O1-28
 Report No.: UT-11-771
 Page: 2 of 9

Code: 1998/2000A Cat./Item: B-D /B3.110 Location: _____
 Drawing No.: ISI-DCN1-002 Description: Nozzle to Shell
 System ID: 50
 Component ID: 1-PZR-WP26-3 Size/Length: N/A Thickness/Diameter: CS/6.187/5.75
 Limitations: Yes - See attached sheets Start Time: 1120 Finish Time: 1132

Instrument Settings
 Serial No.: 007JXT
 Manufacturer: KRAUTKRAMER
 Model: USM-60
 Delay: 14.0744 Range: 5.0"
 Mfl Cal/Vol: .1268 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.28 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 44.1 Cir. Gain (dB): 58.1
 1 Screen Div. = .5 in. of Sound Path
 Linearity Report No.: L-11-138

Search Unit
 Serial No.: G14819
 Manufacturer: KBA
 Size: .5x1.0 Shape: Rect.
 Freq.: 2.28 MHz Style: GAMMA
 Exam Angle: 60 # of Elements: Single
 Mode: Shear
 Measured Angle: 60
 Wedge Style: SWS
 Search Unit Cable
 Type: RQ - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1110	4/18/2011
Inter. Cal.	1120	4/18/2011
Inter. Cal.		
Inter. Cal.	1150	4/18/2011
Final Cal	1312	4/18/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: 86-6522
 Type: ROMPAS

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
.5"	80	2.0	1.0
1.0"	70	4.0	2.0
1.5"	68	6.0	3.0
2.0"	4.0	8.0	4.0
1/4T	60	7.0	3.42

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
38.6	2" Radius	60	8.0	2.0

Calibration Block
 Cal. Block No. 40338
 Thickness 7 Dia.: Flat
 Cal. Blk. Temp. 71 Temp. Tool: MCNDE40127
 Comp. Temp. 78 Temp. Tool: MCNDE40128
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	II-N	Signature	Date	Reviewed	Signature	Date
Mauldin, Larry E.			<i>Larry E. Mauldin</i>	4/18/2011	<i>Gary Moss</i>		4-20-11
Muirhead, Barry A.			<i>Barry Muirhead</i>	4/18/2011	N/A		
Other	Level	N/A	Signature	Date	ANII Review	Signature	Date
N/A					<i>Nancy Christine Shugler</i>		4/20/11

UT Calibration

Site/Unit: Oconee / 1
 Summary No.: 01.B3.110.0011
 Workscope: IBI

Procedure: NDE-520
 Procedure Rev.: 0
 Work Order No.: 01897677

Outage No.: 01-26
 Report No.: UT-11-771
 Page: 3 of 9

Code: 1998/Z000A Cal./Item: B-D /B3.110 Location: _____
 Drawing No.: IBI-OCN1-002 Description: Nozzle to Shell
 System ID: 50
 Component ID: 1-PZR-WP26-3 Size/Length: N/A Thickness/Diameter: CS/8.187/5.75
 Limitations: Yes - See attached sheets Start Time: 1231 Finish Time: 1235

Instrument Settings
 Serial No.: 00TJXT
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 14.0744 Range: 25.0
 M's Cal/Val: .1268 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 66.6/62.8 Circ. Gain (dB): 76.6
1 Screen Div. = 2.5 in. of Sound Path
 Linearity Report No.: L-11-138

Search Unit
 Serial No.: G14819
 Manufacturer: KBA
 Size: .5x1.0 Shape: Rect.
 Freq.: 2.25 MHz Style: GAMMA
 Exam Angle: 60 # of Elements: Single
 Mode: Shear
 Measured Angle: 60
 Wedge Style: SW5

Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1100	4/18/2011
Inter. Cal.	1231	4/18/2011
Inter. Cal.		
Inter. Cal.	1245	4/18/2011
Final Cal	1310	4/18/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: 98-8522
 Type: ROMPAS

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1/8	80	1.1	3.43
2/8	30	2.6	6.54
3/8	18/36	4.0	9.96
Notch	60	5.0	12.15
5/8	15	6.9	16.82

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
38.8	2" Radius	80	.7	2.0

Calibration Block
 Cal. Block No. 40338
 Thickness 7 Dia.: 5.75
 Cal. Blk. Temp. 71 Temp. Tool: MCNDE40127
 Comp. Temp. 76 Temp. Tool: MCNDE40128
 Upstream Downstream Scan dB: 76.6
 CW CCW Scan dB: 76.6
 Exam Surface: O.D.
 Surface Condition: As Ground
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Results: Accept Reject Info Comments: _____
 Percent Of Coverage Obtained > 80%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewed	Signature	Date
Mauldin, Larry E.	II-N	<i>Larry E. Mauldin</i>	4/18/2011	<i>Larry Moss</i>		4-20-11
Muirhead, Barry A.	II-N	<i>Barry A. Muirhead</i>	4/18/2011	<i>JA</i>		
Other	N/A			ANIL Review:	<i>Nancy C. Ritchie</i>	4/20/11

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: <u>1-PZR-WP26-3</u> Item No: <u>01B3.110.0011</u>		remarks:
<input checked="" type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw	Due to nozzle Configuration.	
FROM L <u>N/A</u> to L <u>N/A</u> INCHES FROM W0 <u>1.0"</u> to <u>Beyond</u> ANGLE: <input checked="" type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other _____ FROM <u>0</u> DEG to <u>360</u> DEG		
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		
FROM L _____ to L _____ INCHES FROM W0 _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		
FROM L _____ to L _____ INCHES FROM W0 _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	UT-11-771	
FROM L _____ to L _____ INCHES FROM W0 _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 5 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG	Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> No	
Prepared By: <u>Larry Mauldin</u> Level: <u>II</u> Date: <u>04/18/11</u> Sheet <u>4</u> of <u>9</u>		
Reviewed By: <u>[Signature]</u> Date: <u>4-20-11</u> Authorized Inspector: _____ Date: _____		

ATTACHMENT A
PAGE 5 OF 162

Item No. : 01.B3.110.0011

Pressurizer Sampling Nozzle to Shell


Weld No. : WP26-3

Inspector/Date : Barry Muirhead 4/18/11



Base and Weld Metal Examined with 0° angle.

% Examined 0° = $19.03 / 56.283 \times 100 = 33.8\%$.



Item No. : 01.B3.110.0011

Pressurizer Sampling Nozzle to Shell


Weld No. : WP26-3

Inspector/Date : Barry Muirhead 4/18/11



Base Metal Examined with 60° and 45° angles.

$$\% \text{ Examined } 60^\circ \text{ and } 45^\circ = 19.03 / 44.87 \times 100 = 42.4\%$$



Item No. : 01.B3.110.0011

Pressurizer Sampling Nozzle to Shell

Weld No. : WP26-3


Inspector/Date : Barry Muirhead 04/18/11

■ Total Weld Metal Examined with at least 2 angles from one direction.

A combination of 45° and 60° angles were used to obtain coverage.

% Examined from Surface 1 = $7.015 / 11.413 \times 100 = 61.46\%$.

% Examined from Surface 2, CW, and CCW = 0%.



Item No. : 01.B3.110.0011


Pressurizer Sampling Nozzle to Shell

Weld No. : WP26-3

Inspector/Date : Barry Muirhead 4/18/11

■ Total Base Metal Examined with at least 2 angles from one direction.
A combination of 45° and 60° angles were used to obtain coverage.

$$\% \text{ Examined} = (24.45 + 5.705) / 44.87 \times 100 = 67.2\%$$



PZR Sampling Nozzle to Shell % of Coverage

ATTACHMENT A
PAGE 10 OF 162

Item No. : 01.B3.110.0011

Weld No. : WP26-3

Weld Coverage

<u>Scan</u>	<u>Angle</u>	<u>% Coverage Obtained</u>
S1	45° & 60°	61.46
S2	45° & 60°	0
CW	45° & 60°	0
CCW	45° & 60°	0
	Total	61.46

61.46 + 4 = 15.4 % Coverage

Base Material Coverage

S1	45° & 60°	67.2
CW & CCW	45° & 60°	<u>42.4</u>
	Total	109.6

109.6 + 2 = 54.8 % Coverage

0° Scan Coverage = 33.8 % Coverage

Aggregate Coverage = Weld + Base Material + 0° + 3

= 34.7 % Coverage

Inspector / Date : David K. Z III / 4/20/11

Page 9 of 9

UT Calibrator Examination

Site/Unit: Oconee / 1 Procedure: NDE-840 Outage No.: 01-26
 Summary No.: 01.B3.110.0012 Procedure Rev.: 5 Report No.: UT-11-772
 Workscope: ISI Work Order No.: 01897577 Page: 1 of 1

Code: 1998/2000A Cat./Item: B-D /B3.110 Location: _____
 Drawing No.: ISI-OCN1-002 Description: Nozzle to Shell
 System ID: 50
 Component ID: 1-PZR-WP26-7 Size/Length: N/A Thickness/Diameter: G8/6.187/5.75
 Limitations: See TD report Start Time: 1208 Finish Time: 1215

Instrument Settings

Serial No.: 00TJXT
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 1.0359 Range: 10.0
 M'tl Cal/Val: .233 Pulse: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 31.3 Cir. Gain (dB): N/A
1 Screen Div. = 1.0 in. of Sound Path
 Linearity Report No.: L-11-135

Search Unit

Serial No.: C12004SP
 Manufacturer: KBA
 Size: 1.0 Shape: Round
 Freq.: 2.25 MHz Style: Gamma
 Exam Angle: 0 # of Elements: Single
 Mode: Long
 Measured Angle: N/A
 Wedge Style: Integral

Search Unit Cable

Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1059	4/18/2011
Inter. Cal.	1200	4/18/2011
Inter. Cal.		
Inter. Cal.	1215	4/18/2011
Final Cal	1305	4/18/2011

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1/8	80	1.55	1.54
2/8	70	3.3	3.3
3/8	65	5.0	5.08

Couplant

Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Calibration Block

Cal. Block No. 40338
 Thickness 6.187 Dia.: 5.750
 Cal. Blk. Temp. 71 Temp. Tool: MCNDE40127
 Comp. Temp. 78 Temp. Tool: MCNDE40128
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 80%: No Reviewed Previous Data: Yes

Scan Coverage

Upstream Downstream Scan dB: 37.3
 CW CCW Scan dB: N/A
 Exam Surface: OD
 Surface Condition: As Ground

Reference Block

Serial No.: 88-6522
 Type: ROMPAS

Reference/Stimulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
14.9	BW	80	1.0	1.0

Comments: N/A

Examiner	Level	Signature	Date	Reviewed	Signature	Date
Mauldin, Larry E.	II-N	<i>Larry E. Mauldin</i>	4/18/2011	<i>Barry A. Murrhead</i>		4-20-11
Murrhead, Barry A.	II-N	<i>Barry A. Murrhead</i>	4/18/2011	Site Review	<i>N/A</i>	
Other	Level	Signature	Date	ANII Review	<i>Nancy C. Ricketts</i>	4/20/11

UT Calibration Certification

Site/Unit: Oconee / 1
 Summary No.: 01.B3.110.0012
 Workscope: ISI

Procedure: NDE-820
 Procedure Rev.: 6
 Work Order No.: 01897577

Outage No.: 01-26
 Report No.: UT-11-773
 Page: 1 of 6

Code: 1098/2000A Cat./Item: B-D /B3.110 Location: _____
 Drawing No.: ISI-OCN1-002 Description: Nozzle to Shell
 System ID: 60
 Component ID: 1-PZR-WP26-7 Size/Length: N/A Thickness/Diameter: CS/6.187/5.75
 Limitations: Yes - See attached sheets Start Time: 1223 Finish Time: 1230

Instrument Settings
 Serial No.: DOTJCT
 Manufacturer: KRAUTKRAMER
 Model: USN-80
 Delay: 11.31 Range: 15.0
 M/I Cal/Vel: .1268 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 46.1/52.1 Cir. Gain (dB): N/A
1 Screen Div. = 1.5 in. of Sound Path
 Linearity Report No.: L-11-138

Search Unit
 Serial No.: G14818
 Manufacturer: KBA
 Size: .5x1.0 Shape: Rect.
 Freq.: 2.25 MHz Style: Gamma
 Exam Angle: 45 # of Elements: Single
 Mode: Shear
 Measured Angle: 45
 Wedge Style: SWS

Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Scan Coverage
 Upstream Downstream Scan dB: 66.1
 CW CCW Scan dB: 66.1
 Exam Surface: OD
 Surface Condition: As Ground

Cal. Checks	Time	Date
Initial Cal	1055	4/18/2011
Inter. Cal.	1216	4/18/2011
Inter. Cal.		
Inter. Cal.	1230	4/18/2011
Final Cal	1300	4/18/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: 66-6522
 Type: ROMPAS

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1/8	80	1.4	2.24
2/8	35	3.0	4.70
3/8	20/40	4.8	6.90
Notch	35	6.6	9.51
5/8	15	8.1	12.19

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
32.2	2" Radius	80	1.3	2.0

Calibration Block
 Cal. Block No. 40338
 Thickness 7 Dia.: 5.750
 Cal. Blk. Temp. 74 Temp. Tool: MCNDE40127
 Comp. Temp. 78 Temp. Tool: MCNDE40128
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Comments: _____

Examiner	Level	IL-N	Signature	Date	Reviewer	Signature	Date
Mauldin, Larry E.			<i>Larry E. Mauldin</i>	4/18/2011	<i>Larry E. Mauldin</i>		4-20-11
Mulrhead, Barry A.			<i>Barry A. Mulrhead</i>	4/18/2011	<i>Barry A. Mulrhead</i>		
Other		N/A			ANII Review	<i>Nancy C. Ritchie Shyfter</i>	4/20/11

UT Calibration Examination

Site/Unit: Oconee / 1
 Summary No.: 01.B3.110.0012
 Workscope: ISI

Procedure: NDE-620
 Procedure Rev.: 6
 Work Order No.: 01897577

Outage No.: 01-26
 Report No.: UT-11-773
 Page: 2 of 9

Code: 1998/2000A Cat./Item: B-D /B3.110 Location: _____
 Drawing No.: ISI-OCN1-002 Description: Nozzle to Shell
 System ID: 50
 Component ID: 1-PZR-WP26-7 Size/Length: N/A Thickness/Diameter: CS/6.187/5.75
 Limitations: Yes - See attached sheets Start Time: 1135 Finish Time: 1150

Instrument Settings
 Serial No.: 00TJCT
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 14.0744 Range: 5.0"
 M/TI Cal/Vel: .1265 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Auto/High Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 44.1 Circ. Gain (dB): 58.1
1 Screen Div. = .5 In. of Sound Path
 Linearity Report No.: L-11-138

Search Unit
 Serial No.: G14819
 Manufacturer: KBA
 Size: .5x1.0 Shape: Rect.
 Freq.: 2.25 MHz Style: GAMMA
 Exam Angle: 60 # of Elements: Single
 Mode: Shear
 Measured Angle: 60
 Wedge Style: SWS
Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1110	4/18/2011
Inter. Cal.	1120	4/18/2011
Intrsr. Cal.		
Inter. Cal.	1150	4/18/2011
Final Cal	1312	4/18/2011

Couplant
 Cal. Batch: 09326
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09326
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
.5"	80	2.0	1.0
1.0"	70	4.0	2.0
1.5"	55	6.0	3.0
2.0"	4.0	8.0	4.0
1/4T	50	7.0	3.42

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
38.5	2" Radius	80	8.0	2.0

Calibration Block
 Cal. Block No. 40338
 Thickness 7 Dia.: Flat
 Cal. Blk. Temp. 71 Temp. Tool: MCNDE40127
 Comp. Temp. 78 Temp. Tool: MCNDE40128

Scan Coverage
 Upstream Downstream Scan dB: 58.1
 CW CCW Scan dB: 58.1
 Exam Surface: O.D.
 Surface Condition: As Ground

Reference Block
 Serial No.: 98-8522
 Type: ROMPAS

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info

Comments:

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	I-I-N	Signature	Date	Reviewer	Signature	Date
Mauldin, Larry E.			<i>Larry E. Mauldin</i>	4/18/2011	<i>Larry Moss</i>		4/20/11
Multhead, Barry A.			<i>Barry Multhead</i>	4/18/2011	<i>N/A</i>		
Other		N/A			<i>Dorey C. Ritchie</i>	<i>Shipton</i>	4/20/11

UT Calibration Examination

Site/Unit: Oconee / 1
 Summary No.: 01.B3.110.0012
 Workscope: ISI

Procedure: NDE-820
 Procedure Rev.: 6
 Work Order No.: 01897577

Outage No.: 01-25
 Report No.: UT-11-773
 Page: 3 of 9

Code: 199B/2000A Cat./Item: B-D /B3.110 Location: _____
 Drawing No.: ISI-OCN1-002 Description: Nozzle to Shell
 System ID: 50
 Component ID: 1-PZR-WP28-7 Size/Length: N/A Thickness/Diameter: CS/6.187/5.75
 Limitations: Yes - See attached sheets Start Time: 1239 Finish Time: 1245

Instrument Settings
 Serial No.: 00TJXT
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 14.0744 Range: 25.0
 M'fl Cal/Vol: .1288 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 58.8/62.6 Ctr. Gain (dB): 76.6
1 Screen Div. = 2.5 In. of Sound Path
 Linearity Report No.: L-11-138

Search Unit
 Serial No.: G14819
 Manufacturer: KBA
 Size: .5x1.0 Shape: Rect.
 Freq.: 2.25 MHz Style: GAMMA
 Exam Angle: 60 # of Elements: Single
 Mode: Shear
 Measured Angle: 60
 Wedge Style: SWS

Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1100	4/18/2011
Inter. Cal.	1231	4/18/2011
Inter. Cal.		
Inter. Cal.	1245	4/18/2011
Final Cal	1310	4/18/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1/8	80	1.1	3.49
2/8	30	2.6	6.54
3/8	18/36	4.0	9.98
Notch	60	5.0	12.15
5/8	15	6.9	16.82

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference Block
 Serial No.: 98-6822
 Type: ROMPAS

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
38.8	2" Radius	80	.7	2.0

Calibration Block
 Cal. Block No. 40338
 Thickness 7 Dia.: 5.75
 Cal. Blk. Temp. 71 Temp. Tool: MCNDE40127
 Comp. Temp. 78 Temp. Tool: MCNDE40128
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Scan Coverage
 Upstream Downstream Scan dB: 76.5
 CW CCW Scan dB: 76.6
 Exam Surface: O.D.
 Surface Condition: As Ground

Comments:

Examiner	Level	Signature	Date	Reviewed	Signature	Date
Mauldin, Larry E.	II-N	<i>Larry E. Mauldin</i>	4/18/2011	<i>Larry E. Mauldin</i>		4-20-11
Muirhead, Barry A.	II-N	<i>Barry A. Muirhead</i>	4/18/2011	N/A		
Other	Level	Signature	Date	ANIR Review	Signature	Date
N/A	N/A			<i>Nancy C. Ritchie Shryver</i>		4/20/11

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: <u>1-PZR-WP26-7</u> Item No: <u>01B3.110.0012</u>		remarks:
<input checked="" type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw FROM L <u>N/A</u> to L <u>N/A</u> INCHES FROM W0 <u>1.0"</u> to <u>Beyond</u> ANGLE: <input checked="" type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other _____ FROM <u>0</u> DEG to <u>360</u> DEG		Due to nozzle configuration.
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM L _____ to L _____ INCHES FROM W0 _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM L _____ to L _____ INCHES FROM W0 _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM L _____ to L _____ INCHES FROM W0 _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		UT-11-773
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM L _____ to L _____ INCHES FROM W0 _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 5 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> No
Prepared By: <u>Larry Mauldin</u> Level: <u>II</u> Date: <u>04/18/11</u>	Sheet <u>4</u> of <u>9</u>	
Reviewed By: <u>[Signature]</u> Date: _____	Authorized Inspector: <u>[Signature]</u> Date: <u>4/20/11</u>	

Item No. : 01.B3.110.0012

Pressurizer Sampling Nozzle to Shell


Weld No. : WP26-7

Inspector/Date : Barry Muirhead 4/18/11



Base and Weld Metal Examined with 0° angle.

% Examined 0° = $19.03 / 56.283 \times 100 = 33.8\%$.



ATTACHMENT A
PAGE 16 OF 162

Item No. : 01.B3.110.0012

Pressurizer Sampling Nozzle to Shell


Weld No. : WP26-7

Inspector/Date : Barry Muirhead 4/18/11



Base Metal Examined with 60° and 45° angles.

% Examined 60° and 45° = $19.03 / 44.87 \times 100 = 42.4\%$.



Item No. : 01.B3.110.0012

Pressurizer Sampling Nozzle to Shell

Weld No. : WP26-7


Inspector/Date : Barry Muirhead 04/18/11

■ Total Weld Metal Examined with at least 2 angles from one direction.

A combination of 45° and 60° angles were used to obtain coverage.

% Examined from Surface 1 = $7.015 / 11.413 \times 100 = 61.46\%$.

% Examined from Surface 2, CW, and CCW = 0%.



Item No. : 01.B3.110.0012


Pressurizer Sampling Nozzle to Shell

Weld No. : WP26-7

Inspector/Date : Barry Muirhead 4/18/11

■ Total Base Metal Examined with at least 2 angles from one direction.
A combination of 45° and 60° angles were used to obtain coverage.

$$\% \text{ Examined} = (24.45 + 5.705) / 44.87 \times 100 = 67.2\%$$



PZR Sampling Nozzle to Shell % of Coverage

Item No. : 01.B3.110.0012

Weld No. : WP26-7

ATTACHMENT F
PAGE 20 OF 162

Weld Coverage

<u>Scan</u>	<u>Angle</u>	<u>% Coverage Obtained</u>
S1	45° & 60°	61.46
S2	45° & 60°	0
CW	45° & 60°	0
CCW	45° & 60°	0
	Total	61.46

61.46 ÷ 4 =

15.4

% Coverage

Base Material Coverage

S1	45° & 60°	67.2
CW & CCW	45° & 60°	<u>42.4</u>
	Total	109.6

109.6 ÷ 2 =

54.8

% Coverage

0° Scan Coverage

=

33.8

% Coverage

Aggregate Coverage = Weld + Base Material + 0° ÷ 3

=

34.7

% Coverage

Inspector / Date : David R. [Signature] / 4/10/11

Page 9 of 9

UT Calibration/Amplification

Site/Unit: Oconee / 1 Procedure: PDI-UT-2 Outage No.: 01-26
 Summary No.: 01.89.11.0029 Procedure Rev.: E Report No.: UT-11-757
 Workspace: IBI Work Order No.: 01897774 Page: 1 of 8

Code: 19982000A Cal./Item: B-J /B9.11 Location: _____
 Drawing No.: ISI-OCN1-009 Description: Nozzle to Safe End
 System ID: 50
 Component ID: 1-PIB1-9 Size/Length: N/A Thickness/Diameter: 88/2.33/36.5
 Limitations: Yes - See attached sheets Start Time: 1400 Finish Time: 1415

Instrument Settings
 Serial No.: 014738 Manufacturer: KRAUTKRAMER Model: USN-50 SW
 Delay: 5.8947 Range: 8 M/V Cal/Vel: .1211 Pulse: Square Damping: 500 Reject: 0% Rep. Rate: Autohigh Freq.: 2.25 MHz Filter: Fixed Mode: PE Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 27.7 Cir. Gain (dB): 27.7
1 Screen Div. = .5 In. of Sound Path
 Linearity Report No.: L-11-142

Search Unit
 Serial No.: 01F10K Manufacturer: KBA Size: .5 Shape: Round Freq.: 2.25 MHz Style: Comp - G Exam Angle: 45 # of Elements: Single Mode: Shear Measured Angle: 42 Wedge Style: MSWQC
Search Unit Cable
 Type: RG - 174 Length: 8' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1340	4/17/2011
Inter. Cal.		
Inter. Cal.	1359	4/17/2011
Inter. Cal.		
Final Cal	1550	4/17/2011

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch	80	5	4.03

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
See Axial			

Calibration Block
 Cal. Block No. 40387 Thickness 3.000 Dia.: Flat Exam Surface: O.D. Surface Condition: As Ground
 Upstream Downstream Scan dB: 40 CW CCW Scan dB: 40
 Temp. Tool: MCNDE40136 Surface Condition: As Ground
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Reference Block
 Serial No.: 04-5737
 Type: ROMPAS

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
13.7	1" Radius	80	1.3	1"

Results: Accept Reject Info Comments: N/A
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Hollis, Jacob	II-N	<i>Jacob Hollis</i>	4/17/2011	<i>Ben A. Mars</i>		4-21-11
Day, John, C.	II-N	<i>John C. Day</i>	4/17/2011	<i>Ben A. Mars</i>		
Other	Level	Signature	Date	ANII/Review	Signature	Date
N/A	N/A			<i>Nancy Chittum Slaughter</i>		4/21/11 ATTACHMENT A

UT Calibration/Examination

Site/Unit: Oconee 1 Procedure: PDI-UT-2 Outage No.: 01-26
 Summary No.: 01.B9.11.0029 Procedure Rev.: E Report No.: UT-11-757
 Workscope: ISI Work Order No.: 01897774 Page: 2 of 8

Code: 1998/2000A Cat./Item: B-J /B9.11 Location: _____
 Drawing No.: ISI-OCN1-009 Description: Nozzle to Safe End
 System ID: 80
 Component ID: 1-PIB1-9 Size/Length: N/A Thickness/Diameter: 89/2.33/36.5
 Limitations: Yes - See attached sheets Start Time: 1417 Finish Time: 1425

Instrument Settings
 Serial No.: 014738 Manufacturer: KRAUTKRAMER Model: USN-80 SW
 Delay: 6.2934 Range: 10 M'U Cal/Vol: .1225 Pulse: Square
 Damping: 500 Reject: 0% Rep. Rate: AutoHigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 45.3 Circ. Gain (dB): N/A
1 Screen Div. = 1.0 in. of Sound Path
 Linearity Report No.: L-11-142

Search Unit
 Serial No.: SE0708 Manufacturer: KBA
 Size: .5 Shape: Round Freq.: 2.25 MHz Style: Comp - G
 Exam Angle: 60 # of Elements: Single Mode: Shear
 Measured Angle: 87 Wedge Style: MSWQC
Search Unit Cable
 Type: RG -174 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1345	4/17/2011
Inter. Cal.		
Inter. Cal.	1416	4/17/2011
Inter. Cal.		
Final Cal	1555	4/17/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: 04-8737
 Type: ROMPAS

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
3/4 SDH	80	3.9	3.65

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
15.0	1" Radius	80	1	1"

Calibration Block
 Cal. Block No. 40397 Thickness 3.000 Dia.: Flat
 Cal. Blk. Temp. 76 Temp. Tool: MCNDE40136
 Comp. Temp. 76 Temp. Tool: MCNDE40136
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Scan Coverage
 Upstream Downstream Scan dB: 51.3
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: As Ground

Comments: N/A

Examiner	Level	Signature	Date	Reviewed	Signature	Date
Hollis, Jacob	II-N	<i>Jacob R. Hollis</i>	4/17/2011	<i>Nancy A. Moss</i>		4-21-11
Day, John, C.	II-N	<i>John C. Day</i>	4/17/2011	<i>N/A</i>		
Other	N/A			<i>Nancy C. Retcher</i>	<i>Shirley</i>	4/21/11

ATTACHMENT 1
 PAGE 2.2 OF 16

UT Calibration Examination

Site/Unit: Oconee / 1
 Summary No.: 01.B9.11.0029
 Workscope: ISI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01897774

Outage No.: 01-28
 Report No.: UT-11-757
 Page: 3 of 8

Code: 1998/2000A Cat./Item: B-J /B9.11 Location: _____

Drawing No.: ISI-OCN1-009 Description: Nozzle to Safe End

System ID: 50

Component ID: 1-PIB1-9 Size/Length: N/A Thickness/Diameter: 86/2.33/36.5

Limitations: Yes - See attached sheets Start Time: 1427 Finish Time: 1435

Instrument Settings

Search Unit

Serial No.: 014735
 Manufacturer: KRAUTKRAMER
 Model: USN-60 SW
 Delay: 9.6613 Range: 15
 M/TI Cal/Vol: .1226 Pulsar: Square
 Damping: 590 Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 56 Ctr. Gain (dB): N/A
1 Screen Div. = 1.5 In. of Sound Path
 Linearity Report No.: L-11-142

Serial No.: SE0355
 Manufacturer: GE
 Size: .5 Shape: Round
 Freq.: 2.25 MHz Style: Comp - G
 Exam Angle: 70 # of Elements: Single
 Mode: Shear
 Measured Angle: 70
 Wedge Style: MSWQC

Search Unit Cable

Type: RG - 174
 Length: 6' No. Conn.: 0

Scan Coverage

Upstream Downstream Scan dB: 56
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: As Ground

Calibration Block

Cal. Block No.: 40397
 Thickness 3.000 Dia.: Flat
 Cal. Blk. Temp. 76 Temp. Tool: MCNDE40136
 Comp. Temp. 76 Temp. Tool: MCNDE40136

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Results: Accept Reject Info

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Cal. Checks	Time	Date
Initial Cal	1350	4/17/2011
Inter. Cal.		
Inter. Cal.	1426	4/17/2011
Inter. Cal.		
Final Cal	1558	4/17/2011

Couplant

Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block

Serial No.: 04-5737
 Type: ROMPAS

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
<u>3/4 8DH</u>	<u>80</u>	<u>4</u>	<u>5.9</u>

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
<u>N/A</u>			

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
<u>17.3</u>	<u>1" Radius</u>	<u>80</u>	<u>.7</u>	<u>.1"</u>

Comments: N/A

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Hollis, Jacob	II-N	<i>Jacob P. Hollis</i>	4/17/2011	<i>Gary A. Moss</i>		4-20-11
Day, John, C.	II-N	<i>John C. Day</i>	4/17/2011	Site Review	<i>J.A.</i>	
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			<i>Nancy C. Ritchie Stryker</i>		4/21/11

UT Calibration/Examination

Site/Unit: Oconee / 1 Procedure: PDI-UT-2 Outage No.: 01-26
 Summary No.: 01.B9.11.0029 Procedure Rev.: E Report No.: UT-11-757
 Workscope: ISI Work Order No.: 01697774 Page: 4 of 6

Code: 1998/2000A Cat./Item: B-J /B9.11 Location: _____
 Drawing No.: ISI-OCN1-009 Description: Nozzle to Safe End
 System ID: 50
 Component ID: 1-PIB1-9 Size/Length: N/A Thickness/Diameter: 98/2.33/38.5
 Limitations: Yes - See attached sheets Start Time: 1437 Finish Time: 1443

Instrument Settings
 Serial No.: 014738
 Manufacturer: KRAUTKRAMER
 Model: USN-60 SW
 Delay: 18.6216 Range: 10
 MHz Cal/Val: .234 Pulsar: Square
 Damping: 500 Reject: 0%
 Rep. Rate: Autohigh Freq.: 2 MHz
 Filter: Fixed Mode: PE
 Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 62.4 Circ. Gain (dB): N/A
1 Screen Div. = .1 In. of Sound Path
 Linearly Report No.: L-11-142

Calibration Block
 Cal. Block No. 40297
 Thickness 3.000 Dia.: Flat
 Cal. Bk. Temp. 75 Temp. Tool: MCNDE40136
 Comp. Temp. 75 Temp. Tool: MCNDE40136
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Review	Signature	Date
Hollis, Jacob	II-N	<i>Jacob Hollis</i>	4/17/2011			
Day, John, C.	II-N	<i>John Day</i>	4/17/2011	Site Review	<i>John Day</i>	4-21-11
Other	N/A			AJH Review	<i>Nancy C. Ritchie-Slayton</i>	4/21/11

Cal. Checks	Time	Date
Initial Cal	1385	4/17/2011
Inter. Cal.		
Inter. Cal.	1436	4/17/2011
Inter. Cal.		
Final Cal	1602	4/17/2011

Search Unit
 Serial No.: 98-298
 Manufacturer: RTD
 Size: 2(24x42) Shape: Rect.
 Freq.: 2.0 MHz Style: TRL2
 Exam Angle: 60 # of Elements: Dual
 Mode: Long
 Measured Angle: 57
 Wedge Style: Integral
 Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0
 Scan Coverage
 Upstream Downstream Scan dB: 62.4
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: .As Ground

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
Reference Block
 Serial No.: 04-5737
 Type: ROMPAS

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
<u>3/4 BDH</u>	<u>60</u>	<u>3.9</u>	<u>3.85</u>

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
<u>N/A</u>			

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
<u>64.7</u>	<u>2" Radius</u>	<u>60</u>	<u>2</u>	<u>2"</u>

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: <u>1-PIB1-9</u>		Item No: <u>01B9.11.0029</u>		remarks:
<input checked="" type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		Due to cast material on pump
<input type="checkbox"/> LIMITED SCAN	<input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	<input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw	side:
FROM L <u>N/A</u> to L <u>N/A</u>	INCHES FROM W0	<u>CL</u>	to <u>Beyond</u>	
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60	other _____	FROM <u>0</u>	DEG to <u>360</u>	DEG
<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____	INCHES FROM W0 _____	to _____		
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60	other _____	FROM _____	DEG to _____	DEG
<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____	INCHES FROM W0 _____	to _____		
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60	other _____	FROM _____	DEG to _____	DEG
<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> cw <input type="checkbox"/> ccw	UT-11-757
FROM L <u>N/A</u> to L <u>N/A</u>	INCHES FROM W0 <u>2.2"</u>	to <u>Beyond</u>		Sketch(s) attached
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 5 <input type="checkbox"/> 60	other <u>60RL</u>	FROM <u>0</u>	DEG to <u>360</u>	<input checked="" type="checkbox"/> yes <input type="checkbox"/> No
Prepared By: <u>Jacob R. Hollis</u>	Level: <u>II</u>	Date: <u>04/17/11</u>	Sheet <u>5</u> of <u>8</u>	
Reviewed By: <u>Gary Moss</u>	Date: <u>4-21-11</u>	Authorized Inspector: <u>Nancy C. Ritchie Slaughter</u>	Date: <u>4/21/11</u>	



Supplemental Report

Report No.: UT-11-757

Page: 6 of 8

Summary No.: 01.B9.11.0020

Examiner: Hollis, Jacob

Jacob R. Hollis

Level: II-N

Reviewer: Gary A. Moss

Gary A. Moss

Date: 4.21.11

Examiner: Day, John, C.

John C. Day

Level: II-N

Site Review: N/A

N/A

Date: 4/21/11

Other: N/A

Level: N/A


ANII Review: Nancy Kitchin Stoyler

Nancy Kitchin Stoyler

Date: 4/21/11

Comments:

Sketch or Photo:



Supplemental Report

Report No.: UT-11-757

Page: 7 of 8

Summary No.: 01.B9.11.0029

Examiner: Holts, Jacob

Level: II-N

Reviewer: Sam Moss

Date: 4-21-11

Examiner: Day, John, C.

Level: II-N

Site Review: N/A

Date: 4/21/11

Other: N/A


Level: N/A

ANII Review: Nancy Chute & Stryker

Date: 4/21/11

Comments:

Sketch or Photo:





Determination of Percent Coverage for UT Examinations - Pipe

Attachment A
Page 28 of 162

Site/Unit: <u>Oconee / 1</u>	Procedure: <u>PDI-UT-2</u>	Outage No.: <u>O1-26</u>
Summary No.: <u>O1.B9.11.0029</u>	Procedure Rev.: <u>E</u>	Report No.: <u>UT-11-757</u>
Workscope: <u>ISI</u>	Work Order No.: <u>01897774</u>	Page: <u>8</u> of <u>8</u>

45 deg

Scan 1	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 1
Scan 2	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 2
Scan 3	<u>100.000</u> % Length X <u>50.000</u>	% volume of length / 100 = <u>50.000</u>	% total for Scan 3
Scan 4	<u>100.000</u> % Length X <u>50.000</u>	% volume of length / 100 = <u>50.000</u>	% total for Scan 4

Add totals and divide by # scans = 50.000 % total for 45 deg

Other deg - 60 (to be used for supplemental scans)

The data to be listed below is for coverage that was not obtained with the 45 deg scans.

Scan 1	<u>100.000</u> % Length X <u>0.000</u>	% volume of length / 100 = <u>0.000</u>	% total for Scan 1
Scan 2	<u>100.000</u> % Length X <u>50.000</u>	% volume of length / 100 = <u>50.000</u>	% total for Scan 2
Scan 3	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 3
Scan 4	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 4

Percent complete coverage

Add totals for each scan required and divide by # of scans to determine;

37.500 % Total for complete exam

Site Field Supervisor: David K. Z. III

Date: 4/21/11

UT Calibration, Examination

Site/Unit: Oconee / 1
 Summary No.: 01.B9.11.0029
 Workscope: ISI

Procedure: NDE-930
 Procedure Rev.: 1
 Work Order No.: 01897774

Outage No.: 01-28
 Report No.: UT-11-783
 Page: 1 of 4

Code: 1999/2000A Cat./Item: B-J /B9,11 Location: _____
 Drawing No.: ISI-OCN1-009 Description: Nozzle to Safe End
 System ID: 59
 Component ID: 1-PIB1-9 Size/Length: N/A Thickness/Diameter: 58/2.33/36.5
 Limitations: Yes - See attached sheets Start Time: 1031 Finish Time: 1044

Instrument Settings
 Serial No.: 011LW6
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 10.9418 Range: 5.0"
 M'tl Cal/Vel: .2402 Pulse: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2 MHz
 Filter: Fixed Mode: Dual
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 74 Circ. Gain (dB): 74
1 Screen Div. = .5 In. of Sound Path
 Linearity Report No.: L-11-143

Search Unit
 Serial No.: 09-1252
 Manufacturer: RTD
 Size: 2(10x10) Shape: Square
 Freq.: 2.0 MHz Style: TRLA
 Exam Angle: 70° # of Elements: Dual
 Mode: L-WAVE
 Measured Angle: 70
 Wedge Style: Integral
Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1010	4/18/2011
Inter. Cal.		
Inter. Cal.	1030	4/18/2011
Inter. Cal.		
Final Cal	1225	4/18/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: A09322
 Type: ROMPAS

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1/4T Hole	80	3.7	1.84

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
See Axial			

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
40.8	2" Radius	80	4	1.88

Calibration Block
 Cal. Block No. 50214
 Thickness 2.454 Dia.: Flat
 Cal. Blk. Temp. 69 Temp. Tool: MCNDE40130
 Comp. Temp. 67 Temp. Tool: MCNDE40130
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Scan Coverage
 Upstream Downstream Scan dB: 74
 CW CCW Scan dB: 74
 Exam Surface: D.D.
 Surface Condition: As Ground

Results: Accept Reject Info Comments: N/A
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewed	Signature	Date
Hollis, Jacob	II-N	<i>Jacob Hollis</i>	4/18/2011	<i>Sandy Mon</i>		4-21-11
Day, John, C.	II-N	<i>John Day</i>	4/18/2011	N/A		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			N/A		

UT Calibration Examination

Site/Unit: Oconee / 1
 Summary No.: 01.B9.11.0029
 Workscope: ISI

Procedure: NDE-630
 Procedure Rev.: 1
 Work Order No.: 01897774

Outage No.: 01-26
 Report No.: UT-11-793
 Page: 2 of 4

Code: 1998/2000A Cal./Item: B-J /B9.11 Location: _____

Drawing No.: ISI-OCN1-009 Description: Nozzle to Safe End

System ID: 50

Component ID: 1-PIB1-9 Size/Length: N/A Thickness/Diameter: 88/2.33/36.5

Limitations: Yes - See attached sheets Start Time: 1048 Finish Time: 1102

Instrument Settings
 Serial No.: 011LW6
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 14.8084 Range: 7.0
 M'd Cal/Vol: 2438 Putser: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 1 MHz
 Filter: Fixed Mode: Dual
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 75.1 Circ. Gain (dB): 63.6
1 Screen Div. = .7 In. of Sound Path
 Linearly Report No.: L-11-143

Search Unit
 Serial No.: 03-788
 Manufacturer: RTD
 Size: 2(20x34) Shape: Square
 Freq.: 1.0 MHz Style: TRL1
 Exam Angle: 60 # of Elements: Dual
 Mode: Long
 Measured Angle: 60
 Wedge Style: Integral
Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1013	4/18/2011
Inter. Cal.		
Inter. Cal.	1044	4/18/2011
Inter. Cal.		
Final Cal	1230	4/18/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: A09322
 Type: ROMPAS

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
3/4T Hole	80	4.8	3.218

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
3/4T Hole	80	5.0	3.489

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
46.8	2" Radius	80	3	2"

Calibration Block
 Cal. Block No. 50214
 Thickness 2.464 Dia.: Flat
 Cal. Blk. Temp. 67 Temp. Tool: MCNDE40130
 Comp. Temp. 67 Temp. Tool: MCNDE40130
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Scan Coverage
 Upstream Downstream Scan dB: 75.1
 CW CCW Scan dB: 75.1
 Exam Surface: O.D.
 Surface Condition: As Ground

Results: Accept Reject Info

Comments: N/A

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Hollis, Jacob	II-N	<i>Jacob R. Hollis</i>	4/18/2011	<i>Gay A. Moss</i>		4-21-11
Day, John, C.	II-N	<i>John C. Day</i>	4/18/2011	N/A		
Other	N/A			N/A		

ATTACHMENT A
 PAGE 30 OF 162

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: <u>1-PIB1-9</u> Item No: <u>01.B9.11.0029</u>		remarks:
<input type="checkbox"/> NO SCAN <input checked="" type="checkbox"/> LIMITED SCAN	SURFACE <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2	BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw
FROM L <u>N/A</u> to L <u>N/A</u> INCHES FROM W0 <u>-2</u> to <u>CL</u>		Procedure allows scanning from
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other <u>60RL</u> FROM <u>0</u> DEG to <u>360</u> DEG		cast side only.
<input type="checkbox"/> NO SCAN <input checked="" type="checkbox"/> LIMITED SCAN	SURFACE <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2	BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw
FROM L <u>N/A</u> to L <u>N/A</u> INCHES FROM W0 <u>-1.60</u> to <u>CL</u>		Procedure allows scanning from
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other <u>70RL</u> FROM <u>0</u> DEG to <u>360</u> DEG		cast side only.
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw
FROM L <u>N/A</u> to L <u>N/A</u> INCHES FROM W0 <u>CL</u> to <u>Beyond</u>		
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other <u>60RL</u> FROM <u>N/A</u> DEG to <u>N/A</u> DEG		
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw
FROM L <u>N/A</u> to L <u>N/A</u> INCHES FROM W0 <u>CL</u> to <u>Beyond</u>		UT-11-783
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 5 <input type="checkbox"/> 60 other <u>70RL</u> FROM <u>CL</u> DEG to <u>Beyond</u> DEG		Sketch(s) attached
		<input checked="" type="checkbox"/> yes <input type="checkbox"/> No
Prepared By: <u>Jacob R. Hollis</u>	Level: <u>II</u>	Date: <u>04/18/11</u>
Reviewed By: <u>Jay Mor</u>	Date: <u>4-21-11</u>	Authorized Inspector: <u>N/A</u>
		Sheet <u>3</u> of <u>4</u>

DATA

Supplemental Report

Report No.: UT-11-783

Page: 4 of 4

Summary No.: O1.B9.11.0029

Examiner: Hollis, Jacob

Level: II-N

Reviewer: Henry Moore

Date: 4-21-11

Examiner: Day, John, C.

Level: II-N

Site Review: N/A

Date: _____

Other: N/A

Level: N/A

ANII Review: N/A


Date: _____

Comments:

S1

S2

Sketch or Photo:



UT Calibration, Examination

Site/Unit: Oconee / 1 Procedure: PDI-UT-2 Outage No.: 04-28
 Summary No.: 01.B9.11.0072 Procedure Rev.: E Report No.: UT-11-785
 Workscope: ISI Work Order No.: 01897425 Page: 1 of 8

Code: 1998/2000A Cal./Item: B-J /B9.11 Location: _____
 Drawing No.: ISI-OCN1-013 Description: RC Pump 1B1 to Safe end
 System ID: 50
 Component ID: 1-PDB1-1 Size/Length: N/A Thickness/Diameter: 88/2.33/33.5
 Limitations: Yes - See attached sheets Start Time: 1302 Finish Time: 1312

Instrument Settings
 Serial No.: 011MBT Manufacturer: KRAUTKRAMER Model: USN-60
 Delay: 7.5947 Range: 8.00 M's Cal/Vol: .1268 Pulsar: High
 Damping: 1K Reject: 0% Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 58.8 Cir. Gain (dB): 58.8
1 Screen Div. = .8 in. of Sound Path
 Linearity Report No.: L-11-139

Search Unit
 Serial No.: 0105LJ Manufacturer: KBA Size: 0.5 Shape: Round
 Freq.: 2.25 MHz Style: Comp - G Exam Angle: 45 # of Elements: Single
 Mode: Shear Measured Angle: 45 Wedge Style: M8WQC
 Search Unit Cable Type: RG - 174
 Length: 8' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1000	4/17/2011
Inter. Cal.		
Inter. Cal.	1302	4/17/2011
Inter. Cal.		
Final Cal	1545	4/17/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: 04-5740
 Type: ROMPAS

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch	80	5.2	4.088

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
See Axial			

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
19.0	2" Radius	80	2.4	2.00

Calibration Block
 Cal. Block No. 40397 Thickness 3.000 Dia.: Flat
 Cal. Blk. Temp. 87 Temp. Tool: MCNDE40130
 Comp. Temp. 70.5 Temp. Tool: MCNDE40130
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Scan Coverage
 Upstream Downstream Scan dB: 58.8
 CW CCW Scan dB: 58.8
 Exam Surface: O.D. Surface Condition: As Ground

Results: Accept Reject Info
 Percent Of Coverage Obtained > 80%: No Reviewed Previous Data: No

Comments: Initial Section XI Exam

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Stauffer, Lester, E.	II-N	<i>[Signature]</i>	4/17/2011	<i>[Signature]</i>		4-21-11
Hassel, Matthew, B.	II-N	<i>[Signature]</i>	4/17/2011	Site Review	<i>[Signature]</i>	
Other	Level	Signature	Date	AMR Review	Signature	Date
N/A	N/A					

UT Calibration Examination

Site/Unit: Oconee / 1 Procedure: POI-UT-2 Outage No.: 01-28
 Summary No.: 01.B9.11.0072 Procedure Rev.: E Report No.: UT-11-765
 Workscope: ISI Work Order No.: 01897425 Page: 2 of 8

Code: 1998/2000A Cat./Item: B-J /B9.11 Location: _____
 Drawing No.: ISI-OCN1-013 Description: RC Pump 1B1 to Safe end
 System ID: 80
 Component ID: 1-PDB1-1 Size/Length: N/A Thickness/Diameter: 56/2.33/33.6
 Limitations: Yes - See attached sheets Start Time: 1326 Finish Time: 1336

Instrument Settings

Serial No.: 011MBT
 Manufacturer: KRAUTKRAMER
 Model: USN-80
 Delay: 11.2203 Range: 10.00
 MFI Cal/Vel: .2121 Pulse: High
 Damping: 1K Reject: 0%
 Rep. Rate: Auto/High Freq.: 2.0 MHz
 Filter: Fixed Mode: Dual
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 80.3 Circ. Gain (dB): N/A
1 Screen Div. = 1.0 in. of Sound Path
 Linearity Report No.: L-11-139

Search Unit

Serial No.: 10-1204
 Manufacturer: RYD
 Size: 2(24x42)14L Shape: Rect.
 Freq.: 2.0 MHz Style: YRL 2
 Exam Angle: 60 # of Elements: Dual
 Mode: Long.
 Measured Angle: 80
 Wedge Style: Integral
 Search Unit Cable
 Type: RG - 174
 Length: 8' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	<u>1012</u>	<u>4/17/2011</u>
Inter. Cal.		
Inter. Cal.	<u>1325</u>	<u>4/17/2011</u>
Inter. Cal.		
Final Cal.	<u>1559</u>	<u>4/17/2011</u>

Couplant

Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
<u>3/4T SDH</u>	<u>80</u>	<u>4.4</u>	<u>4.350</u>

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
<u>N/A</u>			

Reference Block

Serial No.: 04-8740
 Type: ROMPAS

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
<u>51.5</u>	<u>2" Radius</u>	<u>80</u>	<u>2.0</u>	<u>2.00</u>

Calibration Block

Cal. Block No.: 40397
 Thickness: 3.000 Dia.: Flat
 Cal. Blk. Temp.: 87 Temp. Tool: MCNDE40130
 Comp. Temp.: 70.5 Temp. Tool: MCNDE40130
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Scan Coverage

Upstream Downstream Scan dB: 71.3
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: As Ground

Results: Accept Reject Info

Comments: Initial Section XI Exam

Percent Of Coverage Obtained > 80%: No Reviewed Previous Data: No

Examiner	Level	Signature	Date	Reviewed	Signature	Date
Stauffer, Lester, E.	III-N		<u>4/17/2011</u>			<u>4-21-11</u>
Haase, Matthew, B.	II-N		<u>4/17/2011</u>	Site Review		
Other	N/A			ANIL Review		

ATTACHMENT A
PAGE 39 OF 162

UT Calibration. .amination

Site/Unit: Ocoee / 1
 Summary No.: 01.B9.11.0072
 Workscope: IBI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01697425

Outage No.: 01-28
 Report No.: UT-11-765
 Page: 3 of 8

Code: 1898/2090A Cat./Item: B-J /B9.11 Location: _____
 Drawing No.: IBI-OCN1-013 Description: RC Pump 1B1 to Safe end
 System ID: 50
 Component ID: 1-PQB1-1 Size/Length: N/A Thickness/Diameter: 56/2.33/33.5
 Limitations: Yes See attached sheets Start Time: 1314 Finish Time: 1324

Instrument Settings

Search Unit

Serial No.: 011MBT
 Manufacturer: KRAUTKRAMER
 Model: USN-80
 Delay: 9.5100 Range: 12.50
 MUI Cal/Vet: .1232 Pulse: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 62.3 Cir. Gain (dB): N/A
1 Screen Div. = 1.25 In. of Sound Path
 Linearity Report No.: L-11-139

Serial No.: SE0773
 Manufacturer: GE
 Size: .5 Shape: Round
 Freq.: 2.25 MHz Style: Comp - G
 Exam Angle: 70 # of Elements: Single
 Mode: Shear
 Measured Angle: 70
 Wedge Style: MSWQC
 Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1007	4/17/2011
Inter. Cal.		
Inter. Cal.	1313	4/17/2011
Inter. Cal.		
Final Cal	1548	4/17/2011

Couplant

Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block

Serial No.: 64-8740
 Type: ROMPAS

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
3/4T 8DH	80	6.3	7.915

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
51.9	2" Radius	80	1.6	1.890

Calibration Block

Cal. Block No. 40397
 Thickness 3.000 Dia.: Flat
 Cal. Blk. Temp. 67 Temp. Tool: MCNDE40130
 Comp. Temp. 70.5 Temp. Tool: MCNDE40130
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Upstream Downstream Scan dB: 62.3
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: As Ground

Scan Coverage

Results: Accept Reject Info

Comments: Initial Section XI Exam

Percent Of Coverage Obtained > 80%: No Reviewed Previous Data: No

Examiner	Level	Signature	Date	Reviewed	Signature	Date
Stauffer, Lester, E.	III-N	<i>[Signature]</i>	4/17/2011	<i>[Signature]</i>		
Hassel, Matthew, S.	II-N	<i>[Signature]</i>	4/17/2011	N/A		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A					

ATTACHMENT A
PAGE 35 OF 162

UT Calibration Examination

Site/Unit: Oconee / 1 Procedure: NDE-640 Outage No.: 01-26
 Summary No.: 01.88.11.0072 Procedure Rev.: 5 Report No.: UT-11-765
 Workscope: IBI Work Order No.: 01897425 Page: 4 of 8

Code: 1998/2000A Cal./Item: B-J /B9.11 Location: _____
 Drawing No.: ISI-OCN1-613 Description: RC Pump 1B1 to Safe end

System ID: 50
 Component ID: 1-PDB1-1 Size/Length: N/A Thickness/Diameter: 88/2.33/33.5

Limitations: None Start Time: 1250 Finish Time: 1300

Instrument Settings Search Unit
 Serial No.: 011MBT Serial No.: 686818
 Manufacturer: KRAUTKRAMER Manufacturer: Panametrics
 Model: USN-80 Size: 1.0 Shape: Round
 Delay: 0.5487 Range: 8.0 Freq.: 2.25 MHz Style: GAMMA
 M'tl Cal/Vel: .2250 Pulsar: High Exam Angle: 0 # of Elements: Single
 Damping: 1K Reject: 0% Mode: Long
 Rep. Rate: Autohigh Freq.: 2.25 MHz Measured Angle: 0
 Filter: Fixed Mode: PE Wedge Style: Integral
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 31.2 Cir. Gain (dB): N/A
1 Screen Div. = .5 in. of Sound Path
 Linearity Report No.: L-11-139 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1250	4/17/2011
Inter. Cal.		
Inter. Cal.		
Inter. Cal.		
Final Cal	1300	4/17/2011

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
Component BW	80	5.5	2.700

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference Block
 Serial No.: 04-8740
 Type: ROMPAS

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
27.4	BW	126	2.0	1.00

Calibration Block
 Cal. Block No. _____ Component _____
 Thickness 2.330 Dia.: 33.500
 Cal. Bk. Temp. 70.5 Temp. Tool: MCNDE40130
 Comp. Temp. 70.5 Temp. Tool: MCNDE40130
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Results: Accept Reject Info
 Percent Of Coverage Obtained > 80%: Yes Reviewed Previous Data: No

Comments: Initial Section XI Exam

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Stauffer, Lester, E.	III-N	<i>[Signature]</i>	4/17/2011	<i>[Signature]</i>	<i>[Signature]</i>	4-20-11
Hassal, Matthew, S.	II-N	<i>[Signature]</i>	4/17/2011	Site Review P/A	<i>[Signature]</i>	
Other N/A	N/A	<i>[Signature]</i>	Date	ANII Review	<i>[Signature]</i>	Date

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: 1-PDB1-1

Item No: 01B9.11.0072

remarks:

Due to 1B1 RCP nozzle

configuration.

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L N/A to L N/A INCHES FROM W0 CL to Beyond
 ANGLE: 0 45 60 other 70 FROM 0 DEG to 360 DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 5 60 other _____ FROM _____ DEG to _____ DEG

Sketch(s) attached

yes No

Prepared By: Matthew Hassell

Level: II

Date: 04/17/11

Sheet 5 of 8

Reviewed By: M. E. Hansen

Date: 4.20.11

Authorized Inspector: [Signature]

Date: 4/20/11

ATTACHMENT A
PAGE 37 OF 162



Supplemental Report

Report No.: UT-11-765

Page: 6 of 8

Summary No.: O1.B9.11.0072

Examiner: Stauffer, Lester, E. *LS*

Level: III-N

Reviewer: *DeHougen*

Date: 4-20-11

Examiner: Hassel, Matthew, B. *MH*

Level: II-N

Site Review: N/A

Date: 4/22/11

Other: N/A


Level: N/A

ANII Review: *[Signature]*

Date: 4/22/11

Comments: Pump S2

Sketch or Photo:



Supplemental Report

Report No.: UT-11-765

Page: 7 of 8

Summary No.: 01.B9.11.0072

Examiner: Stauffer, Lester, E. *[Signature]*

Level: III-N

Reviewer: DE Hansen *[Signature]*

Date: 4.20.11

Examiner: Hassal, Matthew, S. *[Signature]*

Level: II-N

Site Review: N/A

Date: 4/20/11

Other: N/A


Level: N/A

ANII Review: [Signature]

Date: 4/20/11

Comments:

Sketch or Photo:





Determination of Percent Coverage for UT Examinations - Pipe

ATTACHMENT A
PAGE 40 OF 162

Site/Unit: <u>Oconee / 1</u>	Procedure: <u>PDI-UT-2</u>	Outage No.: <u>01-26</u>
Summary No.: <u>01.B9.11.0072</u>	Procedure Rev.: <u>E</u>	Report No.: <u>UT-11-765</u>
Workscope: <u>ISI</u>	Work Order No.: <u>01897425</u>	Page: <u>8</u> of <u>8</u>

45 deg

Scan 1	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 1
Scan 2	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 2
Scan 3	<u>100.000</u> % Length X	<u>50.000</u> % volume of length / 100 =	<u>50.000</u> % total for Scan 3
Scan 4	<u>100.000</u> % Length X	<u>50.000</u> % volume of length / 100 =	<u>50.000</u> % total for Scan 4

Add totals and divide by # scans = 50.000 % total for 45 deg

Other deg - 70 (to be used for supplemental scans)

The data to be listed below is for coverage that was not obtained with the 45 deg scans.

Scan 1	<u>100.000</u> % Length X	<u>50.000</u> % volume of length / 100 =	<u>50.000</u> % total for Scan 1
Scan 2	<u>0.000</u> % Length X	<u>0.000</u> % volume of length / 100 =	<u>0.000</u> % total for Scan 2
Scan 3	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 3
Scan 4	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 4

Percent complete coverage

Add totals for each scan required and divide by # of scans to determine;

37.500 % Total for complete exam

Site Field Supervisor: David K. Z III Date: 4/21/11

UT Calibration Examination

Site/Unit: Oconee 1 1
 Summary No.: 01.B9.11.0072
 Workscope: 1B1

Procedure: NDE-830
 Procedure Rev.: 1
 Work Order No.: 01897425

Outage No.: 01-26
 Report No.: UT-11-774
 Page: 1 of 4

Code: 1898/2000A Cal/Item: B-J /B9.11 Location: _____
 Drawing No.: ISI-OCN1-013 Description: RC Pump 1B1 to Safe end
 System ID: 50
 Component ID: 1-PDB1-1 Size/Length: N/A Thickness/Diameter: SS/2.330/33.5
 Limitations: Yes - See attached sheets Start Time: 1041 Finish Time: 1058

Instrument Settings

Search Unit

Serial No.: 00WHDK
 Manufacturer: KRAUTKRAMER
 Model: USN-80
 Delay: 16.7506 Range: 7.0
 M/T Cal/Vol: 2600 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 1 MHz
 Filter: Fixed Mode: Dual
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 70.2 Ctr. Gain (dB): 71.8
1 Screen Div. = .70 in. of Sound Path
 Linearity Report No.: L-11-130

Serial No.: 03-789
 Manufacturer: RTD
 Size: 2(20x34) Shape: Rect.
 Freq.: 1.0 MHz Style: TRL1
 Exam Angle: 60L # of Elements: Dual
 Mode: Long.
 Measured Angle: 60
 Wedge Style: Integral
 Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1010	4/18/2011
Inter. Cal.		
Inter. Cal.	1040	4/18/2011
Inter. Cal.		
Final Cal	1300	4/18/2011

Couplant

Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block

Serial No.: 04-8740
 Type: ROMPAS

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
3/4T SDH	80	4.8	3.29

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
3/4T SDH	80	8.2	3.60

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
48.5	2" Radius	80	2.8	2.00

Calibration Block

Cal. Block No. 80214
 Thickness 2.464 Dia.: Flat
 Cal. Blk. Temp. 67 Temp. Tool: MCNDE40130
 Comp. Temp. 67 Temp. Tool: MCNDE40130

Scan Coverage

Upstream Downstream Scan dB: 73
 CW CCW Scan dB: 73
 Exam Surface: O.D.
 Surface Condition: As Ground

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Results: Accept Reject Info

Comments: N/A

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: No

Examiner	Level	U-N	Signature	Date	Reviewer	Signature	Date
Hassel, Matthew, B.		II-N	<i>[Signature]</i>	4/18/2011	<i>[Signature]</i>		4-20-11
Stauffer, Lester, E.		III-N	<i>[Signature]</i>	4/18/2011	<i>[Signature]</i>		
Other		N/A			ANII Review		
					<u>N/A</u>		

ATTACHMENT A
PAGE 42 OF 162

UT Calibration .amination

Site/Unit: Oconee / 1
 Summary No.: 01.B9.11.0072
 Workscope: 1B1

Procedure: NDE-630
 Procedure Rev.: 1
 Work Order No.: 01897425

Outage No.: 01-26
 Report No.: UT-11-774
 Page: 2 of 4

Code: 1998/2800A Cat./Item: B-J /B9.11 Location: _____
 Drawing No.: 1B1-OCN1-013 Description: RC Pump 1B1 to Safe end
 System ID: 50
 Component ID: 1-PDB1-1 Size/Length: N/A Thickness/Diameter: SS/2.330/33.5
 Limitations: Yes - See attached sheets Start Time: 1041 Finish Time: 1058

Instrument Settings
 Serial No.: 00VHDK
 Manufacturer: KRAUTKRAMER
 Model: UBN-60
 Delay: 10.8853 Range: 5.00
 M'U Cal/Vet: .2392 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.0 MHz
 Filter: Fixed Mode: Dual
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 80.1 Cir. Gain (dB): 80.6
1 Screen Div. = .5 in. of Sound Path
 Linearly Report No.: L-11-138

Search Unit
 Serial No.: 90-371
 Manufacturer: RTD
 Size: 2(10x10) Shape: Rect.
 Freq.: 2.0 MHz Style: TRLA
 Exam Angle: 70L # of Elements: Dual
 Mode: Long.
 Measured Angle: 70
 Wedge Style: Integral
Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1015	4/18/2011
Inter. Cal.		
Inter. Cal.	1048	4/18/2011
Inter. Cal.		
Final Cal	1308	4/18/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: 04-8740
 Type: ROMPAS

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1/4T SDH	80	3.8	1.90

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1/4T SDH	80	3.9	1.95

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
44.7	2" Radius	60	4.00	2.068

Calibration Block
 Cal. Block No. 50214
 Thickness 2.464 Dia.: Flat
 Cal. Blk. Temp. 67 Temp. Took: MCNDE40130
 Comp. Temp. 67 Temp. Took: MCNDE40130
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasound Indication Report.)

Scan Coverage
 Upstream Downstream Scan dB: 81
 CW CCW Scan dB: 81
 Exam Surface: O.D.
 Surface Condition: As Ground

Results: Accept Reject Info Comments: N/A
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: No

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Hassel, Matthew, S.	II-N	<i>[Signature]</i>	4/18/2011	Barry M. [Signature]		4-20-11
Stauffer, Lester, E.	III-N	<i>[Signature]</i>	4/18/2011	SRA Review		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			N/A		

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: <u>1-PDB1-1</u> Item No: <u>01B9:11.0072</u>		remarks:
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2	BEAM DIRECTION <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw
FROM L <u>N/A</u> to L <u>N/A</u> INCHES FROM W0 <u>CL</u> to <u>Beyond</u>		Procedure allows scanning from
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other <u>70L</u> FROM <u>0</u> DEG to <u>360</u> DEG		cast side only.
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2	
FROM L _____ to L _____ INCHES FROM W0 _____ to _____		
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2	
FROM L _____ to L _____ INCHES FROM W0 _____ to _____		
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2	
FROM L _____ to L _____ INCHES FROM W0 _____ to _____		
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2	
FROM L _____ to L _____ INCHES FROM W0 _____ to _____		
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 5 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		
Prepared By: <u>Lester Stauffer</u> Level: <u>III</u> Date: <u>04/18/11</u> Sheet <u>3</u> of <u>4</u>		UT-11-774
Reviewed By: <u>Barry Michael</u> Date: <u>4-20-11</u> Authorized Inspector: <u>N/A</u> Date: _____		Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> No

DEI

Supplemental Report

Report No.: UT-11-774

Page: 4 of 4

Summary No.: O1.B9.11.0072

Examiner: Hassel, Matthew, S. *M. Hassel*

Level: II-N

Reviewer: Barry Michael

Date: 4-20-11

Examiner: Stauffer, Lester, E. *L. Stauffer*

Level: III-N

Site Review: N/A

Date: _____

Other: N/A


Level: N/A

ANII Review: N/A

Date: _____

Comments:

Sketch or Photo:



ATTACHMENT A
PAGE 44 OF 162

UT Calibration Examination

Site/Unit: Oconee / 1

Procedure: PDI-UT-2

Outage No.: 01-28

Summary No.: 01.CS.11.0029

Procedure Rev.: E

Report No.: UT-11-875

Workscope: IBI

Work Order No.: 01908569

Page: 1 of 7

Code: 1998/2000A

Cat./Item: C-F-1/C5.11

Location: _____

Drawing No.: 1LP-128

Description: Reducer to Valve 1LP-18 (Cast)

System ID: 63A

Component ID: 1LP-128-50

Size/Length: N/A Thickness/Diameter: 1.188 / 12.000

Limitations: Yes - See attached sheet

Start Time: 1517 Finish Time: 1543

Instrument Settings

Search Unit

Serial No.: 00X14L
 Manufacturer: KRAUTKRAMER
 Model: USN-80
 Delay: 5.4644 Range: 3
 M'd Cal/Vol: .1199 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Az. Gain (dB): 27.3 Circ. Gain (dB): 27.3
1 Screen Div. = 3 in. of Sound Path
 Linearity Report No.: L-11-131

Serial No.: SE0708
 Manufacturer: KBA
 Size: .5 Shape: Round
 Freq.: 2.25 MHz Style: Comp - G
 Exam Angle: 45 # of Elements: Single
 Mode: Shear
 Measured Angle: 45
 Wedge Style: MSWQC

Search Unit Cable

Type: RG - 174
 Length: 8' No. Conn.: 0

Scan Coverage

Upstream Downstream Scan dB: 49
 CW CCW Scan dB: 49
 Exam Surface: O.D.
 Surface Condition: As Ground

Calibration Block

Cal. Block No.: 40413
 Thickness 1.125 Dia.: 12
 Cal. Blk. Temp. 72 Temp. Tool: MCNDE40129
 Comp. Temp. 81 Temp. Tool: MCNDE40129
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Results: Accept Reject Info

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Cal. Checks	Time	Date
Initial Cal	1500	2/1/2011
Inter. Cal.		
Inter. Cal.	1516	2/1/2011
Inter. Cal.		
Final Cal	1845	2/1/2011

Couplant

Cal. Batch: 08328
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 08328
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block

Serial No.: A08328
 Type: Rompa

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch	80	5.2	1.845

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch	80	5.3	1.59

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
25.1	1" Radius	80	3.4	1"

Comments: N/A

Examiner	Level	II-N	Signature	Date	Reviewer	Signature	Date
Ransom, Greg J.			<i>Greg Ransom</i>	2/1/2011	<i>Tom H. [Signature]</i>		2/1/2011
Day, John, C.			<i>John Day</i>	2/1/2011	N/A		
Other		N/A			ANII Review	<i>Nancy Chute [Signature]</i>	4/4/11
N/A							



UT Calibrator Examination

Site/Unit: Oconee / 1
 Summary No.: 01.C5.11.0029
 Workscope: ISI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01909569

Outage No.: 01-26
 Report No.: UT-11-675
 Page: 2 of 7

Code: 1998/2000A Cat/Item: C-F-1/C5.11 Location: _____
 Drawing No.: 1LP-128 Description: Reducer to Valve 1LP-18 (Cast)
 System ID: 53A
 Component ID: 1LP-128-80 Size/Length: N/A Thickness/Diameter: 1.188 / 12.000
 Limitations: Yes - See Attached Sheets Start Time: 1545 Finish Time: 1810

Instrument Settings
 Serial No.: 00X14L
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 10.0522 Range: 6
 M'tl Cal/Vol: .1294 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Auto/High Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 45.5 Circ. Gain (dB): 45.5
 1 Screen Div. = .5 in. of Sound Path
 Linearity Report No.: L-11-131

Search Unit
 Serial No.: 007Y13
 Manufacturer: KBA
 Size: 0.6 Shape: Round
 Freq.: 2.25 MHz Style: Comp - G
 Exam Angle: 60 # of Elements: Single
 Mode: Shear
 Measured Angle: 60
 Wedge Style: MSWQC
 Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1503	2/1/2011
Inter. Cal.		
Inter. Cal.	1545	2/1/2011
Inter. Cal.		
Final Cal	1647	2/1/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: A09325
 Type: Rompas

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch	80	4.3	2.32

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
28.1	1" Radius	80	2	1"

Calibration Block
 Cal. Block No.: 40413
 Thickness 1.125 Dia.: 12
 Cal. Blk. Temp. 72 Temp. Tool: MCNDE40129
 Comp. Temp. 81 Temp. Tool: MCNDE40129
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Comments: Used ID notch due to 5 to 1 ratio.

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Ransom, Greg J.	II-N	<i>Greg Ransom</i>	2/1/2011	<i>Greg Ransom</i>		2/1/2011
Day, John, C.	II-N	<i>John Day</i>	2/1/2011	Site Review	<i>N/A</i>	
N/A	N/A			ANII Review	<i>Nancy C. Ritchie-Slaughter</i>	4/4/11

ATTACHMENT A
 PAGE 46 OF 162

UT Calibration Examination

Site/Unit: Oconee / 1 Procedure: PDI-UT-2 Outage No.: 01-28
 Summary No.: O1.C5.11.0029 Procedure Rev.: E Report No.: UT-11-875
 Workscope: ISI Work Order No.: 01909569 Page: 3 of 7

Code: 1998/2000A Cat./Item: C-F-1/C5.11 Location: _____
 Drawing No.: 1LP-128 Description: Reducer to Valve 1LP-18 (Cast)
 System ID: 63A
 Component ID: 1LP-128-80 Size/Length: N/A Thickness/Diameter: 1.169 / 12.000
 Limitations: Yes - See Attached Sheets Start Time: 1613 Finish Time: 1631

Instrument Settings

Serial No.: 00X14L Manufacturer: KRAUTKRAMER Model: USN-60
 Delay: 8.6803 Range: 5" M/V Cal/Vel: .2302 Pulser: High
 Damping: 1K Reject: 0% Rep. Rate: Autohigh Freq.: 2 MHz
 Filter: Fixed Mode: Dual Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 76.5 Circ. Gain (dB): 76.5
1 Screen Div. = .5 In. of Sound Path
 Linearity Report No.: L-11-131

Search Unit

Serial No.: 93-644 Manufacturer: RTD Size: 2 (10x18) Shape: Rectangle
 Freq.: 2.0 MHz Style: TRL2 Exam Angle: 60 # of Elements: Dual
 Mode: Long Measured Angle: 60 Wedge Style: Integral
 Search Unit Cable Type: RG - 174 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1504	2/1/2011
Inter. Cal.		
Inter. Cal.	1612	2/1/2011
Inter. Cal.		
Final Cal	1648	2/1/2011

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
3/4 SDH	80	6.5	2.173

Couplant

Cal. Batch: 09325 Type: ULTRAGEL II
 Mfg.: SONOTECH Exam Batch: 09325
 Type: ULTRAGEL II Mfg.: SONOTECH

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Calibration Block

Cal. Block No. 40413 Thickness 1.125 Dia.: 12
 Cal. Blk. Temp. 72 Temp. Tool: MCNDE40129 Exam Surface: O.D.
 Comp. Temp. 81 Temp. Tool: MCNDE40129 Surface Condition: As Ground
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Scan Coverage

Upstream Downstream Scan dB: 76.5
 CW CCW Scan dB: N/A

Reference Block

Serial No.: A09325 Type: Rompas

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
53.1	1" Radius	80	2	1"

Comments: Used ID notch due to 5 to 1 ratio.

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Ransom, Greg J.	II-N	<i>Greg Ransom</i>	2/1/2011	<i>Greg Ransom</i>		2/1/2011
Day, John, C.	II-N	<i>John Day</i>	2/1/2011	N/A		
Other	N/A			ANII Review	<i>Woney C. Retcher-Slighter</i>	4/4/11

ATTACHMENT A
 PAGE 49 OF 162

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: 1LP-128-80

Item No: O1.C5.11.0029

remarks:

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L N/A to L N/A INCHES FROM W0 CL to Beyond
 ANGLE: 0 45 60 other _____ FROM 0 DEG to 360 DEG

Due to valve configuration

(Cast material)

1-LP-18 Valve

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

UT-11-675

Sketch(s) attached

yes No

Prepared By: Gregory Ransom

Level: II

Date: 02/01/11

Sheet 4 of 7

Reviewed By: [Signature]

Date: 2/1/2011

Authorized Inspector: [Signature]

Date: 4/4/11

attachment A
 page 48 of 162



Supplemer Report

Report No.: UT-11-875

Page: 5 of 7

Summary No.: O1.C5.11.0029

Examiner: Ransom, Greg J. *Greg Ransom*

Level: II-N

Reviewer: *David H. [Signature]*

Date: 2/1/2004

Examiner: Day, John, C. *John Day*

Level: II-N

Site Review: N/A

Date: _____

Other: N/A

Level: N/A

ANII Review: *Wendy L. [Signature]*


Date: 4/14/11

Comments: 1 LP-128-80
Scale 1 to 1

Sketch or Photo:

PIPE (SI)

→ FLOW



Cast Valve (52)
1 LP-018

ATTACHMENT A
PAGE 49 OF 1612



Supplemental Report

Report No.: UT-11-675

Page: 6 of 7

Summary No.: 01.C5.11.0029

Examiner: Ransom, Greg J. *Greg Ransom*

Level: II-N

Reviewer: *Kevin H. B. T.*

Date: *2/1/2011*

Examiner: Day, John, C. *John Day*

Level: II-N

Site Review: *N/A*

Date:

Other: *N/A*


Level: *N/A*

ANII Review: *Nancy Chittick Slaughter*

Date: *4/4/11*

Comments: 1LP-128-80

Sketch or Photo:



Determination of Percent Coverage for UT Examinations - Pipe

ATTACHMENT A
PAGE 51 OF 162

Site/Unit: <u>Oconee / 1</u>	Procedure: <u>PDI-UT-2</u>	Outage No.: <u>01-28</u>
Summary No.: <u>01.C5.11.0029</u>	Procedure Rev.: <u>E</u>	Report No.: <u>UT-11-675</u>
Workscope: <u>ISI</u>	Work Order No.: <u>01809569</u>	Page: <u>7</u> of <u>7</u>

45 deg

Scan 1	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 1
Scan 2	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 2
Scan 3	<u>100.000</u> % Length X <u>50.000</u>	% volume of length / 100 = <u>50.000</u>	% total for Scan 3
Scan 4	<u>100.000</u> % Length X <u>50.000</u>	% volume of length / 100 = <u>50.000</u>	% total for Scan 4

Add totals and divide by # scans = 50.000 % total for 45 deg

Other deg - 60 (to be used for supplemental scans)

The data to be listed below is for coverage that was not obtained with the 45 deg scans.

Scan 1	<u>100.000</u> % Length X <u>50.000</u>	% volume of length / 100 = <u>50.000</u>	% total for Scan 1
Scan 2	<u>100.000</u> % Length X <u>0.000</u>	% volume of length / 100 = <u>0.000</u>	% total for Scan 2
Scan 3	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 3
Scan 4	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 4

Percent complete coverage

Add totals for each scan required and divide by # of scans to determine;

37.500 % Total for complete exam

Site Field Supervisor: _____

David K. Z...

Date: 2/28/2011

UT Calibration Examination

Site/Unit: Oconee / 1
 Summary No.: 01.C5.11.0054
 Workscope: ISI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01897784

Outage No.: 01-26
 Report No.: UT-11-760
 Page: 1 of 8

Code: 1998/2000A Cal./Item: C-F-1/C5.11 Location: _____
 Drawing No.: 1LP-209 Description: Flow Restrictor to Pipe
 System ID: 53A
 Component ID: 1LP-209-17 Size/Length: N/A Thickness/Diameter: 88/1.0/10.0
 Limitations: Yes - See attached sheets Start Time: 1232 Finish Time: 1401

Instrument Settings		Search Unit	
Serial No.:	<u>00X14L</u>	Serial No.:	<u>01P7J2</u>
Manufacturer:	<u>KRAUTKRAMER</u>	Manufacturer:	<u>KBA</u>
Model:	<u>USN-60</u>	Size:	<u>.5</u> Shape: <u>Round</u>
Delay:	<u>4.965</u> Range: <u>2.5"</u>	Freq.:	<u>2.25 MHz</u> Style: <u>Comp - G</u>
MPI Cal/Vol:	<u>.121</u> Pulsar: <u>High</u>	Exam Angle:	<u>45</u> # of Elements: <u>Single</u>
Damping:	<u>1K</u> Reject: <u>0%</u>	Mode:	<u>Shear</u>
Rep. Rate:	<u>Autohigh</u> Freq.: <u>2.25 MHz</u>	Measured Angle:	<u>45</u>
Filter:	<u>Fixed</u> Mode: <u>PE</u>	Wedge Style:	<u>MSWQC</u>
Voltage:	<u>Fixed</u> Other: <u>Fullwave</u>		
Ax. Gain (dB):	<u>N/A</u> Circ. Gain (dB): <u>27.7</u>	Search Unit Cable	
<u>1</u> Screen Div. = <u>.25</u> in. of <u>Sound Path</u>		Type:	<u>RG - 174</u>
Linearity Report No.:	<u>L-11-137</u>	Length:	<u>6'</u> No. Conn.: <u>0</u>

Cal. Checks	Time	Date
Initial Cal	<u>0905</u>	<u>4/16/2011</u>
Inter. Cal.		
Inter. Cal.	<u>1230</u>	<u>4/16/2011</u>
Inter. Cal.		
Final Cal	<u>1630</u>	<u>4/16/2011</u>

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
<u>N/A</u>			





Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
<u>1" Notch</u>	<u>60</u>	<u>5.9</u>	<u>1.478</u>

Calibration Block		Scan Coverage	
Cal. Block No.:	<u>PDI-UT-2-0</u>	Upstream <input type="checkbox"/> Downstream <input type="checkbox"/>	Scan dB: <u>N/A</u>
Thickness:	<u>.60 - 2.0</u> Dia.: <u>Flat</u>	<u>OW</u> <input checked="" type="checkbox"/> <u>CCW</u> <input checked="" type="checkbox"/>	Scan dB: <u>34.8</u>
Cal. Blk. Temp.:	<u>73</u> Temp. Tool: <u>MCNDE40130</u>	Exam Surface:	<u>O.D.</u>
Comp. Temp.:	<u>76</u> Temp. Tool: <u>MCNDE40130</u>	Surface Condition:	<u>As Ground</u>
Recordable Indication(s):	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	(If Yes, Ref. Attached Ultrasonic Indication Report.)	

Reference Block
 Serial No.: 04-5741
 Type: ROMPAS

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
<u>26.7</u>	<u>1" Radius</u>	<u>60</u>	<u>4</u>	<u>1.000</u>

Results: Accept Reject Info Comments: N/A
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Bull, W. Keith	II-N		<u>4/16/2011</u>			<u>4-22-11</u>
Masasi, Matthew, S.	II-N		<u>4/16/2011</u>	<u>N/A</u>		
Other	Level	Signature	Date	ANI Review	Signature	Date
<u>N/A</u>	<u>N/A</u>					

UT Calibration, Examination

Site/Unit: Oconee / 1 Procedure: PDI-UT-2 Outage No.: 01-26
 Summary No.: 01.C6.11.0084 Procedure Rev.: E Report No.: UT-11-780
 Workscope: ISI Work Order No.: 01897784 Page: 2 of 6

Code: 1998/2000A Cat./Item: C-F-1/C6.11 Location: _____
 Drawing No.: 1LP-209 Description: Flow Restrictor to Pipe
 System ID: 63A
 Component ID: 1LP-209-17 Size/Length: N/A Thickness/Diameter: 88/1.0/10.0
 Limitations: Yes - See attached sheets Start Time: 1232 Finish Time: 1401

Instrument Settings
 Serial No.: 00X14L Manufacturer: KRAUTKRAMER Model: USN-60
 Delay: 6.4169 Range: 3" MFU Cal/Vol: .1224 Pulsar: High Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz Filter: Fixed Mode: PE Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 41.9 Cir. Gain (dB): N/A
1 Screen Div. = .3 In. of Sound Path
 Linearity Report No.: L-11-137

Search Unit
 Serial No.: 01F7J0 Manufacturer: KBA Size: .5 Shape: Round
 Freq.: 2.25 MHz Style: Comp - G Exam Angle: 60 # of Elements: Single
 Mode: Shear Measured Angle: 58 Wedge Style: MSWQC
 Search Unit Cable Type: RG - 174 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	0913	4/18/2011
Inter. Cal.		
Inter. Cal.	1311	4/18/2011
Inter. Cal.		
Final Cal	1632	4/18/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Actual Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1" Notch	80	6	1.800

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference Block
 Serial No.: 04-8741
 Type: ROMPAS

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
28.8	1" Radius	80	3.4	1"

Calibration Block
 Cal. Block No.: PDI-UT-2-0 Thickness: .80 - 2.0 Dia.: Flat
 Cal. Bk. Temp.: 73 Temp. Tool: MCNDE40130 Comp. Temp.: 76 Temp. Tool: MCNDE40130
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Results: Accept Reject Info Comments: N/A
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Budi, W. Keith	II-N	<i>[Signature]</i>	4/18/2011	<i>[Signature]</i>	<i>[Signature]</i>	4-22-11
Hassel, Matthew, S.	II-N	<i>[Signature]</i>	4/18/2011	N/A	<i>[Signature]</i>	
Other	N/A	<i>[Signature]</i>		AND Review	<i>[Signature]</i>	4/22/11

UT Calibrator Examination

Site/Unit: Oconee / 1
 Summary No.: 01.C5.11.0084
 Workscope: ISI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01897784

Outage No.: 01-26
 Report No.: UT-11-780
 Page: 3 of 8

Code: 1998/2000A Cal./Item: C-F-1/C5.11 Location: _____
 Drawing No.: 1LP-209 Description: Flow Restrictor to Pipe
 System ID: 53A
 Component ID: 1LP-209-17 Size/Length: N/A Thickness/Diameter: SS/1.0/10.0
 Limitations: Yes - See attached sheets Start Time: 1222 Finish Time: 1401

Instrument Settings
 Serial No.: 00X14L
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 9.458 Range: 3
 M² Cal/Vel: .228 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2 MHz
 Filter: Fixed Mode: Dual
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 68.6 Ctr. Gain (dB): N/A
1 Screen Div. = .3 In. of Sound Path
 Linearity Report No.: L-11-137

Search Unit
 Serial No.: 03-762
 Manufacturer: RTD
 Size: 2(10x18) Shape: Rect.
 Freq.: 2.0 MHz Style: TRL2
 Exam Angle: 60 # of Elements: Dual
 Mode: Long.
 Measured Angle: 61
 Wedge Style: Integral
Search Unit Cable
 Type: RG - 174
 Length: 0' No. Conn.: 0
Scan Coverage
 Upstream Downstream Scan dB: 72.5
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: As Ground

Cal. Checks	Time	Date
Initial Cal	1009	4/18/2011
Inter. Cal.		
Inter. Cal.	1341	4/18/2011
Inter. Cal.		
Final Cal	1634	4/18/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: 04-8741
 Type: ROMPAS

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1" Notch	80	7.1	2.062

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
44.3	1" Radius	80	3.3	1.004

Calibration Block
 Cal. Block No.: PDI-UT-2-0
 Thickness: .50 - 2.0 Dia.: Flat
 Cal. Blk. Temp.: 73 Temp. Tool: MCNDE40130
 Comp. Temp.: 76 Temp. Tool: MCNDE40130
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Results: Accept Reject Info Comments: N/A
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Hassel, Matthew, S.	II-N	<i>[Signature]</i>	4/18/2011	<i>[Signature]</i>		4-22-11
Butt, W. Keith	II-N	<i>[Signature]</i>	4/18/2011	Site Review	<i>[Signature]</i>	
Other	Level	Signature	Date	AN/IL Review	Signature	Date
N/A	N/A					

ATTACHMENT A
 PAGE 54 OF 162

DUKE POWER COMPANY

ISI LIMITATION REPORT

DUKE POWER COMPANY		
ISI LIMITATION REPORT		
Component/Weld ID: <u>1LP-209-17</u> Item No: <u>01.C5.11.0084</u>		remarks:
<input checked="" type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw		Due to valve configuration
FROM L <u>N/A</u> to L <u>N/A</u> INCHES FROM W0 <u>CL</u> to <u>Beyond</u>		cast material / <u>Flow RESTRICTED</u>
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other _____ FROM <u>0</u> DEG to <u>360</u> DEG		<u>4-22-11</u> <u>ATM</u>
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		
FROM L _____ to L _____ INCHES FROM W0 _____ to _____		
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		
FROM L _____ to L _____ INCHES FROM W0 _____ to _____		
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		UT-11-760
FROM L _____ to L _____ INCHES FROM W0 _____ to _____		Sketch(s) attached
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		<input checked="" type="checkbox"/> yes <input type="checkbox"/> No
Prepared By: <u>Matthew Hassell</u> <i>the bond</i> Level: <u>II</u> Date: <u>04/18/11</u> Sheet <u>4</u> of <u>7</u>		
Reviewed By: <u>Gary A. Moss</u> Date: <u>4-22-11</u> Authorized Inspector: <u>[Signature]</u> Date: <u>4/22/11</u>		

Supplemental Report

Report No.: UT-11-780

Page: 5 of 6

Summary No.: 01.C5.11.0084

Examiner: Bull, W. Keith Level: IL-N

Reviewer: [Signature] Date: 4-22-11

Examiner: Hessel, Matthew, B. Level: IL-N


Site Review: N/A Date: [Signature]

Other: N/A Level: N/A

ANII Review: [Signature] Date: 4/27/11

Comments:

Sketch or Photo:



Determination of Percent Coverage for UT Examinations - Pipe

ATTACHMENT A
Page 57 of 162

Site/Unit: <u>Oconee / 1</u>	Procedure: <u>PDI-UT-2</u>	Outage No.: <u>01-26</u>
Summary No.: <u>01.C5.11.0084</u>	Procedure Rev.: <u>E</u>	Report No.: <u>UT-11-780</u>
Workslope: <u>ISI</u>	Work Order No.: <u>01897784</u>	Page: <u>6</u> of <u>6</u>

45 deg

Scan 1	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 1
Scan 2	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 2
Scan 3	<u>100.000</u> % Length X	<u>50.000</u> % volume of length / 100 =	<u>50.000</u> % total for Scan 3
Scan 4	<u>100.000</u> % Length X	<u>50.000</u> % volume of length / 100 =	<u>50.000</u> % total for Scan 4

Add totals and divide by # scans = 50.000 % total for 45 deg

Other deg - 60 (to be used for supplemental scans)

The data to be listed below is for coverage that was not obtained with the 45 deg scans.

Scan 1	<u>100.000</u> % Length X	<u>50.000</u> % volume of length / 100 =	<u>50.000</u> % total for Scan 1
Scan 2	<u>100.000</u> % Length X	<u>0.000</u> % volume of length / 100 =	<u>0.000</u> % total for Scan 2
Scan 3	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 3
Scan 4	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 4

Percent complete coverage

Add totals for each scan required and divide by # of scans to determine:

37.500 % Total for complete exam

Site Field Supervisor:

David K. Z...

Date:

4/22/11



UT Calibration/Examination

Site/Unit: Oconee / Procedure: RDI-UT / Drawing No.: 01-25
 Summary No.: 01-0511-0015 / Procedure Ref.: / Report No.: UT-11-781
 Worksheet: 181 / Work Order No.: 0105770 / Page: 3 of 6

Code: 1898/2000A / Cal Plan: C-F/CG-11 / Location: /
 Drawing No.: 1LP-209 / Description: Pipe In Flow Restrictor
 System ID: 43A
 Component ID: 1LP-209-18 / Start Angle: N/A / Thickness/Diameter: 0311.0/19.0
 Limitations: Yes - See attached sheets / Start Time: 1223 / Finish Time: 1401

Instrument Settings

Serial No.: 00X144 / Search Unit: 181F7J2
 Manufacturer: KRAUTKRAMER / Manufacturer: KBA
 Model: USH-60 / Size: 5 / Shape: Round
 Delay: 4.866 / Range: 2.5 / Freq: 2.25 MHz / Style: Comp-G
 No. Cycles: 121 / Pulse: High / Exam Angle: 45 / # of Elements: Single
 Damping: 1K / Reject: 0% / Mode: Shear
 Rep. Rate: Autohigh / Freq: 2.25 MHz / Measured Angle: 45 / Couplant: /
 Filter: Fixed / Mode: PE / Wedge Style: MSW00 / Cal. Batch: 09325
 Voltage: Fixed / Other: Fullwave / Type: ULTRABEL II
 AE Gain (dB): 27.7 / Circ. Gain (dB): 27.7 / Search Unit Cable: / Mfg.: SONOTECH
 Screen Ch: 25 / Type: Bowed Path / Exam Batch: 09325
 Linearly Report No.: L11-137 / Type: / Mfg.: SONOTECH

Calibration Block

Cal. Block No.: PDI-UT-2.0 / Upgrade: Downstream Scan dB: 34.8
 Thickness: 50 - 2.0 / Dia: F141 / CW Scan dB: 34.8
 Cal. Blk. Temp: 73 / Temp. Tool: MCNDE40130 / Exam Surface: O.D.
 Corp. Temp: 78 / Temp. Tool: MCNDE40130 / Surface Condition: As Ground
 Recordable Indication(s): Yes No (If Yes: Ref. Attached Ultrasonic Indication Report)
 Results: Accept Reject Info / Comments: N/A
 Percent Of Coverage Obtained > 90%: No / Reviewed Previous Date: Yes

Cal. Check	Time	Date
Initial Cal.	0905	4/18/2011
Inter. Cal.		
Inter. Cal.	1220	4/18/2011
Inter. Cal.		
Final Cal.	1830	4/18/2011

Axial Oriented Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
T Notch	89	62	1476

Circumferential Oriented Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
See Axial			

Reference Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
28.7	3" Radius	89	77.5	1.000

Examiner: Bill W. Kalin / Level: U-1 / Signature: [Signature] / Date: 4/18/2011	Reviewer: [Signature] / Signature: [Signature] / Date: 4/22/11
Examiner: Hessel, Matthew E. / Level: U-1 / Signature: [Signature] / Date: 4/18/2011	QA Review: [Signature] / Signature: [Signature] / Date: [Date]
Other: N/A / Level: N/A / Signature: [Signature] / Date: [Date]	AMR Review: [Signature] / Signature: [Signature] / Date: 5/16/11

ATTACHMENT A
 Page 58 of 162



UT Calibration/Examination

Summary No: 0168110005 Procedure: PD-UT-3 Order No: 10156
 Workscope: 183 Work Order No: 01687764 (Report No): UT-11781

Code: 1908/2000A Cal No: CF-10711 Location: _____
 Drawing No: PLP-209 Description: Pipe to Flow Restrictor
 System ID: 53A
 Component ID: PLP-209-18 Size Length: N/A Thickness/Diameter: SS 1.0120
 Limitations: Yes - See attached sheets Start Time: 1232 Finish Time: 1401

Instrument Settings
 Serial No: 700X14L Search Unit: 01P7J0
 Manufacturer: KRAUTKRAMER Manufacturer: KBA
 Model: USM-60 Shape: Round
 Conn: 182169C Range: 3V
 MHz Cal Volt: 1224 Pld: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq: 2.25 MHz
 Filter: Fixed Mode: FB
 Voltage: Fixed Chn: Pulwave
 Ax. Gain (dB): 41.0 Circ. Gain (dB): N/A
 Screen Gv: 1 # of Sound Path: _____
 Linearity Report No: L-11-137

Cal. Checks	Time	Date
Initial Cal.	0913	4/10/2011
Inter. Cal.		
Inter. Cal.	1313	4/10/2011
Inter. Cal.		
Final Cal.	1632	4/10/2011

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1" Notch	80	3	1.000

Calibration Block
 Cal. Block No: PD-UT-3.0 Upstream Downstream Scan dB: 97.1
 Thickness: 50-2.0 Dia: Flat CW CCW Scan dB: N/A
 Cal. Bk. Temp: 73 Temp. Tool: MCNDE40130 Exam. Surface: O.D.
 Comp. Temp: 78 Temp. Tool: MCNDE40130 Surface Condition: As Ground
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report)
 Results: 0.000 Reject Lab: Comments: N/A
 Percent Of Coverage Obtained: 90% Reviewed Previous Date: Yes

Reference Block
 Cal. Batch: 09325
 Type: ULTRAGEL-R
 Mfg: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL-R
 Mfg: SONOTECH
 Serial No: 04-87412
 Type: ROMPAB

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Indicator Block			
Gain dB	Reflector	Signal Amplitude %	Sweep Division
28.0	1" Radius	80	3.4

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Bull, W. Keith	II-N		4/10/2011			4/22/11
Examiner	Level	Signature	Date	Site Review	Signature	Date
Hassel, Matthew S.	II-N		4/10/2011			
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A					5/16/11

ATTACHMENT A
Page 59 of 162



UT Calibration/Examination

Site/Unit: Ocean 1 Procedure: PDI-UT-3 Class No: 01-38
 Summary No: 01-011-005 Procedure Rev: 5 Report No: UT-13-71
 Worksheet: 191 Work Order No: 81997784

Code: 10087000A Cal Item: C-F-UC1-11 Location: _____
 Drawing No: 1LP-200 Description: Pipe to Flow Restrictor
 System ID: 63A
 Component ID: 1LP-200-187 Street Address: N/A Thickness/Diameter: 821.0/10.0
 Unit/Notes: Yes - See attached sheets Start Time: 1233 Finish Time: 1401

Instrument Settings
 Serial No: 00X141
 Manufacturer: KRAUTKRAMER
 Model: USN-40
 Order: 0438 Range: 3
 UT Cal Val: 325 Pulse: High
 Damper: 1K Reflect: 8%
 Rep. Rate: Audible Freq: 2 MHz
 Filter: Fixed Mode: Dual
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 66.5 Cir. Gain (dB): N/A
 1 - Screen Div: 3 In. of Sound Path
 Linearity Report No: L11-137

Search Unit
 Serial No: 03782
 Manufacturer: RTD
 Size: 12(10x10) Shape: Rect
 Freq: 2.0 MHz Style: TRL1
 Beam Angle: 60° % of Element: Dual
 Motion: Lens
 Measured Angle: 61
 Wedge Style: Integral
 Search Unit Cable
 Type: RO-174
 Length: 6' No. Conns: 0

Cal. Checks	Time	Date
Initial Cal.	1000	4/16/2011
Inter. Cal.		
Inter. Cal.	1341	4/16/2011
Inter. Cal.		
Final Cal.	1636	4/16/2011

Axial Oriented Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1" Notch	80	3.5	1.001

Scan Coverage
 Upstream Downstream Scan dB: 72.5
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: As Ground

Reference Block
 Serial No: 04-0761
 Type: R0MPA5

Circumferential Oriented Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
44.5	1" Radius	80	3.5	1.001

Calibration Block
 Cal. Block No: PDI-UT-3-0
 Thickness: 2.0 Dia: Flat
 Cal. Bk. Temp: 73 Temp. Tool: MCNDE40130
 Comp. Temp: 78 Temp. Tool: MCNDE40130
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent of Coverage Obtained > 90%: No Reviewed Previous Date: Yes


Examiner	Level	Signature	Date	Reviewer	Signature	Date
Hassal, Matthew, S.	UT-1	<i>[Signature]</i>	4/16/2011	<i>[Signature]</i>	<i>[Signature]</i>	4/22/11
Bull, W, Keith	UT-1	<i>[Signature]</i>	4/16/2011	QA	<i>[Signature]</i>	
Other	Level N/A	Signature	Date	ANN Review	Signature	Date
N/A					<i>[Signature]</i>	5/16/11

ATTACHMENT A
 PAGE 60 of 162

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: <u>1LP-200-18</u>		Item No: <u>01CS110005</u>		Remarks:
<input checked="" type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		Dir to valve configuration / <u>FLOW</u> & cast configuration: <u>RESTRICTED</u> <u>27m</u> <u>4-22-11</u>
<input type="checkbox"/> LIMITED SCAN	<input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	<input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L <u>N/A</u> to L <u>N/A</u>	INCHES FROM W0	CL	to <u>Beyond</u>	side:
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input checked="" type="checkbox"/> 80	other	FROM <u>0</u>	DEG to <u>360</u> DEG	
<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____	INCHES FROM W0		to _____	
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60	other	FROM _____	DEG to _____ DEG	
<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____	INCHES FROM W0		to _____	
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60	other	FROM _____	DEG to _____ DEG	
<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____	INCHES FROM W0		to _____	
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60	other	FROM _____	DEG to _____ DEG	
Prepared By: <u>Mattew Hoban</u> Level: <u>II</u> Date: <u>4/18/11</u> Sheet: <u>2</u> of <u>2</u>				UT-115781
Reviewed By: <u>[Signature]</u> Date: <u>4-22-11</u> Authorized Inspector: <u>[Signature]</u> Date: <u>5/10/11</u>				Sketch(s) attached: <input checked="" type="checkbox"/> yes <input type="checkbox"/> No



Supplemental Report

Report No. UT-11-789

Page: 5 of 10

Summary No.: 01-C5-11-0085

Examiner: Bull, W. Keith

Level: I-N

Reviewer: [Signature]

Date: 9-22-11

Examiner: Hassel, Matthew, B.

Level: I-N

Sign/Review: [Signature]

Date: [Signature]

Other: N/A


Level: N/A

Sign/Review: [Signature]

Date: [Signature]

Comments:

Sketch or Photo:



ATTACHMENT A
Page 62 of 162



**Determination of Percent Coverage for
UT Examinations - Pipe**

Station: George / Escoria Procedure: RPD UT 2 Outpost No: 0128
 Summary No: 01CS110015 Procedure Rev: RE Report No: UT-11-7811
 Worksheet: 15 Work Order No: 7018977845 Page: 16 of 16

45 deg

Scan 1	Length X	% volume of length / 100 =	% total for Scan 1
Scan 2	Length X	% volume of length / 100 =	% total for Scan 2
Scan 3	100.000 Length X	50.000 % volume of length / 100 =	50.000 % total for Scan 3
Scan 4	100.000 Length X	50.000 % volume of length / 100 =	50.000 % total for Scan 4
Add totals and divide by 4 scans =		50.000	% total for 45 deg

Other data: 100.000 (to be used for supplemental scans)
 The data to be used below is for coverage that was not obtained with the 45 deg scans

Scan 1	100.000 Length X	50.000 % volume of length / 100 =	50.000 % total for Scan 1
Scan 2	100.000 Length X	50.000 % volume of length / 100 =	50.000 % total for Scan 2
Scan 3	Length X	% volume of length / 100 =	% total for Scan 3
Scan 4	Length X	% volume of length / 100 =	% total for Scan 4

Percent complete coverage

Add totals for each scan recorded and divide by 4 of scans to determine:

37.500 % total for complete scan

Station Supervisor: [Signature] Date: 1/22/11

ATTACHMENT A.
 Page 163 of 162

UT Calibrator Minimation

Site/Unit: Oconee / 1
 Summary No.: 01.C5.21.0008
 Workscope: ISI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01909573

Outage No.: 01-28
 Report No.: UT-11-674
 Page: 1 of 9

Code: 1998/2000A Cal/Item: C-F-1/C5.21 Location: _____
 Drawing No.: 1HP-192 Description: Pipe to Flange Orifice
 System ID: 61A
 Component ID: 1HP-192-15 Size/Length: N/A Thickness/Diameter: 0.531 / 4.0 / 88
 Limitations: Yes - See attached sheet Start Time: 1218 Finish Time: 1233

Instrument Settings
 Serial No.: 00X14L
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 4.1781 Range: 1.0"
 M'd Cal/Vol: .1229 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: RE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 33.9 Circ. Gain (dB): 44.5
1 Screen Div. = .15 In. of Sound Path
 Linearity Report No.: L-11-131

Search Unit
 Serial No.: SB0253
 Manufacturer: GE
 Size: .25 Shape: Round
 Freq.: 2.25 MHz Style: Comp - G
 Exam Angle: 45 # of Elements: Single
 Mode: Shear
 Measured Angle: 45
 Wedge Style: MSWQC
Search Unit Cable
 Type: RG - 174
 Length: 8' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	0920	2/1/2011
Inter. Cal.		
Inter. Cal.	1214	2/1/2011
Inter. Cal.		
Final Cal	1430	2/1/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch	80	4.5	.674

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch	80	4.3	.854

Calibration Block
 Cal. Block No.: 40406
 Thickness .531 Dia.: 4
 Cal. Blk. Temp. 72 Temp. Tool: MCNDE40129
 Comp. Temp. 76 Temp. Tool: MCNDE40129
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info

Scan Coverage
 Upstream Downstream Scan dB: 49.9
 CW CCW Scan dB: 49.9
 Exam Surface: O.D.
 Surface Condition: As Ground

Reference Block
 Serial No.: A09325
 Type: Rompas

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
27.6	1" Radius	80	6.55	1"

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Ransom, Greg J.	II-N	<i>Greg Ransom</i>	2/1/2011	<i>Greg Ransom</i>		2/1/2011
Examiner	Level	Signature	Date	Site Review	Signature	Date
Day, John, C.	II-N	<i>John Day</i>	2/1/2011	N/A		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			<i>Nancy C. Pritchard</i>		4/4/11



UT Calibration / Examination

Site/Unit: Oconee / 1
 Summary No.: 01.C5.21.0008
 Workscope: ISI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01809573

Outage No.: 01-28
 Report No.: UT-11-874
 Page: 2 of 9

Code: 1998/2000A Cat./Item: C-F-1/C5.21 Location: _____
 Drawing No.: 1HP-192 Description: Pipe to Flange Orifice
 System ID: 51A
 Component ID: 1HP-192-15 Size/Length: N/A Thickness/Diameter: 0.531 / 4.0 / SS
 Limitations: Yes - See Attached Sheets Start Time: 1305 Finish Time: 1344

Instrument Settings
 Serial No.: 00X14L Manufacturer: KRAUTKRAMER Model: USN-60
 Delay: 7.4500 Range: 2" M'U Cal/Vel: .1229 Pulsar: High Damping: 1K Reject: 0% Rep. Rate: Autohigh Freq.: 2.25 MHz Filter: Fixed Mode: PE Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 58.4 Circ. Gain (dB): N/A
 1 Screen Div. = .2 in. of Sound Path
 Linearity Report No.: L-11-131

Search Unit
 Serial No.: SB0453 Manufacturer: GE Size: .25 Shape: Round Freq.: 2.25 MHz Style: Comp - G Exam Angle: 60 # of Elements: Single Mode: Shear Measured Angle: 60 Wedge Style: MSWQC
 Search Unit Cable: RG - 174 Type: RG - 174 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	0933	2/1/2011
Inter. Cal.		
Inter. Cal.	1304	2/1/2011
Inter. Cal.		
Final Cal	1437	2/1/2011

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
Notch Tip	80	4	.855

Couplant
 Cal. Batch: 09325 Type: ULTRAGEL II Mfg.: SONOTECH
 Exam Batch: 09325 Type: ULTRAGEL II Mfg.: SONOTECH

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Calibration Block
 Cal. Block No. 40408 Thickness .531 Dia.: 4 Cal. Blk. Temp. 72 Temp. Tool: MCNDE40129 Comp. Temp. 76 Temp. Tool: MCNDE40129

Scan Coverage
 Upstream Downstream Scan dB: 58.4 CW CCW Scan dB: N/A Exam Surface: O.D. Surface Condition: As Ground

Reference Block
 Serial No.: A09325 Type: Rompas

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
44.3	1" Radius	80	5	1"

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Comments: N/A

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Ransom, Greg J.	II-N	<i>Greg Ransom</i>	2/1/2011		<i>Greg Ransom</i>	2/1/2011
Day, John, C.	II-N	<i>John Day</i>	2/1/2011	Site Review	N/A	
Other	Level N/A	Signature	Date	ANII Review	Signature	Date
N/A				<i>Money C Ritches Slaughter</i>		4/4/11

ATTACHMENT A
 PAGE 65 OF 162



UT Calibration Examination

Site/Unit: Oconee / 1
 Summary No.: 01.C5.21.0008
 Workscope: ISI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01009573

Outage No.: 01-26
 Report No.: UT-11-674
 Page: 3 of 9

Code: 1998/2000A Cat./Item: C-F-1/C5.21 Location: _____
 Drawing No.: 1HP-192 Description: Pipe to Flange Orifice
 System ID: 51A
 Component ID: 1HP-192-15 Size/Length: N/A Thickness/Diameter: 0.531 / 4.0 / 88
 Limitations: Yes - See Attached Sheets Start Time: 1236 Finish Time: 1302

Instrument Settings
 Serial No.: 00X14L
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 6.4831 Range: 3
 MVI Cal/Vol: .2302 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2 MHz
 Filter: Fixed Mode: Dual
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 59.6 Cir. Gain (dB): N/A
 1 Screen Div. = .3 In. of Sound Path
 Linearity Report No.: L-11-131

Search Unit
 Serial No.: 10-1208
 Manufacturer: RTD
 Size: 2(7X10)1/4L Shape: Rect.
 Freq.: 2.0 MHz Style: TRL 2
 Exam Angle: 70 # of Elements: Dual
 Mode: Long.
 Measured Angle: 70
 Wedge Style: Integral

Search Unit Cable
 Type: RG - 174
 Length: 8' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1014	2/1/2011
Inter. Cal.		
Inter. Cal.	1234	2/1/2011
Inter. Cal.		
Final Cal	1435	2/1/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
3/4 SDH	80	3.9	1.174

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
46.6	1" Radius	80	3.4	1"

Calibration Block
 Cal. Block No. 40406
 Thickness .531 Dia.: 4
 Cal. Blk. Temp. 72 Temp. Tool: MCNDE40129
 Comp. Temp. 76 Temp. Tool: MCNDE40129
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Scan Coverage
 Upstream Downstream Scan dB: 59.6
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: As Ground

Results: Accept Reject Info Comments: N/A
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Ransom, Greg J.	II-N	<i>Greg Ransom</i>	2/1/2011	<i>Greg Ransom</i>		2/1/2011
Day, John, C.	II-N	<i>John Day</i>	2/1/2011	N/A		
Other	Level	Signature	Date	ANII Reviewer	Signature	Date
N/A	N/A			<i>Nancy C. Ritchie</i>	<i>Nancy C. Ritchie</i>	4/4/11

ATTACHMENT A
 PAGE 68 OF 162

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: 1HP-192-15 Item No: 01.C5.21.0006

remarks:

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L N/A to L N/A INCHES FROM W0 CL to Beyond
 ANGLE: 0 45 60 other _____ FROM 0 DEG to 360 DEG

Pipe to flange orifice

configuration.

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

UT-10-674

Sketch(s) attached

yes No

Prepared By: Gregory Ransom Level: II Date: 02/01/11

Sheet 4 of 9

Reviewed By: [Signature] Date: 2/1/2011

Authorized Inspector: [Signature] Date: 2/4/11



Supplemental Report

Report No.: UT-11-674
Page: 5 of 9

Summary No.: O1.C5.21.0008

Examiner: Ransom, Greg J.
Examiner: Day, John, C.
Other: N/A

Level: II-N
Level: II-N
Level: N/A

Reviewer: [Signature]
Site Review: N/A
ANII Review: [Signature]


Date: 3/1/04
Date: [Blank]
Date: 4/14/04

Comments: (Scale 1 to 1) Weld 1HP-192-15

Sketch or Photo:

PIPE
SURFACE 2

FLANGE
SURFACE 1



NO SCAN:



ATTACHMENT A
PAGE 68 OF 162



Supplemental Report

Report No.: UT-11-674

Page: 6 of 8

Summary No.: O1.C5.21.0006

Examiner: Ransom, Greg J. *Greg Ransom*

Level: II-N

Reviewer: *[Signature]*

Date: *2/1/00*

Examiner: Day, John, C. *JCD*

Level: II-N

Site Review: *N/A*

Date:

Other: *N/A*


Level: *N/A*

ANII Review: *Nancy K. [Signature]*

Date: *4/4/14*

Comments:

Sketch or Photo:





Supplemental Report

Report No.: U1-11-874

Page: 7 of 9

Summary No.: O1.C5.21.0008

Examiner: Ransom, Greg J. *Greg Ransom*

Level: II-N

Reviewer: *[Signature]*

Date: 2/1/11

Examiner: Day, John, C. *John Day*

Level: II-N

Site Review: N/A

Date:

Other: N/A

Level: N/A

ANII Review: *[Signature]*


Date: 4/4/11

Comments: Weld 1 HP-192-15
Indication #1 was determined to be a geometric reflector due to I.D. weld root geometry. This was determined using higher angles and plotting.

PIPE (S2)

FLANGE(S1)

Sketch or Photo:





Determination of Percent Coverage for UT Examinations - Pipe

ATTACHMENT A
PAGE 71 OF 162

Site/Unit: <u>Oconee / 1</u>	Procedure: <u>PD-UT-2</u>	Outage No.: <u>01-28</u>
Summary No.: <u>01.C5.21.0006</u>	Procedure Rev.: <u>E</u>	Report No.: <u>UT-11-874</u>
Workscope: <u>ISI</u>	Work Order No.: <u>01809573</u>	Page: <u>8</u> of <u>9</u>

45 deg

Scan 1	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 1
Scan 2	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 2
Scan 3	<u>100.000</u> % Length X	<u>50.000</u> % volume of length / 100 =	<u>50.000</u> % total for Scan 3
Scan 4	<u>100.000</u> % Length X	<u>50.000</u> % volume of length / 100 =	<u>50.000</u> % total for Scan 4

Add totals and divide by # scans = 50.000 % total for 45 deg

Other deg - 60 (to be used for supplemental scans)

The data to be listed below is for coverage that was not obtained with the 45 deg scans.

Scan 1	<u>100.000</u> % Length X	<u>0.000</u> % volume of length / 100 =	<u>0.000</u> % total for Scan 1
Scan 2	<u>100.000</u> % Length X	<u>50.000</u> % volume of length / 100 =	<u>50.000</u> % total for Scan 2
Scan 3	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 3
Scan 4	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 4

Percent complete coverage

Add totals for each scan required and divide by # of scans to determine;

37.500 % Total for complete exam

Site Field Supervisor: *David R. [Signature]*

Date: 03/02/11




Ultrasonic Indication Report

Site/Unit: Oconee / 1 Procedure: PDI-UT-2 Outage No.: 01-26
 Summary No.: 01.C5.21.0006 Procedure Rev.: E Report No.: UT-11-874
 Workscope: ISI Work Order No.: 01909573 Page: 9 of 9

Search Unit Angle: 60 °
 Wo Location: CL
 Lo Location: 9.1.1.1

- Piping Welds
- Ferritic Vessels $\geq 2''T$
- Other _____

MP	Metal Path	Wmax	Distance From Wo To S.U. At Maximum Response
RBR	Remaining Back Reflection	W1	Distance From Wo At Of Max (Forward)
L	Distance From Datum	W2	Distance From Wo At Of Max (Forward)



Comments: N/A

Angle	Indication No.	% Of DAC	W Max		Forward Of Max		Backward Of Max		L1 Of Max	L Max	L2 Of Max	RBR Amp.	Remarks
			W	MP	W1	MP	W2	MP					
1	1	100	.9	1.092	N/A	N/A	N/A	N/A	N/A	360°	N/A	N/A	Geometry

Examiner	Level	II-N	Signature	Date	Reviewer	Signature	Date
Ransom, Greg J.			<i>Greg Ransom</i>	2/1/2011	<i>Keith H. [Signature]</i>		2/1/2011
Examiner	Level	II-N	Signature	Date	Site Review	Signature	Date
Day, John, C.			<i>John Day</i>	2/1/2011	N/A		
Other	Level	N/A	Signature	Date	ANII Review	Signature	Date
N/A					<i>Nancy C. [Signature]</i>		4/4/11

ATTACHMENT A
 PAGE 72 OF 162



UT Calibration Examination

Site/Unit: Oconee / 1 Procedure: PDI-UT-2 Outage No.: 01-25
 Summary No.: 01.C5.21.0024 Procedure Rev.: E Report No.: UT-11-878
 Workscope: ISI Work Order No.: 01909579 Page: 1 of 6

Code: 1998/2000A Cal./Item: C-F-1/C5.21 Location: _____
 Drawing No.: 1-51A-01(3) Description: Pipe to Valve 1HP-128
 System ID: 51A
 Component ID: 1-51A-01-01A Size/Length: N/A Thickness/Diameter: 0.531 / 4.0 / 88
 Limitations: Yes - See attached sheet Start Time: 1001 Finish Time: 1021

Instrument Settings
 Serial No.: 00X14L
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 4.0688 Range: 2
 M'U Cal/Vel: .1224 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 34.5 Circ. Gain (dB): 45.7
1 Screen Div. = .2 In. of Sound Path
 Linearity Report No.: L-11-131

Search Unit
 Serial No.: 8B0263
 Manufacturer: KBA
 Size: .25 Shape: Round
 Freq.: 2.25 MHz Style: Comp - G
 Exam Angle: 45 # of Elements: Single
 Mode: Shear
 Measured Angle: 45
 Wedge Style: MSWQC

Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	0800	2/9/2011
Inter. Cal.		
Inter. Cal.	1000	2/9/2011
Inter. Cal.		
Final Cal.	1200	2/9/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch	80	3.4	.676

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch	80	4.3	.854

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
27.1	1" Radius	80	5	1"

Calibration Block
 Cal. Block No.: 40406
 Thickness: .531 Dia.: 4
 Cal. Blk. Temp.: 72 Temp. Tool: MCNDE40129
 Comp. Temp.: 78 Temp. Tool: MCNDE40129
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 80%: No Reviewed Previous Data: Yes

Scan Coverage
 Upstream Downstream Scan dB: 40.6
 CW CCW Scan dB: 51.7
 Exam Surface: O.D.
 Surface Condition: As Ground

Reference Block
 Serial No.: 87-5590
 Type: ROMPAS

Comments: N/A

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Day, John, C.	II-N	<i>[Signature]</i>	2/9/2011	<i>[Signature]</i>	<i>[Signature]</i>	4-8-11
Ransom, Greg J.	II-N	<i>[Signature]</i>	2/9/2011	N/A		
Other	Level	Signature	Date	ANI Review	Signature	Date
N/A	N/A			<i>[Signature]</i>	<i>[Signature]</i>	4/19/11



UT Calibration Examination

Site/Unit: Oconee / 1 Procedure: PDI-UT-2 Outage No.: 01-26
 Summary No.: 01.C6.21.0024 Procedure Rev.: E Report No.: UT-11-678
 Workscope: ISI Work Order No.: 01909579 Page: 2 of 8

Code: 1998/2000A Cat./Item: C-F-1/C6.21 Location: _____
 Drawing No.: 1-51A-01(3) Description: Pipe to Valve 1HP-128
 System ID: 51A
 Component ID: 1-51A-01-81A Size/Length: N/A Thickness/Diameter: 0.531 / 4.0 / 8S
 Limitations: Yes - See Attached Sheets Start Time: 1023 Finish Time: 1043

Instrument Settings
 Serial No.: 00X14L Manufacturer: KRAUTKRAMER Model: USN-60
 Delay: 5.4262 Range: 2 M'd Cal/Vel: .1229 Pulsar: High Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz Filter: Fixed Mode: PE Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 47.8 Crc. Gain (dB): N/A
 1 Screen Div. = .2 in. of Sound Path
 Linearly Report No.: L-11-131

Search Unit
 Serial No.: SB0453 Manufacturer: GE Size: .25 Shape: Round
 Freq.: 2.25 MHz Style: Comp - G Exam Angle: 60 # of Elements: Single
 Mode: Shear Measured Angle: 60 Wedge Style: MSWQC
 Search Unit Cable Type: RG - 174 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	0805	2/9/2011
Inter. Cal.		
Inter. Cal.	1022	2/9/2011
Inter. Cal.		
Final Cal	1205	2/9/2011

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
3/4 BDH	80	3.7	.735

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Calibration Block
 Cal. Block No.: 40408 Thickness: .531 Dia.: 4
 Cat. Blk. Temp. 72 Temp. Tool: MCNDE40129 Comp. Temp. 78 Temp. Tool: MCNDE40129
 Upstream Downstream Scan dB: 47.8
 CW CCW Scan dB: N/A
 Exam Surface: O.D. Surface Condition: As Ground
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info Comments: N/A
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Reference Block
 Serial No.: 97-5590
 Type: ROMPAS

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
29.3	1" Radius	80	5	1"

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Day, John, C.	II-N	<i>[Signature]</i>	2/9/2011	<i>[Signature]</i>		4-8-11
Ransom, Greg J.	II-N	<i>[Signature]</i>	2/9/2011	N/A		
Other	N/A			ANK Review	<i>[Signature]</i>	4/19/11

ATTACHMENT A
 PAGE 74 OF 162

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: <u>1-51A-01-91A</u> Item No: <u>01C5.21.0024</u>		remarks:
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE: <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 BEAM DIRECTION: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw	Due to component configuration.
FROM L <u>N/A</u> to L <u>N/A</u> INCHES FROM W0 <u>CL</u> to <u>Beyond</u>	ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM <u>0</u> DEG to <u>360</u> DEG	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE: <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____ INCHES FROM W0 _____ to _____	ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE: <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____ INCHES FROM W0 _____ to _____	ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE: <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	UT-11-876
FROM L _____ to L _____ INCHES FROM W0 _____ to _____	ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG	Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> No
Prepared By: <u>John Day</u> Level: <u>II</u> Date: <u>02/09/11</u>	Sheet <u>3</u> of <u>6</u>	
Reviewed By: <u>[Signature]</u> Date: <u>4-8-11</u>	Authorized Inspector: <u>[Signature]</u> Date: <u>4/19/11</u>	



Supplemental Report

Report No.: UT-11-678

Page: 4 of 8

Summary No.: O1.C5.21.0024

Examiner: Day, John, C. *J. D. Day*

Level: II-N

Reviewer: *ME Amos*

Date: 4-8-11

Examiner: Ransom, Greg J. *Greg Ransom*

Level: II-N

Site Review: N/A

Date: _____

Other: N/A

Level: N/A

ANII Review: *Dorey Claitor Slaughter*


Date: 4/19/11

Comments: Scale 1 to 1: Component ID - 1-S1A-01-91A

Sketch or Photo:

PIPE S1

S2 VALVE



ATTACHMENT A

PAGE 76 OF

162



Supplemental Report

Report No.: UT-11-876

Page: 5 of 6

Summary No.: D1.CS.21.0024

Examiner: Day, John, C. *JH Day*

Level: II-N

Reviewer: *AE Homan*

Date: 4.8.11

Examiner: Ransom, Greg J. *Greg Ransom*

Level: II-N

Site Review: N/A

Date:

Other: N/A

Level: N/A

ANII Review: *Nancy C. Ritchie-Slaughter*


Date: 7/19/11

Comments: Scale 1 to 1: Component ID - 1-81A-01-01A

Sketch or Photo:

BPE S1

S2 VALVE



ATTACHMENT A
PAGE 77 OF 162



Determination of Percent Coverage for UT Examinations - Pipe

ATTACHMENT A
PAGE 7B OF 162

Site/Unit: <u>Oconee / 1</u>	Procedure: <u>PDI-UT-2</u>	Outage No.: <u>01-26</u>
Summary No.: <u>01.C5.21.0024</u>	Procedure Rev.: <u>E</u>	Report No.: <u>UT-11-678</u>
Workscope: <u>ISI</u>	Work Order No.: <u>01909579</u>	Page: <u>6</u> of <u>8</u>

45 deg

Scan 1	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 1
Scan 2	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 2
Scan 3	<u>100.000</u> % Length X <u>50.000</u>	% volume of length / 100 = <u>50.000</u>	% total for Scan 3
Scan 4	<u>100.000</u> % Length X <u>50.000</u>	% volume of length / 100 = <u>50.000</u>	% total for Scan 4

Add totals and divide by # scans = 50.000 % total for 45 deg

Other deg - 60 (to be used for supplemental scans)

The data to be listed below is for coverage that was not obtained with the 45 deg scans.

Scan 1	<u>100.000</u> % Length X <u>100.000</u>	% volume of length / 100 = <u>100.000</u>	% total for Scan 1
Scan 2	<u>100.000</u> % Length X <u>100.000</u>	% volume of length / 100 = <u>100.000</u>	% total for Scan 2
Scan 3	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 3
Scan 4	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 4

Percent complete coverage

Add totals for each scan required and divide by # of scans to determine;

75.000 % Total for complete exam

Site Field Supervisor: Rod Sheffield

Date: 4-7-2011

UT Calibration Examination

Site/Unit: Oconee / 1
 Summary No.: O1.C5.21.0041
 Workscope: IBI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01909630

Outage No.: O1-28
 Report No.: UT-11-707
 Page: 1 of 6

Code: 1998/2000A Cat./Item: C-F-1/05.21 Location: _____
 Drawing No.: 1HP-324 Description: Tee to Valve 1HP-119
 System ID: 51A
 Component ID: 1HP-324-118B Size/Length: N/A Thickness/Diameter: 88/0.375/2.5
 Limitations: Yes- See attached sheets Start Time: 1340 Finish Time: 1405

Instrument Settings
 Serial No.: 00WHDK
 Manufacturer: KRAUTKRAMER
 Model: USN-80
 Delay: 3.7058 Range: 1.0"
 MU Cal/Vol: .1228 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 5 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 36.7 Circ. Gain (dB): 47.4
 Screen Div. = .1 In. of Sound Path

Search Unit
 Serial No.: 00DBVW
 Manufacturer: KBA
 Size: 0.25 Shape: Round
 Freq.: 8 MHz Style: Comp - G
 Exam Angle: 45 # of Elements: Single
 Mode: SHEAR
 Measured Angle: 45
 Wedge Style: MSWQC

Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	0920	3/30/2011
Inter. Cal.		
Inter. Cal.	1345	3/30/2011
Inter. Cal.		
Final Cal	1625	3/30/2011

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch	80	5.1	.603

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch	80	6.0	.586

Calibration Block
 Cal. Block No.: 40378
 Thickness: 0.375 Dia.: 2.5
 Cal. Blk. Temp.: 74 Temp. Tool: MCNDE40128
 Comp. Temp.: 84 Temp. Tool: MCNDE40128
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 80%: No. Reviewed Previous Data: Yes

Scan Coverage
 Upstream Downstream Scan dB: 45.7
 CW CCW Scan dB: 47.4
 Exam Surface: O.D.
 Surface Condition: As Ground

Reference Block
 Serial No.: 04-8737
 Type: ROMPAS

Reference/Stimulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
36.7	BDH	20	9.9	.980

Comments: PRF = 2550 Hz

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Foss, Steven	II-N	<i>Steven J. Foss</i>	3/30/2011	<i>[Signature]</i>	4-21-11	
Tucker, Stephen B.	III	<i>[Signature]</i>	3/30/2011	N/A		
Other	Level	Signature	Date	AMII Review	Signature	Date
N/A	N/A					

4/22/11 ATTACHMENT A
 PAGE 79 OF 162

UT Calibration Certification

Site/Unit: Oconee / 1
 Summary No.: 01.C5.21.0041
 Workscope: ISI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01909830

Outage No.: 01-26
 Report No.: UT-11-707
 Page: 2 of 6

Code: 1998/2000A Cat./Item: C-F-1/C5.21 Location: _____
 Drawing No.: 1HP-324 Description: Tee to Valve 1HP-119
 System ID: 51A
 Component ID: 1HP-324-118B Size/Length: N/A Thickness/Diameter: 85/0.375/2.5
 Limitations: Yes Start Time: 1348 Finish Time: 1405

Instrument Settings
 Serial No.: 00WHDK
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 4.898 Range: 1.5
 M'd Cal/Vol: .1250 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 5 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 48.5 Circ. Gain (dB): N/A
 Screen Div. = .15 In. of Sound Path
 Linearity Report No.: L-11-136

Search Unit
 Serial No.: 01JPCD
 Manufacturer: KBA
 Size: .25" Shape: Round
 Freq.: 5 MHz Style: Comp-G
 Exam Angle: 60 # of Elements: Single
 Mode: Shear
 Measured Angle: 60
 Wedge Style: MSWQC
Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1000	3/30/2011
Inter. Cal.		
Inter. Cal.	1409	3/30/2011
Inter. Cal.		
Final Cal	1622	3/30/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Scan Coverage
 Upstream Downstream Scan dB: 54.5
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: As Ground

Reference Block
 Serial No.: 04-8737
 Type: ROMPAS

Axial Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path	
ID Notch	80	4.1	.600	
Circumferential Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path	
N/A				
Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
48.5	SDH	85	4.1	.597

Calibration Block
 Cal. Block No. 40378
 Thickness 0.375 Dia.: 2.5
 Cal. Blk. Temp. 74 Temp. Tool: MCNDE40128
 Comp. Temp. 84 Temp. Tool: MCNDE40128
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Comments: PRF = 2532 Hz

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Foss, Steven	II-N	<i>[Signature]</i>	3/30/2011	<i>[Signature]</i>		4-21-11
Tucker, Stephen B.	III	<i>[Signature]</i>	3/30/2011	Site Review		
Other	N/A			ANII Review	<i>[Signature]</i>	4/7/11



UT Calibration Examination

Site/Unit: Oconee / 1
 Summary No.: 01.C5.21.0041
 Workscope: ISI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01909630

Outage No.: 01-26
 Report No.: UT-11-707
 Page: 3 of 6

Code: 1988/2000A Cal/Item: C-F-1/C5.21 Location: _____
 Drawing No.: 1HP-324 Description: Tee to Valve 1HP-119
 System ID: 51A
 Component ID: 1HP-324-118B Size/Length: N/A Thickness/Diameter: SS/0.375/2.5
 Limitations: Yes - See attached sheets Start Time: 1428 Finish Time: 1440

Instrument Settings
 Serial No.: 00WHDK
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 6.6459 Range: 2.0
 M'd Cal/Vel: 1226 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 57.9 Circ. Gain (dB): N/A
1 Screen Div. = .2 in. of Sound Path
 Linearity Report No.: L-11-136

Search Unit
 Serial No.: SB0253
 Manufacturer: KBA
 Size: .25 Shape: Round
 Freq.: 2.25 MHz Style: Comp - G
 Exam Angle: 70 # of Elements: Single
 Mode: Shear
 Measured Angle: 68
 Wedge Style: MSWQC
 Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1150	3/30/2011
Inter. Cal.		
Inter. Cal.	1427	3/30/2011
Inter. Cal.		
Final Cal	1819	3/30/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: 04-8737
 Type: ROMPAS

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch	80	3.9	.771

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
52.7	SDH	80	3.7	.721

Calibration Block
 Cal. Block No. 40378
 Thickness 0.375 Dia.: 2.5
 Cal. Blk. Temp. 74 Temp. Tool: MCNDE40128
 Comp. Temp. 84 Temp. Tool: MCNDE40128
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info

Scan Coverage
 Upstream Downstream Scan dB: 57.9
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: As Ground

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Foss, Steven	II-N	<i>Steven J. Foss</i>	3/30/2011	<i>[Signature]</i>		4.21.11
Tucker, Stephen B.	III	<i>[Signature]</i>	3/30/2011	Site Review	<i>[Signature]</i>	
Other	N/A	<i>[Signature]</i>		ANII Review	<i>[Signature]</i>	4/22/11

81 of 162

DUKE POWER COMPANY

ISI LIMITATION REPORT



Component/Weld ID: <u>1HP-324-118B</u>		Item No: <u>01.C5.21.0041</u>		remarks:
<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		Limited due to welded
<input checked="" type="checkbox"/> LIMITED SCAN	<input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	<input type="checkbox"/> cw <input type="checkbox"/> ccw	attachments.
FROM L <u>1.75"</u> to L <u>2.75"</u>	INCHES FROM W0 <u>CL</u> to <u>Beyond</u>			
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60	other <u>70</u>	FROM <u>N/A</u> DEG to <u>N/A</u> DEG		
<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		Limited due to welded
<input checked="" type="checkbox"/> LIMITED SCAN	<input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	<input type="checkbox"/> cw <input type="checkbox"/> ccw	attachments.
FROM L <u>6.25</u> to L <u>7.25</u>	INCHES FROM W0 <u>CL</u> to <u>Beyond</u>			
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60	other <u>70</u>	FROM <u>N/A</u> DEG to <u>N/A</u> DEG		
<input checked="" type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		No scan due to valve
<input type="checkbox"/> LIMITED SCAN	<input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw	configuration.
FROM L <u>N/A</u> to L <u>N/A</u>	INCHES FROM W0 <u>CL</u> to <u>Beyond</u>			
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60	other <u>70</u>	FROM <u>0</u> DEG to <u>360</u> DEG		
<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		UT-11-707
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> cw <input type="checkbox"/> ccw	Sketch(s) attached
FROM L _____ to L _____	INCHES FROM W0 _____ to _____			<input checked="" type="checkbox"/> yes <input type="checkbox"/> No
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60	other _____	FROM _____ DEG to _____ DEG		
Prepared By: <u>Steve Foss</u>	Level: <u>II</u>	Date: <u>03/30/11</u>	Sheet <u>4</u>	of <u>8</u>
Reviewed By: <u>DE Houser</u>	Date: <u>4-21-11</u>	Authorized Inspector: <u>[Signature]</u>	Date: <u>4/22/11</u>	

ATTACHMENT A
PAGE 82 OF 162

Summary No. 01.CS.21.0041

Weld No. 1-HP-324-118B

ATTACHMENT A
PAGE 83 OF 162




0% coverage claimed from surface 1 for (2) 1" areas due to welded attachments.

Surface 1
 9.0275" circumference
 -2.0" of missed coverage
 = 7.0275" of coverage
 $7.0275 / 9.0275 \times 100 = 77.85\%$

Surface 2:
 100% coverage for 77.85% of length
 50% coverage for 22.15% of length
 = 88.925% coverage

Scan 1 = 77.85%
 Scan 2 = 88.925%
 Scan 3 = 50%
 Scan 4 = 50%

Total = 66.69%



50% coverage claimed for CW and CCW scanning with 45° for scans 3 and 4.

Determination of Percent Coverage for UT Examinations - Vessels

ATTACHMENT A
PAGE 84 OF 162

Site/Unit: <u>Oconee / 1</u>	Procedure: <u>PDI-UT-2</u>	Outage No.: <u>01-28</u>
Summary No.: <u>01.C5.21.0041</u>	Procedure Rev.: <u>E</u>	Report No.: <u>UT-11-707</u>
Workscope: <u>ISI</u>	Work Order No.: <u>01909630</u>	Page: <u>6</u> of <u>6</u>

0 deg Planar

Scan _____ % Length X _____ % volume of length / 100 = _____ % total for 0 deg

45 deg

Scan 1	<u>77.850</u>	% Length X	<u>100.000</u>	% volume of length / 100 =	<u>77.850</u>	% total for Scan 1
Scan 2	<u>88.925</u>	% Length X	<u>100.000</u>	% volume of length / 100 =	<u>88.925</u>	% total for Scan 2
Scan 3	<u>100.000</u>	% Length X	<u>50.000</u>	% volume of length / 100 =	<u>50.000</u>	% total for Scan 3
Scan 4	<u>100.000</u>	% Length X	<u>50.000</u>	% volume of length / 100 =	<u>50.000</u>	% total for Scan 4

Add totals and divide by # scans = 66.694 % total for 45 deg

Other deg

Scan 1	_____	% Length X	_____	% volume of length / 100 =	_____	% total for Scan 1
Scan 2	_____	% Length X	_____	% volume of length / 100 =	_____	% total for Scan 2
Scan 3	_____	% Length X	_____	% volume of length / 100 =	_____	% total for Scan 3
Scan 4	_____	% Length X	_____	% volume of length / 100 =	_____	% total for Scan 4

Add totals and divide by # scans = _____ % total for _____ deg

Percent complete coverage

Add totals for each angle and scan required and divide by # of angles to determine;

66.694 % Total for complete exam

Note:

Supplemental coverage may be achieved by use of other angles / methods. When used, the coverage for volume not obtained with angles as noted above shall be calculated and added to the total to provide the percent total for the complete examination.

Site Field Supervisor: _____

David K. [Signature]

Date: 4/12/11

UT Calibration Examination

Site/Unit: Oconee / 1
 Summary No.: O1.C5.21.0053
 Workscope: ISI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01903807

Outage No.: 01-28
 Report No.: UT-11-785
 Page: 1 of 7

Code: 1998/2000A Cat./Item: C-F-1/C5.21 Location: _____
 Drawing No.: 1-61A-02 Description: Elbow to Valve 1HP-134
 System ID: 61A
 Component ID: 1-61A-02-34B Size/Length: N/A Thickness/Diameter: 88/531/4.0
 Limitations: Valve configuration Start Time: 1350 Finish Time: 1403

Instrument Settings
 Serial No.: 014BLC
 Manufacturer: KRAUTKRAMER
 Model: USN-60 SW
 Delay: 7.0016 Range: 1.50
 M/TI Cal/Vol: .1230 Pulsar: Square
 Damping: 500 Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 31.0 Circ. Gain (dB): 36.2
 Screen Div. = .15 in. of Sound Path

Search Unit
 Serial No.: 00DNL3
 Manufacturer: KBA
 Size: 0.25 Shape: Round
 Freq.: 2.25 MHz Style: Comp-G
 Exam Angle: 45 # of Elements: Single
 Mode: SHEAR
 Measured Angle: 44
 Wedge Style: MSWQC
 Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1033	4/17/2011
Inter. Cal.		
Inter. Cal.	1349	4/17/2011
Inter. Cal.		
Final Cal	1835	4/17/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: A09322
 Type: ROMPAS

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch	80	4.9	.729

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch	80	3.5	.513

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
30.0	SDH	20	7.0	1.048

Linearity Report No.: L-11-140
Calibration Block
 Cal. Block No.: 50275
 Thickness: 0.831 Dia.: 4.5
 Cal. Blk. Temp.: 74 Temp. Tool: MCNDE40128
 Comp. Temp.: -68 Temp. Tool: MCNDE40128
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Scan Coverage
 Upstream Downstream Scan dB: 43
 CW CCW Scan dB: 49
 Exam Surface: O.D.
 Surface Condition: As Ground

Comments: Pulse Width = 220 NS

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Lester, Robert M.	II-N	<i>Robert M. Lester</i>	4/17/2011	Maya Alon	<i>Maya Alon</i>	4-22-11
Poss, Steven	II-N	<i>Steven Poss</i>	4/17/2011	N/A		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			Nancy C. Richter	<i>Nancy C. Richter</i>	4/26/11

UT Calibrator Examination

Site/Unit: Oconee
 Summary No.: O1.C6.21.0053
 Workscope: ISI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01903607

Outage No.: 01-26
 Report No.: UT-11-785
 Page: 2 of 7

Code: 1998/2000A Cal./Item: C-F-1/C6.21 Location: _____
 Drawing No.: 1-51A-02 Description: Elbow to Valve 1HP-134
 System ID: 51A
 Component ID: 1-51A-02-34B Size/Length: N/A Thickness/Diameter: SSJ.531/4.0
 Limitations: Valve configuration Start Time: 1405 Finish Time: 1417

Instrument Settings
 Serial No.: 014BLC
 Manufacturer: KRAUTKRAMER
 Model: USN-60 SW
 Delay: 5.4803 Range: 2.00
 MTI Cal/Vel: .1230 Pulsar: Square
 Damping: 500 Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 35.7 Circ. Gain (dB): N/A
 1 Screen Div. = .2 In. of Sound Path

Search Unit
 Serial No.: 000CC8
 Manufacturer: KBA
 Size: 0.25 Shape: Round
 Freq.: 2.25 MHz Style: Comp - G
 Exam Angle: 60 # of Elements: Single
 Mode: SHEAR
 Measured Angle: 60
 Wedge Style: MSWQC

Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	1153	4/17/2011
Inter. Cal.		
Inter. Cal.	1404	4/17/2011
Inter. Cal.		
Final Cal	1640	4/17/2011

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
3/4" SDH	60	3.7	.728

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Calibration Block
 Cal. Block No.: 80275
 Thickness: 0.531 Dia.: 4.5
 Cal. Blk. Temp.: 74 Temp. Tool: MCNDE40128
 Comp. Temp.: 68 Temp. Tool: MCNDE40128

Scan Coverage
 Upstream Downstream Scan dB: 41.7
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: As Ground

Reference Block
 Serial No.: A09322
 Type: ROMPAS

Reference/ Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
39.1	FSDH	45	7.4	1.474

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Comments: Pulse Width = 220 NS

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Lester, Robert M.	II-N	<i>Robert M. Lester</i>	4/17/2011	Mary A. Moss		4-22-11
Foss, Steven	II-N	<i>Steven Foss</i>	4/17/2011	JIA		
Other	Level	Signature	Date	ANJ Review	Signature	Date
N/A	N/A			<i>Nancy C. Ritchie-Sloight</i>		4/26/11

UT Calibration Examination

Site/Unit: Oconee / 1 Procedure: PDI-UT-2 Outage No.: 04-28
 Summary No.: 01.C5.21.0053 Procedure Rev.: E Report No.: UT-11-785
 Workscope: IBI Work Order No.: 01903607 Page: 3 of 7

Code: 1998/2000A Cal./Item: C-F-1/C5.21 Location: _____
 Drawing No.: 1-51A-02 Description: Elbow to Valve 1HP-134
 System ID: 51A
 Component ID: 1-51A-02-34B Size/Length: N/A Thickness/Diameter: SSI.531/4.0
 Limitations: Valve configuration Start Time: 1419 Finish Time: 1430

Instrument Settings
 Serial No.: 014BLC Manufacturer: KRAUTKRAMER Model: USN-80 SW
 Delay: 6.7625 Range: 2.00 M/H Cal/Vol: .2273 Pulsar: Square
 Damping: 500 Reject: 0% Rep. Rate: Autohigh Freq.: 2 MHz
 Filter: Fixed Mode: Dual Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 43.0 Circ. Gain (dB): N/A
 1- Screen Div.: .2 In. of Sound Path: _____ Type: _____
 Linearity Report No.: L-11-140

Search Unit
 Serial No.: 10-1205 Manufacturer: RTD Size: 2(7X10) Shape: Rect.
 Freq.: 2.0 MHz Style: TRL 2 Exam Angle: 80 # of Elements: Dual
 Mode: Long. Measured Angle: 80 Wedge Style: Integral
Search Unit Cable
 Type: RG - 174 Length: 8' No. Conn.: 0
Scan Coverage
 Upstream Downstream Scan dB: 46.0
 CW CCW Scan dB: N/A
 Exam Surface: O.D. Surface Condition: As Ground
 Recordable Indication(s): Yes No (If Yes; Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info

Cal. Checks	Time	Date
Initial Cal	1210	4/17/2011
Inter. Cal.		
Inter. Cal.	1418	4/17/2011
Inter. Cal.		
Final Cal	1645	4/17/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: A09322
 Type: ROMPAS

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
3/4" SDH	80	3.0	.768

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
30.0	1" Radius	83	8.0	1.007

Comments: Width = 250 NB

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Lester, Robert M.	II-N	<i>Robert M. Lester</i>	4/17/2011	<i>Ray M. Moss</i>		4-22-11
Foss, Steven	II-N	<i>Steven Foss</i>	4/17/2011	N/A		
Other	N/A			<i>Nancy C. Ritchie-Slaughter</i>		4/20/11

ATTACHMENT A
PAGE 67 OF 162

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: <u>1-51A-02-34B</u> Item No: <u>01.C5.21.0053</u>		remarks:
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input checked="" type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw		Upstream scan limited due to
FROM L <u>0.0"</u> to L <u>14.13</u> INCHES FROM W0 <u>CL</u> to <u>.85"</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM <u>N/A</u> DEG to <u>N/A</u> DEG		valve configuration
<input checked="" type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		Upstream scan limited due to
FROM L <u>0.0"</u> to L <u>14.13"</u> INCHES FROM W0 <u>1.15"</u> to <u>Beyond</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 ^{Re 4-22-11} other _____ FROM <u>N/A</u> DEG to <u>N/A</u> DEG		valve configuration
<input checked="" type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw		Upstream scan limited due to
FROM L <u>0.0"</u> to L <u>14.13"</u> INCHES FROM W0 <u>CL</u> to <u>Beyond</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other _____ FROM <u>N/A</u> DEG to <u>N/A</u> DEG		valve configuration
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		UT-11-785
FROM L _____ to L _____ INCHES FROM W0 _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 5 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> No
Prepared By: <u>Robert Lester</u>	Level: <u>II</u>	Date: <u>04/17/11</u>
Reviewed By: <u>Gary Moss</u>	Date: <u>4-22-11</u>	Authorized Inspector: <u>Nancy R. Stoughton</u> Date: <u>4/26/11</u>

*attachment A
page 88 of 162*

Supplemental Report

Report No.: UT-11-785

Page: 5 of 7

Summary No.: O1.C5.21.0053

Examiner: Lester, Robert M. *Robert M Lester*
Examiner: Foss, Steven *Steven Foss*
Other: N/A

Level: II-N
Level: II-N
Level: N/A

Reviewer: *Sam Moore*
Site Review: *N/A*
ANII Review: *Nancy C. Ritchie*


Date: 4-22-11
Date: 4/27/11

Comments: See pages 4 & 7 for limitations and coverage calculations.

Sketch or Photo:

O1.C5.21.0053
1-51A-02-34B

MAXIMUM SCAN AREA ON VALVE SIDE



attachment A
Page 89 of 162

Supplemental Report

Report No.: UT-...-785

Page: 6 of 7

Summary No.: O1.C5.21.0053

Examiner: Lester, Robert M. *Robert M. Lester*

Level: II-N

Reviewer: *Gary Moss*

Date: 4-22-11

Examiner: Foss, Steven *Steven Foss*

Level: II-N

Site Review: N/A

Date:

Other: N/A

Level: N/A


ANII Review: *Nancy Kitcher Straighter*

Date: 4/27/11


Comments:

Sketch or Photo:


1-51A-02-348



Axial Scans



Circ Scans



Scale: 1" = 1"

% Coverage Calculations

S1 = Elbow	=	100%	(100% of the length x 100% of the volume)
S2 = Valve	=	46.1%	(100% of the length x 46.1% of the volume)
S3 = CW	=	50%	(100% of the length x 50% of the volume)
S4 = CCW	=	50%	(100% of the length x 50% of the volume)
Total	=	246.1 / 4	= <u>61.525 %</u> Aggregate Coverage

UT Calibrator Examination

Site/Unit: Oconee / 1 Procedure: PDI-UT-2 Outage No.: 01-28
 Summary No.: 01.C5.21.0057 Procedure Rev.: E Report No.: UT-11-877
 Workscope: ISI Work Order No.: 01909633 Page: 1 of 7

Code: 1998/2000A Cal/Item: C-F-1/C5.21 Location: _____
 Drawing No.: 1HP-193 Description: Tee to Valve 1HP-28
 System ID: 51A
 Component ID: 1HP-193-12 Size/Length: N/A Thickness/Diameter: SS/531/4.0
 Limitations: Yes - See attached sheets Start Time: 1335 Finish Time: 1345

Instrument Settings
 Serial No.: 014BLC
 Manufacturer: KRAUTKRAMER
 Model: USN-60 SW
 Delay: 4.7000 Range: 1.800
 MUI Cal/Vol: .1230 Pulsar: Square
 Damping: 500 Reject: 0
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filler: Fixed Mode: PE
 Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 27.1 Circ. Gain (dB): 27.1
 Screen Div. = .15 In. of Sound Path
 Linearity Report No.: L-11-140

Search Unit
 Serial No.: 00DD72
 Manufacturer: KBA
 Size: 0.25 Shape: Round
 Freq.: 2.25 MHz Style: Comp - G
 Exam Angle: 45 # of Elements: Single
 Mode: SHEAR
 Measured Angle: 45
 Wedge Style: MSWQC
 Search Unit Cable
 Type: RG-174
 Length: 8' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	0900	3/30/2011
Inter. Cal.		
Inter. Cal.	1330	3/30/2011
Inter. Cal.		
Final Cal	1530	3/30/2011

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ID Notch	80	5.0	.744

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
See Axial			

Calibration Block
 Cat. Block No.: 50275
 Thickness: .528 Dia.: 4.0"
 Cal. Blk. Temp: 73 Temp. Tool: MCNDE40135
 Comp. Temp: 87 Temp. Tool: MCNDE40135
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Scan Coverage
 Upstream Downstream Scan dB: 33.1
 CW CCW Scan dB: 33.1
 Exam Surface: O.D.
 Surface Condition: As Ground

Reference Block
 Serial No.: 04-8741
 Type: ROMPAS

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
26.2	1" Radius	80	6.7	.707

Results: Accept Reject Info Comments: NIA
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Bull, W. Keith	II-N		3/30/2011			4-9-11
Hassel, Matthew, S.	II-N		3/30/2011	Site Review	NIA	
Other	Level	Signature	Date	ANII Review	Signature	Date
NIA	NIA					4/21/11

ATTACHMENT A
 PAGE 92 OF 162

UT Calibration / Inspection

Site/Unit: Oconee / 1 Procedure: PDI-UT-2 Outage No.: 07-28
 Summary No.: 01.C5.21.0057 Procedure Rev.: E Report No.: UT-11-877
 Workscope: ISI Work Order No.: 01908633 Page: 2 of 7

Code: 1988/2000A Cal./Item: C-F-1/C5.21 Location: _____
 Drawing No.: 1HP-193 Description: Tee to Valve 1HP-26
 System ID: 51A
 Component ID: 1HP-193-12 Size/Length: N/A Thickness/Diameter: SS/531/ 4.0
 Limitations: Yes - See Attached Sheets Start Time: 0624 Finish Time: 1057

Instrument Settings

Serial No.: 014BLC Manufacturer: KRAUTKRAMER
 Model: USN-60 SW
 Delay: 4.6378 Range: 1.5
 Mt'd Cal/Val: .123 Pulsar: Square
 Damping: 500 Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 41.3 Cir. Gain (dB): N/A
 1 Screen Div. = .15 In. of Sound Path
 Linearly Report No.: L-11-140

Search Unit

Serial No.: 01F3J5 Manufacturer: KBA
 Size: .25 Shape: Round
 Freq.: 2.25 MHz Style: Comp - G
 Exam Angle: 60 # of Elements: Single
 Mode: Shear
 Measured Angle: 60
 Wedge Style: MSWQC

Cal. Checks	Time	Date
Initial Cal	0824	4/9/2011
Inter. Cal.		
Inter. Cal.	1001	4/9/2011
Inter. Cal.		
Final Cal	1167	4/9/2011

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
3/4 Hole	80	6.4	.605

Couplant

Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Calibration Block

Cal. Block No. 50275 Thickness .528 Dia.: 4.0"
 Cal. Bk Temp: 73 Temp. Tool: MCNDE40135
 Comp. Temp: -87 Temp. Tool: MCNDE40135
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Scan Coverage

Upstream Downstream Scan dB: 47.3
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: As Ground

Reference Block

Serial No.: 04-3741
 Type: ROMPAS

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
41.3	NSH	45	4.5	.668

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Bull, W. Keith	II-N	<i>[Signature]</i>	4/9/2011	<i>[Signature]</i>		4-9-11
Multhead, Barry A.	II-N	<i>[Signature]</i>	4/9/2011	Site Review		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			<i>[Signature]</i>		4/21/11

ATTACHMENT A
 PAGE 93 OF 162

UT Calibrator Examination

Site/Unit: Oconee / 1
 Summary No.: 01.C5.21.0057
 Workscope: ISI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01999633

Outage No.: 01-28
 Report No.: UT-11-877
 Page: 3 of 7

Code: 1998/2000A Cat./Item: C-F-1/C5.21 Location: _____
 Drawing No.: 1HP-193 Description: Toe to Valve 1HP-26
 System ID: 51A
 Component ID: 1HP-193-12 Size/Length: N/A Thickness/Diameter: 88/531/4.0
 Limitations: Yes - See attached sheets Start Time: 0812 Finish Time: 1059

Instrument Settings
 Serial No.: 014BLC
 Manufacturer: KRAUTKRAMER
 Model: USN-80 SW
 Delay: 9.6559 Range: 3"
 MUI Cal/Vol: .230 Pulsar: Square
 Damping: 500 Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.0 MHz
 Filter: Fixed Mode: Dual
 Voltage: 450 Other: Fullwave
 Ax. Gain (dB): 40.6 Circ. Gain (dB): N/A

Search Unit
 Serial No.: 11-87
 Manufacturer: RTD
 Size: 2(8x14)1/4 Shape: Rect.
 Freq.: 2.0 MHz Style: TRL 2
 Exam Angle: 70 # of Elements: Dual
 Mode: Long.
 Measured Angle: 69
 Wedge Style: Integral

Cal. Checks	Time	Date
Initial Cal	0812	4/8/2011
Inter. Cal.		
Inter. Cal.	0944	4/8/2011
Inter. Cal.		
Final Cal	1059	4/8/2011

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
3/4 Hole	80	3.8	1.149

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

1 Screen Div. = .3 in. of Sound Path
 Linearity Report No.: L-11-140
 Calibration Block
 Cal. Block No.: 50275
 Thickness: .528 Dia.: 4.0"
 Cal. Blk. Temp.: 73 Temp. Tool: MCNDE40135
 Comp. Temp.: 87 Temp. Tool: MCNDE40135

Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0
 Scan Coverage
 Upstream Downstream Scan dB: 46.8
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: As Ground

Reference Block
 Serial No.: 8279-0409
 Type: IIV AH

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
30.1	2"	82	6.6	1.977

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 80%: No Reviewed Previous Data: Yes

Comments: N/A

Examiner	Level	U-N	Signature	Date	Reviewed	Signature	Date
Bull, W. Keith			<i>[Signature]</i>	4/8/2011	<i>[Signature]</i>		4-20-11
Examiner	Level	U-N	Signature	Date	Site Review	Signature	Date
Mulrhead, Barry A.			<i>[Signature]</i>	4/8/2011	N/A		
Other	Level	N/A	Signature	Date	ANII Review	Signature	Date
N/A					<i>[Signature]</i>		4/21/11

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: <u>1HP-193-12</u>		Item No: <u>O1.C5.21.0057</u>		remarks:
<input checked="" type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		Due to cast stainless valve
<input type="checkbox"/> LIMITED SCAN	<input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	<input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw	configuration.
FROM L <u>0</u> to L <u>360</u> :	INCHES FROM W0 <u>CL</u> to <u>Beyond</u>			
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60	other <u>70RL</u>	FROM <u>0</u> :	<u>360</u> DEG	
<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____:	INCHES FROM W0 _____ to _____			
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60	other _____	FROM _____	DEG to _____ DEG	
<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____:	INCHES FROM W0 _____ to _____			
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60	other _____	FROM _____	DEG to _____ DEG	
<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> cw <input type="checkbox"/> ccw	UT-11-877
FROM L _____ to L _____:	INCHES FROM W0 _____ to _____			Sketch(s) attached
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60	other _____	FROM _____	DEG to _____ DEG	<input checked="" type="checkbox"/> yes <input type="checkbox"/> No
Prepared By: <u>Matthew Hassel</u>	Level: <u>II</u>	Date: <u>03/30/11</u>	Sheet <u>4</u> of <u>7</u>	
Reviewed By: <u>Gary Moss</u>	Date: <u>4-20-11</u>	Authorized Inspector: <u>Nancy C. Ritchie Shrytten</u>	Date: <u>4/21/11</u>	

ATTACHMENT A
PAGE 95 OF 162

DEC

Supplemental Report

Report No.: UT-11-877

Page: 5 of 7

Summary No.: O1.C5.21.0057

Examiner: Bull, W. Keith *[Signature]*

Level: II-N

Reviewer: *[Signature]*

Date: 4-9-11

Examiner: Hassel, Matthew S. *[Signature]*

Level: II-N

Site Review: N/A

Date: _____

Other: N/A


Level: N/A

ANII Review: *[Signature]*

Date: 4/21/11

Comments: Weld 1 HP-193-12 Coverage

Sketch or Photo:



Supplemental Report

Report No.: UT-11-877

Page: 6 of 7

Summary No: 01.C5.21.0057

Examiner: Bull, W. Keith

Level: II-N

Reviewer: ME Houser

Date: 4.9.11

Examiner: Hassel, Matthew, S.

Level: II-N

Site Review: N/A

Date:

Other: N/A


Level: N/A

ANII Review: Nancy Chetani-Slaughter

Date: 4/24/11

Comments: Weld 1HP-193-12 Coverage

Sketch or Photo:



ATTACHMENT A
PAGE 97 OF 162



Determination of Percent Coverage for UT Examinations - Pipe

ATTACHMENT A
PAGE 98 OF 162

Site/Unit: <u>Oconee / 1</u>	Procedure: <u>PDI-UT-2</u>	Outage No.: <u>01-26</u>
Summary No.: <u>01.C5.21.0057</u>	Procedure Rev.: <u>E</u>	Report No.: <u>UT-11-677</u>
Workscope: <u>ISI</u>	Work Order No.: <u>01909633</u>	Page: <u>7</u> of <u>7</u>

45 deg

Scan 1	<u>100.000</u>	% Length X	<u>0.000</u>	% volume of length / 100 =	<u>0.000</u>	% total for Scan 1
Scan 2	<u>100.000</u>	% Length X	<u>50.000</u>	% volume of length / 100 =	<u>50.000</u>	% total for Scan 2
Scan 3	<u>100.000</u>	% Length X	<u>50.000</u>	% volume of length / 100 =	<u>50.000</u>	% total for Scan 3
Scan 4	<u>100.000</u>	% Length X	<u>50.000</u>	% volume of length / 100 =	<u>50.000</u>	% total for Scan 4

Add totals and divide by # scans = 37.500 % total for 45 deg

Other deg: _____ (to be used for supplemental scans)

The data to be listed below is for coverage that was not obtained with the 45 deg scans.

Scan 1	_____	% Length X	_____	% volume of length / 100 =	_____	% total for Scan 1
Scan 2	_____	% Length X	_____	% volume of length / 100 =	_____	% total for Scan 2
Scan 3	_____	% Length X	_____	% volume of length / 100 =	_____	% total for Scan 3
Scan 4	_____	% Length X	_____	% volume of length / 100 =	_____	% total for Scan 4

Percent complete coverage

Add totals for each scan required and divide by # of scans to determine:

37.500 % Total for complete exam

Site Field Supervisor: _____

David K. Zy

Date: _____

4/12/2011

UT Calibration Certification

Site/Unit: Oconee / 1 Procedure: PDI-UT-2 Outage No.: 01-26
 Summary No.: 01.C5.21.0086 Procedure Rev.: E Report No.: UT-11-670
 Workscope: ISI Work Order No.: 01909587 Page: 1 of 8

Code: 1998/2000A Cal/Item: C-F-1/C5.21 Location: _____
 Drawing No.: 1-51A-01(4) Description: Valve 1HP-108 to Pipe
 System ID: 51A
 Component ID: 1-51A-01-103A Size/Length: N/A Thickness/Diameter: 0.438 / 3.0/ SS
 Limitations: Yes - See attached sheet Start Time: 1421 Finish Time: 1440

Instrument Settings
 Serial No.: 011MBT Manufacturer: KRAUTKRAMER Model: USN-60
 Delay: 3.9322 Range: 1.0 Delay: 1231 Pulsar: High
 Damping: 1K Reject: 0% Reg. Rate: Autohigh Freq.: 5 MHz
 Filter: Fixed Mode: PE Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 31.3 Circ. Gain (dB): 32.7
 Screen Div: 1 In. of Sound Path
 Linearly Report No.: L-11-133
Calibration Block
 Cal. Block No.: 60225 Thickness: 0.438 Dia.: 3.5
 Cal. Blk. Temp.: 78 Temp. Tool: MCNDE40129
 Comp. Temp.: 77 Temp. Tool: MCNDE40129
 Recordable Indication(s): Yes No
 Results: Accept Reject Info
 Percent Of Coverage Obtained: > 60% No Yes
 Reviewed Previous Data: Yes No

Search Unit
 Serial No.: 01FBW4 Manufacturer: KBA Size: 26 Shape: Round
 Freq.: 5 MHz Style: Comp - G Exam Angle: 45 # of Elements: Single
 Mode: Shear Measured Angle: 45 Wedge Style: MSWQC
 Search Unit Cable: RG - 174 Length: 6' No. Conn.: 0
Scan Coverage
 Upstream Downstream Scan dB: 36.3
 CW CCW Scan dB: 36.3
 Exam Surface: O.D. Surface Condition: As Ground
Couplant
 Cal. Batch: 09325 Type: ULTRAGEL II
 Mfg.: SONOTECH Exam Batch: 09325
 Type: ULTRAGEL II Mfg.: SONOTECH
Reference Block
 Serial No.: 04-8741 Type: ROMPAS

Axial Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path	
ID Notch	80	6.0	.6	
Circumferential Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path	
See Axial				
Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
29.7	1" Radius	80	10	1.0

Examiner: <u>Day, John C.</u> Level: <u>II-N</u> Signature: <u>[Signature]</u> Date: <u>2/2/2011</u>	Reviewer: <u>[Signature]</u> Signature: <u>[Signature]</u> Date: <u>2/2/2011</u>
Examiner: <u>Leeper, Winfred C.</u> Level: <u>II-N</u> Signature: <u>[Signature]</u> Date: <u>2/2/2011</u>	Site Review: <u>N/A</u> Signature: _____ Date: _____
Other: <u>N/A</u> Level: <u>N/A</u> Signature: _____ Date: _____	ANII Review: <u>Nancy C. Ritchie Slaughter</u> Signature: <u>[Signature]</u> Date: <u>4/4/11</u>

ATTACHMENT A
 PAGE 99 OF 162

UT Calibrator Examination

Site/Unit: Oconee 1
 Summary No.: 01C5.21.0068
 Workscope: ISI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01909587

Outage No.: 01-28
 Report No.: UT-11-670
 Page: 2 of 8

Code: 1998/2000A Cat./Item: C-F-1/C5.21 Location: _____
 Drawing No.: 1-51A-01(4) Description: Valve 1HP-109 to Pipe
 System ID: 51A
 Component ID: 1-51A-01-103A Size/Length: N/A Thickness/Diameter: 0.438 / 3.0 / 88
 Limitations: Yes - See Attached Sheets Start Time: 1442 Finish Time: 1600

Instrument Settings
 Serial No.: 011MBT Manufacturer: KRAUTKRAMER Model: USN-90
 Delay: 4.9662 Range: 2.0
 M'd Cal/Vel: 1234 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 6 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 47.2 Circ. Gain (dB): N/A
 Screen Div.: 2 in. of Sound Path
 Linearly Report No.: L-11-133

Search Unit
 Serial No.: 0103CM Manufacturer: KBA
 Size: 0.25 Shape: Round
 Freq.: 5.0 MHz Style: Comp - G
 Exam Angle: 60 # of Elements: Single
 Mode: Shear
 Measured Angle: 60
 Wedge Style: MSWQC

Search Unit Cable
 Type: RG-174
 Length: 6 No. Conn.: 0

Scan Coverage
 Upstream Downstream Scan dB: 48.1
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: As Ground

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Cal. Checks	Time	Date
Initial Cal	1325	2/2/2011
Inter. Cal		
Inter. Cal	1441	2/2/2011
Inter. Cal		
Final Cal	1605	2/2/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: 04-8741
 Type: ROMPAS

Axial Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path	
ID Notch	80	4.9	.876	
Circumferential Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path	
N/A				
Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
31.8	1" Radius	80	6	1

Examiner: <u>Day, John C.</u> Level: <u>II-N</u> Signature: <u>[Signature]</u> Date: <u>2/2/2011</u>	Reviewer: <u>[Signature]</u> Signature: _____ Date: <u>2/2/2011</u>
Examiner: <u>Leeper, Winfred C.</u> Level: <u>II-N</u> Signature: <u>[Signature]</u> Date: <u>2/2/2011</u>	Site Review: <u>N/A</u> Signature: _____ Date: _____
Other: <u>N/A</u> Level: <u>N/A</u> Signature: _____ Date: _____	ANII Review: <u>[Signature]</u> Signature: _____ Date: <u>4/4/11</u>

UT Calibration Minimization

Site/Unit: Oconee Procedure: PDI-UT-2 Outage No.: 01-26
 Summary No.: 01.C6.21.0068 Procedure Rev.: E Report No.: UT-11-870
 Workscope: ISI Work Order No.: 01909587 Page: 3 of 8

Code: 1998/2000A Cat/Item: C-F-1/C6.21 Location: _____
 Drawing No.: 1-51A-01(4) Description: Valve 1HP-108 to Pipe
 System ID: 51A
 Component ID: 1-51A-01-103A Size/Length: N/A Thickness/Diameter: 0.438 / 2.0 / SS
 Limitations: Yes - See attached sheet Start Time: 1130 Finish Time: 1200

Instrument Settings
 Serial No.: 00X14L
 Manufacturer: KRAUTKRAMER
 Model: UBN-60
 Delay: 4.0688 Range: 2.5
 MTI Cal/Vol: 1224 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 33.6 Circ. Gain (dB): 33.6
 Screen Div: 25 of Sound Path
 Linearly Report No.: L-11-131

Search Unit
 Serial No.: SB0259
 Manufacturer: GE
 Size: .26 Shape: Round
 Freq.: 2.25 MHz Style: Comp. G
 Exam Angle: 45 # of Elements: Single
 Mode: Shear
 Measured Angle: 43
 Wedge Style: MSWQC
 Search Unit Cable
 Type: RG-174
 Length: 6 No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	0825	2/8/2011
Inter. Cal.		
Inter. Cal.	1000	2/8/2011
Inter. Cal.		
Final Cal	1530	2/8/2011

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
.375 Notch	80	2.1	.528
.750 Notch	80	4.1	1.03
1.250 Notch	80	6.8	1.701

Couplant
 Cal. Batch: 09326
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09326
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
See Axial			

Calibration Block
 Cal. Block No.: PDI-UT-2A-O
 Thickness: 378-1.25 Dia.: Flat
 Cal. Blk. Temp.: 72 Temp. Tool: MCNDE40128
 Comp. Temp.: 77 Temp. Tool: MCNDE40128
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 80%: No
 Reviewed Previous Data: Yes

Reference Block
 Serial No.: 04-8740
 Type: ROMPAS

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
27.0	1" Radius	80	4.0	1.0

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Day, John C.	II-N	<i>[Signature]</i>	2/8/2011	<i>[Signature]</i>	<i>[Signature]</i>	
Examiner	Level	Signature	Date	Site Review	Signature	Date
Ransom, Greg J.	II-N	<i>[Signature]</i>	2/8/2011	N/A		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			<i>[Signature]</i>	<i>[Signature]</i>	4/4/11

UT Calibration Continuation

Site/Unit: Oconee
 Summary No.: 01.C5.21.0066
 Workscope: ISI

Procedure: PDI-UT-2
 Procedure Rev.: E
 Work Order No.: 01909587

Outage No.: 04-28
 Report No.: UT-11-670
 Page: 4 of 8

Code: 1998/2000A Cal./Item: C-F-11C5.21 Location: _____
 Drawing No.: 1-51A-01(4) Description: Valve 1HP-109 to Pipe
 System ID: 51A
 Component ID: 1-51A-01-103A Size/Length: N/A Thickness/Diameter: 0.438 / 3.0/ SS
 Limitations: Yes - See Attached Sheets Start Time: 1208 Finish Time: 1221

Instrument Settings
 Serial No.: 00X14L
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 5.4262 Range: 5.0
 Mtu Cal/Vel: 1229 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.25 MHz
 Filter: Fixed Mode: FE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 41.8 Circ. Gain (dB): 41.5
 Screen Div.: .5 in. of Sound Path

Search Unit
 Serial No.: SB0453
 Manufacturer: GE
 Size: .26 Shape: Round
 Freq.: 2.25 MHz Style: Comp - G
 Exam Angle: 60 # of Elements: Single
 Mode: Shear
 Measured Angle: 60
 Wedge Style: MSWQC

Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	0845	2/8/2011
Inter. Cal.		
Inter. Cal.	1205	2/8/2011
Inter. Cal.		
Final Cal.	1535	2/8/2011

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
.375" Notch Tip	80	1.4	.671
.750 Notch Tip	80	2.7	1.361
1.25 Notch	80	5.0	2.506

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Calibration Block
 Cal. Block No.: PDI-UT-2A-0
 Thickness: 3.75-1.26 Dia.: Flat
 Cal. Blk. Temp.: 72 Temp. Tool: MCNDE40129
 Comp. Temp.: 77 Temp. Tool: MCNDE40129
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Scan Coverage
 Upstream Downstream Scan dB: 47.8
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: As Ground

Reference Block
 Serial No.: 04-8740
 Type: ROMPAS

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
29.6	1" Radius	80	2.0	1.0"

Results: Accept Reject MIP Info
 Percent Of Coverage Obtained > 90%: No
 Reviewed Previous Data: Yes

Comments: N/A

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Day, John C.	II-N	<i>[Signature]</i>	2/8/2011	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Date]</i>
Ransom, Greg	II-N	<i>[Signature]</i>	2/8/2011	Site Review	<i>[Signature]</i>	<i>[Date]</i>
Other	N/A	<i>[Signature]</i>	<i>[Date]</i>	ANII Review	<i>[Signature]</i>	<i>[Date]</i>

ATTACHMENT A
 PAGE 102 OF 162

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: <u>1-51A-01-103A</u>		Item No: <u>01.C5.21.0066</u>		remarks:
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L <u>N/A</u> to L <u>N/A</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 other _____		SURFACE <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw INCHES FROM W0 <u>CL</u> to <u>Beyond</u> FROM <u>0</u> DEG to <u>360</u> DEG		Due to forged valve con- figuration.
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw INCHES FROM W0 _____ to _____ FROM _____ DEG to _____ DEG		
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw INCHES FROM W0 _____ to _____ FROM _____ DEG to _____ DEG		
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw INCHES FROM W0 _____ to _____ FROM _____ DEG to _____ DEG		UT-11-870
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw INCHES FROM W0 _____ to _____ FROM _____ DEG to _____ DEG		Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> No
Prepared By: <u>John Day</u>	Level: <u>II</u>	Date: <u>02/03/11</u>	Sheet <u>5</u> of <u>8</u>	
Reviewed By: _____	Date: _____	Authorized Inspector: <u>Nancy L. Ritchie-Smyth</u>		Date: <u>9/14/11</u>

ATTACHMENT A
PAGE 103 OF 162

Supplemental Report

Report No.: UT-11-870

Page: 6 of 8

Summary No.: 01.C5.21.0066

Examiner: Day, John, C.

Level: II-N

Reviewer:

Date: 2/1/04

Examiner: Leeper, Winfred C.

Level: II-N

Site Review:

Date:

Other: N/A

Level: N/A

ANII Review:

Date: 4/4/14


Comments: Weld # 1-51A-01-103A See attached limitation report.

Sketch or Photo:

FLOW

(FABRIC) VALVE (51)
1HP-109

PIPE (52)





Supplemental Report

Report No.: UT-11-670

Page: 7 of 8

Summary No: O1.C5.21.0068

Examiner: Day, John C. *[Signature]*

Examiner: Leeper, Winfred C. *[Signature]*

Other: N/A

Level: U-N

Level: I-N

Level: N/A

Reviewer: *[Signature]*

Site Review: N/A

ANII Review: *[Signature]*

Date: 2/2/01

Date: 4/4/01

Comments:

Sketch or Photo:

(Facing) VALVE (51)
1HP-109

FLOW

45 (circ)

PIPE (52)



ATTACHMENT A
PAGE 105 OF 162



Determination of Percent Coverage for UT Examinations - Pipe

ATTACHMENT A
PAGE 106 OF 162

Site/Unit: <u>Oconee / 1</u>	Procedure: <u>PDI-UT-2</u>	Outage No.: <u>01-26</u>
Summary No.: <u>O1.C5.21.0066</u>	Procedure Rev.: <u>E</u>	Report No.: <u>UT-11-670</u>
Workscope: <u>ISI</u>	Work Order No.: <u>01909587</u>	Page: <u>8</u> of <u>8</u>

45 deg

Scan 1	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 1
Scan 2	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 2
Scan 3	<u>100.000</u> % Length X <u>50.000</u>	% volume of length / 100 = <u>50.000</u>	% total for Scan 3
Scan 4	<u>100.000</u> % Length X <u>50.000</u>	% volume of length / 100 = <u>50.000</u>	% total for Scan 4

Add totals and divide by # scans = 50.000 % total for 45 deg

Other deg - -60 (to be used for supplemental scans)

The data to be listed below is for coverage that was not obtained with the 45 deg scans.

Scan 1	<u>100.000</u> % Length X <u>100.000</u>	% volume of length / 100 = <u>100.000</u>	% total for Scan 1
Scan 2	<u>100.000</u> % Length X <u>100.000</u>	% volume of length / 100 = <u>100.000</u>	% total for Scan 2
Scan 3	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 3
Scan 4	<u> </u> % Length X <u> </u>	% volume of length / 100 = <u> </u>	% total for Scan 4

Percent complete coverage

Add totals for each scan required and divide by # of scans to determine:

75.000 % Total for complete exam

Site Field Supervisor: *[Signature]*

Date: 03/07/11

UT Calibration Examination

Site/Unit: Oconee Procedure: PDI-UT-10 Outage No.: 01-28
 Summary No.: 01.C5.51.0050 Procedure Rev.: E Report No.: UT-11-878
 Workscope: ISI Work Order No.: 01913780 Page: 1 of 9

Code: 1998/2009A Cal/Item: C-F-2/C5.51 Location: _____
 Drawing No.: 1LPS-563 Description: Pipe to Valve 1LPS-022

System ID: 48
 Component ID: 1LPS-563-14 Size/Length: N/A Thickness/Diameter: CS-SS/0.5/8.0
 Impairments: Yes - See attached sheet Start Time: 0910 Finish Time: 0848

Instrument Settings
 Serial No.: 011MBT Search Unit Serial No.: 011CXD
 Manufacturer: KRAUTKRAMER Manufacturer: KBA
 Model: USN-60 Size: 0.375 Shape: Round
 Delay: 6.7450 Range: 1.5 Freq.: 1.5 MHz Style: Comp - G
 Min Cal Valve: 1288 Pulsar: High Exam Angle: 45 # of Elements: Single
 Damping: 1K Reject: 0% Mode: Shear
 Rep. Rate: Autohigh Freq.: 2.0 MHz Measured Angle: 45
 Filter: Fixed Mode: PE Wedge Style: MSWQC
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 39.0 Circ. Gain (dB): 39.0 Search Unit Cable: _____
 Screen Div.: 18 in. of Sound Path: _____ Type: RG-174
 Linearity Report No.: L-11-139 Length: 8 No. Conn.: 0

Calibration Block
 Cal. Block No.: 69-4287 Scan Coverage
 Thickness: 4" Dia.: Flat CW CCW Scan dB: 40
 Cal. Blk. Temp: 74.0 Temp. Tool: MCNDE40138 Exam Surface: O.D.
 Comp. Temp: 68 Temp. Tool: MCNDE40138 Surface Condition: As Ground
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Date: No

Cal. Checks	Time	Date
Initial Cal	0735	3/31/2011
Inter. Cal.		
Inter. Cal.	0911	3/31/2011
Inter. Cal.		
Final Cal	1140	3/31/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: 66-3258
 Type: ROMPAS

Axial Orientated Search Unit			
Calibration Reflector	Signal AmpRude %	Sweep Division	Sound Path
SDH	80	5.2	.788

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
See Axial			

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
21.7	1" Radius	80	6.8	1.0

Comments: Initial Section XI Exam

Examiner	Level	Signature	Date	Reviewed	Signature	Date
Muirhead, Barry A.	II-N	<i>Barry A. Muirhead</i>	3/31/2011	<i>Debra</i>		4.12.11
Dean, Steven	II-N	<i>Steven Dean</i>	3/31/2011	<i>DA</i>		
Other	N/A			<i>Nancy C. Ritchie-Slaughter</i>		4/20/11

ATTACHMENT A
 PAGE 107 OF 162

UT Calibration Examination

Site/Unit: Oconee
 Summary No.: 0105510050
 Workscope: ISI

Procedure: PDI-UT-10
 Procedure Rev.: E
 Work Order No.: 01913780

Outage No.: 01-26
 Report No.: UT-11-676
 Page: 2 of 9

Code: 1998/2000A Cal./Item: C-F-2/C5_51 Location: _____
 Drawing No.: 1LP8-563 Description: Pipe to Valve 1LP8-022
 System ID: 148
 Component ID: 1LP8-563-14 Size/Length: N/A Thickness/Diameter: CS-SS/0.518.0
 Limitations: Yes - See Attached Sheets Start Time: 0910 Finish Time: 0948

Instrument Settings
 Serial No.: 011MBT
 Manufacturer: KRAUTKRAMER
 Model: USN-80
 Delay: 7.5058 Range: 2.0
 MHI Cal/Vol: 1206 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.0 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 42.4 Circ. Gain (dB): N/A
 Screen Div.: 2 In. of: Sound Path
 Linearity Report No.: L-11-139

Search Unit
 Serial No.: 01MHV4
 Manufacturer: KBA
 Size: .375 Shape: Round
 Freq.: 1.5 MHz Style: Comp - G
 Exam Angle: 80 # of Elements: Single
 Mode: Shear
 Measured Angle: 80
 Wedge Style: M8WQC
 Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0

Scan Coverage
 Upstream Downstream Scan dB: 43
 CW CCW Scan dB: N/A
 Exam Surface: O.D.
 Surface Condition: As Ground

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Revised Previous Data: No

Cal. Checks	Time	Date
Initial Cal.	0740	3/31/2011
Inter. Cal.		
Inter. Cal.	0920	3/31/2011
Inter. Cal.		
Final Cal.	1143	3/31/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: 86-3259
 Type: ROMPAS

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
Near SDH	80	3.4	.684

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
28.4	1" Radius	80	5	1.0

Comments: Initial Section XI Exam

Examiner Level: <u>II-N</u> Multhead, Barry A.	Signature: <u>[Signature]</u> Date: <u>3/31/2011</u>	Reviewer: <u>[Signature]</u> Signature: _____ Date: <u>4.12.11</u>
Examiner Level: <u>II-N</u> Dean, Steven	Signature: <u>[Signature]</u> Date: <u>3/31/2011</u>	Site Review: <u>N/A</u> Signature: _____ Date: _____
Other Level: <u>N/A</u>	Signature: _____ Date: _____	ANII Review: <u>[Signature]</u> Signature: _____ Date: <u>4/20/11</u>

UT Calibration Examination

Site/Unit: Oconee Procedure: PDI-UT-10 Outage No.: 01-28
 Summary No.: 01 C5.51.0050 Procedure Rev.: E Report No.: UT-11-878
 Workscope: SI Work Order No.: 01813780 Page: 3 of 9

Code: 1998/2000A Cat./Item: C-F-2/C5.51 Location: _____

Drawing No.: 1LPS-503 Description: Flt to Valve 1LPS-022

System ID: 148

Component ID: 1LPS-503-14 Size/Length: N/A Thickness/Diameter: C5-SS/0.578.0

Insulations: Yes - See attached sheet Start Time: 0910 Finish Time: 0948

Instrument Settings

Serial No.: 011MBT Search Unit Serial No.: 03-784

Manufacturer: KRAUTKRAMER Manufacturer: RTD

Model: USN-60 Size: 2(7x10) Shape: Rect.

Delay: 6.7076 Range: 1.5 Freq.: 2.0 MHz Style: TRLA

Mt. Cal/Vol: 2350 Pulsar: High Exam Angle: 45 # of Elements: Dual

Damping: 1K Reject: 0% Mode: Long

Rep. Rate: Autohigh Freq.: 2.0 MHz Measured Angle: 45

Filter: Fixed Mode: Dual Wedge Style: Integral

Voltage: Fixed Other: Fullwave

Ax. Gain (dB): 40 Cir. Gain (dB): 40 Search Unit Cable

Screen Div.: 15 in. of Sound Path Type: RG-174

Unclearly Report No.: L-11-139 Length: 6' No. Conn.: 0

Calibration Block

Cal. Block No.: 89-4267 Upstream Downstream Scan dB: 40

Thickness: 4" Dia.: Flat CW CCW Scan dB: 40

Cal. Blk. Temp.: 74.5 Temp. Tool: MCNDE40135 Exam Surface: O.D.

Comp. Temp.: 66 Temp. Tool: MCNDE40135 Surface Condition: As Ground

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Results: Accept Reject Info

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: No

Cal. Checks	Time	Date
Initial Cal	0745	3/31/2011
Inter. Cal.		
Inter. Cal.	0928	3/31/2011
Inter. Cal.		
Final Cal	1148	3/31/2011

Couplant

Cal. Batch: 09325

Type: ULTRAGEL II

Mfg.: SONOTECH

Exam Batch: 09325

Type: ULTRAGEL II

Mfg.: SONOTECH

Reference Block

Serial No.: 86-3258

Type: ROMPAS

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
SDH	80	5.6	.848

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
See Axial			

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
23.4	1" Radius	80	6.6	1.0

Comments: Initial Section XI Exam

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Murphy, Barry A.	II-N	<i>Barry Murphy</i>	3/31/2011	<i>D.E. Jensen</i>		4.12.11
Dean, Steven	II-N	<i>Steven Dean</i>	3/31/2011	Site Review	<i>JA</i>	
Other	Level	Signature	Date	ANII Review	<i>Nancy C. Ritchie Slaughter</i>	4/20/11

ATTACHMENT A
PAGE 109 OF 162

UT Calibration Examination

Site/Unit: Ooconee Procedure: PDI-UT-10 Outage No.: 01-28
 Summary No.: 01-C5.51.0080 Procedure Rev.: E Report No.: UT-11-878
 Workscope: UT/ISI Work Order No.: 01913780 Page: 4 of 9

Code: 1999/2000A Cat./Item: C-F-2/C5.51 Location: _____
 Drawing No.: 1LPS-563 Description: Pipe to Valve 1LPS-022
 System ID: 148
 Component ID: 1LPS-563-14 Size/Length: N/A Thickness/Diameter: CS-SS/0.518.0
 Limitations: Yes - See Attached Sheets Start Time: 0910 Finish Time: 0948

Instrument Settings
 Serial No.: 011MBT Search Unit Serial No.: 03-767
 Manufacturer: KRAUTKRAMER Manufacturer: RTD
 Mode: USH-60 Size: 2(7x10) Shape: Rect.
 Delay: 6.7512 Range: 2.0 Freq.: 2.0 MHz Style: TRL2
 M/T Cal Ver: 2377 Pulsar: High Exam Angle: 60 # of Elements: Dual
 Damping: 1K Reject: 0% Mode: Long
 Rep. Rate: Autohigh Freq.: 2.0 MHz Measured Angle: 60
 Filter: Fixed Mode: Dual Wedge Style: Integral
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 53.5 Circ. Gain (dB): N/A Search Unit Cable Type: RG-174
 Screen DM: 2 In. of: Sound Path Length: 6 No. Conn.: 0
 Linearity Report No.: L-11-139
Calibration Block Scan Coverage
 Cal. Block No.: 88-3289 Upstream Downstream Scan dB: 45
 Thickness: 1" Dia.: Flat CW CCW Scan dB: N/A
 Cal. Blk Temp: 74.8 Temp. Tool: MCNDE40135 Exam Surface: O.D.
 Comp. Temp: 69.2 Temp. Tool: MCNDE40135 Surface Condition: As Ground
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Imp
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: No

Cal. Checks	Time	Date
Initial Cal	0750	3/31/2011
Inter. Cal.		
Inter. Cal.	0940	3/31/2011
Inter. Cal.		
Final Cal	1152	3/31/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: 88-3259
 Type: ROMPAS

Axial Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path	
Near BDH	80	3.5	.700	
Circumferential Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path	
N/A				
Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
29.0	1" Radius	80	5	1.0

Comments: Initial Section XI Exam

Examiner: <u>Murhead, Barry A.</u> Level: <u>II-N</u> Signature: <u>[Signature]</u> Date: <u>3/31/2011</u>	Reviewer: <u>[Signature]</u> Signature: _____ Date: <u>4-12-11</u>
Examiner: <u>Dean, Steven</u> Level: <u>II-N</u> Signature: <u>[Signature]</u> Date: <u>3/31/2011</u>	Site Review: <u>N/A</u> Signature: _____ Date: _____
Other: <u>N/A</u> Level: <u>N/A</u> Signature: _____ Date: _____	ANII Review: <u>[Signature]</u> Signature: _____ Date: <u>4/20/11</u>

ATTACHMENT A
 PAGE 110 OF 162

UT Calibration Examination

Site/Unit: Oconee Procedure: NDE-640 Outage No.: 01-26
 Summary No.: 01.CS.51.0050 Procedure Rev.: 5 Report No.: UT-11-678
 Workscope: 181 Work Order No.: 01913780 Page: 5 of 9

Code: 1998/2000A Cat./Item: C-F-2/CS.51 Location: _____
 Drawing No.: 1LPS-563 Description: Pipe to Valve 1LPS-022
 System ID: 148
 Component ID: 1LPS-563-14 Size/Length: N/A Thickness/Diameter: CS-SS/0.5/8.0
 Limitations: None Start Time: 0905 Finish Time: 0910

Instrument Settings
 Serial No.: 011MBT
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 9.1350 Range: 1.0
 M/TI Cal/Vel: 2371 Pulsar: High
 Damping: 1K Reject: 6%
 Rep. Rate: Autohigh Freq.: 4.0 MHz
 Filter: Fbrd Mode: Dual
 Voltage: Fbrd Other: Fullwave
 Ax. Gain (dB): 38.0 Circ. Gain (dB): 38.0
 Screen Div.: 1 In. of Sound Path
 Linearity Report No.: L-11-139

Search Unit
 Serial No.: 57482-08724
 Manufacturer: KBA
 Size: 3.5X10mm Shape: Round
 Freq.: 4.0 MHz Style: MSEB
 Exam Angle: 0 # of Elements: Dual
 Mode: Long
 Measured Angle: 0
 Wedge Style: Integral
 Search Unit Cable
 Type: RG - 174
 Length: 6' No. Conn.: 0
 Scan Coverage
 Upstream Downstream Scan dB: 38
 CW CCW Scan dB: 38
 Exam Surface: OD
 Surface Condition: As Ground
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: Yes No Reviewed Previous Data: No

Cal. Checks	Time	Date
Initial Cal.	0730	3/31/2011
Inter. Cal.		
Inter. Cal.	0905	3/31/2011
Inter. Cal.		
Final Cal	1135	3/31/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
BW	80	5	.5

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference Block
 Serial No.: 04-7837
 Type: STEP WEDGE

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
36.7	.5" Step	80	5.0	.5

Examiner: Level II-N Signature: Barry A. Muthhead Date: 3/31/2011
 Examiner: Level II-N Signature: Steve Date: 3/31/2011
 Other: Level N/A Signature: Nancy C. Ritchie-Slaughter Date: 4/20/11
 Reviewer: Signature: McLousen Date: 4.12.11
 Site Review: Signature: N/A
 ANII Review: Signature: _____ Date: _____

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: 1LPS-563-14 Item No: 01.C5.51.0050

remarks:

Single side access due to cast

SS valve.

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 0 to L 360 INCHES FROM W0 CL to Beyond
 ANGLE: 0 45 60 other _____ FROM N/A DEG to N/A DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 0 to L 360 INCHES FROM W0 CL to Beyond
 ANGLE: 0 45 60 other _____ FROM N/A DEG to N/A DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

UT-11-578

Sketch(s) attached

yes No

Prepared By: Barry Muirhead Date: 03/31/11 Sheet 6 of 9

Reviewed By: [Signature] Date: 4-12-11 Authorized Inspector: [Signature] Date: 4/20/11

Supplemental Report

Report No.: UT-11-678

Page: 7 of 9

Summary No: D1:CS.51.0050

Examiner: Mulhead, Barry A. *Barry Mulhead*

Level: II-N

Reviewer: *D.E. Howson*

Date: 4.12.11

Examiner: Dean, Steven *Steve Dean*

Level: II-N

Site Review: *DIA*

Date:

Other: N/A


Level: N/A

ANII Review: *Nancy C. Ritchie Saughton*

Date: 4/20/11

Comments: Profile of Weld 1LPS-563-14

Sketch or Photo:





Supplemental Report

Report No.: UT-11-678

Page: 8 of 9

Summary No.: O1.C5.51.0050

Examiner: Muirhead, Barry A. *Barry A. Muirhead*

Level: II-N

Reviewer: *DE Hansen*

Date: 4-12-11

Examiner: Dean, Steven *Steven Dean*

Level: II-N

Site Review: *N/A*

Date: _____

Other: N/A


Level: N/A

ANII Review: *Nancy C. Ritzel-Saylter*

Date: 4/20/11

Comments: Weld 1LPS-563-14 Coverage

Sketch or Photo:



ATTACHMENT A
Page 11.4 of 162



Determination of Percent Coverage for UT Examinations - Pipe

Site/Unit: <u>Oconee / 1</u>	Procedure: <u>PDI-UT-10</u>	Outage No.: <u>01-26</u>
Summary No.: <u>01.C5.51.0050</u>	Procedure Rev.: <u>E</u>	Report No.: <u>UT-11-878</u>
Workscope: <u>ISI</u>	Work Order No.: <u>01913780</u>	Page: <u>9</u> of <u>9</u>

115 A 162
 attached

45 deg

Scan 1	_____	% Length X _____	% volume of length / 100 = _____	% total for Scan 1
Scan 2	_____	% Length X _____	% volume of length / 100 = _____	% total for Scan 2
Scan 3	<u>100.000</u>	% Length X <u>50.000</u>	% volume of length / 100 = <u>50.000</u>	% total for Scan 3
Scan 4	<u>100.000</u>	% Length X <u>50.000</u>	% volume of length / 100 = <u>50.000</u>	% total for Scan 4

Add totals and divide by # scans = 50.000 % total for 45 deg

Other deg - 60 (to be used for supplemental scans)

The data to be listed below is for coverage that was not obtained with the 45 deg scans.

Scan 1	_____	% Length X <u>50.000</u>	% volume of length / 100 = <u>50.000</u>	% total for Scan 1
Scan 2	_____	% Length X <u>0.000</u>	% volume of length / 100 = <u>0.000</u>	% total for Scan 2
Scan 3	_____	% Length X _____	% volume of length / 100 = _____	% total for Scan 3
Scan 4	_____	% Length X _____	% volume of length / 100 = _____	% total for Scan 4

Percent complete coverage

Add totals for each scan required and divide by # of scans to determine:

37.500 % Total for complete exam

Site Field Supervisor: David K. Z III

Date: 4/12/2011

UT Calibration, Examination

Site/Unit: Oconee / 1
 Summary No.: 01.C5.51.0053
 Workscope: ISI

Procedure: PDI-UT-10
 Procedure Rev.: E
 Work Order No.: 01913758

Outage No.: 01-26
 Report No.: UT-11-879
 Page: 1 of 9

Codo: 1998/2000A Cat/Item: C-F-2/C5.51 Location: _____
 Drawing No.: 1LPS-702 Description: Pipe to Valve 1LPSW-16 (Cast SS)
 System ID: 14B
 Component ID: 1LPS-702-50 Size/Length: N/A Thickness/Diameter: SS-CS/0.578.0
 Limitations: Yes - See attached sheet Start Time: 0957 Finish Time: 1035

Instrument Settings
 Serial No.: 011MBT Manufacturer: KRAUTKRAMER Model: USN-60
 Delay: 5.7450 Range: 1.5 Mti Cal/Val: .1288 Pulsar: High
 Damping: 1K Reject: 0% Rep. Rate: Autohigh Freq.: 2.0 MHz
 Filter: Fixed Mode: PE Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 39.0 Cir. Gain (dB): 39.0
1 Screen Div. = .15 In. of Sound Path
 Linearly Report No.: L-11-139

Search Unit
 Serial No.: 011CXD Manufacturer: KBA Size: 0.375 Shape: Round
 Freq.: 1.8 MHz Style: Comp - G Exam Angle: 45 # of Elements: Single
 Mode: Shear Measured Angle: 45 Wedge Style: MSWQC
 Search Unit Cable Type: RG - 174 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal	0735	3/31/2011
Inter. Cal.		
Inter. Cal.	0957	3/31/2011
Inter. Cal.		
Final Cal	1140	3/31/2011

Couplant
 Cal. Batch: 09325 Type: ULTRAGEL II
 Mfg.: SONOTECH Exam Batch: 09325
 Type: ULTRAGEL II Mfg.: SONOTECH

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
SDH	80	5.2	.788

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
See Axial			

Calibration Block
 Cal. Block No.: 89-4287 Thickness: 4" Dia.: Flat
 Cal. Blk. Temp.: 74.5 Temp. Tool: MCNDE40135 Comp. Temp.: 88 Temp. Tool: MCNDE40135
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info

Scan Coverage
 Upstream Downstream Scan dB: 40
 CW CCW Scan dB: 40
 Exam Surface: O.D. Surface Condition: As Ground

Reference Block
 Serial No.: 86-3259 Type: ROMPAS

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
21.7	1" Radius	80	6.6	1.0

Comments: Initial Section XI Exam

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: No

Examiner	Level	II-N	Signature	Date	Reviewed	Signature	Date
Muirhead, Barry A.	Level II-N		<i>Barry Muirhead</i>	3/31/2011	<i>Mike Hansen</i>		4.12.11
Dean, Steven	Level II-N		<i>Steve Dean</i>	3/31/2011	N/A		
Other	Level N/A				<i>Nancy C. Ritchie-Slaughter</i>		4/20/11

UT Calibration Examination

Site/Unit: Oconee Procedure: PDI-UT-10 Outage No.: 01-28
 Summary No.: 01.CS.51.0083 Procedure/Rev.: E Report No.: UT-11-879
 Workscope: IBI Work Order No.: 01913756 Page: 2 of 9

Code: 1998/2000A Cat./Item: C-F-2/C5:51 Location: _____
 Drawing No.: 1LPS-702 Description: Pipe to Valve 1LPSW-16 (Cast SS)
 System ID: 14B
 Component ID: 1LPS-702-50 Size/Length: N/A Thickness/Diameter: SS-CS/0.578.0
 Limitations: Yes - See Attached Sheets Start Time: 0957 Finish Time: 1035

Instrument Settings
 Serial No.: 011MBT
 Manufacturer: KRAUTKRAMER
 Model: USN-60
 Delay: 7.5056 Range: 2.0
 MVI Cal/Vol: 1296 Pulsar: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.0 MHz
 Filter: Fixed Mode: PE
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 42.4 Ctr. Gain (dB): N/A

Search Unit
 Serial No.: 01MHV4
 Manufacturer: KBA
 Size: 375 Shape: Round
 Freq.: 1.5 MHz Style: Comp - G
 Exam Angle: 60 # of Elements: Single
 Mode: Shear
 Measured Angle: 60
 Wedge Style: MSWQC
 Search Unit Cable
 Type: RG - 174

Cal. Checks	Time	Date
Initial Cal	0740	3/31/2011
Inter. Cal.		
Inter. Cal.	1005	3/31/2011
Inter. Cal.		
Final Cal	1143	3/31/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 08325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
Near SDH	80	3.4	.684

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A			

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
26.4	1" Radius	80	5	1.0

Screen Div. = 2 In. of Sound Path
 Uncertainty Report No.: L-11-139
 Calibration Block
 Cal. Block No.: 86-3259 Scan Coverage
 Upstream Downstream Scan dB: 43
 Thickness: N/A Dia: Flat CW CCW Scan dB: N/A
 Cal. Blk Temp: 74.5 Temp. Tool: MCNDE40135 Exam Surface: O.D.
 Comp Temp: 65 Temp. Tool: MCNDE40135 Surface Condition: As Ground
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Date: No

Reference Block
 Serial No.: 86-3259
 Type: ROMPAS

Comments: Initial Section XI Exam

Examiner Multhead, Barry A.	Level II-N	Signature <i>[Signature]</i>	Date 3/31/2011	Reviewer <i>[Signature]</i>	Signature <i>[Signature]</i>	Date 4.12.11
Examiner Dean, Steven	Level II-N	Signature <i>[Signature]</i>	Date 3/31/2011	Site Review DIA	Signature <i>[Signature]</i>	Date
Other N/A	Level N/A	Signature <i>[Signature]</i>	Date	ANII Review <i>[Signature]</i>	Signature <i>[Signature]</i>	Date 4/20/11

ATTACHMENT A
PAGE 119 OF 162

UT Calibration Examination

Site/Unit: Oconee Procedure: PDI-UT-10 Outage No.: 01-26
 Summary No.: 01CS51.0053 Procedure Rev.: E Report No.: UT-11-878
 Workspace: ISI Work Order No.: 01813756 Page: 3 of 3

Code: 1998/2000A Cat./Item: C-F-2/CS.51 Location: _____
 Drawing No.: 1LPS-702 Description: Pipe to Valve 1LPSW-16 (Cast SS)
 System ID: 14B
 Component ID: 1LPS-702-50 Size/Length: N/A Thickness/Diameter: SS-CS/0.5/8.0
 Limitations: Yes - See attached sheet Start Time: 0957 Finish Time: 1035

Instrument Settings
 Serial No.: 011MBT
 Manufacturer: KRAUTKRAMER
 Model: USN-80
 Delay: 5.7078 Range: 1.8
 Min Cal/Vol: 2350 Pulse: High
 Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.0 MHz
 Filter: Fixed Mode: Dual
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 40 Circ. Gain (dB): 40
 Screen Div. s: .15 In. of. Sound Path
 Linearly Report No.: L-11-139

Search Unit
 Serial No.: 03-764
 Manufacturer: RTD
 Size: 2(7x10) Shape: Reol.
 Freq.: 2.0 MHz Style: TRLA
 Exam Angle: 45 # of Elements: Dual
 Mode: Long
 Measured Angle: 45
 Wedge Style: Integral
 Search Unit Cable
 Type: IRG - 174
 Length: 8' No. Conn.: 0
Scan Coverage
 Upstream Downstream Scan dB: 40
 CW CCW Scan dB: 40
 Exam Surface: O.D.
 Surface Condition: As Ground
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 80%: No Reviewed Previous Data: No

Cal. Checks	Time	Date
Initial Cal.	0745	3/31/2011
Inter. Cal.		
Inter. Cal.	1015	3/31/2011
Inter. Cal.		
Final Cal.	1148	3/31/2011

Couplant
 Cal. Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH
 Exam Batch: 09325
 Type: ULTRAGEL II
 Mfg.: SONOTECH

Reference Block
 Serial No.: 85-3259
 Type: ROMPAS

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
SDH	80	6.6	.848

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
See Axial			

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
23.4	1" Radius	80	6.6	1.0

Comments: Initial Section XI Exam

Examiner	Level	Signature	Date	Reviewed	Signature	Date
Multhead, Barry A.	II-N	<i>Barry Multhead</i>	3/31/2011	<i>DE Jones</i>		4-12-11
Dean, Steven	II-N	<i>Steve Dean</i>	3/31/2011	<i>DIA</i>		
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			<i>Nancy C. Richter-Slaughter</i>		4/20/11

UT Calibration Examination

Site/Unit: Oconee Procedure: PDI-UT-10 Outage No.: 01-26
 Summary No.: 01CS510053 Procedure Rev.: E Report No.: UT-11-679
 Workscope: 101 Work Order No.: 01913756 Page: 4 of 9

Code: 1999/2000A Cat./Item: C-F-2/CS.51 Location: _____
 Drawing No.: 1LPS-702 Description: Pipe to Valve 1LPSW-16 (Cast SS)
 System ID: 148 Size/Length: N/A Thickness/Diameter: SS-CS/0.5/8.0
 Component ID: 1LPS-702-50 Start Time: 0957 Finish Time: 1035
 Limitations: Yes - See Attached Sheets

Instrument Settings

Serial No.: 011MBT Manufacturer: KRAUTKRAMER Model: UBN-60
 Delay: 6.7612 Range: 2.0 MHI Cal/Vol: 2577 Pulse: High Damping: 1K Reject: 0%
 Rep. Rate: Autohigh Freq.: 2.0 MHz Filter: Fixed Mode: Dual Voltage: Fixed
 Ax. Gain (dB): 53.5 Circ. Gain (dB): N/A Screen Div. = .2 In. of Sound Path
 Linearity Report No.: L-11-139 Calibration Block: 86-3259
 Cal. Block No.: 86-3259 Thickness: 1" Dia.: Flat
 Cal. Blk. Temp.: 74.5 Temp. Tool: MCNDE40135 Comp. Temp.: 85 Temp. Tool: MCNDE40135
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: No

Search Unit

Serial No.: 03-767 Manufacturer: RTD Size: 2(Tx10) Shape: Rect.
 Freq.: 2.0 MHz Style: TRL2 Exam Angle: 60 # of Elements: Dual
 Mode: Long Measured Angle: 60 Wedge Style: Integral
 Search Unit Cable: RG-174 Length: 6' No. Conn.: 0
 Scan Coverage: Upstream Downstream Scan dB: 45
 CW CCW Scan dB: N/A Exam Surface: O.D. Surface Condition: As Ground
 Reference Block: Serial No.: 86-3259 Type: ROMPAS

Axial Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path	
Near SDH	80	3.5	.700	
Circumferential Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path	
N/A				
Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
29.0	1" Radius	80	5	1:0

Examiner: <u>Level II-N</u> <u>Multhead Barry A</u>	Signature: <u>[Signature]</u> Date: <u>3/31/2011</u>	Reviewer: <u>[Signature]</u> Signature: _____ Date: <u>4.12.11</u>
Examiner: <u>Level II-N</u> <u>Dean Steven</u>	Signature: <u>[Signature]</u> Date: <u>3/31/2011</u>	Site Review: <u>[Signature]</u> Signature: _____ Date: _____
Other: <u>N/A</u> <u>[Signature]</u>	Signature: _____ Date: _____	ANII Review: <u>[Signature]</u> Signature: <u>[Signature]</u> Date: <u>4/20/11</u>

UT Calibration Examination

Site/Unit: Oconee 1 Procedure: NDE-640 Outage No.: 01-26
 Summary No.: 01C5.51.0053 Procedure Rev.: 5 Report No.: UT-11-678
 Workscope: LIBI Work Order No.: 01913758 Page: 5 of 9

Code: 1988/2000A Cat./Item: C-F-2/C5.51 Location: _____
 Drawing No.: 1LPS-702 Description: Pipe to Valve 1LPSW-16 (Cast SS)
 System ID: 14B
 Component ID: 1LPS-702-50 Size/Length: N/A Thickness/Diameter: SS-CS/0.5/9.0
 Installations: None Start Time: 0950 Finish Time: 0957

Instrument Settings
 Serial No.: 011MBT Search Unit Serial No.: 57462-08724
 Manufacturer: KRAUTKRAMER Manufacturer: KSA
 Model: USN-60 Size: 3.5X10mm Shape: Round
 Delay: 9.1350 Range: 1.0 Freq.: 4.0 MHz Style: MSEB
 Cal. Vel.: 2374 Pulsar: High Exam Angle: 0 # of Elements: Dual
 Damping: 1K Reject: 0% Mode: Long
 Rep. Rate: Autohigh Freq.: 4.0 MHz Measured Angle: 0
 Filter: Fixed Mode: Dual Wedge Style: Integral
 Voltage: Fixed Other: Fullwave
 Ax. Gain (dB): 38.0 Circ. Gain (dB): 38.0 Search Unit Cable
 Screen Div.: 1 In. of Sound Path Type: RG-174
 In-situ Report No.: L-11-139 Length: 5' No. Conn.: 0
Calibration Block
 Cal. Block No.: Component Upstream Downstream Scan dB: 38
 Thickness: 500 Dia: 6 CW CCW Scan dB: 38
 Cal. Blk. Temp: 74.5 Temp. Tool: MCNDE40135 Exam Surface: OD
 Comp. Temp: 68 Temp. Tool: MCNDE40135 Surface Condition: As Ground
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: Yes No Reviewed Previous Data: Yes No

Cal. Checks	Time	Date
Initial Cal	0730	3/31/2011
Inter. Cal.		
Inter. Cal.	1025	3/31/2011
Inter. Cal.		
Final Cal	1135	3/31/2011

Couplant	
Cal. Batch:	09325
Type:	ULTRAGEL II
Mfg.:	SONOTECH
Exam Batch:	09325
Type:	ULTRAGEL-II
Mfg.:	SONOTECH

Reference Block	
Serial No.:	04-7837
Type:	STEP WEDGE

Axial Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path	
BW.	80	5	.5	
Circumferential Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path	
N/A				
Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
38.7	.5" Step	80	5.0	.5

Examiner	Level	II-N	Signature	<i>Barry Multhead</i>	Date	3/31/2011	Reviewer	<i>Debra Jensen</i>	Signature		Date	4-12-11
Multhead, Barry A.							Site Review	N/A	Signature		Date	
Examiner	Level	II-N	Signature	<i>Steven Dean</i>	Date	3/31/2011	ANII Review	<i>Nancy C. Ritchie Slaughter</i>	Signature		Date	4/20/11
Dean, Steven												
Other	Level	N/A	Signature		Date							
N/A												

ATTACHMENT A
 PAGE 120 OF 162

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: <u>1LPS-702-50</u>		Item No: <u>O1.C5.51.0053</u>		remarks:
<input checked="" type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		Single side access due to cast
<input checked="" type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	<input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		SS valve.
FROM L: <u>0</u> to L: <u>360</u>	INCHES FROM W0 <u>CL</u> to <u>Beyond</u>			
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other _____	FROM <u>N/A</u> DEG to <u>N/A</u> DEG			
<input checked="" type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		
<input checked="" type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw		
FROM L: <u>0</u> to L: <u>360</u>	INCHES FROM W0 <u>CL</u> to <u>Beyond</u>			
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 other _____	FROM <u>N/A</u> DEG to <u>N/A</u> DEG			
<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		
<input checked="" type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		
FROM L: _____ to L: _____	INCHES FROM W0 _____ to _____			
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____	FROM _____ DEG to _____ DEG			
<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION		
<input checked="" type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		UT-11-679.
FROM L: _____ to L: _____	INCHES FROM W0 _____ to _____			Sketch(s) attached
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____	FROM _____ DEG to _____ DEG			<input checked="" type="checkbox"/> yes <input type="checkbox"/> No
Prepared By: <u>Barry Murrhead</u>	Level: <u>II</u>	Date: <u>03/31/11</u>	Sheet <u>6</u> of <u>9</u>	
Reviewed By: <u>[Signature]</u>	Date: <u>4-12-11</u>	Authorized Inspector: <u>[Signature]</u>	Date: <u>4/20/11</u>	

ATTACHMENT A
PAGE 121 OF 162

Supplemental Report

Report No.: UT-11-879

Page: 7 of 9

Summary No.: O1,CS,51,0053
Examiner: Muirhead, Barry A.
Examiner: Dean, Steven
Other: N/A


Level: II-N
Level: II-N
Level: N/A

Reviewer: M.E. Houser
Site Review: N/A
ANII Review: Nancy C. Ritchie-Smyth

Date: 4-12-11
Date: _____
Date: 4/20/11

Comments: Profile of Weld 1LPS-702-50

Sketch or Photo:



Supplemental Report

Report No.: UT-11-878
Page: 8 of 9

Summary No.: O1.CS.51.0053

Examiner: Multhead, Barry A. *Barry Multhead*

Examiner: Dean, Steven *Steven Dean*

Other: N/A

Level: II-N

Level: II-N

Level: N/A

Reviewer: *AE Hansen*

Site Review: NA

ANII Review: *Nancy C. Ritchie Slaughter*


Date: 4/2/11

Date: _____

Date: 4/20/11

Comments: Weld 1LPS-702-50 Coverage

Sketch or Photo:



ATTACHMENT A
PAGE 123 of 162



Determination of Percent Coverage for UT Examinations - Pipe

ATTACHMENT A
PAGE 174 OF 162

Site/Unit: <u>Oconee / 1</u>	Procedure: <u>PDI-UT-10</u>	Outage No.: <u>01-28</u>
Summary No.: <u>01.C5.51.0053</u>	Procedure Rev.: <u>E</u>	Report No.: <u>UT-11-879</u>
Workscope: <u>ISI</u>	Work Order No.: <u>01913758</u>	Page: <u>9</u> of <u>9</u>

45 deg

Scan 1	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 1
Scan 2	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 2
Scan 3	<u>100.000</u> % Length X	<u>50.000</u> % volume of length / 100 =	<u>50.000</u> % total for Scan 3
Scan 4	<u>100.000</u> % Length X	<u>50.000</u> % volume of length / 100 =	<u>50.000</u> % total for Scan 4

*Add totals and divide by # scans = 50.000 % total for 45 deg

Other deg - +60 (to be used for supplemental scans)

The data to be listed below is for coverage that was not obtained with the 45 deg scans.

Scan 1	<u>100.000</u> % Length X	<u>50.000</u> % volume of length / 100 =	<u>50.000</u> % total for Scan 1
Scan 2	<u>100.000</u> % Length X	<u>0.000</u> % volume of length / 100 =	<u>0.000</u> % total for Scan 2
Scan 3	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 3
Scan 4	<u> </u> % Length X	<u> </u> % volume of length / 100 =	<u> </u> % total for Scan 4

Percent complete coverage

Add totals for each scan required and divide by # of scans to determine:

37.500 % Total for complete exam

Site Field Supervisor: David B. III

Date: 4/12/01



UT Vessel Examination

Site/Unit: Oconee 1 0
 Summary No.: WJ-32
 Workscope: PSI

Procedure: NDE-3830
 Procedure Rev.: 1
 Work Order No.: 01889357

Outage No.: N/A
 Report No.: BOP-UT-09-112
 Page: 1 of 4

Code: 1892/2000A Cal./Item: B-B/B2.51 Location: N/A
 Drawing No.: NU-D-1149-1 Description: Chemical connector to channel body
 System ID: N/A
 Component ID: WJ-32 Size/Length: N/A Thickness/Diameter: .875/8.0/SS
 Limitations: Yes - See supplemental sheet Start Time: 1035 Finish Time: 1105

Examination Surface: Inside Outside Surface Condition: AS GROUND
 Lo Location: 9.1.1.1 Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 09125
 Temp. Tool Mfg.: FISHER Serial No.: MCNDE32770 Surface Temp.: 70 °F
 Cal. Report No.: SHD II-H-09 CAL-09-458, 459, 460, 461 & 462

Angle Used	0	45	45T	60	60T	70L
Scanning dB	43.0	61.7	60.2	65.0	49.0	

Indication(s): Yes No Scan Coverage: Upstream Downstream CW CCW

Comments:
 Scanning db lowered from +14db to maintain 2:1 signal to noise ratio

Results: Accept Reject Info PSI examination S/N N-32389-1 FC 09-01, 09-05
 Percent Of Coverage Obtained > 80%: No 87.7% Reviewed Previous Data: No

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Dean, Steven	II-N	<i>[Signature]</i>	11/4/2009	<i>[Signature]</i>	<i>[Signature]</i>	7/19/11
Examiner	Level	Signature	Date	Site Review	Signature	Date
N/A	N/A					
Other	Level	Signature	Date	ANR Review	Signature	Date
N/A	N/A			<i>[Signature]</i>	<i>[Signature]</i>	7/20/11



Ultrasonic Indication Report

Site/Unit: Oconee / 0
 Summary No.: WJ-32
 Workscope: P81

Procedure: NDE-3630
 Procedure Rev.: 1
 Work Order No.: 01889357

Outage No.: N/A
 Report No.: BOP-UT-09-112
 Page: 2 of 4


Search Unit Angle: 45 & 70
 Wo Location: Centerline of Weld
 Lo Location: B.1.1.1

- Piping Welds
- Ferrous Vessels $\geq 2" T$
- Other Vessels $< 2" T$

MP	Metal Path	W _{max}	Distance From Wo To S.U. At Maximum Response
RBR	Remaining Back Reflection	W ₁	Distance From Wo At Of Max (Forward)
L	Distance From Datum	W ₂	Distance From Wo At Of Max (Forward)

Comments: Weld WJ-32

SIN N-32389-1



Angle	Indication No.	% Of DAC	W Max		Forward Of Max		Backward Of Max		L1 Of Max	L Max	L2 Of Max	RBR Amp.	Remarks
			W	MP	W1	MP	W2	MP					
81	1-45°	90	1.5	2.14	N/A	N/A	N/A	N/A	360°	0-1"	INT	N/A	Root Geometry
82	2-45°	70	0.9	1.20	N/A	N/A	N/A	N/A	360°	0-1"	INT	N/A	Root Geometry
82	3-70°	50	0.9	2.39	N/A	N/A	N/A	N/A	360°	0-6"	INT	N/A	I.D Geometry
82	4-45°	60	0.9	1.20	N/A	N/A	N/A	N/A	360°	0-1"	INT	N/A	Root Geometry

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Dean, Steven	II-N	<i>[Signature]</i>	11/4/2009	<i>Gay Moss</i>	<i>[Signature]</i>	12-8-09
Examiner	Level	Signature	Date	Site Review	Signature	Date
Griebel, David M.	II-N	<i>[Signature]</i>	11/4/2009			
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			<i>Dorothy Ritchie Slaughter</i>	<i>[Signature]</i>	4/27/11

ATTACHMENT A
 PAGE 176 OF 162

DUKE POWER COMPANY

ISI LIMITATION REPORT

DUKE POWER COMPANY		
ISI LIMITATION REPORT		
Component/Weld ID: <u>WJ-32</u> Item No: <u>BOP-UT-09-112</u>		remarks:
<input checked="" type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw FROM L <u>0+3"</u> to L <u>0-3"</u> INCHES FROM W0 <u>CL+1.1</u> to <u>Beyond</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other <u>70</u> FROM <u>0</u> DEG to <u>360</u> DEG		Due to nozzle.
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input checked="" type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw FROM L <u>N/A</u> to L <u>N/A</u> INCHES FROM W0 <u>+0.6</u> to <u>+1.5</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other <u>70</u> FROM <u>0</u> DEG to <u>360</u> DEG		Taper on chemical connector
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM L _____ to L _____ INCHES FROM W0 _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other: _____ FROM _____ DEG to _____ DEG		
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM L _____ to L _____ INCHES FROM W0 _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 5 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> No
Prepared By: <u>Steve Dean</u>	Level: <u>II</u>	Date: <u>11/04/09</u>
Reviewed By: <u>Dan Moss</u>	Date: <u>12-8-09</u>	Authorized Inspector: <u>Nancy C. Ritchie-Slaughter</u> Date: <u>11/27/11</u>
		Sheet <u>3</u> of <u>4</u>

ATTACHMENT A
PAGE 127 OF 162



Supplemental Report

Report No.: BOP-UT-09-112

Page: 4 of 4

Summary No: WJ-32

Examiner: Dean, Steven

Examiner: Gnebel, David M.

Other: N/A

Level: II-N

Level: II-N

Level: N/A

Reviewer: Gay Moss

Site Review:

ANIL Review: Nancy C. Retcher-Slaughter


Date: 12-8-07

Date:

Date: 4/27/11

Comments: Weld WJ-32

Ind. # 1; 2 & 4 are root geometry. Ind. # 3 is a geometric reflector from offset on the I. D. surface.



52

51

Let Down Cooler - Chemical Connector to Channel Body

% Coverage Calculations

ATTACHMENT A
PAGE 1 OF 5
79162

Weld No. : WJ-32

Ø = 8.625"

"r" = 0.875"

Weld Length = 27.1"

Total Inspection Area = 2.28 sq. in.

% Length Limited due to nozzle = 6" / 27.1" x 100 = 22.1%

Aggregate Coverage Calculation

Axial Scans

22.1% of length x 96.5% of the volume of length / 100 = 21.3%

77.9% of length x 97.4% of the volume of length / 100 = 75.9%

Aggregate coverage Axial scans = 21.1 + 75.9 = 97.2%

Circ. Scans


100% of length x 78.1% of the volume of length / 100 = 78.1%

Total = (97.2 + 78.1) / 2 = 87.7% Aggregate Coverage

Letdown Cooler Chemical Connector to Channel Body Total Exam Area

Weld No. : WJ-32

Item No. : N/A



Scale: 1" = 1"

ATTACHMENT A
Page 130 of 162
2 of 5


Letdown Cooler Chemical Connector to Channel Body


Area Examined - Axial Scans

Weld No. : WJ-32

Item No. : N/A

 = Area Not Examined = $0.05 + 0.01 = 0.06$ sq. in.

 = Area Examined = $2.28 - 0.06 / 2.28 \times 100 = 97.4\%$




Scale: 1" = 1"


ATTACHMENT A
 page 131 of 162
 3 of 5


Letdown Cooler Chemical Connector to Channel Body Area Examined @ Nozzle - Axial Scans

Weld No. : WJ-32

Item No. : N/A

 = Area Not Examined = $0.05 + 0.01 + 0.02 = 0.08$ sq. in.

 = Area Examined = $2.28 - 0.08 / 2.28 \times 100 = 96.5\%$



Scale: 1" = 1"


ATTACHMENT A
PAGE 132 of 162
4 of 5


Letdown Cooler Chemical Connector to Channel Body Area Examined - Circ. Scan

Weld No. : WJ-32

Item No. : N/A

 = Area Not Examined = 0.5 sq. in.

 = Area Examined = $2.28 - 0.5 / 2.28 \times 100 = 78.1\%$



Scale: 1" = 1"

ATTACHMENT A
page 133 of 162
5 of 5



UT Base Metal Lamination

Site/Unit: Oconee / 0
 Summary No.: WJ-33
 Workscope: PSI

Procedure: NDE-640
 Procedure Rev.: 5
 Work Order No.: 01889357

Outage No.: N/A
 Report No.: BOP-UT-09-113
 Page: 1 of 2

Code: N/A Cat./Item: N/A Location: N/A
 Drawing No.: N/A Description: N/A
 System ID: N/A
 Component ID: WJ-33 Size/Length: N/A Thickness/Diameter: .875/3.0/SS
 Limitations: None Start Time: 0825 Finish Time: 0829

Examination Surface: Inside Outside Surface Condition: AS GROUND
 Lo Location: 9.1.1.1 Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 09125
 Temp. Tool Mfg.: FISHER Serial No.: MCNDE32770 Surface Temp.: 70 °F Scanning dB: 47.0
 Cal. Report No.: CAL-09-457

Ind. No.	% Loss Back Wall	Amplitude % Full Screen	Position One				Position Max				Position Two				Remarks
			L1	W1	W2	MP	LM	W1	W2	MP	L2	W1	W2	MP	
NRI															

Comments: N/A

Results: Accept Reject Info PSI exam S/W N-32389-1
 Percent Of Coverage Obtained > 90%: Yes Reviewed Previous Data: No

Examiner	Level	II-N	Signature	Date	Reviewer	Signature	Date
Dean, Steven			<i>[Signature]</i>	11/4/2009	<i>[Signature]</i>		12-8-09
Examiner	Level	II-N	Signature	Date	Site Review	Signature	Date
Griebel, David M.			<i>[Signature]</i>	11/4/2009	<u>N/A</u>		
Other	Level	N/A	Signature	Date	ANII Review	Signature	Date
N/A					<i>[Signature]</i>		4/27/11

attachment A
 page 134 of 162



Supplemental Report

Report No.: BOP-UT-09-113

Page: 2 of 2

Summary No.: WJ-33


Examiner: Dean, Steven
Examiner: Griebel, David M.
Other: N/A

Level: II-N
Level: II-N
Level: N/A

Reviewer: Sam Moss
Site Review: N/A
ANII Review: Wing C. Ritchie Stoughton

Date: 12-09
Date:
Date: 4/27/11

Comments: WJ-33



attachment A
page 135 of 162



UT Vessel Examination

Site/Unit: Oconee / 0
 Summary No.: WJ-33
 Workscope: PSI

Procedure: NDE-3630
 Procedure Rev.: 1
 Work Order No.: 01889357

Outage No.: N/A
 Report No.: BOP-UT-09-117
 Page: 1 of 2

Code: 1998/2000A Cat./Item: B-D/B3.150 Location: N/A
 Drawing No.: NU-D-1149-1 Rev. A Description: Nozzle to channel body
 System ID: N/A
 Component ID: WJ-33 Size/Length: N/A Thickness/Diameter: .875/3.0/SS
 Limitations: Yes - See supplemental sheet Start Time: 0952 Finish Time: 1010

Examination Surface: Inside Outside Surface Condition: AS GROUND
 Lo Location: 9.1.1.1 Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 09125
 Temp. Tool Mfg.: FISHER Serial No.: MCNDE32770 Surface Temp.: 70 °F

Cal. Report No.: DME 11-14-09 CAL-09-458, 459, 460, 461 & 462

Angle Used	0	45	45T	60	60T	70L
Scanning dB		43.0	61.7	50.2	55.0	46.0

Indication(s): Yes No Scan Coverage: Upstream Downstream CW CCW

Comments:
 Scanning db lowered from +14db to maintain 2:1 signal to noise ratio

Results: Accept Reject Info PSI examination SIN N-32389-1 FL 09-01, 09-05
 Percent Of Coverage Obtained > 90%: No 54.6% Reviewed Previous Data: No 4/27/11

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Dean, Steven	II-N	<i>[Signature]</i>	11/4/2009	<i>[Signature]</i>	<i>[Signature]</i>	12/8/09
Griebel, David M.	II-N	<i>[Signature]</i>	11/4/2009	Site Review	<i>[Signature]</i>	<i>[Signature]</i>
Other	Level N/A	Signature	Date	ANII Review	Signature	Date
N/A				<i>[Signature]</i>	<i>[Signature]</i>	4/27/11

attachment A
page 136 of 162

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: WJ-33 Item No: BOP-UT-09-117

remarks:

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L N/A to L N/A INCHES FROM W0 Toe to Beyond
 ANGLE: 0 45 60 other 70 FROM 0 DEG to 360 DEG

Due to nozzle.

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 45 60 other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM W0 _____ to _____
 ANGLE: 0 5 60 other _____ FROM _____ DEG to _____ DEG

Sketch(s) attached

yes No

Prepared By: Steve Dean *[Signature]* Level: II Date: 11/04/09

Sheet 2 of 2

Reviewed By: Gary Moss *[Signature]* Date: 12-8-09

Authorized Inspector: Woney Cretcher-Slaughter *[Signature]* Date: 4/27/11

Attachment A
page 137 of 162

Letdown Cooler Nozzle to Channel Body		
Weld No. WJ-33		
Base Material Coverage		
Scan	Radius View	Non-Radius View
Axial	68.2%	52.7%
Circ	65.2%	54.4%
Aggregate @ $68.2 + 52.7 + 65.2 + 54.4 = 240.5/4 = 60.1\%$		
Weld Material Coverage		
Scan	Radius View	Non-Radius View
Axial-S1	45.9%	26.0%
Axial-S2	0.0%	0.0%
Circ-S2	94.1%	66.3%
Circ-S2	94.1%	66.3%
Aggregate @ $45.9 + 26.0 + 0.0 + 0.0 + 94.1 + 66.3 + 94.1 + 66.3 = 392.7/8 = 49.1\%$		
Total Aggregate @ $60.1 + 49.1 = 109.2/2 = 54.6\%$		

Attachment A
 Page 138 of 162

Level III Paul Stafford
 Date 11-4-09

Letdown Cooler Nozzle to Channel Body

Weld No. : WJ-33

Item No. : N/A

BASE MATERIAL AREA OF INTEREST:

$$ABCD: \frac{.875in \times (.45in + 1.1in)}{2} = .72in^2$$

$$GFH: \frac{\pi (.45in)^2}{4} = .16in^2$$

$$EFHI: 1.8in \times .45in = .81in^2$$


$$\underline{\underline{TOTAL = 1.69in^2}}$$

WELD AREA OF INTEREST:

$$BFD: \frac{1.1in \times 1.1in}{2} = .77in^2$$

$$DEF: \frac{30in \times 1.8in}{2} = .27in^2$$

$$\underline{\underline{TOTAL = 1.04in^2}}$$



Scale: 1" = 1"

Attachment A
Page 139 of 162 2 of 7

Letdown Cooler Nozzle to Channel Body

Weld No. : WJ-33

Item No. N/A

BASE METAL COVERAGE - CIRK

ABCD: $7.5in \times 8.75in = 22in^2$

IEG: $\frac{.8in \times 1.4in}{2} = .7in^2$

IGH: $\frac{.35in \times 1.4in}{2} = .75in^2$

HPI: $\frac{.85in \times 30in}{2} = 13in^2$

LMN: $\frac{\pi(.45in^2)}{4} = .16in^2$

IPP: $\frac{30in \times .60in}{2} = .9in^2$


$\frac{.97in^2}{1.69in^2}(100) = 54.4\%$

WELD COVERAGE - CII

EIK: $\frac{30in \times .85in}{2} = .13$

EEI: $\frac{.90in \times 1.35in}{2} = .56in$

$\frac{.69in^2}{1.04in^2}(100) = 66.3\%$



Attachment A

Page 140 of 162 ³ of 7

Letdown Cooler Nozzle to Channel Body

Weld No. : WJ-33

Item No. : N/A

BASE METAL COVERAGE - AXIAL

$$CDE: \frac{\pi (4.5 \text{ in}^2)}{4} = .16 \text{ in}^2$$

$$BCFE: 4.5 \text{ in} \left(\frac{1.5 \text{ in} + 1.35 \text{ in}}{2} \right) = .64 \text{ in}^2$$

$$.64 \text{ in}^2 + .16 \text{ in}^2 = .80 \text{ in}^2$$


$$1.69 \text{ in}^2 = \frac{.80 \text{ in}^2}{.47 \text{ in}} / 1.69 \text{ in} (100) = 52.7 \text{ in}^2$$

WELD COVERAGE - AXIAL

$$ABC: \frac{1.4 \text{ in} + 1.1 \text{ in}}{2} = .77 \text{ in}$$

$$1.04 \text{ in}^2 - .77 \text{ in}^2 = .27 \text{ in}^2$$

$$.27 \text{ in}^2 / 1.04 \text{ in}^2 (100) = 26\%$$



Attachment A
page 141 of 162 4 of 7

Letdown Cooler Nozzle to Channel Body (Radius View)

Weld No. : WJ-33

Item No. : N/A

BASE METAL AREA OF INTEREST

$$ABCD : .875in \times .46in = .39in^2$$

$$CDE : \frac{.875in \times .45in}{2} = .20in^2$$

$$HML : \frac{.50in \times .20in}{2} = .05in^2$$

$$MJKL : .44in \times 1.25in = .55in^2$$

$$ITK : \frac{\pi(45^2)}{4} = .16in^2$$

$$\underline{\underline{TOTAL = 1.35in^2}}$$


WELD AREA OF INTEREST

$$CEF : \frac{.65in \times .875in}{2} = .28in^2$$

$$EFGH : .25in \times .875in = .22in^2$$

$$GHI : \frac{.80in \times .875in}{2} = .35in^2$$

$$\underline{\underline{TOTAL = 0.85in^2}}$$



Attachment A
page 142 of 162 5 of 7

Letdown Cooler Nozzle to Channel Body (Radius View)

Weld No. : WJ-33

Item No. : N/A

BASE MATERIAL COVERAGE - AXIAL

$$ABC = \frac{\pi(45^\circ)}{2} = 16in^2$$

$$ACDF = .45in \left(\frac{.50in + .70in}{2} \right) = .27in^2$$

$$.27in^2 + 16in^2 = .43in^2$$

$$1.35in^2 - .43in^2 = 0.92in^2$$


$$0.92in^2 / 1.35in^2 (100) = 68.2\%$$

WELD COVERAGE - AXIAL

$$AEF = \frac{1.3in \times .70in}{2} = .46in^2$$

$$.85in^2 - .46in^2 = .39in^2$$

$$.39in^2 / .85in^2 (100) = 45.9\%$$



Scale: 1" = 1"

attachment A
page 143 of 162 6 of 7

Down Cooler Nozzle to Channel Body (Radius View)

Weld No. : WJ-33

Item No. : N/A

BASE METAL COVERAGE - CIRCS

CDEF: $.45in \left(\frac{.10in \times 30in}{2} \right) = .29in^2$

CFHI: $\frac{.875in \times .45in}{2} = .20in^2$

GHJK: $.875in \times .45in = .39in^2$

TOTAL = .88in²


$\frac{.88in^2}{1.35in^2} (100) = 65.2\%$

WELD COVERAGE - CIRCS

ABC: $\frac{30in \times 30in}{2} = .05in^2$

$.05in^2 - .05in^2 = .80in^2$

$\frac{.80in^2}{.85in^2} (100) = 94.1\%$



attachment A
Page 144 of 162 7 of 7



UT Vessel Examination

Site/Unit: Oconee / 0 Procedure: NDE-3630 Outage No.: N/A
 Summary No.: WJ-35 Procedure Rev.: 1 Report No.: BOP-UT-09-119
 Workscope: PSI Work Order No.: 01889357 Page: 1 of 4

Code: 1998/2000A Cat./Item: B-B/B2.51 Location: N/A
 Drawing No.: NU-D-1149-1 Rev. A Description: Chemical connector to channel body
 System ID: N/A
 Component ID: WJ-35 Size/Length: N/A Thickness/Diameter: .875/8.0/SS
 Limitations: Yes - See supplemental sheet Start Time: 1107 Finish Time: 1130

Examination Surface: Inside Outside Surface Condition: AS GROUND
 Lo Location: 9.1.1.1 Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 09125

Temp. Tool Mfg.: FISHER Serial No.: MCNDE32770 Surface Temp.: 70 °F

Cal. Report No.: SHD (I-H-01) CAL-09-458, 459, 460, 461 & 462

Angle Used	0	45	45T	60	60T	70L
Scanning dB		43.0	61.7	50.2	55.0	49.0

Indication(s): Yes No Scan Coverage: Upstream Downstream CW CCW

Comments:
Scanning db lowered from +14db to maintain 2:1 signal to noise ratio

Results: Accept Reject Info PSI examination S/N N-32389-1 FC 09-01, 09-05

Percent Of Coverage Obtained > 90%: No - 87.7% Reviewed Previous Data: No

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Dean, Steven	II-N	<i>[Signature]</i>	11/4/2009	<i>[Signature]</i>		7/19/11
Examiner	Level	Signature	Date	Site Review	Signature	Date
N/A	N/A					
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			<i>[Signature]</i>		7/20/11

ATTACHMENT A
 PAGE 145 OF 162

Ultrasonic Indication Report

Site/Unit: Oconee 10 Procedure: NDE-3630 Outage No.: N/A
 Summary No.: WJ-35 Procedure Rev.: 1 Report No.: BOP-UT-09-119
 Workscope: PSI Work Order No.: 01889357 Page: 2 of 4


Search Unit Angle: 70
 Wo Location: Centerline of Weld
 Lo Location: 8.11.1

Piping Welds
 Ferritic Vessels $\geq 2" T$
 Other /vessels $< 2" T$

MP	Metal Path	Wmax	Distance From Wo To S.U. At Maximum Response
RBR	Remaining Back Reflection	W1	Distance From Wo At Of Max (Forward)
L	Distance From Datum	W2	Distance From Wo At Of Max (Forward)

Comments: Weld WJ-35

SIN N-32389-1



Angle	Indication No.	% Of DAC	W Max		Forward Of Max		Backward Of Max		L1 Of Max	L Max	L2 Of Max	RBR Amp	Remarks
			W	MP	W1	MP	W2	MP					
81	1-48	100	1.2	2.30	N/A	N/A	N/A	N/A	360°	0-3"	INT	N/A	Root Geometry
82	2-45	100	0.9	1.25	N/A	N/A	N/A	N/A	360°	0-3"	INT	N/A	Root Geometry
82	3-45L	80	0.9	1.25	N/A	N/A	N/A	N/A	360°	0-3"	INT	N/A	Root Geometry

Examiner: <u>Dean, Steven</u>	Level: <u>II-N</u>	Signature: <i>[Signature]</i>	Date: <u>11/4/2009</u>	Reviewer: <u>Sanjiv Mox</u>	Signature: <i>[Signature]</i>	Date: <u>12-8-09</u>
Examiner: <u>Ortebel, David M.</u>	Level: <u>II-N</u>	Signature: <i>[Signature]</i>	Date: <u>11/4/2009</u>	Site Review: <u>Wmory C Ritchie Slaughter</u>	Signature: <i>[Signature]</i>	Date: <u>4/27/11</u>
Other: <u>N/A</u>	Level: <u>N/A</u>	Signature: <i>[Signature]</i>	Date: <u></u>	ANII Review: <u>Wmory C Ritchie Slaughter</u>	Signature: <i>[Signature]</i>	Date: <u>4/27/11</u>

ATTACHMENT A
PAGE 146 OF 162

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: <u>WJ-35</u>	Item No: <u>BOP-UT-09-119</u>	remarks:
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2	BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw
FROM L <u>0+3"</u> to L <u>0-3"</u>	INCHES FROM W0 <u>CL+1.1</u> to <u>Beyond</u>	Due to nozzle.
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other <u>70</u>	FROM <u>0</u> DEG to <u>360</u> DEG	
<input type="checkbox"/> NO SCAN <input checked="" type="checkbox"/> LIMITED SCAN	SURFACE <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw
FROM L <u>N/A</u> to L <u>N/A</u>	INCHES FROM W0 <u>+0.6</u> to <u>+1.5</u>	Taper on chemical connector.
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other <u>70</u>	FROM <u>0</u> DEG to <u>360</u> DEG	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2	BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw
FROM L _____ to L _____	INCHES FROM W0 _____ to _____	
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____	FROM _____ DEG to _____ DEG	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2	BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw
FROM L _____ to L _____	INCHES FROM W0 _____ to _____	Sketch(s) attached
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____	FROM _____ DEG to _____ DEG	<input checked="" type="checkbox"/> yes <input type="checkbox"/> No
Prepared By: <u>Steve Dean</u>	Level: <u>II</u> Date: <u>11/04/09</u>	Sheet <u>3</u> of <u>4</u>
Reviewed By: <u>[Signature]</u>	Date: <u>12-5-09</u> Authorized Inspector: <u>[Signature]</u>	Date: <u>4/27/11</u>

ATTACHMENT A
PAGE 147 OF 162

Supplemental Report

Report No.: BOP-UT-09-119

Page: 4 of 4

Summary No.: WJ-35

Examiner: Dean, Steven

Level: I-N

Reviewer: Sam Moe

Date: 12-2-09

Examiner: Griebel, David M.

Level: I-N

Site Review: None

Date: 4/27/11


Other: N/A

Level: N/A

ANII Review: None

Date: 4/27/11

Comments: Weld WJ-35
Ind. 2, 1, 2 & 3 are Root Geometry



ATTACHMENT A
PAGE 149 OF 162

Let Down Cooler - Chemical Connector to Channel Body

% Coverage Calculations

Weld No. : WJ-35

$\varnothing = 8.625"$

$t = 0.875"$

Weld Length = 27.1"

Total Inspection Area = 2.28 sq. in.

% Length Limited due to nozzle = $6" / 27.1" \times 100 = 22.1\%$

Aggregate Coverage Calculation

Axial Scans

22.1% of length x 98.5% of the volume of length / $100 = 21.3\%$

77.9% of length x 97.4% of the volume of length / $100 = 75.9\%$

Aggregate coverage Axial scans = $21.1 + 75.9 = 97.2\%$

Circ. Scans

100% of length x 78.1% of the volume of length / $100 = 78.1\%$


Total = $(97.2 + 78.1) / 2 = 87.7\%$ Aggregate Coverage

Inspector / Date: Rob. Huff 11-4-09 Page 1 of 5

Letdown Cooler Chemical Connector to Channel Body Total Exam Area

Weld No. : WJ-35

Item No. : N/A



Scale: 1" = 1"


ATTACHMENT A
Page 150 of 162
2 of 5


Letdown Cooler Chemical Connector to Channel Body Area Examined - Axial Scans

Weld No. : WJ-35

Item No. : N/A

 = Area Not Examined = $0.05 + 0.01 = 0.06$ sq. in.

 = Area Examined = $2.28 - 0.06 / 2.28 \times 100 = 97.4\%$




Scale: 1" = 1"


ATTACHMENT A
page 151 of 162
3 of 5


Letdown Cooler Chemical Connector to Channel Body Area Examined @ Nozzle - Axial Scans

Weld No. : WJ-35

Item No. : N/A

 = Area Not Examined = $0.05 + 0.01 + 0.02 = 0.08$ sq. in.

 = Area Examined = $2.28 - 0.08 / 2.28 \times 100 = 96.5\%$




*ATTACHMENT A
page 152 of 162
4 of 5*


Letdown Cooler Chemical Connector to Channel Body Area Examined - Circ. Scan

Weld No. : WJ-35

Item No. : N/A

 = Area Not Examined = 0.5 sq. in.

 = Area Examined = $2.28 - 0.5 / 2.28 \times 100 = 78.1\%$



Scale: 1" = 1"

ATTACHMENT A
page 153 of 162
5 of 5



UT Vessel Examination

Site/Unit: Ozonee / 0 Procedure: NDE-3630 Outage No.: N/A
 Summary No.: WJ-38 Procedure Rev.: 1 Report No.: BOP-UT-09-120
 Workscope: PSI Work Order No.: 01889357 Page: 1 of 2

Code: 1998/2000A Cat./Item: B-D/B3.160 Location: N/A
 Drawing No.: NU-D-1148-1 Rev. A Description: Nozzle to channel body
 System ID: N/A
 Component ID: WJ-38 Size/Length: N/A Thickness/Diameter: .875/3.0/SS
 Limitations: Yes - See supplemental sheet Start Time: 1012 Finish Time: 1034

Examination Surface: Inside Outside Surface Condition: AS GROUND
 Lo Location: 9.1.1.1 Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 08125
 Temp. Tool Mfg.: FISHER Serial No.: MCNDE32770 Surface Temp.: 70 °F

Cal. Report No.: DMA 11-14-09 CAL-09-458, 459, 460, 461 & 462

Angle Used	0	45	45T	80	80T	70L
Scanning dB		43.0	61.7	60.2	55.0	48.0

Indication(s): Yes | No Scan Coverage: Upstream Downstream CW CCW

Comments:
Scanning db lowered from +14db to maintain 2:1 signal to noise ratio

Results: Accept Reject Info PSI examination SIN 32389-1 FC 09-01, 09-05
 Percent Of Coverage Obtained > 90%: No - ~~100%~~ Reviewed Previous Data: No 9/4/27/11

Examiner	Level	U-N	Signature	Date	Reviewed	Signature	Date
Dean, Steven			<i>[Signature]</i>	11/4/2009	<i>[Signature]</i>		12-8-09
Examiner	Level	U-N	Signature	Date	Site Review	Signature	Date
Griebel, David M.			<i>[Signature]</i>	11/4/2009			
Other	Level	N/A	Signature	Date	ANII Review	Signature	Date
N/A			<i>[Signature]</i>		<i>[Signature]</i>		4/27/11

ATTACHMENT A
 PAGE 154 OF 162

DUKE POWER COMPANY

ISI LIMITATION REPORT

Component/Weld ID: <u>WJ-38</u>		Item No: <u>BOP-UT-09-120</u>		remarks:
<input checked="" type="checkbox"/> NO SCAN	SURFACE		BEAM DIRECTION	
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1	<input checked="" type="checkbox"/> 2	<input checked="" type="checkbox"/> 1	<input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw
FROM L <u>N/A</u>	to L <u>N/A</u>	INCHES FROM W0 <u>Toe</u>		to <u>Beyond</u>
ANGLE: <input type="checkbox"/> 0	<input checked="" type="checkbox"/> 45	<input checked="" type="checkbox"/> 60	other <u>70</u>	FROM <u>0</u> DEG to <u>360</u> DEG
<input type="checkbox"/> NO SCAN	SURFACE		BEAM DIRECTION	
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 1	<input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw
FROM L _____	to L _____	INCHES FROM W0 _____		to _____
ANGLE: <input type="checkbox"/> 0	<input type="checkbox"/> 45	<input type="checkbox"/> 60	other _____	FROM _____ DEG to _____ DEG
<input type="checkbox"/> NO SCAN	SURFACE		BEAM DIRECTION	
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 1	<input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw
FROM L _____	to L _____	INCHES FROM W0 _____		to _____
ANGLE: <input type="checkbox"/> 0	<input type="checkbox"/> 45	<input type="checkbox"/> 60	other _____	FROM _____ DEG to _____ DEG
<input type="checkbox"/> NO SCAN	SURFACE		BEAM DIRECTION	
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 1	<input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw
FROM L _____	to L _____	INCHES FROM W0 _____		to _____
ANGLE: <input type="checkbox"/> 0	<input type="checkbox"/> 45	<input type="checkbox"/> 60	other _____	FROM _____ DEG to _____ DEG
				Sketch(s) attached
				<input type="checkbox"/> yes <input type="checkbox"/> No
Prepared By: <u>Steve Dean</u>	Level: <u>II</u>	Date: <u>11/04/09</u>	Sheet <u>2</u> of <u>2</u>	
Reviewed By: <u>Gay Moore</u>	Date: <u>12-5-09</u>	Authorized Inspector: <u>Nancy Britcher-Slaughter</u>	Date: <u>4/27/11</u>	

ATTACHMENT A
PAGE 155 OF 162

Letdown Cooler Nozzle to Channel Body		
Weld No. WJ-36		
Base Material Coverage		
Scan	Radius View	Non-Radius View
Axial	68.2%	52.7%
Circ	65.2%	54.4%
Aggregate @ $68.2 + 52.7 + 65.2 + 54.4 = 240.5/4 = 60.1\%$		
Weld Material Coverage		
Scan	Radius View	Non-Radius View
Axial-S1	45.9%	26.0%
Axial-S2	0.0%	0.0%
Circ-S2	94.1%	66.3%
Circ-S2	94.1%	66.3%
Aggregate @ $45.9 + 26.0 + 0.0 + 0.0 + 94.1 + 66.3 + 94.1 + 66.3 = 392.7/8 = 49.1\%$		
Total Aggregate @ $60.1 + 49.1 = 109.2/2 = 54.6\%$		

Attachment A
page 156 of 162


Level III Rod Sheffield
Date 11-4-09

Letdown Cooler Nozzle to Channel Body

Weld No. : WLT 36

Item No. : N/A

Total Exam Area = 2.72 sq. in.



Scale: 1" = 1"

ATTACHMENT A
PAGE 159 OF 162

INSPECTOR/DATE: David L. Jones III / 11/4/09

Attachment 2 of 7

Letdown Cooler Nozzle to Channel Body Area Examined - Circ. Scans

Weld No. : WJ-36


Item No. : N/A



Area not Examined = $0.81 + 0.40 = 1.21$ sq. in.



Area Examined = $2.72 - 1.21 / 2.72 \times 100 = 55.5\%$



ATTACHMENT A
PAGE 158 OF 162

INSPECTOR: David K. B. III / 11/4/09

Attachment 3 of 7

Letdown Cooler Nozzle to Channel Body Area Examined - Axial Scans

Weld No. : WT-36


Item No. : N/A



Area not Examined = 1.49 sq. in.



Area Examined = $2.72 - 1.49 / 2.72 \times 100 = 45.2\%$



Scale: 1" = 1"

ATTACHMENT A
PAGE 159 OF 162

INSPECTOR: David R. III / 11/4/09


Attachment 4 of 7

Letdown Cooler Nozzle to Channel Body (Radius View)

Weld No. : WJ-36

Item No. : DA

Total Exam Area = 2.30 sq. in.



Scale: 1" = 1"


ATTACHMENT A
PAGE 160 OF 162

INSPECTOR: David K. B. III / 11/4/09 Attachment 5 of 7


Letdown Cooler Nozzle to Channel Body (Radius View , Area Examined - Axial Scans

Veld No.: WT-36


Item No.: N/A



Area not Examined = 0.92 sq. in.



Area Examined = $2.30 - 0.92 / 2.30 \times 100 = 60.0\%$



INSP/DATE: David K. B III / 11/21/09

Attachment 6 of 7

ATTACHMENT A
PAGE 161 OF 162

Setdown Cooler Nozzle to Channel Body (Radius View)

Area Examined - Circ. Scans

Weld No.: WT-36


Item No.: 2/A



Area not Examined = 0.42 sq. in.



Area Examined = $2.30 - 0.42 / 2.30 \times 100 = 81.7\%$



INSP/DATE: David K. Z III / 11/4/09

Attachment 7 of 7

ATTACHMENT A
PAGE 162 OF 162