

ELECTRIC OPERATOR ORDERING DATA SHEET

CUSTOMER: STONE & WEBSTER PROJECT: NIAGARA MOHAWK SHEET 1 OF 1

AN ORDER: P2-7026 ITEMS: 38 QTY: 4

NOS: 2 CCP-MOV 14A, 14B, 18A, 18B

PER SPEC. NMP2-P304 R REV. PREVIOUSLY FORWARDED  ATTACHED  TO FOLLOW

VALVE DESC.: 12" 150# B.B. GATE C/S  
 NUCL. CLASS: 3 ORIFICE DIA: 11.125  
 STEM DIA.: 2 THD., 1/4 P., 1/4 L.  
 STEM LIFT: 12 1/8 STEM SPEED: 10.8 IN/MIN  
 OPER. DR DESIGN 200 MAX. DIEF. 100  
 PRESS. 250 PSIG PRESS. 150 PSIG  
 MAX. TEMP: 160 °; POSS. VOLT. DROP: 20%  
 OPER. CURRENT: 575 VOLT., 3 PH., 60 CYCLES  
 OPERATOR: SMB 0 MOTOR 25 FT/LBS  
 MOTOR RPM: 1700, CONTROL VOLTAGE: 120/1/60  
 DUTY MINS.: 5 , 15 , 30 , CONT.   
 TOR INSULATION: CLASS B , CLASS H   
 CLASS RAD H , C/CHAMB CLASS   
 MOTOR HEATER , MOTOR DRAIN   
 LIM. SW. HEATER , LIM. SW. DRAIN   
 2-TGLS , 4-TGLS , LARGE L.S. COVER   
 20 PT. T.B , 30 PT. T.B , 40 PT. T.B   
 M.D.P.I.  SLIDE WIRE TRANSMITTER   
 SPECIAL WIRE MARKERS: 1  
 SPECIAL PAINT/FINISH: \_\_\_\_\_  
 UNIT TO HAVE SELF-LOCKING GEAR RATIO   
 DRIVE NUT WILL BE THREADED BY VELAN

STEM THRUST : STEM TORQUE:  
9776 LBS. : 152 FT/LI  
 O/A RATIO : MOTOR CALC. TORQUE  
39.11 : 10.7 FT/LI  
 TORQUE SPRING NO.: 60-600-0017-1  
 TORQUE SWITCH SETTINGS:  
 NORMAL: 1 3/4 MAX.: 3 3/16 FAIL: —  
 STALLED TORQUE: 749 FT/LI  
 HANDWHEEL DIA.: 12 "RATIO: 21.1  
 ADDED HANDWHEEL SPUR GEAR: —  
 VALVE MAX TORQUE: 2052 FT/LI  
 MAX. ALLOW. H'WHEEL TORQUE 326 FT/LI  
 VALVE SURVIVES STALLED TORQUE: YES

SPECIAL REQUIREMENTS

- 1-Furnish certified sepias & prin for approval as follows: 2 sepi and 5 prints.
- 2-All Dugs. must show Velan Order No. as well as Tag Nos.
- 3-SEE ATTACHED QUOTE FOR ADDITIONAL DETAILS

BB1901180017-05

	0 REV.	1	2	3	4	5	6	7
Compiled By: <u>LW</u>								
Approved By: <u>RF S.S. 70</u>								
Rev. By: <u>JT 80574</u>								



Plan No.: P2-7026 Items: 38 Velen Dug. No.:  
 Live Desc.: 12 " 150 lbs. R.B. Gate S/S FORGED NL

Line Press.: 100 PSI  
 Drif. Dia.: 1.125 Drif. Area: 97.16 ΔP @ Temp.: 150 PSI @ 160 °F  
 Stem Dia.: 2 Stem Area: 3.14 Thd: 1/4 - 1/4 L. Lift = 12 7/8"

Stem Thrust - O.A. x ΔP x Seat Fact. = 97.16 x 150 x 0.3 = 4372  
 Line Press. x S.A. = 3.14 x 100 = 314  
 Packing Friction Load = 5090  
 Total Stem Thrust = 9776

Stem Torque = Stem Thrust x Thd. Fact. = 9776 x 0.01552 = 152

O/A or Unit Ratio = Motor Design R.P.M. / Stem Speed in./min. = 1700 / 10.861 = 39.11  
 Thread Lead = 1/4

Motor Calc. Torque (100% VOLTAGE) = Stem Torque / 152 = 10.7

Pull out eff. x appl. fact. x O/A ratio = 0.4 x 0.9 x 39.11 = 14.1

Motor calc. Torque @ Reduced Voltage = 10.7 / 0.64 = 16.85

N.B. IF DC supply, do not Sq. % V. (% Volt.)<sup>2</sup>

Called Torque = Mot. Stall Torque x St. Eff. % x O/A Ratio = 29 x 0.55 x 39.11 = 624\*

624 x 1.2 = 749 FE. Lbs. 2 x Stem Torque = 2 x 152 = 48

H/W Pull = H/W Ratio x Unit Eff. x H/W Dia. = 21.1 x 0.3 x 1 = 6.33

Max. Torq. Sw. Setting = Mot. Torq. x P/O Eff. x App. Factor x O/A Ratio = 25 x 0.4 x 0.9 x 39.11 = 35.2

Max. H/Wheel Torque = H'W<sup>PULL</sup> x MAX. Torq. x H'W Rad. (ft) / Stem Torque = 48 x 2062 / 152 = 326

Operating Time = (60 x Lift) / Stem Speed = 6820 / 152 = 45 Sec's.


SMA 0 Operator with 25 ft. # Motor. Max. Thrust = 2400

Max. Stem Torque = 500 # O/A Ratio Range = 26.14 - 150.8

H/W Ratio = 21.1 : 1 + Add gear - : 1 Max. Stem Dia.: 2 3/8"

Current Supply 575 Volts 3PH 60CY Must Operate at 80 % Voltage

	0	1	2	3	4	5	6	7
Conciled By: APR 10, 1978								
Approved By: Rfe 18478								
Ind. Rev. By: [Signature]								




VELAN ORDER: P2-7026-N

VALVE ITEM: 38

PAGE 3 OF 3

(A) Stall Thrust of Motor Operator @ 110% Volt =  
Stall Torque of Operator @ 110% Volt ÷ Stem Factor =  
...749... ÷ 0.01552... = 48260 lbs. (thrus)

(B) Allowable Thrust on Valve (Before Failure) =  
Valve Max. Torque ÷ Stem Factor =  
...2062... ÷ 0.01552... = 132861 lbs. (thrus)



STONE & WEBSTER ENGINEERING CORPORATION  
 3 EXECUTIVE CAMPUS, P. O. BOX 5200  
 CHERRY HILL, N. J. 08034

DATE	January 19, 1982
J. O. NO.	12177
P. O. NO.	NMP2-P801H
LTR. NO.	742, 842
REF.	File P801H (enc)

VIA

DEAR SIRs:

THE FOLLOWING ARE  ATTACHED;  SENT SEPARATELY:

TO

Mr. C. D. Terry  
 Manager - Project Engineering  
 Niagara Mohawk Power Corporation  
 300 Erie Boulevard West  
 Syracuse, New York 13202

<u>1</u> COPIES	PRINTS	REPRODUCIBLES	MICROFILM APERTURE CARDS
EACH OF			
<input type="checkbox"/> DRAWINGS	<input checked="" type="checkbox"/> SPECIFICATIONS	<input type="checkbox"/> DOCUMENTS	<input type="checkbox"/> NOTES OF CONFERENCE

STATUS		PLEASE NOTE	SENT FOR YOUR	
<input type="checkbox"/> FINAL	<input checked="" type="checkbox"/> APPROVED	<input type="checkbox"/> REVISIONS	<input type="checkbox"/> APPROVAL	<input type="checkbox"/> COMMENT
<input type="checkbox"/> PRELIMINARY	<input type="checkbox"/> APPROVED AS REVISED AS DEFINED IN SPECIFICATION	<input type="checkbox"/> ADDITIONS	<input checked="" type="checkbox"/> USE	<input checked="" type="checkbox"/> INFORMATION
<input type="checkbox"/> NO COMMENT	<input type="checkbox"/> UNACCEPTABLE	<input type="checkbox"/> COMMENTS	<input checked="" type="checkbox"/> FILES	<input type="checkbox"/> CONCURRENCE
<input type="checkbox"/> SUGGESTIONS AS NOTED	<input type="checkbox"/>		<input type="checkbox"/>	

**YOUR ATTENTION IS DIRECTED TO THE FOLLOWING:**

RELEASED FOR:  FABRICATION  PURCHASE OF NECESSARY MATERIALS.

PLEASE REVISE AND SUBMIT \_\_\_\_\_ PRINTS \_\_\_\_\_ REPRODUCIBLES \_\_\_\_\_ MICROFILM APERTURE CARDS.

PLEASE SUBMIT \_\_\_\_\_ PRINTS \_\_\_\_\_ REPRODUCIBLES \_\_\_\_\_ MICROFILM APERTURE CARDS OF  DOCUMENTS  DRAWINGS  SHOP DETAIL

PLEASE RETURN ONE COPY EACH OF THIS MATERIAL BEARING YOUR APPROVAL OR COMMENTS.

PLEASE ACKNOWLEDGE RECEIPT OF THIS MATERIAL BY SIGNING AND RETURNING THE ENCLOSED COPY OF THIS FORM.

WE TRUST THAT THESE NOTES ARE IN ACCORDANCE WITH YOUR UNDERSTANDING; IF NOT, PLEASE ADVISE US.

**IMPORTANT** SHOULD ANY REVISION TO DOCUMENTS OR DRAWINGS RETURNED HERewith INVOLVE A PRICE INCREASE, THE SUPPLIER MUST NOTIFY STONE & WEBSTER PURCHASING DEPARTMENT WITHIN TEN (10) DAYS EVEN THOUGH A DEFINITE ESTIMATE CANNOT BE GIVEN AT THE TIME. OTHERWISE, THE PURCHASER WILL CONSIDER THE REVISIONS MADE WITHOUT COST.

ENGINEERING SERVICES SCOPE OF WORK NO. NMP2-P801H  
 DYNAMIC TESTING OF MOTOR OPERATORS  
 NINE MILE POINT NUCLEAR STATION - UNIT 2

Enclosed please find one (1) "Approved" copy of Addendum 2 to Engineering Services Scope of Work (ESSOW) No. NMP2-P801H, "Dynamic Testing of Motor Operators", dated January 19, 1982, for your use, files, and information.

Very truly yours,

**ORIGINAL  
 SIGNED FOR**  
 C. C. Zapple  
 Project Engineer

PS:MK

Copies to: CD Terry (enc)  
 RANorman (enc)  
 TELempges (2-enc)

PStipcevich (enc)  
 KMWhite (enc)  
 Document Control Systems/Site (enc)  
 Document Control/CHOC  
 ADColeman  
 MKrautheim





NOTED JAN 19 1982 M. NELMS

Copy to:

SFManno(encl)	MADurka	ABlum(encl)	Job Book G51(encl)
WARumberger(encl)	SMFeldman	RABerry	P801H(encl)
CDTerry(encl)	SCChow	LFFendo	WPCS7/6522/XXX
ERKlein(encl)	CCZappile	JJPanchison	NAMuni(encl)
DLPracht(encl)	WPHennessy	RJMcMorland	
	CECrocker	JMGwinn(encl) (Boston)	
	PStipceovich(encl)	GHEast (Boston)	
	AWChan	ARJoyce (Boston)	
	RPiha	JJSorrentino (Boston)	
		JRHall (Boston)	

Mr. C. D. Terry  
 Manager - Project Engineering  
 Niagara Mohawk Power Corporation  
 300 Erie Boulevard West  
 Syracuse, NY 13202

January 19, 1982  
 J.O. No. 12177  
 9M2-11,609

Dear Mr. Terry:

PURCHASE ORDER NO. NMP2-P801H  
 DYNAMIC TESTING OF MOTOR OPERATORS  
NINE MILE POINT NUCLEAR STATION - UNIT 2

This letter summarizes the results of the supplementary Phase I tests of two Limitorque operators performed between November 9, 1981, and December 22, 1981. A detailed test report will be issued by National Technical Systems during the last week of January 1982.

Summary of Test Results

1. Limitorque Operator SHB-0-25

Successfully completed the following tests without chatter exceeding 2 milliseconds:

- a. Vibration aging (paragraph 3.1\*)
- b. Random multifrequency biaxial test (paragraph 3.2) with ZPA > 12 g's
- c. Single axis sine beat tests (paragraph 3.3) up to 6 g's
- d. Fragility tests (paragraph 3.4) up to 11 g's.

Fourteen g's with chatter less than 5 milliseconds

\*All referenced paragraphs from ESSOW No. NMP2-P801H, Attachment 1



CDT

2.

2. Limitorque Operator SMB-000-5

Successfully completed the following tests without chatter exceeding 2 milliseconds:

- a. Vibration aging
- b. Random multifrequency biaxial test with ZPA  $\gt$  6 g's
- c. Single axis sine beat tests up to 6 g's

Note: At 100 Hz, chatter exceeding 2 milliseconds but below 5 milliseconds was observed throughout this test.

- d. Fragility tests up to 14 g's

Notes: (1) Chatter exceeding 2 milliseconds; but below 5 milliseconds was observed throughout this series of tests.

- (2) At 8 g's, between 15.9 Hz and 25 Hz, torque switch chatter resulted in incomplete strokes. Limitorque representative corrected this problem by adjusting the contactor gap in accordance with Attachment 5 of the specification.

Please note that the maximum attainable accelerations, due to test table limitations during the sine beat tests, ranged from 8 g's at 5.0 Hz to 12-14 g's at 20 Hz. Also, during the course of the test, the following significant changes to the specification were made:

1. ZPA of the RRS for Operator SMB-000-5 was lowered from 10 g's to 6g's in order to prevent possible damage to the operator.
2. The number of sine beats for the fragility tests at frequencies 10, 12.6, and 15.9 Hz was reduced from 20 to 6. This change is acceptable, consistent with paragraph 3.3.1, and resulted in a considerable time saving.



January 19, 1982  
9M2-11,609

CDT

3.

A copy of the specification addendum, reflecting these and other minor changes, is enclosed. For additional information, please contact Mr. N. A. Muni at Telephone No. (609) 482-3148.

Very truly yours,

**ORIGINAL****SIGNED FOR**C. C. Zappie  
Project Engineer

Enclosure

EM:SRJ

xc: SFHanno(encl)  
WARumberger(encl)  
CDTerry(encl)  
ERKlein(encl)  
DLPracht(encl)

JBDrab(Limitorque Corporation)(encl)  
JJEenders(Limitorque Corporation)  
SIsbitsky(Velan Engineering Company)  
JStrohm(Bechtel Power Corporation)(encl)  
RTjernlund(Sargent & Lundy)  
JPEtzweiler(Long Island Lighting Company)(encl)  
JMollick(Philadelphia Electric Company)(encl)  
MRahman(Gulf States Utilities Company)(encl)  
JSullivan(Washington Public Power Supply System)  
GRCrane(Commonwealth Edison Company)  
DJFrederic(Cincinnati Gas & Electric Company)



Copyright 1982  
 Stone & Webster Engineering Corporation  
 Cherry Hill Operations Center  
 Cherry Hill, New Jersey  
 I  
 NUCLEAR SAFETY RELATED

1.5  
 1.6  
 1.7  
 1.8  
 1.9  
 1.10

J.O. No. 12177  
 Spec. No. NMP2-P801H

Addendum 2 1.13  
 Page A2-1 of 5 1.14

January 19, 1982

Addendum 2  
 Specification for

1.16  
 1.17

ENGINEERING SERVICES SCOPE OF WORK  
FOR  
DYNAMIC TESTING OF MOTOR OPERATORS

1.19  
 1.20  
 1.21

Nine Mile Point Nuclear Station - Unit 2  
 Niagara Mohawk Power Corporation  
 Scriba, New York

1.23  
 1.24  
 1.25

Seller:  
 National Technical Services, Incorporated  
 9551 Canoga Avenue  
 Chatsworth, California

1.27  
 1.28  
 1.29  
 1.30

APPROVAL

1.32

	<u>SIGNATURE</u>	<u>DATE</u>	
Preparer:	<u>Phil Stasone</u>	<u>1/18/82</u>	1.34
Specialist:	<u>Bob White</u>	<u>1/18/82</u>	1.35
Lead Engineer:	<u>Mark G. Jones</u>	<u>1/18/82</u>	1.36
Engineering Assurance:	<u>Alfredo R. Pozzi</u>	<u>1/18/82</u>	1.37
Project Engineer:	<u>C.E. Cook</u>	<u>1/19/82</u>	1.38
			1.39

This Addendum 2 includes changes to the Engineering Service 1.42  
 Scope of Work dated October 29, 1981, agreed to by the 1.43  
 Seller and the Engineers. 1.44





<u>Item</u>	<u>Change to Specification</u>	
1	<u>Page:</u> 5	1.55
	<u>Delete:</u> Line 5.44	1.56
	<u>Reason:</u> Specification change	1.57
2	<u>Page:</u> 2, Attachment 1, line 1.10/63	2.2
	<u>Add:</u> - The number of accelerometers may be reduced to 12 for the fragility test. -	2.3 2.4 2.5
	<u>Reason:</u> Specification change	2.6
3	<u>Page:</u> 3, Attachment 1, line 1.10/111	2.9
	<u>Delete:</u> - During stroking, the sine sweep motion is to be replaced with a "white noise" vibration input in frequency range 5 to 200 Hz, superimposed over a 60 Hz sine wave input, with a maximum combined acceleration of 0.75 g. At the end of the operational period, the sine sweep test is to be resumed. -	2.10 2.12 2.13 2.14
	<u>Reason:</u> Specification change	2.16
4	<u>Page:</u> 4, Attachment 1, line 1.10/141	2.19
	<u>Delete:</u> - corresponding -	2.20
	<u>Reason:</u> Specification change	2.21
5	<u>Page:</u> 5, Attachment 1, line 1.10/155	2.24
	<u>Delete:</u> - 1.5 seconds or greater as necessary -	2.25 2.26
	<u>Add:</u> - sufficient -	2.27
	<u>Reason:</u> Specification change	2.28
6	<u>Page:</u> 7, Attachment 1, line 1.10/277	2.31
	<u>Delete:</u> - 1.5 seconds or greater as necessary -	2.32 2.33
	<u>Add:</u> - sufficient -	2.34
	<u>Reason:</u> Specification change	2.35




<u>Item</u>	<u>Change to Specification</u>			
7	<u>Page:</u>	8, Attachment 1, 1.10/293		2.38
		through 1.10/295		2.39
	<u>Delete:</u>			2.40
- Test Frequency	No. of Beats	Oscillations per Beat		2.42
10.0	20	15		2.44
12.6	20	15		2.45
15.9	20	15 -		2.46
	<u>Add:</u>			2.48
- Test Frequency	No. of Beats	Oscillations per Beat		2.50
10.0	6	15		2.52
12.6	6	15		2.53
15.9	6	15 -		2.54
	<u>Reason:</u>	Specification change		2.56
8	<u>Pages:</u>	9 and 10, Attachment 1		3.1
	<u>Delete:</u>	Existing Figures 1 and 2 of Attachment 1		3.2 3.3
	<u>Add:</u>	Attached Figures 1 (Page A2-4 of 5) and 2 (Page A2-5 of 5)		3.4 3.5
	<u>Reason:</u>	Specification change		3.6
9	<u>Page:</u>	Attachment 6		3.10
	<u>Delete:</u>			3.11
- Operator Mounting Screw Torque				3.13
<u>SMB-000-5:</u>	5/16 inch screw	16.5 ft-lbs -		3.14
	<u>Add:</u>			3.15
- Operator Mounting Screw Torque				3.17
<u>SMB-000-5:</u>	5/16 inch screw	25 ft-lbs unlubricated -		3.18
	<u>Reason:</u>	Specification change		3.19



FIGURE 1

REQUIRED RESPONSE SPECTRA FOR OPERATOR MODEL SMB+0-25  
HORIZONTAL AND VERTICAL DIRECTIONS  
2% DAMPING




46 7403  
10

KE LOGARITHMIC 3 X 3 CYCLES  
KEUFFEL & ESSER CO. MAX 1000

W49



FIGURE 2







STONE & WEBSTER ENGINEERING CORPORATION

3 EXECUTIVE CAMPUS, P. O. BOX 5200  
CHERRY HILL, N. J. 08034

DATE	June 10, 1982
J. O. NO.	12177
P. O. NO.	NMP2-P801H
LTR. NO.	T-47, 622
REF.	FILE P801H (enc)

VIA

National Technical Systems Inc.  
26525 Golden Valley Road  
Saugus, California 91350

DEAR SIRs:

THE FOLLOWING ARE  ATTACHED;  SENT SEPARATELY:

Attn: Ms. Terry Hampton

<u>1</u>	COPIES	PRINTS	REPRODUCIBLES	MICROFILM APERTURE CARDS
EACH OF				
<input type="checkbox"/>	DRAWINGS	<input type="checkbox"/>	SPECIFICATIONS	
<input checked="" type="checkbox"/>	DOCUMENTS	<input type="checkbox"/>	NOTES OF CONFERENCE	

STATUS		PLEASE NOTE	SENT FOR YOUR	
<input type="checkbox"/> FINAL	<input checked="" type="checkbox"/> APPROVED	<input type="checkbox"/> REVISIONS	<input type="checkbox"/> APPROVAL	<input type="checkbox"/> COMMENT
<input type="checkbox"/> PRELIMINARY	<input type="checkbox"/> APPROVED AS REVISED	<input type="checkbox"/> ADDITIONS	<input checked="" type="checkbox"/> USE	<input checked="" type="checkbox"/> INFORMATION
<input type="checkbox"/> NO COMMENT	<input type="checkbox"/> UNACCEPTABLE	<input type="checkbox"/> COMMENTS	<input checked="" type="checkbox"/> FILES	<input type="checkbox"/> CONCURRENCE
<input type="checkbox"/> SUGGESTIONS AS NOTED	<input type="checkbox"/>		<input type="checkbox"/>	

YOUR ATTENTION IS DIRECTED TO THE FOLLOWING:

RELEASED FOR:  FABRICATION  PURCHASE OF NECESSARY MATERIALS

PLEASE REVISE AND SUBMIT \_\_\_\_\_ PRINTS \_\_\_\_\_ REPRODUCIBLES \_\_\_\_\_ MICROFILM APERTURE CARDS.

PLEASE SUBMIT \_\_\_\_\_ PRINTS \_\_\_\_\_ REPRODUCIBLES \_\_\_\_\_ MICROFILM APERTURE CARDS OF  DOCUMENTS  DRAWINGS  SHOP DETAIL

PLEASE RETURN ONE COPY EACH OF THIS MATERIAL BEARING YOUR APPROVAL OR COMMENTS.

PLEASE ACKNOWLEDGE RECEIPT OF THIS MATERIAL BY SIGNING AND RETURNING THE ENCLOSED COPY OF THIS FORM.

WE TRUST THAT THESE NOTES ARE IN ACCORDANCE WITH YOUR UNDERSTANDING; IF NOT, PLEASE ADVISE US.

**IMPORTANT** SHOULD ANY REVISION TO DOCUMENTS OR DRAWINGS RETURNED HERewith INVOLVE A PRICE INCREASE, THE SUPPLIER MUST NOTIFY STONE & WEBSTER PURCHASING DEPARTMENT WITHIN TEN (10) DAYS EVEN THOUGH A DEFINITE ESTIMATE CANNOT BE GIVEN AT THE TIME. OTHERWISE, THE PURCHASER WILL CONSIDER THE REVISIONS MADE WITHOUT COST.

PURCHASE ORDER NO. NMP2-P801H  
DYNAMIC TESTING OF MOTOR OPERATORS  
NINE MILE POINT NUCLEAR STATION-UNIT 2  
NIAGARA MOHAWK POWER CORPORATION

548-9291

Test Report

Rev. 2

5/25/82

Very truly yours,  
**ORIGINAL  
SIGNED FOR**

M. A. Durka  
Lead Mechanics Engineer

PS:JM

Copies to: RWHammelmann (enc)  
DLPracht (enc)  
MJCarrington (enc)

GMSchierberg/GLVolpe-3 245/5  
KMWhite  
Document Control Systems/Site (enc)  
Document Control/CHOC  
PStipcevich (enc)  
JMartin



**STONE & WEBSTER ENGINEERING CORPORATION**  
**REVIEW OF SUPPLIER'S TECHNICAL DOCUMENT**

▲ 5040.51B

PAGE 1 OF 1

SUPPLIER <b>NATIONAL TECHNICAL SYSTEMS</b>		P.O. NO. <b>P801H</b>	DOCUMENT TITLE <b>TEST REPORT</b>		DOC. ID. NO. <b>548-9291</b>	REV. <b>2</b>	DATE <b>5/25/82</b>
DATE RECEIVED <input type="checkbox"/> NEW SUBMITTAL <input checked="" type="checkbox"/> RESUBMITTAL		SPEC. NO. / DATE <b>P801H</b>	REV. <b>-</b>	ADDEN. <b>2</b>	SPEC. TITLE <b>DYNAMIC TESTING OF MOTOR OPERATORS</b>		
GOVERNING CODE(S) & DATE(S) <b>---</b>		SPECIAL REQUIREMENTS <b>---</b>			DWG REFERENCE(S) S & W SUPPLIER <b>---</b>		
SPECIALIST <b>A. CHAN</b>	PROJECT <b>NMPC</b>	J.O. NO. <b>12177</b>	RESPONSIBLE ENG <b>P. STIPCEVICH</b>	LOCATION <b>1B</b>	EXT. <b>3690</b>	DATE <b>6/7/82</b>	

COMMENTS:

**NATIONAL TECHNICAL SYSTEMS TEST REPORT #548-9291**

**REVISION 2, DATED 5/25/82 IS APPROVED.**

Stone & Webster Engineering Corporation	
<input checked="" type="checkbox"/>	APPROVED AS DEFINED IN THE SPECIFICATIONS
<input type="checkbox"/>	UNACCEPTABLE
<input type="checkbox"/>	APPROVED AS REVISED AS DEFINED IN THE SPEC.
<input type="checkbox"/>	REVIEWED
J.O. No.	<b>12177</b>
SPEC. No.	<b>P801H</b>
DATE	<b>6/8/82</b>
BY	<b>P. STIPCEVICH</b>

RESUBMITTAL REQUIRED  
 YES  NO

REVIEWER <b>P. STIPCEVICH</b>	DEPT./DIV. ENGINEERING <b>EQ, MECHANICS</b>	DATE <b>6/7/82</b>	LOCATION <b>1B</b>	EXTENSION <b>3640</b>
----------------------------------	--	-----------------------	-----------------------	--------------------------



REVISION SUMMARY

<u>Revision</u>	<u>Date</u>	<u>Page(s) Affected</u>	<u>Paragraph(s) Affected</u>
2	5-24-82	12	Paragraph 5.2.3 - Change Test Numbers 1 through 9; Under "Test Duration" column change "27" to "35"; Under "Observations" column add: "Report of Test 1", change "Repeat of Test 1" to "Repeat of Test 2", change "Repeat of Test 5 ..." to "Repeat of Test 6 ..."
2	5-24-82	D-1	Add Natural Frequencies Chart
2	5-24-82	D-1a	Renumber page
2	5-24-82	F-1 - F-29	Appendix F - Correct typo - "...@ 002 sec" to "...@.002 sec"
2	5-24-82	G-1 - G-36	Appendix G - Correct typo - "...@ 002 sec" to "...@.002 sec"
2	5-24-82	2	Paragraph 3.2 - Add "... response..."; 3.2A - Change "6 g's" to "6 g"; 3.2B - Change "12 g's" to "12 g"

These Revisions Reviewed and Approved By:

A. Froelich  
 for PUBLICATIONS MANAGER, Theresa Hampton

Date: 5/25/82

David P. Bame  
 PROJECT MANAGER, David P. Bame

Date: 5-25-82

Robert A. Ely  
 QUALITY ASSURANCE MANAGER, Robert A. Ely

Date: May 25, 1982

Stone & Webster Engineering Corporation	
<input checked="" type="checkbox"/>	APPROVED AS DEFINED IN THE SPECIFICATIONS
<input type="checkbox"/>	UNACCEPTABLE
<input type="checkbox"/>	APPROVED AS REVISED AS DEFINED IN THE SPEC
<input type="checkbox"/>	REVIEWED
J.O. No.	<u>12177</u>
SPEC. No.	<u>P801H</u>
DATE	<u>6/8/82</u>
BY	<u>P. STUBESKI</u>



2.0 REFERENCES

- 2.1 National Technical Systems Test Procedure Number 548-9291, Revision A, dated October 29, 1981.
- 2.2 Stone & Webster Engineering Corporation's Engineering Services Scope of Work for Dynamic Testing of Motor Operators, ESSOW Number NMP2-P801H and Addenda 1 and 2.

3.0 SUMMARY

3.1 VIBRATION AGING TEST

Limiter torque motor operators, types SMB-000-5 and SMB-0-25, were subjected to 90 minutes of vibration aging in each axis in accordance with IEEE-392-1980 and maintained performance consistent with pretest baseline measurements.

No chatter exceeding two milliseconds was recorded on the limit switch contacts.

3.2 RANDOM MULTIFREQUENCY BIAxIAL TEST

Operators, types SMB-000-5 and SMB-0-25, were subjected to a minimum of 105 seconds of random biaxial multifrequency input motion with a frequency content of 1 Hz to 100 Hz. These tests were performed in accordance with the requirements of Reference 2.2, for the 105 seconds, in two test orientations at the levels listed below. Typical response plots are shown in Figures 1, 2, and 3.

- A. Operator SMB-000-5 - minimum ZPA of 6 g
- B. Operator SMB-0-25 - minimum ZPA of 12 g

The performance of each operator was consistent with its pretest baseline values. No chatter exceeding two milliseconds was recorded on the limit switch contacts.





6.2.2.1 At approximately 27 seconds after the start of the test, the operator was observed to have come loose. The test was stopped immediately. Examination of the operator revealed that the operator mounting screws had come loose and that there was a considerable amount of localized deformation of the aluminum mounting plate under the bolt heads.

The Customer's representative determined that a combination of the small bearing area under the socket head mounting bolts and the low bearing capacity of the aluminum mounting plate had resulted in excessive deformation of the mounting plate under the bolt head, which in turn caused loosening of the bolts. In bearing area under the socket head mounting bolts and the low bearing capacity of the aluminum mounting plate had resulted in excessive deformation of the mounting plate under the bolt head, which in turn caused loosening of the bolts. In order to properly distribute the bot loads, 3/16 inch thick steel washers were placed under the bolts and the test was continued.

6.2.3 Operator SMB-000-5

Test Number	Direction of Loading	IRS Figure (Appendix E)	Test Duration (seconds)	Operating Voltage (% of nominal)	Stroke Time (sec.)		Chatter > 2 milliseconds	Oservations
					Open to Close	Close to Open		
1	X & Z	-	-	-	-	-	-	Mounting Bolts Broke See 6.2.3.1 Report of Test 1
2	X & Z	1 & 2	35	80	10	10	No	
3	X & Z	3 & 4	35	100	10	10	No	
4	X & Z	5 & 6	35	110	10	10	No	
5	X & Z	7 & 8	35	80	10	10	No	Repeat of Test 2
6	X & Y	9 & 10	35	80	10	10	No	ZPA Lower than required
7	X & Y	11 & 12	35	100	10	10	No	
8	X & Y	13 & 14	35	110	10	10	No	
9	X & Y	15 & 16	35	80	10	10	No	Repeat of Test 6 with Higher ZPA



APPENDIX D  
X-Y Transmissibility Plots



NATURAL FREQUENCIES

OPERATOR SMB-0-25

Frequency	Gross Structure/Component
64 Hz	Motor
130 Hz	Gross Structure
140 Hz	Gross Structure
150 Hz	Limit Switch
165 Hz	Limit Switch

OPERATOR SMB-000-5

Frequency	Gross Structure/Component
90 Hz - 100 Hz	Gross Structure
125 Hz - 145 Hz	Gross Structure
180 - 200 Hz	Gross Structure



100

9  
8  
7  
6  
5  
4  
3  
2


SPECIMEN: LIMITORQUE VALVE MOTOR  
SMB-0-25  
 TEST AXIS: X DATE: 11-19-81  
 TEST LEVEL: \_\_\_\_\_  
 G: \_\_\_\_\_ FILTER B.W. \_\_\_\_\_  
 ACCEL. NO. 4 CONTROL \_\_\_\_\_  
5-200 HZ START OF 50MIN RUN

10

g/  
pk  
D-1a

1.0

0.1







APPENDIX F  
Seismic Sine Beat Test Data Sheets



SINE BEAT  
National Technical Systems - Chatsworth

3.3.1 "X" Axis (Vertical)

SMB-0-25

12/4/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	6.0	5.1	-	55	7	-	
6.3	6	6.0	-	5+	55	6	-	
7.9	6	6.0	5.1	-	55	2	-	
10.0	6	6.0	-	5	55	6	-	

National Technical Systems - Los Angeles

12/13/1 P.M.

15.6	6	6.0	-	5.32	-	3	No	1408
15.9	6	6.0	5.25	-	-	3	No	1412
20.0	6	6.0	-	5.32	-	2	No	1415
25.0	6	6.0	5.25	-	-	2	No	1420
30.0	6	6.0	-	5.4	-	3	No	1422
35.0	6	6.0	5.25	-	-	3	No	1425
			Pretest					
			5.18	5.32				



SINE BEAT

National Technical Systems - Chatsworth

3.3.1 "Y" Axis (Horizontal)

SMB-0-25

12/4/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	6.0	-	(Stroke not run)	100	3	No	
6.3	6	6.0	-	5.5	100	6	No	
7.9	6	6.0	4.1	-	50	4	No	
10.0	6	6.0	-	5.1	55	5	No	

National Technical Systems - Los Angeles

12/12/1 P.M.

1.6	6	6.0	5.35	-	-	5	No	1536
15.9	6	6.0	-	5.48	-	5	No	1540 Note (1)
20.0	6	6.0	5.35	-	-	6	No	1550
25.0	6	6.0	-	5.43	-	4	No	1552
30.0	6	6.0	5.31	-	-	7	No	1554
35.0	3	6.0	-	5.42	-	2	No	1556
	first try					3		
	3							
	second try							
			Los Angeles	Pretest				
			5.27	5.37				



SINE BEAT

National Technical Systems - Chatsworth

3.3.1 "Z" Axis (Horizontal)

SMB-0-25

12/4/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	6.0	5.0	-	55	5	No	
6.3	6	6.0	-	5.0	55	2	No	
7.9	6	6.0	5.0	-	55	0	No	
10.0	6	6.0	-	5.1	55	3	No	

National Technical Systems - Los Angeles

12/12/1 P.M.

6.6	6	6.0	5.38	-	-	4	No	2029
15.9	6	6.0	-	5.55	-	2	No	2032
20.0	6	6.0	5.26	-	-	2	No	2053
25.0	6	6.0	-	5.36	-	4	No	2055
30.0	6	6.0	5.23	-	-	2	No	2057
35.0	6	6.0	-	5.34	-	2	No	2058





SINE BEAT

National Technical Systems - Los Angeles

3.3.2 "X" Axis (Vertical)

SMB-0-25

12/13/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks 3.3.2, 3.3.3 3.3.4 run concurrently by frequency
			Closed-Open	Open-Closed				
10.0	10	4.6	5.37	-	-	4	No	1436
12.6	10	4.6	5.31	-	-	3	No	1444
15.9	10	4.6	-	5.37	-	2	No	1458
20.0	10	4.6	5.22	-	-	5	No	1509
25.0	10	4.6	-	5.42	-	4	No	1514
30.0	10	4.6	5.28	-	-	5	No	1520
35.0	10	4.6	-	5.32	-	4	No	1528
40.0	10	4.6	5.29	-	-	6	No	1534
45.0	20	4.6	-	5.38	-	3	No	1538
50.0	20	4.6	5.29	-	-	5	No	1542
55.0	20	4.6	-	5.32	-	4	No	1546
60.0	20	4.6	5.17	-	-	5	No	1551
70.0	10	4.6	-	5.28	-	3	No	1555
85.0	10	4.6	5.20	-	-	2	No	1558
100.0	10	4.6	-	5.28	-	2	No	1600



SINE BEAT

National Technical Systems - Los Angeles

3.3.2 "Y" Axis (Horizontal)

SMB-0-25

12/12/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
10.0	10	4.6	5.41	-	-	5	No	1605
12.6	10	4.6	-	5.39	-	5	No	1611
15.9	10	4.6	5.38	-	-	3	No	1613
20.0	10	4.6	-	5.44	-	4	No	1615
25.0	10	4.6	5.38	-	-	5	No	1617
30.0	10	4.6	-	5.42	-	6	No	1619
35.0	10	4.6	5.31	-	-	3	No	1622
40.0	10	4.6	-	5.42	-	3	No	1624
45.0	20	4.6	5.31	5.47	-	3	No	1626
50.0	20	4.6	5.31	5.41	-	4	No	1627
55.0	20	4.6	5.29	5.40	-	2	No	1629
60.0	20	4.6	5.28	5.37	-	4	No	1631
70.0	13	4.6	5.37	-	-	3	No	1633
85.0	10	4.6	-	5.33	-	2	No	1635
100.0	10	4.6	5.25	-	-	3	No	1636



SINE BEAT

National Technical Systems - Los Angeles

3.3.2 "Z" Axis (Horizontal)

SMB-0-25

12/12/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks 3.3.2, 3.3.3 3.3.4 run concurrently
			Closed-Open	Open-Closed				
10.0	10	4.6	5.27	-	-	2	No	2119
12.6	10	4.6	-	5.45	-	5	No	2128
15.9	10	4.6	5.27	-	-	3	No	2136
20.0	10	4.6	-	5.33	-	4	No	2145
25.0	10	4.6	5.17	-	-	2	No	2152
30.0	10	4.6	-	5.4	-	2	No	2208
35.0	10	4.6	5.20	-	-	2	No	2214
40.0	10	4.6	-	5.31	-	2	No	2219
45.0	20	4.6	5.33	-	-	6	No	2225
50.0	20	4.6	-	5.28	-	2	No	0937
55.0	20	4.6	5.24	-	-	4	No	0943
60.0	20	4.6	-	5.31	-	4	No	0947
70.0	10	4.6	5.16	-	-	1	No	0952
85.0	10	4.6	-	5.41	-	3	No	0956
100.0	10	4.6	5.18	-	-	3	No	1001



SINE BEAT

National Technical Systems - Los Angeles

3.3.3 "X" Axis (Vertical)

SMB-0-25

12/13/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks Run concurrently by freq. with 3.3.2
			Closed-Open	Open-Closed				
10.0	40	3.5	5.27 ←	5.29	-	2	No	1436
12.6	40	3.5	5.20 ←	5.34	-	1	No	1444
15.9	40	3.5	5.26 →	5.33	-	1	No	1458
20.0	40	3.5	5.23 ←	5.42	-	1	No	1509
25.0	40	3.5	5.19 →	5.37	-	1	No	1515
30.0	40	3.5	5.15 ←	5.41	-	2	No	1521
35.0	40	3.5	5.26 ←	5.42	-	2	No	1528
40.0	40	3.5	5.25 →	5.37	-	1	No	1534
45.0	40	3.5	5.19 ←	5.40	-	2	No	1538
50.0	40	3.5	5.16 →	5.34	-	1	No	1543
55.0	40	3.5	5.25 ←	5.32	-	1	No	1547
60.0	40	3.5	5.35 ←	5.43	-	3	No	1551
70.0	5	3.5	5.16	-	-	2	No	1555
85.0	5	3.5	-	5.29	-	1	No	1558
100.0	5	3.5	5.21	-	-	1	No	1600





SINE BEAT

National Technical Systems - Los Angeles

3.3.3 "Y" Axis (Horizontal)

SMB-0-25

12/12/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
10.0	40	3.5	5.33	← 5.55	-	2	No	1649
12.6	40	3.5	5.4	← 5.5	-	3	No	1838
15.9	40	3.5	5.34	← 5.43	-	2	No	1845
20.0	40	3.5	5.27	← 5.41	-	2	No	1851
25.0	40	3.5	5.24	← 5.51	-	2	No	1858
30.0	40	3.5	5.36	← 5.36	-	3	No	1904
35.0	40	3.5	5.35	→ 5.39	-	3	No	1910
40.0	40	3.5	5.31	→ 5.43	-	2	No	1915
45.0	40	3.5	5.44	→ 5.49	-	2	No	1919
50.0	40	3.5	5.22	→ 5.33	-	3	No	1936
55.0	40	3.5	5.22	→ 5.42	-	2	No	1941
60.0	40	3.5	5.18	→ 5.35	-	3	No	1946
70.0	5	3.5	5.28	-	-	2	No	1950
85.0	5	3.5	-	5.22	-	1	No	1952
100.0	5	3.5	5.18	-	-	2	No	1954



SINE BEAT

National Technical Systems - Los Angeles

3.3.3 "Z" Axis (Horizontal)

SMB-0-25

12/12/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks (Run concurrently with 3.3.2)
			Closed-Open	Open-Closed				
10.0	40	3.5	5.29	← 5.29	-	1	No	2120
12.6	40	3.5	5.26	→ 5.39	-	1	No	2129
15.9	40	3.5	5.3	← 5.44	-	2	No	2137
20.0	40	3.5	5.24	→ 5.36	-	1	No	2146
25.0	40	3.5	5.23	← 5.22	-	1	No	2153
30.0	40	3.5	5.31	→ 5.29	-	1	No	2209
35.0	40	3.5	5.22	← 5.30	-	2	No	2215
40.0	40	3.5	5.16	→ 5.31	-	2	No	2219
45.0	40	3.5	5.19	← 5.34	-	1	No	2226
50.0	40	3.5	5.18	→ 5.37	-	1	No	0938
55.0	40	3.5	5.20	← 5.37	-	0	No	0944
60.0	40	3.5	5.22	→ 5.32	-	0	No	0948
70.0	5	3.5	-	5.34	-	0	No	0953
85.0	5	3.5	5.24	-	-	0	No	0956
100.0	5	3.5	-	5.27	-	0	No	1001



SINE BEAT

National Technical Systems - Los Angeles

3.3.4 "X" Axis (Vertical)

SMB-0-25

Extra

12/13/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks (Run concurrently with 3.3.3)
			Closed-Open	Open-Closed				
10.0	103	2.0	-	5.31	-	1	No	1438
12.6	104	2.0	5.21	5.29	-	2	No	1443 1446
15.9	106	2.0	5.25	5.38	-	1	No	1450 1500
20.0	103	2.0	5.20	5.44	-	1	No	1504 1510
25.0	101	2.0	5.22	5.30	-	4	No	1513 1516
30.0	100	2.0	5.32	5.29	-	3	No	1518 1521
35.0	103	2.0	5.14	5.38	-	1	No	1524 1530
40.0	102	2.0	5.21	5.35	-	1	No	1532 1535
45.0	102	2.0	(Post Vib.) 5.16	5.40	-	3	No	1537 1539
50.0	100	2.0	5.17	5.32	-	4	No	1541 1544
55.0	101	2.0	5.16	5.36	-	4	No	1545 1548
60.0	100	2.0	5.16	5.28	-	2	No	1550 1552
70.0	20	2.0	-	5.31	-	1	No	1554 1556
85.0	20	2.0	5.17	-	-	1	No	1557 1559
100.0	20	2.0	-	5.29	-	2	No	1601
			Post Test					
			5.16	5.29				



SINE BEAT

National Technical Systems - Los Angeles

3.3.4 "Y" Axis (Horizontal)

SMB-0-25

12/12/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks (Done concurrently with 3.3.3 by frequency)
			Closed-Open	Open-Closed				
10.0	103	2.0	5.31	5.39	-	0	No	1650
12.6	101	2.0	5.32	5.39	-	1	No	1840 1843
15.9	102	2.0	5.28	5.37	-	1	No	1846 1849
20.0	101	2.0	5.36	5.43	-	2	No	1853 1856
25.0	101	2.0	5.38	5.36	-	2	No	1859 1901
30.0	100	2.0	-	5.32	-	2	No	1906 1908
45.0	100	2.0	5.44	5.36	-	2	No	1911 1914
40.0	101	2.0	5.32	5.27	-	2	No	1916 1918
45.0	101	2.0	5.21	5.34	-	2	No	1920 1923
50.0	100	2.0	5.27	5.33	-	2	No	1937 1939
55.0	101	2.0	5.28	5.35	-	1	No	1942 1944
60.0	100	2.0	5.21	5.32	-	2	No	1947 1949
70.0	20	2.0	-	5.38	-	1	No	1950 1951
80.0	20	2.0	5.36	-	-	1	No	1953
100.0	20	2.0	-	5.39	-	1	No	1954
			Post Test					
			5.29	5.3				





SINE BEAT

National Technical Systems - Los Angeles

3.3.4 "Z" Axis (Horizontal)

SMB-0-25

Extra

12/12/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks (Run concurrently with 3.3.3)
			Closed-Open	Open-Closed				
10.0	104	2.0	5.22	5.4	-	1	No	2121 2125
12.6	102	2.0	5.28	5.34	-	2	No	2131 2134
15.9	102	2.0	5.23	5.3	-	3	No	2138 2142
20.0	104	2.0	5.17	5.31	-	1	No	2148 2151
25.0	105	2.0	5.19	5.44	-	2	No	2154 2159
30.0	105	2.0	5.25	5.4	-	2	No	2210 2212
35.0	104	2.0	5.33	5.34	-	2	No	2215 2217
40.0	104	2.0	5.17	5.38	-	2	No	2220 2222
45.0	102	2.0	5.17	5.34	-	1	No	2227 2229
50.0	106	2.0	5.22	5.32	-	1	No	0939 0941
55.0	104	2.0	5.32	5.30	-	2	No	0945 0946
60.0	100	2.0	5.19	5.34	-	1	No	0949 0950
70.0	20	2.0	5.19	-	-	1	No	0953
80.0	20	2.0	-	5.34	-	1	No	0957
90.0	20	2.0	5.31	-	-	1	No	1002
			Post Test					
			5.21	5.35				

12/13/1  
A.M.



SINE BEAT

National Technical Systems - Chatsworth

3.3.1 "X" Axis (Vertical)

SMB-000-5

12/5/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	6.0	11.1	-	55	5	No	
6.3	6	6.0	-	12.5	55	0	No	
7.9	6	6.0	11.8	-	55	1	No	
10.0	6	6.0	-	12.2	55	1	No	

National Technical Systems - Los Angeles

12/10/1 A.M.

1.6	6	6.0	11.88	-	70	5	Yes (on piggy back units)	(See Note 1) high g input-30 g
15.9	6	6.0	-	11.88	-	3	No	
20.0	6	6.0	11.92	-	-	6	No	
25.0	6	6.0	-	11.90	-	2	No	
30.0	6	6.0	11.91	-	-	7	No	
35.0	6	6.0	-	11.93	-	8	No	

Note 1: Modified limit switch - chatter  
Operator limit switch - no chatter



SINE BEAT

National Technical Systems - Chatsworth

3.3.1 "Y" Axis (Horizontal)

SMB-000-5

12/5/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	6.0	11.0	-	-	2	No	
6.3	6	6.0	-	12.7	-	2	No	
7.9	6	6.0	11.4	-	-	2	No	
10.0	6	6.0	-	12.1	-	3	No	

National Technical Systems - Los Angeles

12/9/1 A.M.

6	6	6.0	11.92	-	-	4	No	Rattle in motor - does not effect operation
15.9	6	6.0	-	11.84	-	5	No	
20.0	6	6.0	11.86	-	-	5	No	
25.0	6	6.0	-	11.90	-	5	No	
30.0	6	6.0	11.87	-	-	3	No	
35.0	6	6.0	-	11.93	-	3	No	



SINE BEAT

National Technical Systems - Chatsworth

3.3.1 "Z" Axis (Horizontal)

SMB-000-5

12/5/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	6.0	12.0	-	-	4	No	
6.3	6	6.0	-	12.0	-	3	No	
7.9	6	6.0	11.0	-	-	0	No	
10.0	6	6.0	-	11.0	-	3	No	

National Technical Systems - Los Angeles

12/9/1 A.M.

6	6	6.0	(Time not obtained)	-	50	12	No	
15.9	6	6.0	-	11.75	60	17	No	
20.0	6	6.0	11.88	-	-	11	No	
25.0	6	6.0	-	11.96	-	6	No	
30.0	6	6.0	11.95	-	-	12	No	
35.0	6	6.0	-	11.87	-	4	No	





SINE BEAT

National Technical Systems - Los Angeles

3.3.2 "X" Axis (Vertical)

SMB-000-5

12/10/1 A.M. .

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
10.0	10	4.6	11.87	11.90	-	6	No	
12.6	10	4.6	11.83	11.88	-	12	No	
15.9	10	4.6	11.85	11.88	-	10	No	#3 Accel. lost; wire connection fixed
20.0	10	4.6	11.87	11.87	-	9	No	
25.0	10	4.6	11.84	11.89	-	4	No	
30.0	10	4.6	11.83	11.82	-	3	No	
35.0	10	4.6	11.93	-	-	12	No	
40.0	10	4.6	11.84	11.88	-	7	No	Accels. 11, 12, 13, 14, 15, 19 showed increased response
45.0	20	4.6	11.82	11.86	-	5	No	
50.0	9 2nd Try	4.6	8.7	9.1	-	14	No	Rotors checked for setting * - changed stroke time - First time - going from closed to open - actuator did not complete stroke - All accels put on 30 g range before run
	11 1st Try		11.81	4.34		11	No	
55.0	20	4.6	-	8.6	-	4	No	
60.0	20	4.6	8.9	8.6	-	2	No	
70.0	10	4.6	-	8.8	-	3	No	



SINE BEAT

National Technical Systems - Los Angeles (Continued)

3.3.2 "X" Axis (Vertical)

SMB-000-5

12/10/1 A.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
85.0	10	4.6	8.7	-	-	3	No	
100.0	10	4.6	-	8.9	-	3	No	

\* Note: Operator did not complete stroke. Improper contact in limit switch was thought to be the cause at first. Limit switch was slightly adjusted, resulting in shorter stroke time. Operator again did not complete stroke. A short circuit in the control circuit was the cause.



SINE BEAT

National Technical Systems - Los Angeles

3.3.2 "Y" Axis (Horizontal)

SMB-000-5

12/10/1 A.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
10.0	10	4.6	-	8.75	-	6+1	No	2150
12.6	10	4.6	8.65	-	-	6	No	2154
15.9	10	4.6	-	8.84	-	9	No	2159
20.0	10	4.6	Timing not obtained >6.1	-	-	6	No	2205 See Note (1)
25.0	10	4.6	-	8.78	-	2	No	2209
30.0	10	4.6	8.7	-	-	2	No	2210
35.0	10	4.6	-	8.75	-	3	No	2213
40.0	10	4.6	8.6	-	-	0	No	2215
45.0	20	4.6	-	8.9	-	2	No	2218
50.0	20	4.6	8.8	-	-	6	No	2220
55.0	20	4.6	-	8.75	-	4	No	2222
60.0	20	4.6	8.67	-	-	7	No	2236
70.0	10	4.6	-	8.65	-	2	No	2238
85.0	10	4.6	8.69	-	-	2	No	2239
100.0	10	4.6	-	8.75	-	5	Yes	2241 (1)
100.0	10	4.6	-	-	-	3	Yes	Rerun for (2) contact chatter monitor 2245

(1) Chatter - > 2 msec  
(2) No chatter above 3 msec



SINE BEAT

National Technical Systems - Los Angeles

3.3.2 "Z" Axis (Horizontal)

SMB-000-5

12/11/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
10.0	10	4.6	8.69	-	-	11	No	1315
12.6	10	4.6	-	8.82	-	8	No	1318
15.9	10	4.6	8.69	-	-	5	No	1321
20.0	10	4.6	-	8.90	-	5	No	1324
25.0	10	4.6	8.75	-	-	5	No	1326
30.0	10	4.6	-	8.74	-	4	No	1328
35.0	10	4.6	8.7	-	-	3	No	1329
40.0	10	4.6	-	8.82	-	4	No	1331
45.0	20	4.6	8.71	-	-	3	No	1333
50.0	20	4.6	-	8.86	-	2	No	1337
55.0	20	4.6	8.6	-	-	4	No	1339
60.0	20	4.6	-	8.82	-	3	No	1341
70.0	10	4.6	8.59	-	-	3	No	1343
85.0	10	4.6	-	8.8	-	3	No	1344
100.0	10	4.6	8.59	-	-	4	No	1346





SINE BEAT

National Technical Systems - Los Angeles

3.3.3 "X" Axis (Vertical)

SMB-000-5

12/10/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
10.0	40	3.5	not timed	8.85	-	18	No	(1520 Hours) Stroke started at beat 8
12.6	40	3.5	8.7	8.85	-	14	No	1526 Hours
15.9	40	3.5	8.6	8.84	-	12	No	1532 Hours
20.0	40	3.5	8.6	8.8	-	~10	No	1540 Hours
25.0	40	3.5	8.6	8.8	-	11	No	1541 Hours
30.0	40	3.5	8.55	8.8	-	7	No	1546
35.0	40	3.5	8.6	8.8	-	8	No	1549
40.0	40	3.5	8.65	8.75	-	9	No	1552
45.0	40	3.5	8.6	8.85	-	11	No	1555
50.0	40	3.5	8.55	8.8	-	10	No	1614
55.0	40	3.5	8.65	8.8	-	6	No	1617 Taped engage lever to hand wheel
60.0	40	3.5	8.65	8.76	-	6	No	1621
70.0	5	3.5	8.62	-	-	4	No	1626
85.0	5	3.5	-	Not Stroked	-	0	No	1628
100.0	5	3.5	-	8.72	-	2	No	1629



SINE BEAT

National Technical Systems - Los Angeles

3.3.3 "Y" Axis (Horizontal)

SMB-000-5

12/10/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
10.0	40	3.5	8.6	8.77	-	5	No	Start 2256 Stop 2259
12.6	40	3.5	8.94	8.82	-	4	No	Start 2300 Stop 2302
15.9	40	3.5	Lost time 8.6 Post Vib.	7.9	-	8+1	No	Start 2304 See Stop 2306 Note (1)
20.0	40	3.5	8.69	8.84	-	3	No	Stop 2312
25.0	40	3.5	8.6	8.82	-	3	No	Start 2315 Stop 2316
30.0	40	3.5	8.62	8.84	-	3	No	Start 2318 Stop 2319
35.0	40	3.5	8.7	8.85	-	4	No	Start 2335 Stop 2336
40.0	40	3.5	8.64	8.83	-	8	No	Start 2348 Stop 2349
45.0	40	3.5	8.63	8.83	-	2	No	Start 2350 Stop 2351
50.0	40	3.5	8.61	8.76	-	2	No	Start 2352 Stop 2354
55.0	40	3.5	8.62	8.75	-	2	No	Start 2355 Stop 2356
60.0	40	3.5	8.60	8.82	-	3	No	Change o' graph paper Start 2400 Stop 2402
	5	3.5		8.81	-	4	No	Stop 2405



SINE BEAT (Continued)

National Technical Systems - Los Angeles

3.3.3 "Y" Axis (Horizontal)

SMB-000-5

12/10/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
85.0	5	3.5	8.64	-	-	3	No	Start 2407 Stop 2408
100.0	5	3.5	-	8.78 Pre Vib. not run during Vib.	-	-	Yes	Start 2410 Stop 2411 See Note (2)

- Notes: (1) Chatter > 2 msec  
(2) No chatter above 3 msec



SINE BEAT

National Technical Systems - Los Angeles

3.3.3 "Z" Axis (Horizontal)

SMB-000-5

12/11/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
10.0	40	3.5	8.61	8.95	-	5	No	1348 Accel #3. bad charge amp out- detected
12.6	40	3.5	8.57	8.9	-	4	No	Start 1426 Stop 1429 Acce #1 bad
15.9	40	3.5	8.57	8.79	-	4 1st try +3 2nd try	No	Start 1441 Stop 1443 See Note (1)
20.0	40	3.5	8.66	8.91	-	3	No	1500
25.0	40	3.5	8.6	8.9	-	4	No	1504
30.0	40	3.5	8.61	8.78	-	3	No	1511
35.0	40	3.5	8.5	8.75	-	3	No	Start 1512 Stop 1513
40.0	40	3.5	8.5	8.82	-	4	No	Start 1514 Stop 1515
45.0	40	3.5	8.59	8.84	-	4	No	Start 1516 Stop 1517
50.0	40	3.5	8.57	8.82	-	3	No	Start 1523 Stop 1524
55.0	40	3.5	8.56	8.75	-	4	No	Start 1525 Stop 1526
60.0	40	3.5	8.59	8.8	-	5	No	Start 1527 Stop 1528
70.0	5	3.5	-	8.8	-	3	No	1530
80.0	5	3.5	8.55	-	-	4	No	1531
100.0	5	3.5	-	8.86	-	3	No	1543





SINE BEAT

National Technical Systems - Los Angeles

3.3.4 "X" Axis (Vertical)

SMB-000-5

12/10/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
10.0	103	2.0	8.62	8.85	-	2	No	Start 1639 Stop 1644
12.6	102	2.0	8.6	8.8	-	3	No	Start 1646 Stop 1651
15.9	101	2.0	8.7	8.9	-	4	No	Start 1655 Stop 1659 Put use on slower paper speed
20.0	100	2.0	8.6	8.9	-	5	No	Start 1702 Stop 1706
25.0	101	2.0	8.7	8.85	-	4	No	Start 1709 Stop 1712
30.0	101	2.0	8.75	8.8	-	4	No	Start 1714 Stop 1718
35.0	101	2.0	8.55	8.9	-	4	No	Start 1719 Stop 1722
40.0	104	2.0	8.6	8.8	-	1	No	Start 1724 Stop 1727
45.0	101	2.0	8.65	8.85	-	4	No	Start 1729 Stop 1731
50.0	101	2.0	8.7	8.9	-	4	No	Start 1732 Stop 1735
55.0	102	2.0	8.8	8.9	-	3	No	Start 1742 Stop 1744
60.0	100	2.0	8.75	8.85	-	5	No	Start 1745 Stop 1747 (Change tapes)



SINE BEAT

National Technical Systems - Los Angeles (Continued)

3.3.4 "X" Axis (Vertical)

SMB-000-5

12/10/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed- Open	Open- Closed				
70.0	21	2.0	8.7	-	-	4	No	Start 1816 Stop 1817
85.0	23	2.0	-	8.85	-	2	No	Start 1818 Stop 1819
100.0	22	2.0	8.77	-	-	3	No	Start 1820 Stop 1821



SINE BEAT

National Technical Systems - Los Angeles

3.3.4 "Y" Axis (Horizontal)

SMB-000-5

12/11/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
10.0	100	2.0	8.72	8.81	-	5	No	Start 1007 Stop 1012
12.6	100	2.0	8.64	8.69	-	(Post) 5+2	No	Start 1056 Stop 1100
15.9	100	2.0	8.8	8.77	-	5	No	Start 1103 Stop 1107
20.0	103	2.0	8.69	8.73	-	2	No	Start 1109 Stop 1113
25.0	102	2.0	8.85	Not Stroked During Test	-	3	No	Stroked post test closed-no time
30.0	102	2.0	8.80	8.77	-	3	No	Start - Stop 1123
35.0	100	2.0	8.47	8.63	-	5	No	Start 1125 Stop 1128
40.0	101	2.0	8.68	8.64	-	4	No	Start 1129 Stop 1132
45.0	101	2.0	8.34	8.67	-	4	No	Start 1138 Stop 1142
50.0	100	2.0	8.68	8.64	-	5	No	Start 1143 Stop 1145
55.0	101	2.0	8.6	8.88	-	4	No	Start 1146 Stop 1149
60.0	100	2.0	8.59	8.86	-	5	No	Start 1150 Stop



SINE BEAT

National Technical Systems - Los Angeles (Continued)

3.3.4 "Y" Axis (Horizontal)

SMB-000-5

12/11/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated. @.002 sec	Remarks
			Closed- Open	Open- Closed				
70.0	20	2.0	8.62	-	-	3	No	Start 1154 Stop 1154:30
85.0	20	2.0	-	8.78	-	2	No	Start 1156 Stop 1156:30
100.0	20	2.0	-	-	-	3	No	Start 1157 Stop 1158 See Note (1)

Note: (1) Chatter > 2 msec  
No chatter above 3 msec





SINE BEAT

National Technical Systems - Los Angeles

3.3.4 "Z" Axis (Horizontal)

SMB-000-5

12/11/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
10.0	102	2.0	8.86	8.94	-	3	No	Start 1559 Stop 1604 Set amps at 10 g range were 30 g range
12.6	102	2.0	8.69	8.85	-	3	No	Start 1606 Stop 1612
15.9	101	2.0	8.74	8.78	-	4	No	Start 1634 Stop 1638
20.0	103	2.0	8.66	8.84	-	2	No	Start 1640 Stop 1645
25.0	103	2.0	8.59	8.75	-	2	No	Start 1656 Stop 1659
30.0	102	2.0	8.62	8.75	-	3	No	Start 1700 Stop 1703
35.0	103	2.0	8.56	8.76	-	2	No	Start 1704 Stop 1706
40.0	102	2.0	8.53	8.83	-	3	No	Start 1707 Stop 1710
45.0	103	2.0	8.57	8.83	-	2	No	Start 1711 Stop 1713
50.0	104	2.0	8.57	8.54	-	1	No	Start 1714 Stop 1716
55.0	103	2.0	8.54	8.73	-	2	No	Start 1716:30 Stop 1718
0	103	2.0	8.85	8.75	-	2	No	Start 1719 Stop 1720



SINE BEAT

National Technical Systems - Los Angeles (Continued)

3.3.4 "Z" Axis (Horizontal)

SMB-000-5

12/11/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed- Open	Open- Closed				
70.0	20	2.0	8.64	-	-	3	No	1721
85.0	20	2.0	-	8.75	-	2	No	1722
100.0	20	2.0	8.56	-	-	2	No	1724



APPENDIX G  
Fragility Test Data Sheets



SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "X" Axis (Vertical) SMB-0-25 Fragility Test 8 g 12/15/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	8.0	5.3	-	-	-	No	*1400 (*Table limits)
6.3	6	8.0	-	5.4	-	-	No	
7.9	6	8.0	5.4	-	-	-	No	
10.0	20	8.0	5.4	5.4	-	-	No	
12.6	20	8.0	5.2	5.4	-	-	No	

National Technical Systems - Los Angeles

12/13/1 P.M.

15.9	20	8.0	5.33 ←	5.31	-	5	No	1700
20.0	20	8.0	5.35 ←	5.35	-	5	No	1657
25.0	20	8.0	5.25 ←	5.39	-	4	No	1655
30.0	20	8.0	5.4 ←	5.39	-	5	No	1651
35.0	20(6) (14)	8.0	5.36 ←	5.34	-	5+3	No	1648 ↑
40.0	20	8.0	5.19	5.34	-	6	No	1620
45.0	15	8.0	5.19	-	-	5	No	1623
50.0	15	8.0	-	5.32	-	4	No	1625
55.0	15	8.0	5.29	-	-	3	No	1627
60.0	15	8.0	-	5.35	-	4	No	1629
70.0	15	8.0	5.39	-	-	3	No	1631
0	15	8.0	-	5.40	-	2	No	1633
0.0	15	8.0	5.28	-	-	3	No	1635
		Post Test	5.18 ←	5.37				





## SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "Y" Axis (Horizontal) SMB-0-25 Fragility Test 8 g 12/15/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	8.0+	-	5.3	-	6+	No	*1300 (*Table limits)
6.3	6	8.0+	5.3	-	-	6+	No	
7.9	6	8.0+	-	5.4	-	-	No	
10.0	20	8.0	5.2	5.3	-	-	No	
12.6	20	8.0	5.2	5.3	-	-	No	
			Post Test					
			5.28	5.38				

National Technical Systems - Los Angeles

 12/15/81 A.M.  
12/14/81 P.M.

15.9	20	8.0	5.36	5.33	-	2	No	1317
20.0	20	8.0	5.22	5.26	-	2	No	1315
25.0	20	8.0	5.23	5.33	-	3	No	1313
30.0	20	8.0	5.21	5.47	-	3	No	1311 †
35.0	20	8.0	5.20	5.49	-	3	No	1309
40.0	20	8.0	5.23	5.32	-	2	No	1329
45.0	15	8.0	-	5.33	-	2	No	1332
50.0	15	8.0	5.21	-	-	3	No	1333
55.0	15	8.0	-	5.36	-	3	No	1334
60.0	15	8.0	5.22	-	-	4	No	1335
0	15	8.0	-	5.30	-	3	No	1336



SINE BEAT

National Technical Systems - Los Angeles (Continued)

12/15/81 A.M.

12/14/81 P.M.

3.4.1 "Y" Axis (Horizontal) SMB-0-25 Fragility Test 8 g

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
85.0	15	8.0	5.28	-	-	2	No	1338
100.0	15	8.0	-	5.30	-	2	No	1339
		Los Angeles	Pre Test					
			5.27	5.39				
			5.20	5.28				
			Post Test					
			5.21	5.30				



SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "Z" Axis (Horizontal) SMB-0-25 Fragility Test 8 g 12/15/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	8.0	5.2	-	-	-	No	1620
6.3	6	8.0	-	5.3	-	-	No	
7.9	6	8.0	5.3	-	-	-	No	
10.0	20	8.0	5.3	5.3	-	-	No	
12.6	20	8.0	5.4	5.4	-	-	No	

National Technical Systems - Los Angeles

12/14/1 P.M.

15.9	20	8.0	5.35	5.42	-	4	No	1044
20.0	20	8.0	5.35	5.41	-	4	No	1042
25.0	20	8.0	5.28	5.31	-	7	No	1040
30.0	20	8.0	5.26	5.38	-	7	No	1038
35.0	20	8.0	5.22	5.40	-	9	No	1035
40.0	20	8.0	5.32	5.28	-	4	No	1104
45.0	15	8.0	5.22	-	-	5	No	1106
50.0	15	8.0	-	5.36	-	5	No	1107
55.0	15	8.0	5.18	-	-	4	No	1109
60.0	15	8.0	-	5.31	-	3	No	1110
70.0	15	8.0	5.22	-	-	2	No	1112



SINE BEAT

National Technical Systems - Los Angeles (Continued)

3.4.1 "Z" Axis (Horizontal) SMB-0-25 Fragility Test 8 g 12/15/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
85.0	15	8.0	-	5.34	-	2	No	1113
100.0	15	8.0	5.20	-	-	2	No	1115
		Los Angeles	Pre Test					
			5.26	5.34				
			Post Test					
			5.18	5.32				





SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "X" Axis (Vertical) SMB-0-25 Fragility Test 10 g 12/15/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed- Open	Open- Closed				
5.0	-	-	-	-	-	-	-	
6.3	6	8+	-	5.5	-	-	No	} Table limit
7.9	6	8+	5.2	-	-	-	No	
10.0	13	10+	5.2	5.4	-	-	No	
12.6	17	10+	5.2	5.6	-	-	No	
15.9	18	10+	5.3	5.3	-	-	No	



SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "X" Axis (Vertical) SMB-0-25 Fragility Test 12 g 12/15/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	-	-	-	-	-	-	-	
6.3	-	-	-	-	-	-	-	
7.9	-	-	-	-	-	-	-	
10.0	9	11+	-	5.3	-	-	No	
12.6	6	11+	-	-	-	-	No	
15.9	8	11+	5.3	-	-	-	No	
		Post Test	5.2	5.28				Completed 1800

National Technical Systems - Los Angeles

12/21/81 P.M.

20.0	20	12	5.19	→ 5.27	-	3	No	1616
25.0	20	12	5.28	→ 5.37	-	5	No	1620
30.0	20	12	5.18	→ 5.36	-	4	No	1623
35.0	20	12	5.20	→ 5.32	-	4	No	1626
40.0	20	12	5.30	→ 5.44	-	5	No	1658
45.0	15	12	5.23	-	-	3	No	1700
50.0	15	12	-	5.44	-	3	No	1702
55.0	15	12	5.22	-	-	4	No	1703
60.0	15	12	-	5.33	-	3	No	1705
70.0	15	12	5.28	-	-	4	No	1706
85.0	15	12	-	5.32	-	3	No	1707
90.0	15	12	5.19	-	-	4	No	1709
		Pre Test	5.26	← 5.33				
		Post Test	5.22	← 5.30				



SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "Y" Axis (Horizontal) SMB-0-25 Fragility Test 10 g 12/15/1 A.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	-	-	-	-	-	-	-	} Table Limits
6.3	6	8+	5.3	-	-	-	No	
7.9	6	8+	-	5.3	-	-	No	
10.0	10	10+	5.3	5.3	-	-	No	
12.6	8	10+	5.4	5.3	-	-	No	
15.9	10	10+	5.2	5.3	-	-	No	Test Completed 1938
		Post Test	5.18	5.32				



SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "Y" Axis (Horizontal) SMB-0-25 Fragility Test 12 g 12/15/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	-	-	-	-	-	-	-	
6.3	-	-	-	-	-	-	-	
7.9	-	-	-	-	-	-	-	
10.0	10	11+	-	-	-	-	No	} Test run in conjunction with 10 g test - these are table limits
12.6	12	11+	-	-	-	-	No	
15.9	10	11+	-	-	-	-	No	

National Technical Systems - Los Angeles

12/21/81 P.M.

20.0	20	12	5.25	→ 5.30	-	4	No	1447
25.0	20	12	5.25	→ 5.43	-	4	No	1449
30.0	20	12	5.25	→ 5.45	-	3	No	1451
35.0	20	12	5.22	→ 5.32	-	3	No	1453
40.0	20	12	5.20	← 5.28	-	4	No	1422 ↑
45.0	15	12	-	5.32	-	3	No	1426 ↓
50.0	15	12	5.15	-	-	5	No	1427
55.0	15	12	-	5.35	-	3	Yes	1428 Note (1)
60.0	15	12	5.28	-	-	5	Yes	1430 Note (1)
70.0	15	12	-	5.31	-	5	Yes	1432 Note (2)





SINE BEAT

National Technical Systems - Los Angeles (Continued)

3.4.1 "Y" Axis (Horizontal) SMB-0-25 Fragility Test 12 g 12/15/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed- Open	Open- Closed				
85.0	15+6	12	5.26	-	-	5	Yes	1433 Note (2)
100.0	15+6	.12	-	5.33	-	5	Yes	1435 Note (1)
		Pre Test	5.16	5.35				
		Post Test	5.22	5.30				

Notes: (1) Chatter > 2 msec; under 4 msec  
(2) Chatter > 2 msec; under 2.5 msec



SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "Z" Axis (Horizontal) SMB-0-25 Fragility Test 10 g 12/15/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	9	5.2	-	-	-	No	} Table Limits
6.3	6	9	-	5.4	-	-	No	
7.9	6	9	5.5	-	-	-	No	
10.0	12	10+	5.2	5.4	-	-	No	
12.6	12	10+	5.2	5.3	-	-	No	
15.9	14	10+	5.1	5.3	-	-	No	
		Post Test	-	-				

National Technical Systems - Los Angeles

12/21/1

20.0	20							
25.0	20							
30.0	20							
35.0	20							
40.0	20							
45.0	15							
50.0	15							
55.0	15							
60.0	15							
70.0	15							
0	15							
100.0	15							
		Post Test						



SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "Z" Axis (Horizontal) SMB-0-25 Fragility Test 12 g 12/15/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	-	-	-	-	-	-	-	
6.3	-	-	-	-	-	-	-	
7.9	-	-	-	-	-	-	-	
10.0	8	11+	-	-	-	-	No	} Run in conjunction with 10 g test. These are table limits.
12.6	8	11+	-	-	-	-	No	
15.9	6	11+	-	-	-	-	No	
		Post Test	-	-				

National Technical Systems - Los Angeles

12/21/1 A.M.

20.0	20	12	5.25	5.39	-	2 + 6	No	1119
25.0	20	12	5.30	5.36	-	20 + 5	No	1143
30.0	20	12	5.29	5.39	-	3	No	1224
35.0	20	12	5.27	5.36	-	4	No	1306
40.0	20	12	5.23	5.39	-	4	No	1319
45.0	15	12	5.25	-	-	5	No	1326
50.0	15	12	-	5.42	-	4	No	1327
55.0	15	12	5.22	-	-	3	No	1328
60.0	15	12	-	5.34	-	3	No	1329
70.0	15	12	5.37	-	-	4	No	1330
85.0	15	12	-	5.39	-	4	No	1337
0	15	12	5.24	-	-	4	No	1339
		Pre Test	5.25	5.25				
		Post Test	-	-				



SINE BEAT

National Technical Systems - Los Angeles

3.4.1 "X" Axis (Vertical) SMB-0-25 Fragility Test 14 g 12/21/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
20.0	20	14	5.25	→ 5.34	-	4	No	1757
25.0	20	14	5.23	→ 5.32	-	4	No	1753
30.0	20	14	5.25	→ 5.34	-	4	No	1750
35.0	20	14	5.28	→ 5.39	-	4	No	1747
40.0	20	14	5.25	← 5.31	-	6	No	↓ 1720 ↑
45.0	15	14	-	5.31	-	4	No	1724
50.0	15	14	5.17	-	-	4	No	1726
55.0	15	14	-	5.26	-	4	No	1728
60.0	15	14	5.26	-	-	4	No	1730
70.0	15	14	-	5.31	-	3	No	1733
85.0	15	14	5.17	-	-	4	No	1734
100.0	15	14	-	5.43	-	3	No	1735
Post Test								





SINE BEAT

National Technical Systems - Los Angeles

Fragility Test  
55 to 100 Hz

3.4.1 "Y" Axis (Horizontal)

SMB-0-25

No Chatter Level Test \*

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
* Chatter exceeding 2 milliseconds was detected during the 12 g's Fragility Test. This test was performed to establish input level at which there is no chatter in excess of 2 milliseconds.								
55.0	24	8 to 12	5.29			4	No chatter @ 11.0 g	
60.0	27	8 to 12	5.28			6	No chatter @ 11.0 g	
70.0	14	8 to 12	5.28			4	No chatter @ 11.0 g	
80.0	18	8 to 12	5.23			3	No chatter @ 11.0 g	
90.0	31	8 to 12	5.31			3	No chatter @ 11.0 g	



SINE BEAT

National Technical Systems - Los Angeles

3.4.1 "Y" Axis (Horizontal) SMB-0-25 Fragility Test 14 g

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
20.0	g** 20	14	5.34	5.45	-	4	No	
25.0	20	14	5.32	5.42	-	3	No*	
30.0	20	14	5.25	5.41	-	4 + 3	No	
35.0	20	14	5.32	5.48	-	3	Yes	} No chatter @ 5.0 msec
40.0	20	14	5.38	5.42	-	7	Yes	
45.0	15	14	5.30	-	-	4	Yes	
50.0	15	14	-	5.34	-	3	No	
55.0	15 + 12	14	5.32	5.40	-	-	Yes (N.O.)	} No chatter @ 5.0 msec
60.0	15 + 6	14	-	5.41	-	-	Yes (N.O.)	
70.0	15 + 6	14	-	5.40	-	-	Yes (N.O.)	} No chatter @ 2.5 msec
85.0	15 + 6	14	-	5.34	-	-	Yes (N.O.)	
100.0	15 + 7	14	-	5.41	-	-	Yes (N.C.)	No chatter @ 4.0 msec

\* Normally open circuit indicated a short circuit on the chatter monitor. A check with an ohmmeter indicated that there was no short in limit switch. Chatter monitor had developed a fault internally. New channel was used.

\*\* Test stopped due to shaker table support imbalance.

Pre Test 5.28 5.32 9:40 A.M. 12/22/81

Post Test 5:22 5.34 12:22 P.M. 12/22/81



SINE BEAT

National Technical Systems - Los Angeles

3.4.1 "Z" Axis (Horizontal) SMB-0-25 Fragility Test 14 g 1:50 P.M.  
12/22/81

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
20.0	20	14	5.18	5.31	-	3	No	14.28
25.0	20	14	5.20	5.32	-	4		14.26
30.0	20	14	5.19	5.46	-	3		14.18
35.0	20	14	5.26	5.35	-	3		14.16
40.0	20	14	5.25	5.42	-	5		13.59
45.0	15	14	-	5.28	-	2		14.02
50.0	15	14	5.18	-	-	2		14.03
55.0	15	14	-	5.31	-	3		14.04
60.0	15	14	5.20	-	-	2		14.06
70.0	15	14	-	5.36	-	4		14.07
85.0	15	14	5.20	-	-	3		14.09
100.0	15	14	-	5.30	-	3		14.11
Pre Test			5.43	5.43	13:50			
Post Test			5.30	5.32	14:30			



SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "X" Axis (Vertical) SMB-000-5 Fragility Test 8 g 12/16/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	8	8.7	-	-	-	No	(Post Test) Open 8.7 Close 8.8
6.3	6	8	-	8.9	-	-	No	
7.9	6	8	8.7	-	-	-	No	
10.0	14	8	8.7	8.9	-	-	No	
12.6	7	8	8.7	8.8	-	-	No	
15.9	6+	8	8.7	8.8	-	-	No	
20.0	20	8	8.6	8.9	-	-	No	
25.0	20	8	8.7	8.8	-	-	No	

National Technical Systems - Los Angeles

12/18/1

30.0	20*	8	8.69	8.72	-	3	No	
30.0	20	8	8.72	8.76	-	5	No	
35.0	20	8	8.59	8.81	-	4	No	
40.0	20	8	8.58	8.78	-	8	No	
45.0	15	8	-	8.77	-	4	No	
50.0	15	8	8.72	-	-	2	No	1458
55.0	15	8	-	8.78	-	3	No	1502
60.0	15	8	8.71	-	-	2	No	1504
70.0	15	8	-	8.75	-	1	No	1507
80.0	15	8	8.69	-	-	1	No	1508
90.0	15	8	-	8.74	-	4	No	1509

\* Test repeated - below 8 g level





SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "Y" Axis (Horizontal) SMB-000-5 Fragility Test 8 g 12/16/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	9+	-	8.9	-	-	No	
6.3	6	9+	8.7	-	-	-	No	
7.9	5	8+	-	8.9	-	-	No	
10.0	3	9+						
	11	8+	8.6	8.9	-	-	No	
12.6	9	9+						
	6+	9+	8.7	8.9	-	-	No	
15.9	6	8+	8.7	8.9	-	-	No	
	11	9+						

National Technical Systems - Los Angeles

12/11/1 P.M.

15.9	20	8	Stopped mid-stroke	8.8	-	6	No	2204	} Note (4)
20.0	20	8 (No Vib.)	-	4.5	-	4	No	2201	
			8.55	8.8					
25.0	20	8 (No Vib.)	6.0	5.4	-	6	No	2108	
			8.6	8.8					
30.0	20	8	7.67	7.39	-	6	No	2106	
35.0	20	8	9.2	8.85	-	3	No	2103	
40.0	20	8	8.62	-	-	7	No	2038	↑
45.0	15	8	-	8.82	-	4	No	2040	↓
50.0	15	8	8.56	-	-	5	No	2042	
0	15	8	-	8.76	-	4	No	2044	
0	15	8	8.7	-	-	4	No	2046	



SINE BEAT

National Technical Systems - Los Angeles (Continued)

3.4.1 "Y" Axis (Horizontal) SMB-000-5 Fragility Test 8 g 12/11/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
70.0	15 +7 See Note (1)	8	-	8.88	-	6	Yes	2047 Note (1)
85.0	15	8	-	-	-	3	Yes	2050 Note (2)
100.0	15	8	-	8.8	-	4	Yes	2054 Note (3)

Notes: (1)(2)(3) Chatter exceeding 2 msec., No chatter above 4 msec.  
 (4) Operator failed to complete stroke @ 25, 20 and 15.9 Hz.  
 Test stopped to investigate and correct the problem.



SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "Y" Axis (Horizontal)

SMB-000-5

Fragility Test 8 g 12/16/1  
Repeat of Problem Frequencies

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
15.9	20	8	8.7	8.9	-	-	No	
20.0	20	8	8.6	8.9	-	-	No	
25.0	20	8	8.7	8.9	-	-	No	

\* After proper gapping of the torque switch contacts by Limitorque representative, 8 g level tests @ the above frequencies were repeated. There was no gap between the stationary "L" bracket and the contact finger. This may have resulted in inadequate contact pressure and excessive contact chatter.



SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "Z" Axis (Horizontal) SMB-000-5 Fragility Test 8 g 12/16/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	4	9+	-	8.8	-	-	No	(Post Test Open 8.7 Closed 8.8)
6.3	6	9+	8.7	-	-	-	No	
7.9	5	9+	-	8.8	-	-	No	
10.0	6+	9+	8.6	8.8	-	-	No	
12.6	6+	9+	8.6	8.8	-	-	No	
15.9	6+	9+	8.7	8.8	-	-	No	

National Technical Systems - Los Angeles 12/11/1 P.M.

15.9	20	8	8.72 ←	8.87	-	6	No	1834 1836
20.0	20	8	8.73 ←	8.85	-	8	No	1831 1833
25.0	20	8	8.57 ←	8.81	-	7	No	1828 1830
30.0	20	8	8.67 ←	8.81	-	4	No	1825 1827
35.0	20	8	8.56 ←	8.74	-	3	No	1820 ↑ ↓ 1822
40.0	20	8	8.7 ←	8.75	-	3	No	1852 1854
45.0	15	8	8.51 ←	8.75	-	4	No	1856 1857
50.0	15	8	8.5 ←	8.8	-	4	No	1858 1859





SINE BEAT

National Technical Systems - Los Angeles (Continued)

3.4.1 "Z" Axis (Horizontal) SMB-000-5 Fragility Test 8 g 12/11/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
55.0	15	8	-	8.6	-	5	No	2004 See 2005 Note (2)
60.0	15 <sup>(8)</sup> (7)	8	8.9	-	-	5 + 4	No	2007 See 2009 Note (3)
70.0	15	8	-	8.75	-	2	No	2010
85.0	15	8	8.55	-	-	3	No	2011
100.0	15	8	-	8.74	-	3	No	2014
Los Angeles Post Test			8.65	8.78				



SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "X" Axis (Vertical) SMB-000-5 Fragility Test 10 g 12/16/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	-	-	-	-	-	-	Table limits reached in 8 g test for freq. below 10 Hz
6.3	6	-	-	-	-	-	-	
7.9	6	-	-	-	-	-	-	
10.0	6	10+	-	8.8	-	-	No	Table limits
	6	9	-	-	-	-	-	
12.6	6	10	-	-	-	-	No	Table limits
	6	9	-	-	-	-	-	
15.9	7	10+	-	-	-	-	No	Table limits
	5	9	-	-	-	-	-	

National Technical Systems - Los Angeles

12/18/1 P.M.

20.0	20	10	8.75	8.82	-	8	No	1546
25.0	20	10	8.66	8.77	-	5	No	1550
30.0	20	10	8.63	8.77	-	2	No	1553
35.0	20	10	8.63	8.81	-	3	No	1554
40.0	20	10	8.63	8.79	-	7	No	↓ 1514 ↑
45.0	15	10	8.66	-	-	5	No	1519
50.0	15	10	-	8.70	-	5	No	1520
55.0	15	10	8.69	-	-	1	No	1522
60.0	15	10	-	8.83	-	2	Yes	Open Operator contacts - 2.5 ms setting - OK



SINE BEAT

National Technical Systems - Los Angeles (Continued)

3.4.1 "X" Axis (Vertical) SMB-000-5 Fragility Test 10 g 12/18/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
70.0	15	10	8.65	-	-	2	No	Open Operator contacts - 2.5 ms setting - OK
85.0	15	10	-	8.80	-	3	No	Reset to 2 ms on open contacts
100.0	15	10	8.66	-	-	3	No	Reset to 2 ms on open contacts



SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "Y" Axis (Horizontal) SMB-000-5 Fragility Test 10 g 12/16/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	-	-	-	-	-	-	} Table limits reached in previous test
6.3	6	-	-	-	-	-	-	
7.9	5	10	8.7	-	-	-	No	
10.0	3 2	10 11	-	8.8	-	-	No	
12.6	6+	10+	-	-	-	-	No	Only 1 test run - results noted by g level
15.9	5 2	10+ 11	8.7	-	-	-	No	

National Technical Systems - Los Angeles

12/18/1 P.M.

20.0	20	10	8.65 ←	8.81	-	6	No	1712
25.0	20	10	8.58 ←	8.78	-	4	No	1715
30.0	20	10	8.66 ←	8.83	-	2	No	1717
35.0	20	10	8.71 ←	8.85	-	2	No	1719
40.0	20	10	-	8.81	-	3	No	1722
45.0	15 + 4	10	8.69	-	-	4	No	1734
50.0	15	10	-	8.84	-	3	No	1736
55.0	15	10	8.70	-	-	4	No	1737
60.0	15	10	-	8.94	-	4	Yes	1739





SINE BEAT

National Technical Systems - Los Angeles (Continued)

3.4.1 "Y" Axis (Horizontal) SMB-000-5 Fragility Test 10 g 12/18/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
70.0	15	10	8.63	-	-	3	Yes	1740 See Note (1)
85.0	15 + 9	10	-	8.95	-	3	Yes	1743 See Note (1)
100.0	26	10	8.76	-	-	2	Yes	1746 See Note (1)
		Los Angeles	Pre Test 8.62   8.77 Post Test 8.66   8.83					

Note: (1) Chatter > 2 msec, < 5 msec.



SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "Z" Axis (Horizontal) SMB-000-5 Fragility Test 10 g 12/16/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	2	10	-	-	-	-	No	One Test series run results noted by g level
6.3	6	10+	-	-	-	-	No	
7.9	1	10	-	-	-	-	No	
10.0	6+	10+	-	-	-	-	No	
12.6	8+	10+	-	-	-	-	No	
15.9	6+	10+	-	-	-	-	No	

National Technical Systems - Los Angeles

12/18/1 P.M.

20.0	20	10	8.71	→ 8.84	-	8	No	1954
25.0	20	10	8.62	→ 8.83	-	4	No	2003
30.0	20	10	8.62	→ 8.83	-	3	No	2006
35.0	20	10	8.67	→ 8.84	-	4	No	2013
40.0	20	10	8.56	← 8.81	-	4	No	1852↑
45.0	15	10	-	8.83	-	4	No	1854
50.0	15	10	8.67	-	-	5	No	1856
55.0	15	10	-	8.86	-	5	No	1858
60.0	15	10	8.87	-	-	4	No	1900
70.0	15	10	-	8.81	-	6	No	1938
85.0	15	10	8.68	-	-	4	No	1940
90.0	15+16	10	-	8.81	-	3	Yes <5 msec.	1942
Los Angeles			Pre Test 8.69   8.83 Post Test					



SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "X" Axis (Vertical) SMB-000-5 Fragility Test 12 g 12/16/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	-	-	-	-	-	-	Table limits reached in previous test except as noted
6.3	6	-	-	-	-	-	-	
7.9	6	-	-	-	-	-	-	
10.0	1	13	-	-	-	-	No	
12.6	6	-	-	-	-	-	-	
15.9	6	-	-	-	-	-	-	

National Technical Systems - Los Angeles

12/19/1 P.M.

20.0	20	12	8.63	→ 8.88	-	4	No	1355
25.0	20	12	8.60	→ 8.84	-	4	No	1352
30.0	20	12	8.74	→ 8.85	-	5	No	1350
35.0	20	12	8.62	→ 8.79	-	4	No	1340
40.0	20	12	8.60	→ 8.76	-	3	No	1404
45.0	15	12	8.60	-	-	2	No	1405
50.0	15	12	-	8.85	-	2	No	1406
55.0	15	12	8.60	-	-	2	Yes	1408 Note (1)
60.0	15	12	-	8.85	-	2	Yes	1410
70.0	15	12	8.70	-	-	2	No	1411
0	15	12	-	-	-	4	No	1413



SINE BEAT

National Technical Systems - Los Angeles (Continued)

3.4.1 "X" Axis (Vertical) SMB-000-5 Fragility Test 12 g 12/16/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
Repeat 85.0	15	12	8.68	8.87	-	5	No	
100.0	15 + 3	12	-	8.89	-	3	-	
			Pre Test 8.60	8.86				

Note: (1) Chatter > 2 msec, < 5 msec.





SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "Y" Axis (Horizontal) SMB-000-5 Fragility Test 12 g 12/16/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	-	-	-	-	-	-	One test run - results noted by "g" level
6.3	6	-	-	-	-	-	-	
7.9	6	-	-	-	-	-	-	
10.0	3	12	-	-	-	-	No	
12.6	6	-	-	-	-	-	No	
15.9	3	12+	-	-	-	-	No	

National Technical Systems - Los Angeles

12/19/1 A.M.

20.0	20	12	8.66	→ 8.85	-	4	No	1136
25.0	20	12	8.64	→ 8.87	-	4	No	1135
30.0	20	12	8.65	→ 8.82	-	4	No	1133
35.0	20	12	8.62	→ 8.86	-	6	No	1130
40.0	20	12	8.63	← 8.75	-	3	No	↓ 1049↑
45.0	15	12	-	8.89	-	3	No	1051
50.0	15 + 7	12	8.63	-	-	3	Yes	1055 Note (1)
55.0	15 + 3	12	-	8.85	-	1	No	1057
60.0	15	12	8.60	-	-	1	No	1059
70.0	15 + 5	12	-	8.84	-	1	Yes	1100 Note (1)



SINE BEAT

National Technical Systems - Los Angeles (Continued)

3.4.1 "Y" Axis (Horizontal) SMB-000-5 Fragility Test 12 g 12/19/1 A.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
85.0	15 + 5	12	8.71	-	-	2	Yes	1103 Note (1)
100.0	15 + 14	12	-	8.88	-	2	Yes	1105 Note (1)
	Los Angeles		{ Pre Test 8.65   8.75 Post Test 8.60   8.83					

Note: (1) Chatter > 2 msec., < 5 msec.



SINE BEAT

National Technical Systems - Chatsworth

3.4.1 "Z" Axis (Horizontal) SMB-000-5 Fragility Test 12 g 12/16/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
5.0	6	-	-	-	-	-	-	One test run - results noted by "g" level
6.3	6	-	-	-	-	-	-	
7.9	6	-	-	-	-	-	-	
10.0	6	-	-	-	-	-	-	
12.6	6	-	-	-	-	-	-	
15.9	not noted	12	-	-	-	-	No	

National Technical Systems - Los Angeles

12/19/1 A.M.

20.0	20	12	8.64	8.85	-	5	No	2025
25.0	20	12	8.64	8.79	-	3	No	2029
30.0	20	12	8.65	8.79	-	3	No	2031
35.0	20	12	8.69	8.80	-	2	No	2033
40.0	20	12	8.63	8.85	-	4	No	2055
45.0	15	12	8.81	8.84	-	3	No	2057
50.0	15	12	8.65	-	-	3	No	2058
55.0	15	12	-	8.80	-	3	No	2101
60.0	15	12	8.71	-	-	3	No	2103
70.0	15	12	-	8.82	-	4	No	2104



SINE BEAT

National Technical Systems - Los Angeles (Continued)

3.4.1 "Z" Axis (Horizontal) SMB-000-5 Fragility Test 12 g 12/18/1

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
85.0	15	12	8.78	-	-	2	No	2105
100.0	15 +11	12	-	8.83	-	3	Yes	2107 Note (1)
	Los Angeles		Post Test 8.68	8.78				

Note: (1) Chatter > 2 msec., < 5 msec.





SINE BEAT

National Technical Systems - Chatsworth

Extra

3.4.1 "X" Axis (Vertical) SMB-000-5 Fragility Test 14 g 12/19/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
20.0	20	-	-	→ -	-	-	-	Note: Limit reached previous test
25.0	20	14	8.64	→ 8.88	-	5	No	1512
30.0	10 10.	14	8.60	→ 8.90	-	4 5	No	1510 1441
35.0	20	14	8.65	→ 8.84	-	4	No	1438
40.0	20	14	-	8.81	-	6	No	1432
45.0	15	14	8.63	-	-	4	No	1430
50.0	15 + 3	14	-	8.85	-	3	Yes	1428 Note (1)
55.0	15	14	8.77	-	-	2	Yes	1427 Note (1)
60.0	15	14	-	8.85	-	2	Yes	1425 Note (1)
70.0	15	14	8.62	-	-	3	Yes	1423 Note (1)
85.0	15	14	-	8.95	-	4	No	1422
100.0	15	14	8.60	-	-	4	No	1420
			Pre Test					
			8.63	8.86				

Note: (1) > 2 msec., < 5 msec.



SINE BEAT

National Technical Systems - Los Angeles

3.4.1 "Y" Axis (Horizontal) SMB-000-5 Fragility Test 14 g 12/19/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
20.0	20	-	-	-	-	-	-	Test not run
25.0	20 + 4	14	8.62	8.91	-	5	Yes	1616 Note (1)
30.0	20	14	8.66	8.80	-	4	No	1614
35.0	20	14	8.62	8.83	-	5	No	1611↑
40.0	20	14	8.66	8.86	-	3	No	1636
45.0	15	14	-	8.82	-	4	Yes	1638 Note (1)
50.0	15	14	8.69	-	-	5	Yes	1639 Note (1)
55.0	15	14	-	8.82	-	4	Yes	1642 Note (1)
60.0	15	14	8.67	-	-	3	No @ 4 msec.	1644
70.0	15	14	-	8.83	-	3	No @ 4 msec.	1645
85.0	15	14	8.73	-	-	1	Yes	1646 Note (1)
100.0	15	14	-	8.81	-	2	Yes	1648 Note (1)
			Pre Test					
			8.59	8.85				
			Post Test					
			8.63	8.87				

Note: (1) > 2 msec., < 5 msec.



SINE BEAT

National Technical Systems - Los Angeles

3.4.1 "Z" Axis (Horizontal) SMB-000-5 Fragility Test 14 g 12/19/1 P.M.

Freq. (Hz)	No. of Beats	Level (g)	Time - Sec.		Control Signal Filter - Hz	No. of Setup Beats	Chatter Indicated @.002 sec	Remarks
			Closed-Open	Open-Closed				
20.0	20	-	-	-	-	-	-	Test not run
25.0	20	14	8.75	8.81	-	3	No	1726
30.0	20	14	8.71	8.84	-	2	Yes	1724 Note (1)
35.0	20	14	8.85	8.89	-	4	No @ 4 msec.	1722
40.0	20	14	8.61	8.86	-	5	No	1703 <sup>↑</sup>
45.0	15	14	8.70	-	-	4	No	1705
50.0	15	14	-	8.82	-	2	Yes	1707 Note (1)
55.0	15	14	8.71	-	-	4	Yes	1708 Note (1)
60.0	15	14	-	8.91	-	2	No @ 3 msec.	1710
70.0	15	14	8.69	-	-	5	No @ 3 msec.	1712
85.0	15	14	-	8.87	-	6	Yes	1714 Note (1)
100.0	15	14	8.69	-	-	4	Yes	1717 Note (1)
			Pre Test					
			8.71	8.81				
			Post Test					
			8.60	8.80				

Note: (1) > 2 msec., < 5 msec.



STONE & WEBSTER ENGINEERING CORPORATION

3 EXECUTIVE CAMPUS, P. O. BOX 5200  
CHERRY HILL, N. J. 08034

DATE	June 10, 1982
J. O. NO.	12177
P. O. NO.	NMP2-P801H
LTR. NO.	T-47, 612
REF.	FILE P801H (enc)

VIA

TO National Technical Systems Inc.  
26525 Golden Valley Road  
Saugus, California 91350  
  
Attn: Ms. Terry Hampton

DEAR SIRs:

THE FOLLOWING ARE  ATTACHED;  SENT SEPARATELY:

1	COPIES	PRINTS	REPRODUCIBLES	MICROFILM APERTURE CARDS
EACH OF				
<input type="checkbox"/>	DRAWINGS	<input type="checkbox"/>	SPECIFICATIONS	
<input checked="" type="checkbox"/>	DOCUMENTS	<input type="checkbox"/>	NOTES OF CONFERENCE	

STATUS		PLEASE NOTE	SENT FOR YOUR	
<input type="checkbox"/> FINAL	<input type="checkbox"/> APPROVED	<input type="checkbox"/> REVISIONS	<input type="checkbox"/> APPROVAL	<input type="checkbox"/> COMMENT
<input type="checkbox"/> PRELIMINARY	<input checked="" type="checkbox"/> APPROVED AS REVISED AS DEFINED IN SPECIFICATION	<input type="checkbox"/> ADDITIONS	<input checked="" type="checkbox"/> USE	<input checked="" type="checkbox"/> INFORMATION
<input type="checkbox"/> NO COMMENT	<input type="checkbox"/> UNACCEPTABLE	<input type="checkbox"/> COMMENTS	<input checked="" type="checkbox"/> FILES	<input type="checkbox"/> CONCURRENCE
<input type="checkbox"/> SUGGESTIONS AS NOTED	<input type="checkbox"/>		<input type="checkbox"/>	

YOUR ATTENTION IS DIRECTED TO THE FOLLOWING:

RELEASED FOR:  FABRICATION  PURCHASE OF NECESSARY MATERIALS

PLEASE REVISE AND SUBMIT \_\_\_\_\_ PRINTS \_\_\_\_\_ REPRODUCIBLES \_\_\_\_\_ MICROFILM APERTURE CARDS.

PLEASE SUBMIT \_\_\_\_\_ PRINTS \_\_\_\_\_ REPRODUCIBLES \_\_\_\_\_ MICROFILM APERTURE CARDS OF  DOCUMENTS  DRAWINGS  SHOP DETAIL

PLEASE RETURN ONE COPY EACH OF THIS MATERIAL BEARING YOUR APPROVAL OR COMMENTS.

PLEASE ACKNOWLEDGE RECEIPT OF THIS MATERIAL BY SIGNING AND RETURNING THE ENCLOSED COPY OF THIS FORM.

WE TRUST THAT THESE NOTES ARE IN ACCORDANCE WITH YOUR UNDERSTANDING; IF NOT, PLEASE ADVISE US.

**IMPORTANT** SHOULD ANY REVISION TO DOCUMENTS OR DRAWINGS RETURNED HERewith INVOLVE A PRICE INCREASE, THE SUPPLIER MUST NOTIFY STONE & WEBSTER PURCHASING DEPARTMENT WITHIN TEN (10) DAYS EVEN THOUGH A DEFINITE ESTIMATE CANNOT BE GIVEN AT THE TIME. OTHERWISE, THE PURCHASER WILL CONSIDER THE REVISIONS MADE WITHOUT COST.

PURCHASE ORDER NO. NMP2-P801H  
DYNAMIC TESTING OF MOTOR OPERATORS  
NINE MILE POINT NUCLEAR STATION-UNIT 2  
NIAGARA MOHAWK POWER CORPORATION

548-9291

Test Report

Rev. 1

4/12/82

NOTE: SWEC is in receipt of Rev. 2.

Very truly yours,  
**ORIGINAL**  
**SIGNED FOR:**

M. A. Durka  
Lead Mechanics Engineer

PS:JM

Copies to: RWHammelmann (enc)  
DLPracht (enc)

GMSchierberg/GLVolpe-3 245/5  
KMWhite  
Document Control Systems/Site (enc)  
Document Control/CHOC  
PStipcevich (enc)  
JMartin





**STONE & WEBSTER ENGINEERING CORPORATION**  
**REVIEW OF SUPPLIER'S TECHNICAL DOCUMENT**

▲ 5040.51B

PAGE 1 OF 1

SUPPLIER <b>NATIONAL TECHNICAL SYSTEMS</b>		P.O. NO. <b>P801H</b>	DOCUMENT TITLE <b>TEST REPORT</b>		DOC. ID. NO. <b>548-9291</b>	REV. <b>1</b>	DATE
DATE RECEIVED <input type="checkbox"/> NEW SUBMITTAL <input checked="" type="checkbox"/> RESUBMITTAL		SPEC. NO. / DATE <b>P801H</b>	REV. <b>-</b>	ADDEN. <b>2</b>	SPEC. TITLE <b>DYNAMIC TESTING OF MOTOR OPERATORS</b>		
GOVERNING CODE(S) & DATE(S)		SPECIAL REQUIREMENTS			DWG REFERENCE(S) <b>S &amp; W SUPPLIER</b>		
SPECIALIST <b>A CHAN</b>	PROJECT <b>NMP2</b>	J.O. NO. <b>12177</b>	RESPONSIBLE ENG <b>P. STIREVICH</b>	LOCATION <b>1B</b>	EXT. <b>3640</b>	DATE <b>6/7/82</b>	

COMMENTS:

**NATIONAL TECHNICAL SYSTEMS TEST REPORT # 548-9291 REVISION 2, DATED APRIL 12, 1982, HAS BEEN REVIEWED AND IS MARKED "APPROVED AS REVISED." THE FOLLOWING COMMENTS ARE TO BE INCORPORATED INTO THE REPORT**

- 1) ADD NATURAL FREQUENCY TABLE**
- 2) ADD CERTIFICATE OF COMPLIANCE**
- 3) CORRECT TABLE G.2.3 TO COMPLY WITH THE ATTACHED**
- 4) CORRECT CHATTER DURATION INDICATED IN APPENDICES F & G TO READ 0.002 SECONDS**
- 5) CORRECT PARAGRAPH 3.2, PAGE 2 FROM "TYPICAL TRS PLOTS ARE SHOWN IN FIGURES 1 & 2" TO "TYPICAL TRS PLOTS ARE SHOWN IN FIGURES 1, 2 AND 3"**

Stone & Webster  
Engineering Corporation

APPROVED AS DEFINED IN THE SPECIFICATIONS

UNACCEPTABLE

APPROVED AS REVISED AS DEFINED IN THE SPEC.

REVIEWED

J.O. No. **12177**

SPEC. No. **P801H**

DATE **6/7/82**

BY **R STIREVICH**

RESUBMITTAL REQUIRED  
 YES     NO

REVIEWER <b>P. STIREVICH</b>	DEPT./DIV. <b>ENG. / MECHANICS</b>	DATE <b>6/7/82</b>	LOCATION <b>1B</b>	EXTENSION <b>3640</b>
---------------------------------	---------------------------------------	-----------------------	-----------------------	--------------------------



6.2. Operator SMB-000-5

Test Number	Direction of Loading	TRS Figure (Appendix E)	Test Duration (seconds)	Operating Voltage (% of Nominal)	Stroke time (sec.)		Chatter > 2 msecs.	Observation
					Open to Close	Close to Open		
1	X & Z	—	—	—	—	—	—	MOUNTING BOLTS BROKE SEE C.2.3.1
2	X & Z	1 & 2	35'	80	10	10	NO	REPEAT OF TEST 1
3	X & Z	3 & 4	35'	100	10	10	NO	
4	X & Z	5 & 6	35'	110	10	10	NO	
5	X & Z	7 & 8	35'	80	10	10	NO	REPEAT OF TEST 2
6	X & Y	9 & 10	35'	80	10	10	NO	ZPA LOWER THAN REQUIRED
7	X & Y	11 & 12	35'	100	10	10	NO	
8	X & Y	13 & 14	35'	110	10	10	NO	
9	X & Y	15 & 16	35'	80	10	10	NO	REPEAT OF TEST 6 WITH HIGHER ZPA





Volume I of III  
Report Number 548-9291, Revision 1  
Dynamic Testing  
of  
Limiterque Operators  
and  
Modified Limit Switches

12 April 1982

Stone & Webster Engineering Corporation	
<input type="checkbox"/>	APPROVED AS DEFINED IN THE SPECIFICATIONS
<input type="checkbox"/>	UNACCEPTABLE
<input checked="" type="checkbox"/>	APPROVED AS REVISED AS DEFINED IN THE SPEC.
<input type="checkbox"/>	REVIEWED
J.O. No.	12177
SPEC. No.	PA01H
DATE	6/7/82
BY	P. STIPCEVICH

TESTED FOR:

STONE & WEBSTER ENGINEERING CORP.  
3 Executive Campus  
P.O. Box 5200  
Cherry Hill, NJ 08034

TESTED BY:

NATIONAL TECHNICAL SYSTEMS  
Testing Division  
20988 West Golden Triangle Road  
Canyon Country, CA 91350  
(805) 259-8184



REVISION SUMMARY

<u>Revision</u>	<u>Date</u>	<u>Page(s) Affected</u>	<u>Paragraph(s) Affected</u>
1	4/12/82	All	All

These revisions were reviewed and approved by:

Prepared By: Theresa Hampton Date: April 29, 1982  
PUBLICATIONS, Theresa Hampton

Approved By: David P. Bame Date: 4-30-82  
PROJECT MANAGER, David P. Bame

Approved By: Robert A. Ely Date: April 30, 1982  
QUALITY ASSURANCE MANAGER, Robert A. Ely





TABLE OF CONTENTS

Section	Description	Page
VOLUME I		
1.0	PURPOSE . . . . .	1
2.0	REFERENCES. . . . .	2
3.0	SUMMARY . . . . .	2
3.1	Vibration Aging Test . . . . .	2
3.2	Random Multifrequency Biaxial Test . . . . .	2
3.3	Single Axis Sine Beat Test . . . . .	5
3.4	Fragility Test . . . . .	5
4.0	TEST CONDITIONS AND TEST EQUIPMENT. . . . .	6
4.1	Test Conditions . . . . .	6
4.2	Test Equipment . . . . .	6
5.0	TEST PROCEDURE AND TEST RESULTS . . . . .	7
5.1	Specimen Preparation . . . . .	7
5.2	Baseline Test . . . . .	8
6.0	DYNAMIC TEST PROGRAM . . . . .	9
6.1	Vibration Aging . . . . .	10
6.2	Random Multifrequency Biaxial Test . . . . .	11
6.3	Sine Beat Tests . . . . .	16
6.4	Fragility Tests . . . . .	20
FIGURES		
1	Test Response Spectra (TRS) . . . . .	3
2	Test Response Spectra (TRS) . . . . .	4
3	Required Response Spectra . . . . .	14
TABLES		
I	Sine Beat Waveform Characteristics . . . . .	17
II	Sine Beat Waveform Characteristics . . . . .	21
APPENDICES		
A	Equipment List . . . . .	A-1
B	Exhibit I and II and General Data Sheets of Torque Measurements . . . . .	B-1
C	Stroke Times - Sine Beat Test and Accelerometer Locations . . . . .	C-1
VOLUME II		
D	X-Y Transmissibility Plots . . . . .	D-1



TABLE OF CONTENTS (Continued)

---

Section	Description	Page
VOLUME III		
APPENDICES		
E	Test Response Spectra Plots . . . . .	E-1
F	Seismic Sine Beat Test Data Sheets . . . . .	F-1
G	Fragility Test Data Sheets . . . . .	G-1



1.0

PURPOSE

The purpose of this report is to present the results of the tests performed on the following test articles in accordance with Stone and Webster Engineering Corporation's ESSOW Number NMP2-P801 H (Reference 2.2) and National Technical Systems Procedure Number 548-9291 (Reference 2.1). Tests were performed during the period of November 9, 1981 through December 22, 1981.

<u>Test Articles</u>	<u>Model Number or Designation</u>
Group 1: A. Limitorque motor operator	SMB-000-5 Serial Number 293417
*B. Modified limit switch (outboard) with vibration resistant screws, RTV gasket and a bracket	3B
*C. Modified limit switch (outboard) with vibration resistant screws	3C
Group 2: A. Limitorque motor operator	SMB-0-25 Serial Number 301059
*B. Modified limit switch (outboard) with vibration resistant screws, RTV gasket and a bracket	12B
*C. Modified limit switch (outboard) with vibration resistant screws	12C

\* Modified limit switches are tested only as a replacement of the operator internal limit switches, should the latter fail prior to the completion of the test program. Since no failure of the internal limit switches was observed, the outboard limit switches were not substituted into the operators and, at customer's request, test details are not included herein. However, outboard limit switch accelerometer readings have been recorded on magnetic tape and are available.



2.0 REFERENCES

- 2.1 National Technical Systems Test Procedure Number 548-9291, Revision A, dated October 29, 1981.
- 2.2 Stone & Webster Engineering Corporation's Engineering Services Scope of Work for Dynamic Testing of Motor Operators, ESSOW Number NMP2-P801H and Addenda 1 and 2.

3.0 SUMMARY

3.1 VIBRATION AGING TEST

Limitorque motor operators, types SMB-000-5 and SMB-0-25, were subjected to 90 minutes of vibration aging in each axis in accordance with IEEE-392-1980 and maintained performance consistent with pretest baseline measurements.

No chatter exceeding two milliseconds was recorded on the limit switch contacts.

3.2 RANDOM MULTIFREQUENCY BIAXIAL TEST

Operators, types SMB-000-5 and SMB-0-25, were subjected to a minimum of 105 seconds of random biaxial multifrequency input motion with a frequency content of 1 Hz to 100 Hz. These tests were performed in accordance with the requirements of Reference 2.2, for the 105 seconds, in two test orientations at the levels listed below. Typical TRS plots are shown in Figures 1 and 2.


A. Operator SMB-000-5 - minimum ZPA of 6 g's

B. Operator SMB-0-25 - minimum ZPA of 12 g's

The performance of each operator was consistent with its pretest baseline values. No chatter exceeding two milliseconds was recorded on the limit switch contacts.







Response Acceleration (g Peak)  
FIGURE 1. (TRS) Test Response Spectra

EARTHQUAKE RESPONSE  
SPECTRA Biaxial (72x72)

SPECTRUM HORIZ  VERT

EVENT OBE  SSE

OTHER Max. Capability

PERCENT DAMPING 2%

ANALYSIS BAND \_\_\_\_\_

CUSTOMER  
Stone & Webster Eng. Corp.

MJO  
548-9291

ITEM  
Limatorque Operators  
Model SMB-000-5 & SMB-0-25

P/N \_\_\_\_\_

S/N \_\_\_\_\_

AXIS X-Y  Y-Z



EARTHQUAKE RESPONSE  
SPECTRA      Biaxial (72x72)

SPECTRUM HORIZ  VERT

EVENT OBE  SSE

OTHER      Max. Capability

PERCENT DAMPING 2%

ANALYSIS BAND  
\_\_\_\_\_

CUSTOMER  
  
Stone & Webster Eng. Corp.  
MJO  
548-9291

ITEM  
  
Limitorque Operators  
Model SMR-000-5 & SMR-0-25

P/N \_\_\_\_\_

S/N \_\_\_\_\_

AXIS X-Y       Y-Z




FIGURE 2. (TRS) Test Response Spectra



3.3 SINGLE AXIS SINE BEAT TEST

Operators SMB-000-5 and SMB-0-25 were subjected to a series of sine beats in the frequency range of 5 Hz to 100 Hz at input levels of up to 6 g in accordance with Reference 2.2.

The performance of operator SMB-000-5 was consistent with pre-test baseline values except that at 100 Hz, limit switch contact chatter, exceeding two milliseconds but below five milliseconds, was observed.

The performance of operator SMB-0-25 was consistent with pretest values. No limit switch contact chatter exceeding two milliseconds was recorded.

3.4 FRAGILITY TEST

3.4.1 Operator SMB-0-25 was subjected to fragility tests in the frequency range from 5 Hz to 100 Hz at input levels of up to 14 g. The performance of the operator remained consistent with baseline values up to 11 g. Limit switch contact chatter not exceeding five milliseconds was observed at 14 g.

3.4.2 Operator SMB-000-5 was subjected to fragility tests in the frequency range from 5 Hz to 100 Hz at input levels up to 14 g. The performance of the operator was consistent with baseline values except that limit switch contact chatter exceeding two milliseconds, but below five milliseconds, was observed during these tests.

Operator SMB-000-5 experienced torque switch contact chatter resulting in incomplete operator strokes at 8 g's between the frequencies of 15.9 Hz and 25 Hz. After adjusting the torque switch contacts in accordance with Attachment Number 5 of Reference 2.2, the fragility tests in the frequency range of 5 Hz to 100 Hz were completed without torque switch chatter up to 14 g.



4.0 TEST CONDITIONS AND TEST EQUIPMENT

4.1 TEST CONDITIONS

Unless otherwise specified herein, all tests were performed at room ambient conditions defined as a temperature of  $73 \pm 18^{\circ}\text{F}$  ( $23 \pm 10^{\circ}\text{C}$ ), a relative humidity of  $50 \pm 30$  percent, and a barometric pressure of  $28.5 +2.0, -3.0$  inches of mercury absolute ( $725 +50, -75$  mm of mercury absolute).

4.2 TEST EQUIPMENT

The test equipment tabulated in Appendix A was calibrated, as required, in accordance with MIL-C-45662A and is traceable to the National Bureau of Standards (NBS). The NBS traceability records are maintained on file in the NTS Quality Assurance Office.





5.0 TEST PROCEDURES AND TEST RESULTS

5.1 SPECIMEN PREPARATION

5.1.1 An examination of the specimens indicated that, with the exception of the SMB-000-5 operator limit switch, all the external bolts and screws were tight. The limit switch assembly and mounting screws of the SMB-000-5 operator were loose.

5.1.2 The limit switch contacts were inspected and adjusted in accordance with Exhibit I of Appendix B. Records of inspection and adjustments are presented in Exhibit II of Appendix B. Approximately 15 percent of the contacts required adjustment.

At the request of the customer's representative, one contact (numbered 9 on the limit switch) on each limit switch was readjusted for only a 0.005 inch gap. The purpose of introducing this out-of-specification gap was to enable the customer to determine the need for contact adjustment.

5.1.3 All the limit switch screws were tightened at the customer's direction to the values shown in Exhibit II of Appendix B. Screw identification and the corresponding torque values are also presented in Appendix B. Lower torque values were used for some screws, as noted in the data sheets, either to avoid possible damage to the plastic fingerbase or as limited by the capacity of the slotted screw heads used.

During the tightening process, a fingerbase of the SMB-0-25 operator was slightly damaged under a screw head which had a star washer. At the customer's request the damaged fingerbase was replaced with one removed from a spare limit switch.



5.2 BASELINE TEST

5.2.1 Specimens in each group were individually mounted on the customer furnished fixtures. The fixtures were capable of simulating seating torque on the operators. The modified limit switches were rigidly mounted on the fixtures such that their heights and orientations were identical to the switch position in the operators.

5.2.2 Operator mounting bolts were torqued as follows:

<u>Operator</u>	<u>Number and Size of Bolt</u>	<u>Torque</u>
SMB-000-5	4 x 5/16" diameter	16.5 ft/lbs (lubricated)
SMB-0-25	4 x 3/4" diameter	138 ft/lbs (lubricated)

5.2.3 All the limit switches were set by Limitorque personnel to provide a stroke of approximately 1-3/4 inches.

5.2.4 Operators were wired in accordance with the wiring diagram of Reference 2.2. Each operator was stroked through a complete cycle at 80, 100 and 110 percent of the nominal voltage. Stroke times were recorded and are presented in Appendix C.

5.2.5 All the limit switch screws, as well as the operator mounting and motor mounting bolts, were torque-stripped to provide a visual indication of screw looseness.



6.0

DYNAMIC TEST PROGRAM

The operators and modified limit switches were mounted on a test fixture plate supplied by the customer as described in Paragraph 5.2. The mounting bolts were torqued to the values in Reference 2.2. An operator stem was also supplied by the customer for the tests and were used in conjunction with the mounting plate to allow the operator to develop seating loads.

The operators were wired in accordance with Reference 2.2. The lower (spare) contacts of the limit switch were monitored for chatter on two channels. One channel monitored all the normally open contacts, connected in series. The other channel monitored all the normally closed contacts, connected in series. The interval of chatter being monitored by the test equipment ranged from two microseconds to 100 milliseconds. The chatter interval was set at two milliseconds.

The tests were performed on the shaker tables listed below for the following tests:

<u>Test</u>	<u>Shake Table</u>
Vibration Aging	Electrodynamic
Random Multifrequency Biaxial	Hydraulic
Sine Beat and Fragility	The tests performed at the Chatsworth facility were performed on the hydraulic shake table and those performed at the LAX facility were performed on the electrodynamic table. Test logs in Appendices F and G indicate the facility where the tests were conducted.

Twenty-three accelerometers were used to monitor the dynamic response during the vibration aging, random multifrequency and the sine beat tests. Twelve accelerometers were used during the fragility tests.

Accelerometer locations are shown in Appendix C. Accelerometer data were recorded on strip recorders and on magnetic tapes.



6.1 VIBRATION AGING

- 6.1.1 Operators SMB-0-25 and SMB-000-5 were exposed to sinusoidal motion at the level of 0.75 g or 0.025 inch double amplitude displacement with the frequency sweeping from 5 Hz to 200 Hz at a rate of two-octaves per minute. Ninety minutes of vibration was applied in each orthogonal axis. The operators were stroked every 7-1/2 minutes to change state.
- 6.1.2 Transmissibility plots (Response Acceleration/Input Acceleration versus Frequency) are provided in Appendix D. Stroke times observed throughout the test were consistent with those recorded in the Baseline tests, Paragraph 5.2.
- 6.1.3 No chatter was observed during this test. Examination of the torque stripes and comparisons of acceleration response at the start of the test and at the end of the test did not indicate loose screws.





6.2 RANDOM MULTIFREQUENCY BIAXIAL TEST

6.2.1 Operators SMB-0-25 and SMB-000-5 were subjected to several random multifrequency input motions applied biaxially along one principal horizontal axis and the vertical axis simultaneously. Operators, mounted on the test fixtures, were rotated 90° in the horizontal plane and the tests repeated. The input motions in the two axes were phase independent with frequencies from 1 Hz to 100 Hz. Amplitudes of the 1/12-octave frequency bands were adjusted to obtain the desired TRS of the horizontal and vertical input motions. Test Response Spectra (TRS) are provided in Appendix E. The number of tests, test directions, axes of loadings and results are described below.

6.2.2 Operator SMB-0-25

Test Number	Direction of Loading	TRS Figure	Test Duration (seconds)	Operating Voltage (% of nominal)	Shake Time		Chatter > 2 milliseconds	Observations
					Open to Close	Close to Open		
1	X	1	35	80	5	5	No	No Z Input
2	X & Z	2 & 3	35	80	5	5	No	
3	X & Z	4 & 5	35	100	5	5	No	
4	X & Z	6 & 7	35	110	5	5	No	
5	X & Y	8 through 12	27	80	5	5	No	Mounting Bolts came Loose. See 6.2.2.1
6	X & Y	13 & 14	35	100	5	5	No	
7	X & Y	15 & 16	35	110	5	5	No	
8	X & Y	17 through 21	35	80	5	5	No	



6.2.2.1 At approximately 27 seconds after the start of the test, the operator was observed to have come loose. The test was stopped immediately. Examination of the operator revealed that the operator mounting screws had come loose and that there was a considerable amount of localized deformation of the aluminum mounting plate under the bolt heads.

The Customer's representative determined that a combination of the small bearing area under the socket head mounting bolts and the low bearing capacity of the aluminum mounting plate had resulted in excessive deformation of the mounting plate under the bolt head, which in turn caused loosening of the bolts. In order to properly distribute the bolt loads, 3/16 inch thick steel washers were placed under the bolts and the test was continued. The results are described below.

6.2.3 Operator SMB-000-5

Test Number	Direction of Loading	IRS Figure (Appendix E)	Test Duration (seconds)	Operating Voltage (% of nominal)	Stroke Time (sec.)		Chatter > 2 milliseconds	Observations
					Open to Close	Close to Open		
1	X & Z	1 & 2	35	80	10	10	No	Mounting Bolts Broke See 6.2.3.1
2	X & Z	3 & 4	35	100	10	10	No	
3	X & Z	5 & 6	35	110	10	10	No	
4	X & Z	7 & 8	35	80	10	10	No	Repeat of Test 1
5	X & Y	9 & 10	27	80	10	10	No	ZPA Lower than required
6	X & Y	11 & 12	35	100	10	10	No	
7	X & Y	13 & 14	35	110	10	10	No	
8	X & Y	15 & 16	35	80	10	10	No	Repeat of Test 5 with Higher ZPA



6.2.3.1 Just before the table motion was brought to full level, the operator was observed to have come loose. The test was stopped immediately.

Examination of the operator revealed that two of the four mounting bolts had sheared off and the other two were loose. Also, there was a considerable amount of local deformation of the aluminum base plate under the bolt (mounting) heads as well as on the walls of the bolt holes.

The Customer's representative concluded that the cause of the bolt failure was due to insufficient bearing capacity of the aluminum mounting plate. Steel washers 3/16 inch thick were placed under the bolt heads and the bolts were tightened to 24 ft/lbs torque (dry) instead of the previously used torque of 16 ft/lbs (lubricated). Also, the test input levels were reduced to envelope the RRS of Figure 3.






FIGURE 3. Required Response Spectra





6.2.4

Post-test examinations did not indicate any physical damage to the operators. All the screws and mounting bolts were tight. Operators were stroked at the nominal voltage and the stroke times were consistent with those recorded in the base-line tests.



6.3

SINE BEAT TESTS

Operators SMB-0-25 and SMB-000-5 were subjected to a series of sine beat tests in accordance with Table I. Initially, at least a 1.5 second pause between beats was used. After examining the response acceleration traces and confirming that the response decayed much more rapidly at higher frequencies, the minimum pause between beats was reduced as follows:

<u>Frequency Range</u>	<u>Pause Time</u>
5 Hz to 25 Hz	1.5 second
30 Hz to 50 Hz	1.0 second
55 Hz to 100 Hz	0.75 second

A detailed log of the test is provided in Appendix F.



TABLE I

SINE BEAT WAVEFORM CHARACTERISTICS

The input acceleration magnitude shall produce a peak response of 6.0 g for each beat at the operator base.

Test Frequency (Hz)	Number of Beats	Oscillations Per Beat
5.0	6	15
6.3	6	15
7.9	6	15
10.0	6	15
12.6	6	15
15.9	6	15
20.0	6	15
25.0	6	15
30.0	6	15
35.0	6	15

The input acceleration magnitude shall produce a peak response of 4.6 g for each beat at the operator base.

Test Frequency (Hz)	Number of Beats	Oscillations Per Beat
10.0	10	10
12.6	10	10
15.9	10	10
20.0	10	10
25.0	10	10
30.0	10	10
35.0	10	10
40.0	10	10
45.0	10	10
50.0	10	10
55.0	10	10
60.0	10	10
70.0	10	10
85.0	10	10
100.0	10	10



TABLE I (Continued)

SINE BEAT WAVEFORM CHARACTERISTICS

The input acceleration magnitude shall produce a peak response of 3.5 g for each beat at the operator base.

Test Frequency (Hz)	Number of Beats	Oscillations Per Beat
10.0	40	10
12.6	40	10
15.9	40	10
20.0	40	10
25.0	40	10
30.0	40	10
35.0	40	10
40.0	40	10
45.0	40	10
50.0	40	10
55.0	40	10
60.0	40	10
70.0	5	10
85.0	5	10
100.0	5	10

The input acceleration magnitude shall produce a peak response of 2.0 g for each beat at the operator base.

Test Frequency (Hz)	Number of Beats	Oscillations Per Beat
10.00	100	10
12.6	100	10
15.9	100	10
20.0	100	10
25.0	100	10
30.0	100	10
35.0	100	10
40.0	100	10
45.0	100	10
50.0	100	10
55.0	100	10
60.0	100	10
70.0	20	10
85.0	20	10
100.0	20	10





6.3.1 Operator SMB-0-25

The operator was functional throughout the test and maintained a consistant stroke time. There was no chatter exceeding two milliseconds observed during this test.

6.3.2 Operator SMB-000-5

The operator was functional throughout the test and maintained a consistant stroke time. Except at 100 Hz, there was no chatter exceeding two milliseconds observed. At 100 Hz chatter was observed to be within five milliseconds.



6.4 FRAGILITY TESTS

Operators SMB-0-25 and SMB-000-5 were subjected to a series of sine beat tests in each axis at incremental acceleration levels. The test frequencies, number of beats at each test frequency, and oscillations per beat at each acceleration level are described in Table II. Tests were performed at each of the following acceleration levels.

SMB-0-25: 8 g 12 g and 14 g

SMB-000-5: 8 g 10 g 12 g and 14 g

Due to test table limitations, the highest input accelerations ranged from 9 g. to 12 g in the frequency range of 5 Hz to 15.9 Hz. Detailed records are provided in the test log in Appendix G. Significant observations are listed herein.

6.4.1 SMB-0-25

Operator SMB-0-25 was tested up to an acceleration level of 14 g. Operator performance was consistent with the baseline data. Chatter was within two milliseconds up to an input acceleration of 11 g. Between 11 g and 14 g, chatter in excess of two milliseconds, up to a maximum of five milliseconds, was observed.

6.4.2 SMB-000-5

Operator SMB-000-5 was tested up to an acceleration level of 14 g. Operator performance was consistent with baseline data. During the 8 g test at frequencies of 15.9 Hz, 20 Hz and 25 Hz the operator failed to complete the stroke. The test was temporarily suspended until an inspection of the operator could be performed. The manufacturer's representative, upon inspection, concluded that the torque switch contact pressure was insufficient, resulting in contact chatter. Contact gaps were adjusted in accordance with Exhibit I of Appendix B. Note that the torque switch contacts were not inspected or adjusted prior to the start of the test. There was no recurrence of this condition anytime during the remainder of the test program.

Throughout this test, chatter exceeded two milliseconds. The chatter indicator interval was increased to five milliseconds. No chatter exceeding five milliseconds was observed.

6.4.3 A post test visual examination of the specimens did not reveal any physical damage. All the screws and mounting bolts were determined to be tight.



TABLE II  
SINE BEAT WAVEFORM CHARACTERISTICS

Test Frequency (Hz)	Number of Beats	Oscillations Per Beat
5.0	6	15
6.3	6	15
7.9	6	15
10.0	6	15
12.6	6	15
15.9	6	15
20.0	20	15
25.0	20	15
30.0	20	15
35.0	20	15
40.0	20	15
45.0	15	10
50.0	15	10
55.0	15	10
60.0	15	10
70.0	15	10
85.0	15	10
100.0	15	10



APPENDIX A  
Equipment List





SEISMIC TEST

NTS Number D932V  
Instrument Servo Controller  
Manufacturer Shore Western Manufacturing Company  
Model Number SC 1329C  
Serial Number None  
Type Electronic single/dual loop  
Range 0 to 10" stroke  
Accuracy  $\pm 5\%$  full scale  
Calibration N/A

NTS Number D991V  
Instrument X-Y Display  
Manufacturer Spectral Dynamics Corporation  
Model Number 13116  
Serial Number 400  
Type Cathode Ray Tube  
Linearity 3%

NTS Number D992V  
Instrument Shock Spectrum Analyzer  
Manufacturer Spectral Dynamics Corporation  
Model Number 13231 (Part of SD321 System)  
Serial Number 21  
Special Note Companion to D993V  
Resolution 0 to 100 volts  
Frequency Range 1 Hz to 10 kHz  
Calibration 12 months (Cal. due 4-6-82)

NTS Number D993V  
Instrument Transient Memory  
Manufacturer Spectral Dynamics Corporation  
Model Number 13192 (Part of SD321 System)  
Serial Number 24  
Special Note Companion to D992V  
Calibration 12 months (Cal. due 4-6-82)

NTS Number D1010V  
Instrument X-Y Plotter  
Manufacturer Esterline Angus, Inc.  
Model Number XY575  
Serial Number 976142  
Accuracy  $\pm 0.25\%$  full scale  
Maximum Input  $\pm 15$  volts DC  
Calibration 6 months (Cal. due 5-19-82)



NTS Number D1025V  
 Instrument Sweep Oscillator  
 Manufacturer Unholtz-Dickie Corporation  
 Model Number OSC-1  
 Serial Number 132  
 Frequency Range 2 Hz to 5,000 Hz  
 Calibration 6 months (Cal. due 1-15-82)

NTS Number D1026V  
 Instrument Servo Programmer  
 Manufacturer Unholtz-Dickie Corporation  
 Model Number SPA-7  
 Serial Number 107  
 Frequency Range 5 Hz to 10,000 Hz  
 Range more than 80DB dynamic range  
 Special Features 7 crossovers  
 Calibration 6 months (Cal. due 4-14-82)

NTS Number D1071V  
 Instrument Seismic Signal Synthesizer  
 Manufacturer Bird Enterprises  
 Model Number None  
 Serial Number 102  
 Bandwidth 1/6 octave  
 Frequency Range 0.92 to 32.0 Hz  
 Calibration Prior to test

NTS Number D1204V  
 Instrument Oscilloscope, 18 Channel  
 Manufacturer Honeywell, Inc.  
 Model Number 1858  
 Serial Number 2461 MK 74  
 Range depends on plug-in used  
 frequency response  
 DC to 5 kHz sine,  
 15 kHz square wave  
 up to 7.2 in trace amplitude  
 Accuracy depends on plug-in used  
 Calibration Prior to Test

NTS Number D1221V  
 Instrument Sine Beat Computer  
 Manufacturer Ohio Scientific  
 Model Number Challenger 8  
 Serial Number None  
 Calibration N/A



NTS Number D1222V  
 Instrument Disk Drive  
 Manufacturer Ohio Scientific  
 Model Number None  
 Serial Number None  
 Calibration N/A

NTS Number D1223V  
 Instrument Keyboard  
 Manufacturer Ohio Scientific  
 Model Number None  
 Serial Number None  
 Calibration N/A

NTS Number D1225V  
 Instrument Color Monitor  
 Manufacturer Gold Star  
 Model Number GS  
 Serial Number None  
 Calibration N/A

NTS Number D1226V  
 Instrument FM Tape Recorder  
 Manufacturer Sangamo-Weston  
 Model Number Sabre VI  
 Serial Number None  
 Calibration Prior to Test

NTS Number D1227V  
 Instrument Color Video Camera  
 Manufacturer Panasonic  
 Model Number PK-800  
 Serial Number None  
 Calibration N/A

NTS Number D1228V  
 Instrument Portable VCR  
 Manufacturer Quasar  
 Model Number VH 5300  
 Serial Number SBO 2610631  
 Calibration N/A

NTS Number D1232V  
 Instrument Oscillograph, 18 Channel  
 Manufacturer Honeywell, Inc.  
 Model Number 1858  
 Serial Number 2209DB78  
 Range Depends on plug-ins  
 Type Fiber Optic  
 Calibration 12 months (Cal. due 7-20-82)



NTS Number D1249V  
Instrument Accelerometer  
Manufacturer PCB Piezotronics, Inc.  
Model Number 308B  
Serial Number 8281  
Range 50 g/5000 g max/1-3 kHz  
Accuracy 0.5% to 1 kHz  
Sensitivity 99.6 mV/g @ 100 Hz, 8 g's pk  
Output Bias level 11.3 volts  
Calibration 6 months (Cal. due 1-8-82)

NTS Number D1250V  
Instrument Accelerometer  
Manufacturer PCB Piezotronics, Inc.  
Model Number 308B  
Serial Number 8282  
Range 50 g/5000 g max/1-3 kHz  
Accuracy 0.5% to 1 kHz  
Sensitivity 99.6 mv/g @ 100 Hz, 8 g's pk  
Output Bias level 11.2 volts  
Calibration 6 months (Cal. due 1-8-82)

NTS Number D1251V  
Instrument Charge and Voltage Amplifier  
Manufacturer PCB Piezotronics, Inc.  
Model Number 464M10  
Serial Number 647  
Range 1 to 50 k units/12 ranges  
Accuracy .01 to 110 PC/Unit  
1 and 2 (Black Scale):  $\pm 5\%$   
other ranges:  $\pm 1\%$   
Amp Linearity,  $\pm 10V$ :  $\pm 0.1\%$   
Sensitivity DC drift:  $\pm 1MV$ , 8 hours  
Output .01 to 110 PC/Unit  
Calibration  $\pm 10 V$ ,  $\pm 50 mA$  Max, 2 ohms  
Prior to Test





NTS Number D1252V  
 Instrument Charge and Voltage Amplifier  
 Manufacturer PCB Piezotronics, Inc.  
 Model Number 464 MIO  
 Serial Number 648  
 Range 1 to 50 k Units/12 ranges  
 0.1 to 110 PC/Units

Accuracy 1 and 2 (Black Scale):  $\pm 5\%$   
 Other Ranges:  $\pm 1\%$   
 Amp Linearity,  $\pm 10$  V:  $\pm 0.1\%$   
 DC drift:  $\pm 1$  MV, 8 hours  
 Sensitivity .01 to 100 PC/Unit  
 Output  $\pm 10$  V,  $\pm 50$  mA Max, 2 ohms  
 Calibration Prior to Test

NTS Number E1058V  
 Instrument Servo Controller  
 Manufacturer Shore Western Manufacturing Company  
 Model Number SC 1125SP  
 Serial Number None  
 Range 0 to 10 inch stroke  
 Accuracy  $\pm 5\%$  full scale  
 Calibration N/A

NTS Number E1078V  
 Instrument Line Impedance Stabilization Network  
 Manufacturer Solar Electronics Company  
 Model Number None  
 Serial Number 7413320  
 Type 6338-5-TS-50N  
 Range 5 UH, 50 Amp: 600 Vdc maximum  
 285 Vac 60 cycles maximum  
 Calibration Prior to Test

NTS Number E1177V  
 Instrument Oscilloscope  
 Manufacturer Tektonix, Inc.  
 Model Number T922  
 Serial Number B010331  
 Calibration 6 months (Cal. due 2-15-82)

NTS Number E1259V  
 Instrument Variable Transformer  
 Manufacturer AETL  
 Model Number None  
 Serial Number None  
 Range 3 phase, 30 Amp, 600 Vac  
 Type 440 Vac  
 Special Note with motor controller  
 Calibration N/A



NTS Number G502V  
Instrument Torque Wrench  
Manufacturer Herbrand  
Model Number FJ-300-1  
Serial Number 0157360  
Range 0 to 300 inch-pounds  
Accuracy  $\pm 3\%$   
Calibration 12 months (Cal. due 5-5-82)

NTS Number G599V  
Instrument Timer  
Manufacturer Standard Electric Products Company  
Model Number J5310  
Serial Number None  
Range 0 to 60 minutes by 0.2 second;  
Accuracy  $\pm 0.1\%$   
Calibration 1 year (Cal. due 3-23-82)

NTS Number G603V  
Instrument Torque Wrench  
Manufacturer S-K Tools  
Model Number 74015  
Serial Number 7465842  
Type Beam  
Accuracy  $\pm 2\%$   
Calibration 12 months (Cal. due 5-5-82)

NTS Number G614V  
Instrument Closed Circuit TV Camera  
Manufacturer Panasonic  
Model Number WV-401  
Serial Number 774646  
Resolution 500 lines at center  
Aperature F1.6  
Minimum Illumination 2-foot candles  
Focal Length 16 mm  
Calibration N/A

NTS Number G615V  
Instrument Video Monitor  
Manufacturer Panasonic  
Model Number WV-411  
Serial Number None  
Calibration N/A



NTS Number G616V  
Instrument Video Monitor  
Manufacturer Panasonic  
Model Number WV-411  
Serial Number 770849  
Size 9 inch  
Number of Channels 3  
Resolution 500 lines at center  
Calibration N/A

NTS Number G617V  
Instrument Video Monitor  
Manufacturer Panasonic  
Model Number WV-411  
Serial Number 770849  
Size 9 inch  
Number of Channels 3  
Resolution 500 lines at center  
Calibration N/A

NTS Number G618V  
Instrument Remove Control Box  
Manufacturer Panasonic  
Model Number WV-433  
Serial Number 6Y0002  
Number of Channels 3  
Special Features Controls panning heads  
Calibration N/A

NTS Number G619V  
Instrument Pan Head  
Manufacturer Panasonic  
Model Number WV-431  
Serial Number 680060  
Range 300° degree panning angle  
Calibration N/A

NTS Number None  
Instrument Seismic Simulator  
Manufacturer National Technical Systems  
Model Number None  
Serial Number None  
Type 36 x 36  
Calibration N/A



VIBRATION TEST

NTS Number D136L  
Instrument Accelerometer  
Manufacturer Endevco Corporation  
Model Number 2242M4  
Serial Number 8805  
Type Piezoelectric  
Range "Frequency" 5 to 6000 cps  
"Shock" 0 to 2000 g's  
"V.B." 0 to 1000 peak g's  
Accuracy "Frequency Response"  $\pm 5\%$   
"Amp. Linearity"  $\pm 1\%$   
Calibration 6 months (Cal. due 4-19-82)

NTS Number D144L  
Instrument Charge Amplifier  
Manufacturer Unholtz-Dickie Corporation  
Model Number D11MGV-8  
Serial Number C407  
Range Filter A: 5 kHz  
Filter B: 10 kHz  
Calibration Prior to Use

NTS Number D145L  
Instrument Charge Amplifier  
Manufacturer Unholtz-Dickie Corporation  
Model Number D11MGV-8  
Serial Number C408  
Range Filter A: 5 kHz  
Filter B: 10 kHz  
Calibration Prior to Use

NTS Number D146L  
Instrument Charge Amplifier  
Manufacturer Unholtz-Dickie Corporation  
Model Number D11MGV-8  
Serial Number C409  
Range Filter A: 5 kHz  
Filter B: 10 kHz  
Calibration Prior to Use

NTS Number D147L  
Instrument Charge Amplifier  
Manufacturer Unholtz-Dickie Corporation  
Model Number D11MGV-8  
Serial Number C410  
Range Filter A: 5 kHz  
Filter B: 10 kHz  
Calibration Prior to Use





NTS Number D149L  
 Instrument Charge Amplifier  
 Manufacturer Unholtz-Dickie Corporation  
 Model Number D11MGV-8  
 Serial Number C412  
 Range Filter A: 5 kHz  
 Filter B: 10 kHz  
 Calibration Prior to Use

NTS Number D173L  
 Instrument Accelerometer  
 Manufacturer Endevco Corporation  
 Model Number 2242  
 Serial Number AA53  
 Type Piezoelectric  
 Range "Frequency" 50 to 6000 Hz  
 "Shock" 0 to 2000 g  
 "Vibration" 0 to 1000 peak g  
 Frequency Response ±5%  
 Amplitude Linearity ±1%  
 Calibration 6 months (Cal. due 1-16-82)

NTS. Number D201L  
 Instrument Accelerometer  
 Manufacturer Bruel & Kjaer  
 Model Number 8303  
 Serial Number 345037  
 Type Piezoelectric  
 Range 200-15 kHz; 0-10 K g's  
 Accuracy ±2%  
 Calibration 3 months (Cal. due 1-30-82)

NTS Number D289L  
 Instrument Accelerometer  
 Manufacturer Endevco Corporation  
 Model Number 2242  
 Serial Number AA24 (Body #428-71)  
 Type Piezoelectric  
 Frequency Range 3 to 6 kHz  
 "Vibration" 0 to 1 K g's  
 "Shock" 0 to 2 K g's  
 "Output" 10 mV/g  
 Accuracy ±1%  
 Calibration 6 months (Cal. due 1-31-82)



NTS Number D292L  
 Instrument Accelerometer  
 Manufacturer Endevco Corporation  
 Model Number 2242  
 Serial Number AA32  
 Type Piezoelectric  
 Frequency Range 3 to 6 kHz  
 "Vibration" 0 to 1 K g's  
 "Shock" 0 to 2 K g's  
 "Output" 10 mV/g  
 Accuracy ±1%  
 Calibration 6 months (Cal. due 4-19-82)

NTS Number D293L  
 Instrument Accelerometer  
 Manufacturer Endevco Corporation  
 Model Number 2242-M4  
 Serial Number 7893  
 Accuracy ±5.0%  
 Calibration 6 months (Cal. due 1-31-82)

NTS Number D472L  
 Instrument Accelerometer  
 Manufacturer Endevco Corporation  
 Model Number 2242  
 Serial Number 4814/42-A054  
 Range "Frequency" 3-6 kHz  
 "Vibration" 0-1 K g's  
 "Shock" 0-2 K g's  
 "Output" 10 mV/g  
 Accuracy ±1%  
 Type Piezoelectric  
 Calibration 6 months (Cal. due 1-31-82)

NTS Number D473L  
 Instrument Accelerometer  
 Manufacturer Endevco Corporation  
 Model Number 2242  
 Serial Number 1737/42-344  
 Range "Frequency" 3-6 kHz  
 "Vibration" 0-1 K g's  
 "Shock" 0-2 K g's  
 "Output" 10 mV/g  
 Accuracy ±1%  
 Type Piezoelectric  
 Calibration 6 months (Cal. due 2-3-82)



NTS Number D474L  
Instrument Accelerometer  
Manufacturer Endevco Corporation  
Model Number 2242  
Serial Number 8810/42-A471  
Range "Frequency" 3-6 kHz  
"Vibration" 0-1 K g's  
"Shock" 0-2 K g's  
"Output" 10 mV/g  
Accuracy ±1%  
Type Piezoelectric  
Calibration 6 months (Cal. due 1-31-82)

NTS Number D476L  
Instrument Accelerometer  
Manufacturer Endevco Corporation  
Model Number 2242  
Serial Number AA20/42-A096  
Range "Frequency" 3-6 kHz  
"Vibration" 0-1 K g's  
"Shock" 0-2 K g's  
"Output" 10 mV/g  
Accuracy ±1%  
Type Piezoelectric  
Calibration 6 months (Cal. due 1-30-82)

NTS Number D477L  
Instrument Accelerometer  
Manufacturer Endevco Corporation  
Model Number 2242  
Serial Number 4808/42-A063  
Range "Frequency" 3-6 kHz  
"Vibration" 0-1 K g's  
"Shock" 0-2 K g's  
"Output" 10 mV/g  
Accuracy ±1%  
Type Piezoelectric  
Calibration 6 months (Cal. due 1-31-82)

NTS Number D479L  
Instrument Accelerometer  
Manufacturer Endevco Corporation  
Model Number 2242  
Serial Number 1718/42-060  
Range "Frequency" 3-6 kHz  
"Vibration" 0-1 K g's  
"Shock" 0-2 K g's  
"Output" 10 mV/g  
Accuracy ±1%  
Type Piezoelectric  
Calibration 6 months (Cal. due 4-19-82)



NTS Number D490L  
Instrument Accelerometer  
Manufacturer Endevco Corporation  
Model Number 2226C  
Serial Number CX90  
Range "Frequency Response" 2 to 5000 Hz  
"Vibration" 0 to 1000 g's  
"Shock" 0 to 2000 g's  
Accuracy ±2%  
Calibration 6 months (Cal. due 1-30-82)

NTS Number D491L  
Instrument Accelerometer  
Manufacturer Endevco Corporation  
Model Number 2226C  
Serial Number CX77  
Range "Frequency Response" 2 to 5000 Hz  
"Vibration" 0 to 1000 g's  
"Shock" 0 to 2000 g's  
Accuracy ±2%  
Calibration 6 months (Cal. due 1-14-82)

NTS Number D520L  
Instrument Accelerometer  
Manufacturer Endevco Corporation  
Model Number 2224C  
Serial Number GA33  
Range 0 to 1000 g  
Accuracy ±5.0%  
Calibration 6 months (Cal. due 1-13-82)

NTS Number D525L  
Instrument Ensemble Averager  
Manufacturer Spectral Dynamics Corporation  
Model Number SD309  
Serial Number 109  
Range 1 to 1024 ensembles, 10 Hz to 20 kHz  
Calibration 12 months (Cal. due 1-29-82)

NTS Number D543L  
Instrument Charge Amplifier  
Manufacturer Unholtz-Dickie Corporation  
Model Number 8 PMC  
Serial Number None  
Range 1 to 100 g  
Accuracy ±1.0%  
Calibration Prior to Use





NTS Number D544L  
Instrument Charge Amplifier  
Manufacturer Unholtz-Dickie Corporation  
Model Number 8 PMC  
Serial Number None  
Range 1 to 100 g  
Accuracy  $\pm 1.0\%$   
Calibration Prior to Use

NTS Number D549L  
Instrument Charge Amplifier  
Manufacturer Unholtz-Dickie Corporation  
Model Number 8 PMC  
Serial Number None  
Range 1 to 100 g  
Accuracy  $\pm 1.0\%$   
Calibration Prior to Use

NTS Number D552L  
Instrument Charge Amplifier  
Manufacturer Unholtz-Dickie Corporation  
Model Number 8 PMC  
Serial Number None  
Range 1 to 100 g  
Accuracy  $\pm 1.0\%$   
Calibration Prior to Use

NTS Number D560L  
Instrument Charge Amplifier  
Manufacturer Unholtz-Dickie Corporation  
Model Number 8 PMC  
Serial Number None  
Range 1 to 100 g  
Accuracy  $\pm 1.0\%$   
Calibration Prior to Use

NTS Number D562L  
Instrument Charge Amplifier  
Manufacturer Unholtz-Dickie Corporation  
Model Number 8 PMC  
Serial Number None  
Range 1 to 100 g  
Accuracy  $\pm 1.0\%$   
Calibration Prior to Use

NTS Number D565L  
Instrument Automatic Sigma Clipper/Mixer  
Manufacturer National Technical Systems, LAX  
Model Number NTSL1  
Serial Number None  
Calibration Prior to Use



NTS Number D532V  
Instrument Accelerometer Standard  
Manufacturer Endevco Corporation  
Model Number 2215E  
Serial Number NA99  
Type Piezoelectric  
Accuracy  $\pm 2\%$   
Calibration 6 months (Cal. due 1-16-82)

NTS Number D571V  
Instrument Accelerometer  
Manufacturer Endevco Corporation  
Model Number 2220C  
Serial Number RE77  
Type Piezoelectric  
Range "Maximum Acceleration"  
 $\pm 1000$  g (sine)  
 $\pm 5000$  g (shock)  
"Temperature Range"  $-65^{\circ}\text{F}$  to  $300^{\circ}\text{F}$   
Frequency Range 2 to 10,000 Hz  
Accuracy  $\pm 3\%$   
Calibration 6 months (Cal. due 4-13-82)

NTS Number D663V  
Instrument Accelerometer  
Manufacturer Endevco Corporation  
Model Number 2224C  
Serial Number DA09  
Type Piezoelectric  
Frequency Range 2 to 6000 Hz  
Maximum Acceleration  $\pm 1000$  g (sine)  
Accuracy  $\pm 2.5\%$   
Calibration "Maximum Shock"  $\pm 2000$  g  
6 months (Cal. due 2-3-82)

NTS Number D655V  
Instrument Accelerometer  
Manufacturer Endevco Corporation  
Model Number 2217 M2  
Serial Number Q851  
Type Piezoelectric  
Range "Frequency" 4 to 6000 Hz  
"Vibration"  $\pm 1000$  peak g (sine)  
"Maximum Shock"  $\pm 2000$  g  
Frequency Response  $\pm 5\%$   
Accuracy  $\pm 2\%$   
Calibration 6 months (Cal. due 4-2-82)



NTS Number D703V  
Instrument Charge Amplifier  
Manufacturer Unholtz-Dickie Corporation  
Model Number 8 PMCV  
Serial Number None  
Range 1 to 100 mV or PCmB/g;  
0 to 1000 g in 7 ranges  
Accuracy meter,  $\pm 2\%$ ; output voltage,  $\pm 1\%$   
Calibration Prior to Use

NTS Number D768V  
Instrument Charge Amplifier  
Manufacturer Unholtz-Dickie Corporation  
Model Number 8 PMCVA  
Serial Number None  
Calibration Prior to Use

NTS Number D919V  
Instrument Accelerometer  
Manufacturer Endevco Corporation  
Model Number 2242M1  
Serial Number JA25 (Body No. 5247)  
Range 0 to 5000 Hz  
Calibration Prior to Use

NTS Number D920V  
Instrument Accelerometer  
Manufacturer Endevco Corporation  
Model Number 2211C  
Serial Number JA16 (Body No. 5209)  
Type Piezoelectric  
Range 0 to 5000 Hz  
Calibration Prior to Use

NTS Number D931V  
Instrument Accelerometer  
Manufacturer Endevco Corporation  
Model Number 2242C  
Serial Number Body C500  
Type Piezoelectric  
Range 2 to 6000 Hz  
3.1 mV rms/g peak  
Accuracy  $\pm 3\%$   
Calibration Prior to Use



NTS Number D957V  
Instrument Oscilloscope  
Manufacturer Hewlett-Packard  
Model Number 122AR (MB N-185)  
Serial Number 521-07906 (MB 524)  
Frequency Range DC to 200 kHz  
Accuracy  $\pm 5\%$   
Calibration Prior to Use

NTS Number D997V  
Instrument Accelerometer  
Manufacturer Endevco Corporation  
Model Number 2246  
Serial Number JA12  
Type Piezoelectric  
Frequency Range 0 to 4000 Hz  
Accuracy  $\pm 3\%$   
Calibration Prior to Use

NTS Number D1005V  
Instrument Charge Amplifier  
Manufacturer Unholtz-Dickie Corporation  
Model Number 8 PMCVA  
Serial Number None  
Range 0 to 100. g in 5 ranges  
Accuracy  $\pm 5\%$   
Calibration Prior to Use

NTS Number D1022V  
Instrument Amplitude Servo/Monitor  
Manufacturer Spectral Dynamics Corporation  
Model Number SD105-C-1  
Serial Number 627  
Range 1 to 10 kHz in 2 ranges  
manual or automatic  
Special Features monitors accel, Vel, and Disp.  
Accuracy  $\pm 4\%$   
Calibration 6 months (Cal. due 1-3-82)

NTS Number D1052V  
Instrument Charge and Voltage Amplifier  
Manufacturer Unholtz-Dickie Corporation  
Model Number 8 PMCV  
Serial Number None  
Range 0 to 1000 g in 7 ranges  
Accuracy output voltage,  $\pm 1\%$ ; meter  $\pm 2\%$   
Gain 1 to 100 mV or PCmV/g  
Calibration Prior to Use





NTS Number D1054V  
 Instrument Charge and Voltage Amplifier  
 Manufacturer Unholtz-Dickie Corporation  
 Model Number 8 PMCV  
 Serial Number None  
 Range 0 to 1000 g in 7 ranges  
 Accuracy output voltage,  $\pm 1\%$ ; meter  $\pm 2\%$   
 Gain 1 to 100 mV or PCmB/g  
 Calibration Prior to Use

NTS Number D1055V  
 Instrument Charge and Voltage Amplifier  
 Manufacturer Unholtz-Dickie Corporation  
 Model Number 8 PMCV  
 Serial Number None  
 Range 0 to 1000 g in 7 ranges  
 Accuracy output voltage,  $\pm 1\%$ ; meter  $\pm 2\%$   
 Gain 1 to 100 mV or PCmB/g  
 Calibration Prior to Use

NTS Number D1072V  
 Instrument Charge Amplifier  
 Manufacturer Unholtz-Dickie Corporation  
 Model Number 8 PMC  
 Serial Number None  
 Range 0 to 1000 g in 7 ranges  
 Accuracy  $\pm 1\%$  gain;  $\pm 1\%$  meter  
 Gain 1 to 100 peak PC/peak g  
 Frequency Response  $\pm 1\%$ , 10 Hz to 5 kHz  
 Calibration Prior to Use

NTS Number D1073V  
 Instrument Charge Amplifier  
 Manufacturer Unholtz-Dickie Corporation  
 Model Number 8 PMC  
 Serial Number None  
 Range 0 to 1000 g in 7 ranges  
 Accuracy  $\pm 1\%$  gain;  $\pm 1\%$  meter  
 Gain 1 to 100 peak PC/peak g  
 Frequency Response  $\pm 1\%$ , 10 Hz to 5 kHz  
 Calibration Prior to Use

NTS Number D1076V  
 Instrument Charge Amplifier  
 Manufacturer Unholtz-Dickie Corporation  
 Model Number 8 PMC  
 Serial Number None  
 Range 0 to 1000 g in 7 ranges  
 Accuracy  $\pm 1\%$  gain;  $\pm 1\%$  meter  
 Gain 1 to 100 peak PC/peak g  
 Frequency Response  $\pm 1\%$ , 10 Hz to 5 kHz  
 Calibration Prior to Use



NTS Number D1103V  
 Instrument Charge and Voltage Amplifier  
 Manufacturer Unholtz-Dickie Corporation  
 Model Number 8 PMCV  
 Serial Number None  
 Range 0 to 1000 g in 7 ranges  
 Accuracy output voltage,  $\pm 1\%$ ; meter,  $\pm 2\%$   
 Gain 1 to 100 mV or PCmV/g  
 Calibration Prior to Use

NTS Number D1106V  
 Instrument Accelerometer  
 Manufacturer Endevco Corporation  
 Model Number 2215C  
 Serial Number LA92  
 Range "Shock"  $\pm 2000$  g (peak)  
 "Vibration"  $\pm 1000$  g (sinusoidal)  
 "Frequency Range" 2 to 6000 Hz  
 "Frequency Response"  $\pm 5\%$   
 "Amplitude Linearity"  $\pm 2\%$   
 Accuracy Piezoelectric  
 Type 8362  
 Body Number 6 months (Cal. due 1-14-82)  
 Calibration.

NTS Number D1120V  
 Instrument Sweep Oscillator  
 Manufacturer Spectral Dynamics Corporation  
 Model Number SD104A-5  
 Serial Number 1804  
 Range 0.005 Hz to 50 kHz in five 3 decade ranges  
 Frequency Response  $\pm 2\%$   
 Calibration 6 months (Cal. due 12-12-81)

NTS Number D1196V  
 Instrument Charge Amplifier  
 Manufacturer Unholtz-Dickie Corporation  
 Model Number 8 PMCVA  
 Serial Number None  
 Range 1 to 1000 g in 7 ranges  
 1 to 100 mV or PC  
 Accuracy output voltage,  $\pm 1\%$ ; meter,  $\pm 2\%$   
 Calibration Prior to Use

NTS Number D1226V  
 Instrument FM Tape Recorder  
 Manufacturer Sangamo-Weston  
 Model Number Sabre VI  
 Serial Number 6474  
 Type 3 speed, total of 15 channels  
 Calibration Prior to Use



NTS Number D1231V  
 Instrument Accelerometer  
 Manufacturer Endevco Corporation  
 Model Number 2220C  
 Serial Number EU03  
 Accuracy  $\pm 1.8\%$  20 Hz to 2.5%/4000 Hz  
 Type Piezoelectric  
 Calibration 6 months (Cal. due 12-15-81)

NTS Number D1232V  
 Instrument Oscilloscope, 18 Channels  
 Manufacturer Honeywell, Inc.  
 Model Number 1858  
 Serial Number 2209DB78  
 Range depends on plug-ins  
 Type fiber optic  
 Calibration Prior to Use

NTS Number E4482F  
 Instrument Oscilloscope, 18 Channels  
 Manufacturer Honeywell, Inc.  
 Model Number 1858-T7900  
 Serial Number 0156BE76  
 Range depends on gazvos used  
 Accuracy  $\pm 3\%$   
 Chart Speed 0.1 to 160 ips in 15 steps  
 Timing Marks 0.001 to 10 seconds  
 Calibration Prior to Use

NTS Number E398L  
 Instrument Digital Multimeter-Counter  
 Manufacturer Valhalla Scientific  
 Model Number 4440  
 Serial Number 7-1967  
 Type LED display  
 Range 0 to 500 volts AC in 5 ranges;  
 0 to 1000 volts DC in 5 ranges;  
 0 to 20 megohms in 6 ranges;  
 0 to 2000 milliamps, AC ordc, in 5 ranges;  
 0 to 10 mHz in 5 ranges;  
 Accuracy AC volts,  $\pm 0.25\%$  of reading,  $\pm 0.25\%$  F.S.;  
 DC volts,  $\pm 0.05\%$  of reading,  $\pm 0.025\%$  F.S.;  
 resistance,  $\pm 0.1\%$  of reading,  $\pm 0.05\%$  F.S.;  
 AC current,  $\pm 1\%$  of reading,  $\pm 0.1\%$  to 10 kHz;  
 DC current,  $\pm 0.3\%$  of reading,  $\pm 0.05\%$  F.S.;  
 frequency count  $\pm 0.01\%$  of reading,  
 $\pm 0.005\%$  F.S.  
 Calibration 6 months (Cal. due 3-18-82)



NTS Number G184L  
 Instrument Stop Watch  
 Manufacturer Junghans  
 Model Number 165  
 Serial Number None  
 Range 0 to 60 seconds  
 Accuracy  $\pm 0.2\%$   
 Calibration 12 months (Cal. due 8-11-82)

NTS Number None  
 Instrument Voltage/Frequency Log Converter  
 Manufacturer Rockwell  
 Model Number Unknown  
 Serial Number N 682 492  
 Calibration (Cal. due 1-12-82)

NTS Number None  
 Instrument SD 129  
 Manufacturer Rockwell  
 Model Number Unknown  
 Serial Number N 682 628  
 Calibration (Cal. due 11-4-82)

NTS Number None  
 Instrument Charge Amplifier  
 Manufacturer Rockwell  
 Model Number Unknown  
 Serial Number S260591  
 Calibration (Cal. due 11-29-82)

NTS Number None  
 Instrument Charge Amplifier  
 Manufacturer Rockwell  
 Model Number Unknown  
 Serial Number S260595  
 Calibration (Cal. due 11-29-82)

NTS Number None  
 Instrument Charge Amplifier  
 Manufacturer Rockwell  
 Model Number Unknown  
 Serial Number S260956  
 Calibration (Cal. due 11-29-82)

NTS Number None  
 Instrument Charge Amplifier  
 Manufacturer Rockwell  
 Model Number Unknown  
 Serial Number S260958  
 Calibration (Cal. due 11-29-82)





APPENDIX B  
Exhibit I and II and General Data Sheets  
of  
Torque Measurements





GEARED LIMIT SWITCH  
FINGER ASSEMBLY ADJUSTMENT

The Limitorque recommended procedure for checking and adjusting the geared limit finger assembly is as outlined below (ref. attached finger assembly sketch):

1. Rotate the "rotor" to the normal trip position where contact is made between the rotor and finger assembly.
2. With the finger and rotor in contact, measure the gap between the finger and "L" bracket of the finger assembly. This measurement should be made at the finger assembly spring. The normal gap, with the finger in contact with the rotor, should be .020/.040 inches.
3. If the normal gap as defined in (2) above is not .020/.040 inches, the "L" bracket of the finger assembly should be bent to achieve the normal gap.







# EXHIBIT II

## GEARED LIMIT SWITCH SCREW TIGHTENING PROCEDURE

Geared limit switch screws which require measured torque preload should be tightened to the following limits:

1/4 inch screws	9ft-lbs
5/16 inch screws	18ft-lbs
3/8 inch screws	30ft-lbs

The above torques require that the screw thread is not lubricated during the tightening process. When screw threads are lubricated, the above values should be reduced to compensate for reduced thread friction.

NOTE: Because of the unpredictability of screw joint variables, particularly thread friction, it is Limitorque policy not to tighten geared limit switch fasteners to a measured torque. Limitorque procedure requires the assembly person to tighten fasteners tight based on the feel of the threaded joint as determined by the experience of the assembly person.

## OPERATOR MOUNTING SCREW TORQUE

<u>SMB-000-5</u> : 5/16 inch screws	16.5 ft - lbs
<u>SMB-0-25</u> : 3/4 inch screws	138 ft - lbs

The above torques require lubricated screw threads.







APPROVED ENGINEER'S TEST LABORATORIES

GENERAL DATA SHEET

TEST GAP MO 548-5291

CUSTOMER STONE & WEBSTER

TEST ITEM LIMIT SWITCH P/N (2" A RESIN)

SPECIFICATION \_\_\_\_\_ PAR \_\_\_\_\_

PARAMETER	UNITS		CONTACT		CONTACT		CONTACT	
	DATE	TIME	.020"	.040"	.020"	.040"	.020"	.040"
1			>	> OK	5	>	>	RESIST
1C			>	> OK	5C	>	>	
2			>	> OK	6	>	>	ADJUST
2C			>	> OK	6C	>	>	
3			>	<	7	>	>	> OK
3C			>	> OK	7C	>	>	> OK
4			>	> OK	8	>	>	> OK
4C			>	> OK	8C	>	>	> OK
9			>	> ADJUST	13	>	>	> OK
9C			< .009	> ADJUST	13C	>	>	>
10			>	> OK	14	>	>	>
10C			< .004	> OK	14C	>	>	>
11			>	<	15	>	>	>
11C			>	<	15C	>	>	> OK
12			>	> OK	16	>	>	>
12C			>	> OK	16C	>	>	> OK

GENERAL TEST NOTES: < = LESS THAN, > = MORE THAN  
 - IF IT IS < .020 IT SHALL BE ADJUSTED  
 - IF IT IS > .040 IT SHALL BE CHECKED FOR SPRING

TEST BY [Signature] OF 28

ENGR. [Signature]

DATE \_\_\_\_\_ GOVT CAR \_\_\_\_\_

PRE TEST





APPROVED ENGINEERING TEST LABORATORIES

GENERAL DATA SHEET

TEST

CUSTOMER

TEST ITEM

SPECIFICATION

P/N 12" A

S/N

PAR

PARAMETER	UNITS		CONTACT		CONTACT		CONTACT	
	DATE	TIME	.020"	.040"	.020"	.040"	.020"	.040"
1			< .018	<	5	>	>	NOTE
1C			>	<	5C	< .010	>	OK
2			>	<	6	>	<	
2C			< .007	>	6C	>	<	OK
3			< .018	<	7	>	<	
3C			>	<	7C	>	<	
4			>	<	8	>	<	
4C			>	<	8C	>	>	OK
9			>	>	13	>	>	OK
9C			>	>	13C	< .010	<	
10			>	>	14	>	<	
10C			>	>	14C	< .018	<	
11			>	<	15	>	<	
11C			< .018	>	15C	>	<	
12			>	>	16	< .015	>	OK
12C			>	<	16C	< .007	<	

GENERAL TEST NOTES: < = LESS THAN. > = MORE THAN

- IF IT IS < .020 IT SHALL BE ADJUSTED

- IF IT IS > .040 IT SHALL BE CHECKED FOR SPRING

\* NO. 5 STACK SPRING (REPAIRED) < .040

PRE TEST

TEST BY: [Signature]

ENGR. [Signature]

DATE

PAGE 38

OF 38

B-5





APPROVED ENGINEERING TEST LABORATORIES

GENERAL DATA SHEET

TEST

STAP

MO

548-9291

CUSTOMER

STORE & REPOSTER

TEST ITEM

AMT SWITCH

P/N

12" B

S/N

SPECIFICATION

PAR

PARAMETER	UNITS		CONTACT		CONTACT		.020"		.040"	
	DATE	TIME								
1			>	<	5		>	>	OK	
1C			<	<	5C		<	<		
2			>	<	6		>	>	OK	
2C			<	>	6C		>	<		
3			>	<	7		>	<		
3C			>	<	7C		>	>	OK	
4			>	<	8		>	<		
4C			>	<	8C		>	<		
9			>	>	9		>	>	OK	
9C			>	<	9C		>	<		
10			>	>	10		>	>	OK	
10C			<	<	10C		<	<		
11			>	>	11		>	>	OK	
11C			>	<	11C		>	<		
12			>	<	12		<	<		
12C			>	<	12C		<	<		
13			>	>	13		>	>	OK	
13C			<	<	13C		<	<	OK	
14			>	<	14		>	<		
14C			<	<	14C		<	<		
15			>	<	15		>	<		
15C			>	>	15C		>	>	OK	
16			<	<	16		<	<		
16C			<	<	16C		<	<		

GENERAL TEST NOTES: < = LESS THAN, > = MORE THAN

- IF IT IS < .020 IT SHALL BE ADJUSTED

- IF IT IS > .040 IT SHALL BE CHECKED FOR SPRING

TEST POST

48

OF

178

TEST BY ENGR.

[Signature]

DATE

GOVT QAR

P2E TEST





APPROVED ENGINEERING TEST LABORATORIES

GENERAL DATA SHEET

TEST

GAD

MJO

548-9291

CUSTOMER

STONE & WEBSTER

TEST ITEM

LIMIT SWITCH

P/N 12"-C

S/N

SPECIFICATION

PAR

PARAMETER	UNITS		CONTACT		CONTACT		CONTACT	
	DATE	TIME	.020"	.040"	.020"	.040"	.020"	.040"
1			>	<	5	<.015	>	OK
1C			>	<	5C	>	>	OK
2			>	<	6	<.010	<	
2C			>	<	6C	>	>	OK
3			<.005	<	7	>	>	OK
3C			>	>	7C	>	<	
4			<.015	<	8	>	>	OK
4C			>	<	8C	>	<	
9			>	>	13	>	<	
9C			<.010	<	13C	<.007	<	
10			>	<	14	>	>	
10C			>	<	14C	>	<	
11			>	>	15	>	<	
11C			>	<	15C	>	>	OK
12			>	>	16	>	<	
12C			>	<	16C	>	>	OK

GENERAL TEST NOTES: < = LESS THAN, > = MORE THAN  
 - IF IT IS < .020 IT SHALL BE ADJUSTED  
 - IF IT IS > .040 IT SHALL BE CHECKED FOR SPRING

PAGE

58

OF

58

TEST BY

[Signature]

DATE

PRE TEST

GOVT QAR







APPROVED ENGINEERING TEST LABORATORIES

GENERAL DATA SHEET

TEST: PRE-TESTING CHECK MJO 548-9291

CUSTOMER: STONE & WELDS TERN

TEST ITEM: LIMIT SWITCH P/N 3" C S/N \_\_\_\_\_

SPECIFICATION \_\_\_\_\_ PAR \_\_\_\_\_

PARAMETER	UNITS		CONTACT .020"		CONTACT .040"	
	DATE	TIME				
	11-9	1830	1	>	>	
			1C	<.000	<	
			2	>	<	
			2C	<.000	<	
			3	<.016	<	
			3C	>	<	
			4	<.010	<	
			4C	>	>	
			9	>	<	
			9C	>	>	
			10	>	<	
			10C	>	<	
			11	<.018	<	
			11C	>	<	
			12	<.014	<	
			12C	>	<	
			5	<.000	<	
			5C	>	>	
			6	<.000	<	
			6C	>	<	
			7	>	<	
			7C	<.000	<	
			8	>	<	
			8C	<.000	<	
			13	>	<	
			13C	<.018	<	
			14	>	<	
			14C	>	<	
			15	>	<	
			15C	>	<	
			16	>	<	
			16C	<.014	<	

GENERAL TEST NOTES: < = LESS THAN. > = MORE THAN

- IF IT IS <.020 IT SHALL BE ADJUSTED

- IF IT IS >.040 IT SHALL BE CHECKED FOR SPRING

PRE TEST

5.0  
PAGE

STC OF 68

TEST BY ENGR.

*[Signature]*

DATE GOVT QAR





APPROVED ENGINEERING TEST LABORATORIES

GENERAL DATA SHEET

TEST PRE TESTING CHECK

CUSTOMER STONE & WEBSTER

TEST ITEM Limit Switch

AJ0 548-92291

PIN 3" B S/N

SPECIFICATION

PAR

PARAMETER	UNITS		CONTACT .020"		CONTACT .040"	
	DATE	TIME				
1			>	>	5	<.003 >
1C			>	>	5C	>
2			>	>	6	<.014 >
2C			<.005 <	<	6C	>
3			>	<	7	<.000 <
3C			<.000 <	<	7C	>
4			<	<	8	<.018 <
4C			>	<	8C	>
9			>	<	13	
9C			>	<	13C	
10			>	<	14	
10C			<.014 <	<	14C	
11			>	<	15	>
11C			>	>	15C	>
12			<.016 <	>	16	>
12C			<.018 <	>	16C	>

GENERAL TEST NOTES: < = LESS THAN. > = MORE THAN

- IF IT IS <.020 IT SHALL BE ADJUSTED

- IF IT IS >.040 IT SHALL BE CHECKED FOR SPRING

PRE TEST

13 PAGE

87 OF 78

TEST BY ENGR.

*[Signature]*

DATE

GOVT QAR





APPROVED ENGINEERING TEST LABORATORIES

GENERAL DATA SHEET

TEST PRE TESTING CHECK NO. 548 9291

CUSTOMER STONE & WEBSTER

TEST ITEM LIMIT SWITCH P/N 3" A

SPECIFICATION PAR

PARAMETER							
UNITS		CONTACT	.020"	.040"	CONTACT	.020"	.040"
DATE	TIME						
11-9	1600	1	>	<	5	>	< Adj. Down
		1C	>	<	5C	>	<
		2	>	<	6	>	<
		2C	>	>	6C	>	<
		3	>	>	7	>	<
		3C	< .012	<	7C	>	<
		4	>	<	8	>	<
		4C	< .005	<	8C	>	<
		9	>	>	13	>	<
		9C	>	<	13C	< .017	<
		10	>	>	14	>	<
		10C	>	<	14C	>	<
		11	>	<	15	>	<
		11C	>	<	15C	>	<
		12	>	<	16	>	<
		12C	< .001	<	16C	>	<

GENERAL TEST NOTES: < = LESS THAN. > = MORE THAN

- IF IT IS < .020 IT SHALL BE ADJUSTED

- IF IT IS > .040 IT SHALL BE CHECKED FOR SPRING

PRE TEST

AGE

8

OF

8

TEST BY ENGR.

[Signature]

DATE

GOVT QAR



# DATA SHEET

Test Title: **TORQUE**

Spec. Para. S/N

12" A REV.

Part No. 542-0291  
 P.O. No. \_\_\_\_\_  
 Date \_\_\_\_\_  
 Amb. Temp. \_\_\_\_\_  
 Photo \_\_\_\_\_  
 Test Med. \_\_\_\_\_

NO	SCREEN NO.	TORQUE REQ	SCREEN SIZE	TORQUE SET	REMARKS	SCREEN NO.	TORQUE REQ	SCREEN SIZE	TORQUE SET	REMARKS
		"Lbs	"	"Lbs			"Lbs	"	"Lbs	
1	1	108	1/4	90	NO WASHER	13	NA			
2	2	↓	↓	90	LUBED	14	NA			
3	3	↓	↓	90		15	216	5/16	150	NO GASKETS
4	4	↓	↓	90	START WASHER	16	↓	↓	100	↓
5	5	↓	↓	50						
6	6	↓	↓	50						
7	7	↓	↓	50	NO WASHER					
8	8	↓	↓	50						
9	9	216	5/16	150	RTV					
10	10	↓	↓	150						
11	11	↓	↓	150						
12	12	↓	↓	150						

GENERAL TEST NOTES:

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Specimen Passed \_\_\_\_\_

Specimen Failed \_\_\_\_\_

N.O.D. Written \_\_\_\_\_

Tested By ADP

Witness \_\_\_\_\_

Sheet No. \_\_\_\_\_ of \_\_\_\_\_

Approved \_\_\_\_\_

Date: \_\_\_\_\_

Date: \_\_\_\_\_

of \_\_\_\_\_

B-11







# DATA SHEET

Cr. for STANDARD WEATHER Job. No. 542-9291  
 P.O. No. \_\_\_\_\_  
 Date \_\_\_\_\_  
 Spec. 12" A Amb. Temp. \_\_\_\_\_  
 Para. \_\_\_\_\_ Photo \_\_\_\_\_  
 S/N \_\_\_\_\_ Test Med. \_\_\_\_\_

Test Title: **TORQUE**

NO	SCREW NO.	TORQUE REQ	SCREW SIZE	TORQUE SET	REMARKS	SCREW NO.	TORQUE REQ	SCREW SIZE	TORQUE SET	REMARKS
		"Lbs		"Lbs						
1	1	108	1/4	81	REDUCED TORQUE DUE TO OIL HOLES	13				
2	2	↓	↓	81		14				
3	3	↓	↓	81		15			150	
4	4	↓	↓	81		16			175	
5	5									
6	6									
7	7									
8	8									
9	9			175						
10	10			150						
11	11			175						
12	12			175						

B-12

GENERAL TEST NOTES:

1-4 (RECHECKED AND NOW SET FOR 90" LBS)

\* NEW SHEET 12" A REV

G = GASKET SUPPLIED

Specimen Passed _____	Tested By: <u>JUB</u> Date: _____ Witness _____ Date: _____ Sheet No. _____ of _____ Approved _____
Specimen Failed _____	
N.O.D. Written _____	



# DATA SHEET

Test Title: **TORQUE**

Spec. Para. S/N \_\_\_\_\_  
 Date \_\_\_\_\_  
 Amb. Temp. \_\_\_\_\_  
 Photo \_\_\_\_\_  
 Test Med. \_\_\_\_\_  
 P.O. No. \_\_\_\_\_  
 Net. No. **543-2281**

NO	SCREW NO.	TORQUE REQ	SCREW SIZE	TORQUE SET	REMARKS	SCREW NO.	TORQUE REQ	SCREW SIZE	TORQUE SET	REMARKS
							"Lbs	"	"Lbs	
1	1	108	1/4	108	NO WASHER	13	NA			NO WASH
2	2	↓	↓	108	↓	14	NA			↓
3	3	↓	↓	108	↓	15	216	5/16	216	↓
4	4	↓	↓	108	↓	16	↑	↓	↓	↓
5	5	↓	↓	↓	FLAT WASHER					
6	6	↓	↓	↓	↓					
7	7	↓	↓	108	SUSTAIN IN PLASTIC					NT
8	8	↓	↓	108	↓					
9	9	216	5/16	216	NO WASHER					
10	10	↓	↓	↓	↓					GR NY
11	11	↓	↓	↓	↓					
12	12	↓	↓	↓	↓					


GENERAL TEST NOTES:

NY = NYLOCK INSERT  
 G = GASKET SUPPLIED  
 NT = NYLON ON THREADS  
 GR = GASKET OF RTV.

Specimen Passed \_\_\_\_\_  
 Specimen Failed \_\_\_\_\_  
 N.O.D. Written \_\_\_\_\_  
 Tested By **WNB** Date: \_\_\_\_\_  
 Witness \_\_\_\_\_ Date: \_\_\_\_\_  
 Sheet No. \_\_\_\_\_ of \_\_\_\_\_  
 Approved \_\_\_\_\_

B-13





# DATA SHEET

Test Title: **TORQUE**

STANDARD WEIGHTS  
 Spec: \_\_\_\_\_  
 Para: \_\_\_\_\_  
 S/N: \_\_\_\_\_

Job No: **543-929**  
 P.O. No: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Amb. Temp: \_\_\_\_\_  
 Photo: \_\_\_\_\_  
 Test Med: \_\_\_\_\_

NO	SCREW NO.	TORQUE REQ	SCREW SIZE	TORQUE SET	REMARKS	SCREW NO.	TORQUE REQ	SCREW SIZE	TORQUE SET	REMARKS
		"Lbs	"	"Lbs			"Lbs	"	"Lbs	
1	1	108	44	108	NO GASKET	13	NA			
2	2	↓		↓	G/NY	14	NA			
3	3	↓		↓		15	216	5/16	216	NO GASKET NY
4	4	↓		↓	FLAT WASHER	16	↓	↓	↓	
5	5	↓		↓						
6	6	↓		↓	NT					
7	7	↓		↓						
8	8	↓		↓	NO WASHER					
9	9	216	5/16	216						
10	10	↓		↓	G NY					
11	11	↓		↓						
12	12	↓		150						

GENERAL TEST NOTES:

GR = GASKET MADE OF RTV  
 G = GASKET SUPPLIED  
 NT = NYLON ON THREADS  
 NY = NYLOCK. INSECT

Specimen Passed \_\_\_\_\_

Specimen Failed \_\_\_\_\_

N.O.D. Written \_\_\_\_\_

Tested By

Witness \_\_\_\_\_

Sheet No. \_\_\_\_\_

Approved

*WAB*

Date: \_\_\_\_\_

Date: \_\_\_\_\_

of \_\_\_\_\_





1000 2500 3000 3500 4000 4500

STANDARD TEST METHOD  
 P.O. No. 542-9291  
 Date \_\_\_\_\_  
 Amb. Temp: \_\_\_\_\_  
 Photo \_\_\_\_\_  
 Test Med. \_\_\_\_\_

# DATA SHEET

Spec: 3" A  
 Para. \_\_\_\_\_  
 S/N \_\_\_\_\_

Test Title: **TORQUE**

NO	SCREEN NO.	TORQUE REQ	SCREEN SIZE	TORQUE SET	REMARKS	SCREEN NO.	TORQUE REQ	SCREEN SIZE	TORQUE SET	REMARKS
		"Lbs	"	"Lbs				"Lbs	"	"Lbs
1	1	108	1/4	108	NO WASH	13	216	5/16	150	NO
2	2	↓	↓	108	G	14	↓	↓	150	NO
3	3	↓	↓	108		15	↓	↓	165	STAR
4	4	↓	↓	108		16	↓	↓	175	STAR
5	5	↓	↓	108		STAR WASH				
6	6	↓	↓	108	G					
7	7	↓	↓	108						
8	8	↓	↓	108						
9	9	216	5/16	175		STAR				
10	10	150	↓	150	G					
11	11	175	↓	175						
12	12	150	↓	150						

B-15

GENERAL TEST NOTES:


G = GASKET PROVIDED

Specimen Passed \_\_\_\_\_  
 Specimen Failed \_\_\_\_\_  
 N.O.D. Written \_\_\_\_\_

Tested By [Signature] Date: \_\_\_\_\_  
 Witness \_\_\_\_\_ Date: \_\_\_\_\_  
 Sheet No. \_\_\_\_\_ of \_\_\_\_\_  
 Approved \_\_\_\_\_







# DATA SHEET

Test Title: **TORQUE**

Spec. Para. S/N \_\_\_\_\_  
 Date \_\_\_\_\_  
 Amb. Temp. \_\_\_\_\_  
 Photo \_\_\_\_\_  
 Test Med. \_\_\_\_\_

Job No. **542-9291**  
 P.O. No. \_\_\_\_\_  
 Date \_\_\_\_\_  
 Amb. Temp. \_\_\_\_\_  
 Photo \_\_\_\_\_  
 Test Med. \_\_\_\_\_

NO	SCREW NO.	TORQUE REQ	SCREW SIZE	TORQUE SET	REMARKS	SCREW NO.	TORQUE REQ	SCREW SIZE	TORQUE SET	REMARKS
		"Lbs	"	"Lbs			"Lbs	SIZE	"Lbs	
1	1	108" Lbs	1/4	108" Lbs	NO WASH	13	216	5/16	216	(NO)
2	2	↓	↓	↓	↓	14	↓	↓	↓	(NO)
3	3	↓	↓	↓	↓	15	NA	5/16	NA	(NO)
4	4	↓	↓	↓	↓	16	NA	5/16	NA	(NO)
5	5	↓	↓	↓	FLAT WASH					
6	6	↓	↓	↓	↓					NT
7	7	↓	↓	↓	↓					
8	8	↓	↓	↓	↓					
9	9	216" Lbs	5/16	216 Lbs	NO WASH					
10	10	↓	↓	↓	↓					
11	11	↓	↓	↓	↓					
12	12	↓	↓	↓	↓					

GENERAL TEST NOTES:

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Specimen Passed \_\_\_\_\_  
 Specimen Failed \_\_\_\_\_  
 N.O.D. Written \_\_\_\_\_

Tested By **PAB** Date: \_\_\_\_\_  
 Witness \_\_\_\_\_ Date: \_\_\_\_\_  
 Sheet No. \_\_\_\_\_ of \_\_\_\_\_  
 Approved \_\_\_\_\_

B-16





# DATA SHEET

Test Title: **TORQUE**

STANDARD WEIGHT  
 3113  
 Spec. \_\_\_\_\_  
 Para. \_\_\_\_\_  
 S/N \_\_\_\_\_

Part No. **542-9291**  
 P.O. No. \_\_\_\_\_  
 Date \_\_\_\_\_  
 Amb. Temp. \_\_\_\_\_  
 Photo \_\_\_\_\_  
 Test Med. \_\_\_\_\_

NO	SCREEN NO.	TORQUE REQ	SCREEN SIZE	TORQUE SET	REMARKS	SCREEN NO.	TORQUE REQ	SCREEN SIZE	TORQUE SET	REMARKS	
1	1	108 lbs	1/4	108 lbs	NO WASH	13	216 lbs	5/16	216 lbs	NO	
2	2	↓	1/4	↓	G/NY	14	↓	5/16	↓	NO	
3	3	↓	1/4	↓		15	NA	5/16	NA	NO	
4	4	↓	1/4	↓		16	NA	5/16	NA	NO	
5	5	↓	1/4	↓		FLAT WASH					
6	6	↓	1/4	↓	NT						
7	7	↓	1/4	↓							
8	8	↓	1/4	↓							
9	9	216 lbs	5/16	216 lbs	NO WASH						
10	10	↓	5/16	↓	GR/ NY						
11	11	↓	5/16	↓							
12	12	↓	5/16	↓							

GENERAL TEST NOTES:

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Specimen Passed \_\_\_\_\_

Specimen Failed \_\_\_\_\_

N.O.D. Written \_\_\_\_\_

Tested By **SNB**

Witness \_\_\_\_\_

Sheet No. \_\_\_\_\_

Approved \_\_\_\_\_

Date: \_\_\_\_\_

Date: \_\_\_\_\_

of \_\_\_\_\_

B-17




BOOK NO. \_\_\_\_\_

LOCATION \_\_\_\_\_ J. O. NO. \_\_\_\_\_

REPORT NO. \_\_\_\_\_ PG. NO. \_\_\_\_\_

DATE \_\_\_\_\_ BY \_\_\_\_\_



operator mounting  
 (135) 1656 IN LBS  
 W C5A  
 GR = GASKET MADE OF RTV  
 G = GASKET SUPPLIED  
 NT = NYLON ON THREAD  
 NY = "NYLOCK" INSERT

COLT. #	DESCRIPTION	12A (FROM FIELD)		12B (BRACKET)		12C (SCREWS)	
		WASHER NO	TORQUE	WASHER NO	TORQUE	WASHER NO	TORQUE
4	INTERNAL 1 1/4" 20UNC 5/8	G	90 IN LB (LUBRICATED)	G/NY	108 IN LB	G/NY	108 IN LB
5	1 1/4" 20UNC 5/8	star	50 IN LB	flat	108 IN LB	flat	108 IN LB
6		star		flat		NT	
7		star		flat		NT	
8		star		flat		NT	
9	5/16" 18UNC 3/4	NO	150 IN LB	NO	216 IN LB	NO	216 IN LB
10		NO		GR		NY	
11		NO		NY		NY	
12		NO					
13		NOT USED					
14	NOT USED						
15	5/16" 18UNC 1	NO	150 (LBS)	NO	216 IN LB	NO	216 IN LB
16		NO		NY		NY	

*[Signature]*



ENGINEER'S RECORD BOOK

BOOK NO. \_\_\_\_\_

LOCATION \_\_\_\_\_


I. O. NO. \_\_\_\_\_

REPORT NO. \_\_\_\_\_

PG. NO. \_\_\_\_\_

DATE \_\_\_\_\_

BY \_\_\_\_\_



operator mounting 198 in dia  
(16.5) with CSA

- GR = GASKET MADE OF RTV
- G = GASKET SUPPLIED
- NT = NYLON ON THREAD
- NY = "NYLOCK" INSERT


BOLT #	DESCRIPTION	3A (FROM FIELD)		3B (BRACKET)		3C (SCREWS)	
		WASHER	TORQUE	WASHER	TORQUE	WASHER	TORQUE
1-4	INTERNAL (1/4" 20 UNC 5/8)	NO	108 IN LB	NO	108 IN LB	NO	108 IN LB
5	1/4" 20 UNC 5/8	star	108 IN LB	flat	108 IN LB	flat	108 IN LB
6		star		flat		flat	
7		star		flat		flat	
8		star		flat		flat	
9	5/16" 18 UNC 3/4	star	175	no	216 IN LB	no	216 IN LB
10		star		no		no	
11		star		no		no	
12		star		no		no	
13	5/16" 18 UNC 3/4	no	150	no	216 IN LB	no	216 IN LB
14		no		no		no	
15	5/16" 18 UNC 1	star	165	no	216 IN LB	no	216 IN LB
16		star		no		no	





APPENDIX C  
Stroke Times - Sine Beat Test  
and  
Accelerometer Locations






Control Accelerometers

Stone and Webster  
MJO # 548-9291

LIMITORQUE OPERATOR, Model # SMB-000-5  
and MODIFIED LIMIT SWITCHES, P/N - 3B and 3C

RESPONSE ACCELEROMETER LOCATIONS  
FOR SINE BEAT TESTING ONLY.







STONE AND WEBSTER  
MJO # 548-9291


Specimen : LIMITORQUE OPERATOR, Model # SMB-000-5 and  
MODIFIED LIMIT SWITCHES, P/N - 3B and 3C

RESPONSE ACCELEROMETER LOCATIONS

Accel. #	Location	Axis
1.-	Operator Gear Box .....	X
2.-	Operator Gear Box .....	Z
3.-	Operator Gear Box .....	Y
4.-	Operator Limit Switch .....	X
5.-	Operator Limit Switch .....	Z
6.-	Operator Limit Switch .....	Y
7.-	Operator Motor .....	Z
8.-	Operator Motor .....	X
9.-	Operator Housing .....	Z
10.-	Operator Housing .....	Y
11.-	Modified Limit Switch ( 3C ).....	Active axis
12.-	Modified Limit Switch Block .....	Active axis

\* These accelerometer locations are applicable to the SINE BEAT portion of the test only.





Switch # 3B


Switch 3C

Control Accelerometers

Stone and Webster  
MJO # 548-9291

LIMITORQUE OPERATOR, Model # SMB-000-5  
and MODIFIED LIMIT SWITCHES, P/N - 3B and 3C

RESPONSE ACCELEROMETER LOCATIONS  
FOR SEISMIC AND SINE SURVEY TESTING  
ONLY.









STONE AND WEBSTER  
MJO # 548-9291


Specimen : LIMITORQUE OPERATOR, Model # SMB-000-5 and  
MODIFIED LIMIT SWITCHES, P/N - 3B and 3C

RESPONSE ACCELEROMETER LOCATIONS

Accel. #	Location	Axis
1.-	Operator Gear Box .....	X
2.-	Operator Housing .....	X
3.-	Switch Block .....	X
4.-	Operator Gear Box .....	Z
5.-	Operator Housing .....	Z
6.-	Switch Block .....	Z
7.-	Operator Gear Box .....	Y
8.-	Operator Housing .....	Y
9.-	Switch Block .....	Y
10.-	Operator Switch .....	X
11.-	Switch # 3B (top) .....	X
12.-	Switch # 3C (top) .....	X
13.-	Switch # 3C (bottom).....	X
14.-	Operator Switch .....	Y
15.-	Switch # 3B (top) .....	Y
16.-	Switch # 3C (top) .....	Y
17.-	Switch # 3C (bottom) .....	Y
18.-	Operator Switch.....	Z
19.-	Switch # 3B (top).....	Z
20.-	Switch # 3C (top).....	Z
21.-	Operator Motor.....	X
22.-	Operator Motor.....	Y
23.-	Operator Motor.....	Z

\* These accelerometer locations are applicable to the SEISMIC and SINE SURVEY portion of the test only.





Stone and Webster  
 MJO # 548-9291  
 LIMITORQUE OPERATOR,  
 Model # SMB-0-25 and  
 MODIFIED LIMIT SWITCHES, P/N - 12B and 12C

RESPONSE ACCELEROMETER LOCATIONS  
 FOR SEISMIC AND SINE SURVEY TESTING  
 ONLY.





STONE AND WEBSTER  
MJO# 548-9291


Specimen : LIMITORQUE OPERATOR, Model # SMB-0-25 and  
MODIFIED LIMIT SWITCHES, P/N - 12B and 12C

Test Date : December 3, 1981

RESPONSE ACCELEROMETER LOCATIONS

Accel. #	Location	Axis
1.-	Operator Gear Box.....	X
2.-	Operator Housing.....	X
3.-	Switch Block.....	X
4.-	Operator Gear Box.....	Z
5.-	Operator Housing.....	Z
6.-	Switch Block.....	Z
7.-	Operator Gear Box.....	Y
8.-	Operator Housing.....	Y
9.-	Switch Block.....	Y
10.-	Operator Switch.....	X
11.-	Switch # 12C (top).....	X
12.-	Switch # 12B (top).....	X
13.-	Switch # 12B (bottom).....	X
14.-	Operator Switch.....	Y
15.-	Switch # 12C (top).....	Y
16.-	Switch # 12B (top).....	Y
17.-	Switch # 12B (bottom).....	Y
18.-	Operator Switch.....	Z
19.-	Switch # 12C (top).....	Z
20.-	Switch # 12B (top).....	Z
21.-	Operator Motor .....	X
22.-	Operator Motor .....	Y
23.-	Operator Motor .....	Z






Control Accelerometers

Stone and Webster  
MJO # 548-9291

LIMITORQUE OPERATOR, Model # SMB-0-25  
and MODIFIED LIMIT SWITCHES, P/N - 12B and 12C

RESPONSE ACCELEROMETER LOCATIONS  
FOR SINE BEAT TESTING ONLY.









STONE AND WEBSTER  
 MJO # 548-9291

Specimen : LIMITORQUE OPERATOR, Model # SMB-0-25 and  
 MODIFIED LIMIT SWITCHES, P/N - 12B and 12C

RESPONSE ACCELEROMETER LOCATIONS

Accel. #	Location	Axis
1.-	Operator Gear Box.....	X
2.-	Operator Gear Box.....	Z
3.-	Operator Gear Box.....	Y
4.-	Operator Switch.....	X
5.-	Operator Switch.....	Z
6.-	Operator Switch.....	Y
7.-	Operator Motor.....	Z
8.-	Operator Motor.....	X
9.-	Operator Housing.....	Active Axis
10.-	Operator Housing.....	Horizontal Crosstalk
11.-	Switch # 12C (bottom).....	Active axis
12.-	Switch Block.....	Active axis

\* These accelerometer locations are applicable to  
 the SINE BEAT portion of the test only.





F.M. TAPE AND OSCILLOGRAPH SET-UP

Customer STONE & WEBSTER

MJO# 548-9291

Test Item LIMITORQUE VALVE MOTOR

P/N SMB-000-5

S/N \_\_\_\_\_

Date 12-9-81

15 IPS

15 IPS

VISICORDER #1				VISICORDER #2				TAPE #1			TAPE #2		
Ch.	Accel	Trace	G/in Sens.	Ch.	Accel	Trace	G/in Sens.	Ch.	Mv/g	Accelerometer	Ch.	Mv/g	Accelerometer
1				1	13			1	1	1	1	1	21
2				2	21			2	2	2	2	2	15
3				3	15			3	3	3	3	3	16
4				4	16			4	4	4	4	4	17
5				5	17			5	5	5	5	5	18
6				6	18			6	6	6	6	6	19
7				7	19			7	7	7	7	7	10
8				8	10			8	8	8	8	8	14
9				9	14			9	9	9	9	9	22
20				10	22			10	20	20	10	10	23
11				11	23			11	11	11	11	11	24 CONTROL
12				12	24			12	12	12	12	12	—
				13				13	13	13	13	13	—
				14				14	VOICE	VOICE	14	14	VOICE
				15									
				16									
				17									
				18									

ACCELEROMETER LOCATIONS

Accel. I.D.#	SURVEYS AXES						Location
	X	Y	Z	XY	YZ		

Technician Jim FARRIS

Date 12-9-81





NTS

A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev. 1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-7-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMD-000-5 SIN \_\_\_\_\_  
 NTS SPECIFICATION TP# 548-9291 PAR 7.6

Date	TEST DESCRIPTION
------	------------------

12-7-81	EQUIPMENT ARRIVED FROM CHATSWORTH. SETTING UP INSTRUMENTATION.
12-8-81	CHECKED OUT INSTRUMENTATION, RAN DYNAMIC CAL, RAN SINE BEAT (BARE SHAKER).
12-9-81	MOUNTED TEST SPECIMEN IN "Z" AXIS & INSTALLED ACCELEROMETERS.

Time	SINE BEAT 15 OSC./BEAT 6 BEATS	TAPE REC. CHANNEL
1817	12.6 HZ 6 gpk CHARGE AMP. RANGE 10	000 - 240
1829	15.9 HZ " 30	240 - 466
1835	20 HZ " 30	466 - 592
1848	25 HZ " 30	592 - 724
1854	30 HZ " 30	724 - 877
1900	35 HZ " 30	877 - 975
1915	ROTATED TO "Y" AXIS SINE BEAT 15 OSC./BEAT 6 BEATS.	
1941	12.6 HZ 6 gpk CHARGE AMP. RANGE 30	975 - 1132
* 1948	15.9 HZ " 30	1132 - 1264
1953	20 HZ " 30	1264 - 1374
1957	25 HZ " 30	1374 - 1474
2003	30 HZ " 30	1474 - 1565
2004	35 HZ " 30	1565 - 1631

\* NOTE: PULSE 4 AUDIALLY HIGHER WITH SAME INPUT

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim Rice DATE \_\_\_\_\_  
 PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ C-10 GOVT GAR. \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-9-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TPE 548-9291 PAR 7.6

Date TEST DESCRIPTION

2015	ROTATED TO "X" AXIS.		
12-10-81	SINE BEAT 15 OSC/BEAT 6 BEATS	TAPES COUNTER	
0935	12.6 HZ 6g PK CHARGE AMP. RANGE 30	1631-1775	
	LOST 6 ACCEL'S, RE-MOUNTED ACCEL'S.		
1025	15.9 HZ 6g PK CHARGE AMP. RANGE 30	1775-1861	
1027	20 HZ " 30	1861-1969	
1040	25 HZ " 30	1969-2036	
1045	30 HZ " 30	2036-2119	
1050	35 HZ " 30	2119-2221	

TESTING COMPLETE ON SMB-000-5 FOR 6g PK INPUT SINE BEAT. NOTE: IN "X" AXIS THE 12.6 HZ LEVEL WAS PERFORMED WITH FILTERING AT 70HZ ON THE RETURN SIGNAL FROM THE MONITOR ACCEL-EROMETER. THIS RESULTED IN A GREATER THAN 6.0g PK VALUE AT FREQUENCIES IN EXCESS OF 70HZ AS SEEN ON THE OSCILLOGRAPH RECORDS. CUSTOMER REQUESTS THAT FILTERING BE ELIMINATED AND THAT THIS SINE BEAT TEST AT 12.6 HZ IN THE "X" AXIS BE COUNTED AS THE FRAGILITY PORTION OF TESTING. THE 6.0g PK UNFILTERED @ 12.6 HZ IN THE "X" AXIS WILL BE PERFORMED AT A LATER TIME.

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim Rice DATE \_\_\_\_\_







NTS

A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-10-81 MJO 54F-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMA-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 54F-9291 PAR 7.6

Date	TEST DESCRIPTION		
12-10-81	SINE BEAT 10 OSC/BEAT 10 BEATS		TAPE COUNTER
1125	10 HZ	4.6gPK CHARGE AMPS. RANGE 10	000 - 157
1137	12.6 HZ	"	157 - 317
1142	15.9 HZ	"	317 - 443
1150	20 HZ	"	443 - 553
1154	25 HZ	"	553 - 641
1157	30 HZ	"	641 - 723
1305	35 HZ	"	723 - 847
1311	40 HZ	"	847 - 934
1317	20 BEATS	ACCEL'S 11,12,13,14,15 & 19	934 - 1072
	45 HZ	4.6gPK ON 30g RANGE	
1320	50 HZ	" ABORTED AFTER 11 BEATS.	1072 - 1203
	UNIT DID NOT CYCLE PROPERLY		
1404	50 HZ	4.6gPK 9 BEATS	1203 - 1288
1420	55 HZ	4.6gPK 20 BEATS - ALL CIA ON 30	1288 - 1423
1434	60 HZ	" " - MONITOR ACCEL.#24	1423 - 1541
1441	70 HZ	" 10 BEATS ON 10g RANGE	1541 - 1628
1444	85 HZ	" "	1628 - 1704
1446	100 HZ	" "	1704 - 1790

AETL ID	CALIB. DUE DATE	AETL ID	CALIB. DUE DATE	AETL ID	CALIB. DUE DATE

TEST BY JIM RICE & DATE \_\_\_\_\_  
JIM FARRIS  
 ENGR. \_\_\_\_\_ GOVT. CAR. \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-10-61 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.6

Date "X" Axis TEST DESCRIPTION

12-10-61	SINE BEAT 10 OSC/BEAT 40 BEATS	TAPE COUNTER
	10-25 HZ 1500 MSEC BETWEEN BEATS	
Time	25-100 HZ 1000 MSEC " "	--
1525	10 HZ 3.5 g PK MONITOR ACCEL. #24 ON	1790-2050
1529	12.6 HZ " 10 g RANGE. ALL	2050-2249
1536	15.9 HZ " RESPONSES ON 30g	2249-2435
1539	20 HZ " RANGE	2435-2584
1545	25 HZ " "	2584-2743
1549	30 HZ " "	2743-2857
1551	35 HZ " "	2857-2964
1555	40 HZ " "	2964-3065
1558	45 HZ " "	3065-3176
1615	50 HZ " ALL 9A ON 10g RANGE	NEW TAPES 000-130
1620	55 HZ " "	130-224
1624	60 HZ " 40 BEATS	224-314
1626	70 HZ " 5 BEATS	314-361
1628	85 HZ " "	361-
1630	100 HZ " "	-421
	SINE BEAT 10 OSC/BEAT 100 BEATS	
1643	10 HZ 2.0 g PK	421-857
1653	12.6 HZ " "	857-1234
1702	15.9 HZ " "	1234-1595
1707	20 HZ " "	1595-1935

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim FARRIS DATE \_\_\_\_\_

PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ C-13 \_\_\_\_\_ GOVT QAR. \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-10-81 MJO 548-9291  
 CUSTOMER STONE E WEBSTER  
 TEST ITEM LIMITOR QUE VALVE MOTOR PIN S1MB-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP#548-9291 PAR 7.6

Date	"X" Axis	TEST DESCRIPTION			
12-10-81	SINE BEAT	10 OSC/BEAT 100 BEATS	TAPE COUNTER		
1710	25 HZ	2.0 g PK ALL CIA 10g RANGE	1935-2256		
1716	30 HZ	"	2256-2489		
1720	35 HZ	"	2489-2719		
1725	40 HZ	"	2719-2935		
1730	45 HZ	" CIA #14 30g RANGE	2935-3156		
1735	50 HZ	"	3156-3328		
1740	55 HZ	"	3328-3490		
1745	60 HZ	"	3490 -		
1817	70 HZ	" 20 BEATS	NEW TAPE 000-080		
1820	85 HZ	" " CIA 12,13 30g RANGE	080-137		
1824	100 HZ	" " CIA 19 " "	137-202		
ROTATED TO "Y" AXIS					
SINE BEAT 10 OSC/BEAT 10 BEATS					
2150	10 HZ	4.6 g PK ALL CIA ON 30g RANGE	202-338		
2155	12.6 HZ	"	338-469		
2200	15.9 HZ	"	469-570		
2205	20 HZ	"	570-650		
2208	25 HZ	"	650-714		
2210	30 HZ	"	714-770		
2212	35 HZ	"	770-824		
2215	40 HZ	"	824-867		
2216	45 HZ	" 20 BEATS	867-934		
AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim Rice DATE \_\_\_\_\_  
 PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ GOVT QAR. \_\_\_\_\_





NTS

A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-10-81 MJO 548-9291  
 CUSTOMER STANE E WEASTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.6

Date	TEST DESCRIPTION	TAPE COUNTER
12-10-81 " Y" Axis		
2220	50 HZ 4.6gpk 20 BEATS	934-1001
2222	55 HZ " "	1001-1066
2236	60 HZ " "	1066-1143
2238	70 HZ " 10 BEATS	1143-1189
2240	85 HZ " "	1189-1233
2242	100 HZ " "	1233-1294
NOTE: ON 100 HZ SINE BEAT THE NORMALLY CLOSED CONTACT INDICATED CHATTER AFTER VALVE WAS CYCLED CLOSED. CUSTOMER REQUESTS RERUN AT 100 HZ.		
2245	100 HZ 4.6gpk 10 BEATS	1294-1345
NOTE: CHATTER IN EXCESS OF 2.0 M SEC. WAS NOTED AGAIN. CUSTOMER REQUESTS CONTINUATION OF TESTING AT 3.5g PK. SINE BEAT 10.05g/BEAT 40 BEATS		
2256	10 HZ 3.5gpk ALL CIR ON 10g RANGE	1345-1541
2302	12.6 HZ " "	1541-1702
2305	15.9 HZ " "	1702-1928
2310	20 HZ " "	1928-2082
2316	25 HZ " "	2082-2230
2320	30 HZ " "	2230-2370
2325	35 HZ " "	2370-2479
2348	40 HZ " "	2479-2584

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim Rice DATE \_\_\_\_\_  
 PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ GOVT CAR. \_\_\_\_\_







NTS

A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-10-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TR# 548-9291 PAR 7.6

Date	TEST DESCRIPTION			
2352	45 HZ	3.5g PK	40 BEATS	2584-2678
2355	50 HZ	"	"	2678-2774
2400	55 HZ	"	"	2774-2862
0005	60 HZ	"	"	2862-2941
0008	70 HZ	"	5 BEATS	2941-3020
0010	85 HZ	"	"	3020-3085
0012	100 HZ	"	" ACCEL'S 17,18 ON 30g	3085-3200
NOTE: CUSTOMER REQUESTED 3 ADDITIONAL PULSES AT 100 HZ WITH LEVEL INCREASED TO 4.6g PK TO MONITOR CHATTER IN EXCESS OF 3 M SEC. NO CHATTER WAS NOTED.				
12-11-81	PROBLEM WITH P.A. - SYA REPAIRED			
	SINE BEAT 10 OSC/BEAT 100 BEATS			NEW TAPE
1015	10 HZ	2.0g PK		000-443
PROBLEM WITH ACCEL R-11. BAD CABLE & BAD THREADS ON ACCEL.				
1031	12.6 HZ	2.0g PK	ALL CIA ON 10g RANGE	443-825
1105	15.9 HZ	"		825-1177
1115	20 HZ	"		1177-1502
1120	25 HZ	"		1502-1811
1125	30 HZ	"		1811-2035
1130	35 HZ	"		2035-2253
1135	40 HZ	"		2253-2462

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ TEST BY Jim Eric S' DATE \_\_\_\_\_  
Jim FARRIS  
 ENGR. \_\_\_\_\_ GOVT QAR. \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-11-81 MO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMR-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP#548-9291 PAR 7.6

Date	TEST DESCRIPTION	TAPE COUNTER
12-11-81 "Y" AXIS		
1145	45 HZ 2.0 g PK 100 BEATS	2462-2669
1148	50 HZ " "	2669-2834
1151	55 HZ " "	2834-2994
1153	60 HZ " "	2994-3158
1155	70 HZ " 20 BEATS	3158-3213
1157	85 HZ " "	3213-3270
1200	100 HZ " "	3270-3326
NOTE: CHATTER IN EXCESS OF 2 M SEC.		
AT 100 HZ, NO CHATTER IN EXCESS OF 3 M SEC.		
1205	ROTATING TO "Z" AXIS	
1319	SINE BEAT 10 OSC/BEAT	NEW TAPES
1321	10 HZ 4.6 g PK 10 BEATS	000-120
1324	12.6 HZ " "	120-194
1327	15.9 HZ " "	194-253
1329	20 HZ " "	253-316
1331	25 HZ " "	316-376
1333	30 HZ " "	376-423
1335	35 HZ " "	423-469
1337	40 HZ " "	469-515
1339	45 HZ " 20 BEATS	515-567
1340	* 50 HZ " "	567-635
* CHANGED RANGE ON CIA FROM 10 TO 30'S FOR ACCEL'S R-10, 11, 14, 15, 16, 17, 18, & 19		

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ TEST BY JIM FARRIS DATE \_\_\_\_\_  
 C-17 GOVT GAR. \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-11-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.6

Date	TEST DESCRIPTION	TAPES COUNTER
12-11-81 "Z" Axis		
1342	55HZ 4.6g PK 20 BEATS	635-689
1344	60HZ " "	689-741
1346	70HZ " 10 BEATS	747-774
1348	85HZ " "	774-810
1351	100HZ " "	810-849
	SINE BEAT 10 OSC/BEAT 40 BEATS	
1334	10HZ 3.5g PK	849-1031
1359	NOTE: BAD TRACE ON "O" GRAPH FOR R-3. BAD CHARGE AMP. CUSTOMER REQUESTED THAT TEST CONTINUE WITHOUT R-3.	
1430	12.6HZ 3.5g PK	1031-1211
	NOTE: R-11 BAD AT BEGINNING OF SINE BEAT. 60HZ ON G/A WITH P.A. ON. CUSTOMER OK'D CONTINUING TEST	
1445	15.9HZ 3.5g PK 29 BEATS	1211-1328
1457	" " 11 BEATS	1328-1395
1502	20HZ " 40 BEATS	1395-1549
1505	25-HZ " "	1549-1699
1511	30 HZ " "	1699-1814
1515	35-HZ " "	1814-1918
1517	40 HZ " "	1918-2023
1520	45-HZ " "	2023-2124
1526	50 HZ " "	2124-2223

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim Farrell's DATE \_\_\_\_\_  
 PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ C-18 GOVT GAR. \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-11-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMR-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TR# 548-9291 PAR 7.6

Date	TEST DESCRIPTION			TAPE COUNTER
1528	55 HZ	3.5g PK	40 BEATS	2223 - 2320
1531	60 HZ	"	"	2320 - 2419
1533	70 HZ	"	5 BEATS	2479 - 2452
1538	85 HZ	"	"	2452 - 2484
1545	100 HZ	"	"	2484 - 2519
	SINE BEAT 10 OSC/B EAT 100 BEATS			
1607	10 HZ	2.0g PK	ALL CIA ON 10g RANGE	2519 - 2843
1615	12.6 HZ			2943 - 3320
	CHANGING MAG. TAPES			NEW TAPE
1642	15.9 HZ	2.0g PK		000 - 338
1647	20 HZ	"		338 - 692
1700	25 HZ	"		692 - 1022
1702	30 HZ	"		1022 - 1253
1706	35 HZ	"		1253 - 1464
1710	40 HZ	"		1464 - 1675
1714	45 HZ	"		1675 - 1875
1716	50 HZ	"		1875 - 2043
1718	55 HZ	"		2043 - 2204
1720	60 HZ	"		2204 - 2364
1724	70 HZ	"	20 BEATS	2364 - 2416
1726	85 HZ	"	"	2416 - 2465
1728	100 HZ	"	"	2465 - 2519

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ TEST BY Jim Farris DATE \_\_\_\_\_  
 ENGR. \_\_\_\_\_ GOVT QAR. \_\_\_\_\_  
 C-19







F.M. TAPE AND OSCILLOGRAPH SET-UP

Customer STONE E WEBSTER MJO# 5-48-9291

Test Item LIMITORQUE VALVE MOTOR

P/N SMB-000-5 E SMB-0-25 S/N \_\_\_\_\_ Date 12-11-81

VISICORDER #1				VISICORDER #2				TAPE #1		TAPE #2	
Ch.	Accel	Trace	G/in Sens.	Ch.	Accel	Trace	G/in Sens.	Ch.	Mv/g Accelerometer	Ch.	Mv/g Acceleromete
1	1			1	13			1		1	1
2	2			2	21			2		2	2
3	3			3	15			3		3	4
4	4			4	16			4		4	5
5	5			5	17			5		5	7
6	6			6	18			6		6	8
7	7			7	19			7		7	10
8	8			8	10			8		8	14
9	9			9	14			9		9	18
10	20			10	22			10		10	21
11	11			11	23			11		11	22
12	12			12	24			12		12	23
13				13				13		13	24 CONTROL
14				14				14		14	VOICE
15				15							
16				16							
17				17							
18				18							

ACCELEROMETER LOCATIONS

Accel.	I.D.#	SURVEYS			AXES		Location
		X	Y	Z	XY	YZ	

Technician JIM FARRIS Date 12-11-81




BOOK NO. \_\_\_\_\_

LOCATION \_\_\_\_\_ J. O. NO. \_\_\_\_\_

REPORT NO. \_\_\_\_\_ PG. NO. \_\_\_\_\_

DATE \_\_\_\_\_ BY \_\_\_\_\_

RANDOM E<sup>1</sup> SINE BEAT TESTS



*internal  
claw base (inside edge)  
(ambiguity  
note)*

Y = 0 to axis of motor  
X = vertical  
Z = L to axis of motor





NTS

A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-11-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-000-5 S/N \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.7

Date	"Z" Axis	TEST DESCRIPTION	TAPE COUNTER
12-11-81		SINE BEAT (FRAGILITY) 15 OSC/BEAT	
1824	35 HZ	8 g PK 20 BEATS ALL CIA ON 10g RANGE	2519-2668
1827	30 HZ	" " ALL CIA IN 30g RANGE	2668-2838
1831	25 HZ	" "	2838-3002
1833	20 HZ	" "	3002-3184
1836	15.9 HZ	" "	3184-3365
		SINE BEAT (FRAGILITY) 10 OSC/BEAT	
1854	40 HZ	8 g PK 20 BEATS	3365-3502
1857	45 HZ	" 15 BEATS	3502-3554
1900	50 HZ	" "	3554-END

NOTE: TAPE RECORDER #1 MALFUNCTIONED.  
 MOVED CRITICAL ACCEL'S TO TAPE  
 RECORDER #2 AS FOLLOWS:

CHANNEL	ACCEL.	CHANNEL	ACCEL.
1	1	8	14
2	2	9	18
3	4	10	21
4	5	11	22
5	7	12	23
6	8	13	24
7	10	14	VOICE

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ C-22 \_\_\_\_\_ GOVT QAR. \_\_\_\_\_  
 TEST BY Jim Rice DATE \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-11-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMA-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPES COUNTER
12-11-81	SINE BEAT (FRAGILITY) 10 OSC/BEAT	NEW TAPES
	"Z" AXIS. ACCEL'S 10, 14 & 18 ON 100g RANGE. ALL OTHERS ON 30g RANGE.	
2006	55HZ 8g PK 15 BEATS	000-052
2008	60HZ " "	052-155
2010	70HZ " "	155-198
2012	85HZ " "	198-249
2015	100HZ " "	249-307
	CHANGE TO "Y" AXIS	
	SINE BEAT (FRAGILITY) 10 OSC/BEAT	
2041	40HZ 8g PK 20 BEATS. ALL ON 30g RANGE	307-438
2043	45HZ " 15 BEATS.	438-493
2045	50HZ " "	493-552
2046	55HZ " "	552-601
2048	60HZ " "	601-654
2049	70HZ " "	
	NOTE: CHATTER NOTED - NOT DUE TO CONTACTS.	
2051	70HZ 8g PK 7 BEATS	654-706
	NOTE: NO CHATTER	
2055	85HZ 8g PK 15 BEATS	706-759
	NOTE: CHATTER AT 2 msec. NO CHATTER AT 4 msec.	
	100HZ 8g PK 15 BEATS + 4 ADDITIONAL	759-853

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ TEST BY JIM RICE DATE \_\_\_\_\_  
 ENGR. \_\_\_\_\_ C-23 \_\_\_\_\_ GOV'T GAR. \_\_\_\_\_







A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-11-81 MJO 548-9291  
 CUSTOMER STONE E WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR IN SMB-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TPE 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPE COUNTER
12-11-81	NOTE: AT 100 HZ CHATTER WAS NOTED AT 2 M SEC. NO CHATTER AT 5 M SEC. CHATTER WAS NOTED ON "3B" AT 2 M SEC. DURING THE ADDITIONAL 4 PULSES. SINE BEAT (FRAGILITY) IS OSC/BEAT	
2105	35 HZ 89 PK 20 BEATS	853-958
2108	30 HZ " "	958-1048
2125	25 HZ " "	1048-1203
	UNIT DID NOT COMPLETE FULL STROKE DURING CYCLING. REMOVED COVER TO EXAMINE UNIT.	
2200	REINSTALLED COVER. CUSTOMER REQUEST RE-RUN OF 25 HZ SINE BEAT.	
2201	25 HZ 89 PK 17 BEATS	1203-1313
	NOTE: UNIT STILL MALFUNCTIONING. DID NOT CYCLE FULLY (7.5 SEC).	
2204	20 HZ 89 PK 20 BEATS	
	NOTE: UNIT WILL NOT CYCLE FULLY (4.5 SEC)	1313-1410
2210	15.9 HZ 89 PK 20 BEATS	1410-1531
	NOTE: UNIT WILL NOT CYCLE FULLY (4.5 SEC). CUSTOMER EXAMINING UNIT. CHANGED CONTACTS ON SAME ROTOR.	

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. JIM RICE DATE \_\_\_\_\_ GOVT ORG. \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-11-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMA-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPES COUNTER
12-11-81	SINE BEAT 15 OSC/BEAT "Y" AXIS	
2250	20 HZ 8g PK 20 BEATS	1531-1663
NOTE: TESTING TO BE DISCONTINUED AT THIS TIME.		

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ TEST BY Jim Rice DATE \_\_\_\_\_  
 ENGR. C-25 GOVT QAR. \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-12-81 MJO 548-9291  
 CUSTOMER STONE S WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMA-0-25 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.6

Date	TEST DESCRIPTION	TAPE COUNTER
12-12-81	SETTING UP IN THE "Y" AXIS SINE BEAT 15 OSC/BEAT CIA 30g	CONTINUED ON SMA-0005 TAPE
1534	12.6 HZ 6.0g PK 6 BEATS RANGE	1623-1784
1537	15.9 HZ " "	1784-1839
1545	20 HZ " "	1839-1915
1547	25 HZ " "	1915-1963
1550	30 HZ " "	1963-2029
1554	35 HZ " "	2029-2102
1606	10 HZ 4.6g PK 10 BEATS 10 OSC/BEAT	2102-2184
1610	12.6 HZ " "	2184-2257
1612	15.9 HZ " "	2257-2307
1614	20 HZ " "	2307-2371
1615	25 HZ " "	2371-2431
1616	30 HZ " "	2431-2489
1617	35 HZ " "	2489-2541
1618	40 HZ " "	2541-2585
1624	45 HZ 20 BEATS	2585-2653
1626	50 HZ " "	2653-2727
1627	55 HZ " "	2727-2783
1628	60 HZ " "	2783-2838
1632	70 HZ 10 BEATS	2838-2892
1634	85 HZ " "	2892-2932
1636	100 HZ 4.6g PK " "	2932-2971

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim Rice DATE \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-12-81 AJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-0-25 SIN \_\_\_\_\_  
 SPECIFICATION NTS TPT# 548-9291 PAR 7.6

Date	"Y" Axis	TEST DESCRIPTION	TAPES COUNTER
12-12-81	SINE BEAT	10 OSC/BEAT 9A 10g RANGE	
1825	10 HZ	40 BEATS 3.5gPK	000 - 503
	"	100 BEATS 2.0gPK	--
1830	12.6 HZ	40 BEATS 3.5gPK	503 - 1000
	"	100 BEATS 2.0gPK	
1835	15.9 HZ	40 BEATS 3.5gPK	1000 - 1308
	"	100 BEATS 2.0gPK	
1850	20 HZ	40 BEATS 3.5gPK	1308 - 1647
	"	100 BEATS 2.0gPK	
1858	25 HZ	40 BEATS 3.5gPK	1647 - 1963
	"	100 BEATS 2.0gPK	
1903	30 HZ	40 BEATS 3.5gPK	1963 - 2267
	"	100 BEATS 2.0gPK	
1908	35 HZ	40 BEATS 3.5gPK	2267 - 2559
	"	100 BEATS 2.0gPK	
1913	40 HZ	40 BEATS 3.5gPK	2559 - 2848
	"	100 BEATS 2.0gPK	
1918	45 HZ	40 BEATS 3.5gPK	2848 - END
	"	100 BEATS 2.0gPK	
1935	50 HZ	40 BEATS 3.5gPK	000 - 269
	"	100 BEATS 2.0gPK	
1940	60 HZ	40 BEATS 3.5gPK	269 - 476
	"	100 BEATS 2.0gPK	

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim Rice DATE \_\_\_\_\_  
 PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ GOVT QAR. \_\_\_\_\_







A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-12-51 MO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-0-25 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.6

Date	TEST DESCRIPTION	TAPE COUNTER
	CIA 10g	
12-12-51	SINE BEAT 10 OSC/BEAT "Y" AXIS	
1945	55 HZ 40 BEATS 3.5g PK	476-691
	" 100 " 2.0g PK	-
1947	70 HZ 5 BEATS 3.5g PK	691-747
	" 20 " 2.0g PK	
1950	85 HZ 5 BEATS 3.5g PK	747-813
	" 20 " 2.0g PK	-
1954	100 HZ 5 BEATS 3.5g PK	813-894
	" 20 " 2.0g PK	
	CHANGING TO "Z" AXIS	
	SINE BEAT 15 OSC/BEAT 6.0g PK	
2028	12.6 HZ 6 BEATS	894-950
2040	15.9 HZ "	950-1067
2050	20 HZ "	1067-1125
2053	25 HZ "	1125-1182
2055	30 HZ "	1182-1229
2057	35 HZ "	1229-1272
	OPENED UNIT TO EXAMINE, #10 BAD	
	SINE BEAT 10 OSC/BEAT	
2117	10 HZ 4.6g PK	1272-1755
	" 3.5g PK	
	" 2.0g PK	

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. Jim Rice TEST BY \_\_\_\_\_ DATE \_\_\_\_\_  
 GOVT CAR. \_\_\_\_\_





NTS

A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-12-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITING VALVE MOTOR PIN SMA-0-25 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP # 548-9291 PAR 7.6

Date	TEST DESCRIPTION	GRA	IOg	TAPES COUNTER
12-12-81	SINE BEAT 10 OSC/BEAT "Z" AXIS			
2130	12.6 HZ 4.6 gPK 10 BEATS			1755-2194
	" 3.5 gPK 40 "			"
	" 2.0 gPK 100 "			"
2134	15.9 HZ 4.6 gPK 10 BEATS			2194-2698
	" 3.5 gPK 40 "			"
	" 2.0 gPK 100 "			"
2140	20 HZ 4.6 gPK 10 BEATS			2698-3175
	" 3.5 gPK 40 "			"
	" 2.0 gPK 100 "			"
2150	25 HZ 4.6 gPK 10 BEATS			3175- END
	" 3.5 gPK 40 "			"
	" 2.0 gPK 100 "			"
2203	30 HZ 4.6 gPK 10 BEATS			000-278
	" 3.5 gPK 40 "			"
	" 2.0 gPK 100 "			"
2217	35 HZ 4.6 gPK 10 BEATS			278-517
	" 3.5 gPK 40 "			"
	" 2.0 gPK 100 "			"
2219	40 HZ 4.6 gPK 10 BEATS			517-759
	" 3.5 gPK 40 "			"
	" 2.0 gPK 100 "			"

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. Jim Rice DATE \_\_\_\_\_ GOVT CAR. \_\_\_\_\_





NTS

A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-13-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMA-0-25 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.6

Date	TEST DESCRIPTION	C/A 100	TAPE COUNTER
12-12-81	SINE BEAT 10 OSC/BEAT "Z" AXIS		
2123	45HZ 4.6gPK 20 BEATS		759-1029
	" 3.5 40 "		"
	" 2.0 100 "		
124381	50HZ 4.6gPK 20 BEATS		1029-1282
0935	" 3.5 40 "		
	" 2.0 100 "		
0940	55HZ 4.6gPK 20 BEATS		1282-1516
	" 3.5 40 "		
	" 2.0 100 "		
0945	60HZ 4.6gPK 20 BEATS		1516-1762
	" 3.5 40 "		
	" 2.0 100 "		
0950	70HZ 4.6gPK 10 BEATS		1762-1879
	" 3.5 7 "		
	" 2.0 20 "		
0956	85HZ 4.6gPK 10 BEATS		1879-1967
	" 3.5 5 "		
	" 2.0 20 "		
1000	100HZ 4.6gPK 10 BEATS		1967-2041
	" 3.5 5 "		
	" 2.0 20 "		

CHANGING TO "X" AXIS

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim Rice DATE \_\_\_\_\_  
 PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ C-30 \_\_\_\_\_ GOVT QAR. \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-13-81 MJO 548-9291  
 CUSTOMER STONE & WEASTAR  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-0-25 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP # 548-9291 PAR 7.6

Date	TEST DESCRIPTION	CIA = 10g	TAPE COUNTER
12-13-81	SINE BEAT 15 OSC/BEAT "X" AXIS		
1409	12.6 HZ 6.0 g PK 6 BEATS		2041-2159
1411	15.9 HZ " "		2159-2231
1412	20 HZ " "		2231-2285
1415	25 HZ " "		2285-2352
1419	30 HZ " "		2352-2418
1420	35 HZ " "		2418-2481
	SINE BEAT 10 OSC/BEAT "X" AXIS CIA 10g		
1440	10 HZ 4.6 g PK 10 BEATS		2481-2960
	" 3.5 40 "		
	" 2.0 100 "		
1448	12.6 HZ 4.6 g PK 10 BEATS		2960- END
	" 3.5 40 "		
	" 2.0 100 "		
1454	15.9 HZ 4.6 g PK 10 BEATS		000-398
	" 3.5 40 "		
	" 2.0 100 "		
1505	20 HZ 4.6 g PK 10 BEATS		398-756
	" 3.5 40 "		
	" 2.0 100 "		
1510	25 HZ 4.6 g PK 10 BEATS		756-1087
	" 3.5 40 "		
	" 2.0 100 "		

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY JIM RICE DATE \_\_\_\_\_  
 ENGR. \_\_\_\_\_ GOVT CAR. \_\_\_\_\_  
 PAGE \_\_\_\_\_ OF \_\_\_\_\_ C-31







A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-13-81 MO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMIT TORQUE VALVE MOTOR PIN SMB-0-25 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.6

Date	TEST DESCRIPTION			TAPE COUNTER
	SINE BEAT 10 OSC/BEAT "X" AXIS CIA 10g			
1517	30 HZ	4.6 g PK	10 BEATS	1087-1350
	"	3.5	40 "	-
	"	2.0	100 "	
1528	35 HZ	4.6 g PK	10 BEATS	1350-1596
	"	3.5	40 "	
	"	2.0	100 "	
1532	40 HZ	4.6 g PK	10 BEATS	1596-1846
	"	3.5	40 "	
	"	2.0	100 "	
1536	45 HZ	4.6 g PK	20 BEATS	1846-2092
	"	3.5	40 "	
	"	2.0	100 "	
1540	50 HZ	4.6 g PK	20 BEATS	2092-2334
	"	3.5	40 "	
	"	2.0	100 "	
1544	55 HZ	4.6 g PK	20 BEATS	2334-2571
	"	3.5	40 "	
	"	2.0	100 "	
1548	60 HZ	4.6 g PK	20 BEATS	2571-2800
	"	3.5	40 "	
	"	2.0	100 "	

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim Rice DATE \_\_\_\_\_  
 PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ GOVT QAR. \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-13-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMD-0-25 SIN \_\_\_\_\_  
 SPECIFICATION NTS TR# 548-9291 PAR 7.6

Date	TEST DESCRIPTION			TAPES COUNTER
	SINE BEAT 10.055/BEAT "X" AXIS CIA 10g			
1554	70HZ	4.6g PK	10 BEATS	2800-2906
	"	3.5	5 "	-
	"	2.0	20 "	
1556	85HZ	4.6g PK	10 BEATS	2906-3014
	"	3.5	5 "	
	"	2.0	20 "	
1558	100HZ	4.6g PK	10 BEATS	3014-3121
	"	3.5	5 "	
	"	2.0	20 "	
1619	40HZ	8g PK	20 BEATS CIA 30g	3121-3226
1621	45HZ		15 BEATS	3226-3293
1623	50HZ			3293-3356
1625	55HZ			3356-3426
1627	60HZ			3426-3491
1629	70HZ			3491-3556
1631	85HZ			3556-3616
1633	100HZ			3616-3681
1649	35HZ	8g PK	20 BEATS 15.055/BEAT	3681-3797
1652	30HZ	"	"	3797-3881
1654	25HZ	"	"	3881-3971
1657	20HZ	"	"	3971-4071
1700	15.9HZ	"	"	4071-END

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim Rice DATE \_\_\_\_\_  
 PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ GOVT GAR. \_\_\_\_\_  
 C-33





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-14-81 MO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMA-0-25 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPE COUNTER
12-14-81	CHANGING TO "Z" AXIS SINE BEAT (FRAGILITY) 15 OSC/BEAT	CUST TAPE 000-076
1020	35 HZ 8g PK 20 BEATS CIA 30g	076-203
1024	30 HZ " "	203-298
1028	25 HZ " "	298-388
1030	20 HZ " "	388-481
1032	15.9 HZ " "	481-584
	SINE BEAT (FRAGILITY) 15 OSC/BEAT	
1100	40 HZ 8g PK 20 BEATS	584-650
1102	45 HZ 15	650-705
1104	50 HZ	705-753
1106	55 HZ	753-798
1108	60 HZ	798-842
1110	70 HZ	842-883
1112	85 HZ	883-922
1114	100 HZ	922-963
	CHANGING TO "Y" AXIS SINE BEAT (FRAGILITY) 15 OSC/BEAT	
1310	35 HZ 8g PK 20 BEATS CIA 30g	963-1052
1312	30 HZ " "	1052-1132
1314	25 HZ " "	1132-1221
1316	20 HZ " "	1221-1308
1318	15.9 HZ " "	1308-1401

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim Farris DATE \_\_\_\_\_  
 PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ C-34 GOVT QAR. \_\_\_\_\_











A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-18-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR P/N SMB-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPE COUNTER
	NOTE: LIMITORQUE REP. ADJUSTED	
	CONTACTS ON TORQUE SWITCH 12-14-81	
12-18-81	SETTING UP IN "X" AXIS	--
	SINE BEAT (FRAGILITY) 15 OSC/BEAT CIA 30g	
1330	30HZ 8g PK 20 BEATS (LEVEL TOO LOW)	060-143
1340	" " " REPEAT	143-201
	CHECKED ACCEL. #3 RE-CAL'D OK	
1430	35HZ 8g PK 20 BEATS	201-245
1450	40HZ 20 BEATS 10 OSC/BEAT	245-293
1455	45HZ 15	293-318
1500	50HZ	318-348
1503	55HZ	348-373
1505	60HZ	373-396
1507	70HZ	396-418
1509	85HZ	418-437
1510	100HZ	437-461
1514	40HZ 10g PK 20 BEATS	461-507
1519	45HZ 15	507-537
1521	50HZ	537-561
1523	55HZ	561-584
1524	60HZ	584-609
1525	70HZ	609-636
1527	85HZ	636-657

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim FARRIS DATE \_\_\_\_\_  
 PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ GOVT QAR. \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-18-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITROQUE VALVE MOTOR PIN SMA-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TR# 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPE COUNTER
12-18-81	SINE BEAT (FRAGILITY) "X" AXIS	
1329	100 HZ 10 g PK 15 BEATS 10 OSC/BEAT	657-682
1547	20 HZ " 20 BEATS 15 OSC/BEAT	682-743
1550	25 HZ " " "	743-789
1553	30 HZ " " "	789-831
1555	35 HZ " " "	831-871
	NOTE: DID NOT DO SINE BEAT AT 9g PK PER CUSTOMER REQUEST	
1600	ROTATING SHAKER TO SLIP AXIS. SETTING UP IN "Z" AXIS. SINE BEAT 15 OSC/BEAT CIA 30g	
1712	20 HZ 10 g PK 20 BEATS	871-931
1715	25 HZ	931-977
1718	30 HZ	977-1019
1720	35 HZ	1019-1059
1730	40 HZ 10 OSC/BEAT	1059-1091
1734	45 HZ 15 BEATS	1091-1125
1736	50 HZ	1125-1160
1738	55 HZ	1160-1173
1740	60 HZ	1173-1187
1742	70 HZ	1187-1226
1744	85 HZ	1226-
1746	100 HZ	-1314

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY JIM FARRIS DATE \_\_\_\_\_  
 ENGR. \_\_\_\_\_ GOVT CAR. \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-18-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TR# 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPE COUNTER
12-18-81	NOTE: SINE BEAT 10gPK "X" AXIS CHATTER INDICATED AT 60HZ 2 MSEC. RESET TO 2.5 MSEC. NO CHATTER. AT 70HZ 2.5 MSEC. NO CHATTER AT 85HZ 2.0 M SEC. NO CHATTER AT 100HZ 2.0 M SEC. NO CHATTER	
	NOTE: SINE BEAT 10gPK "Y" AXIS CHATTER AT 70HZ 2 MSEC. NO CHATTER AT 3 MSEC. CHATTER AT 85HZ 2 MSEC. NO CHATTER AT 4 MSEC. CHATTER AT 100HZ 2 MSEC NO CHATTER AT 4 M SEC.	
1750	CHANGING TO "Z" AXIS SINE BEAT 10 OSC/BEAT ACCEL'S 4, 5, 6 & 11 ON 100g RANGE ALL OTHERS ON 30g RANGE	
1853	40 HZ 10gPK 20 BEATS	1314-1351
1855	45 HZ " 15 BEATS	1351-1379
1857	50 HZ " "	1379-1405
1859	55 HZ " "	1405-1429
1901	60 HZ " "	1429-1454

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ TEST BY JIM FARRIS DATE \_\_\_\_\_  
 C-38 GOVT QAR. \_\_\_\_\_





NTS

A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-18-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMA-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPE COUNTER
12-18-81	NOTE: ALL BOLTS NOT UTILIZED TO ATTACH FIXTURE TO ADAPTER PLATE. REMOVED ALL BOLTS. FIXTURE NOT MATED FLAT WITH ADAPTER PLATE. FILED ALL HIGH SPOTS ON ADAPTER PLATE MAINLY AROUND TAPPED HOLES. FIXTURE MATES BETTER WITH ADAPTER PLATE BUT STILL ROCKS A LITTLE. USING ONLY 6 ATTACH BOLTS. OK PER CUSTOMER FOR THIS AXIS.	
1939	70 HZ 10 g PK 15 BEATS 10 osc/BEAT	1454-1484
1941	85 HZ " " "	1484-1505
1943	100 HZ " " "	1505-1545
1945	NOTE: 16 ADDITIONAL BEATS AT 100 HZ PER CUSTOMER REQUEST	
1955	20 HZ 10 g PK 20 BEATS 15 osc/BEAT	1545-1650
2004	25 HZ " " "	1650-1689
2008	30 HZ " " "	1689-1705
2013	35 HZ " " "	1705-1730

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY JIM FARRIS DATE \_\_\_\_\_  
 PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ C-39 \_\_\_\_\_ GOVT CAR. \_\_\_\_\_







A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-18-81 MJO 548-9291  
 CUSTOMER STANG & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMR-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TR# 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPS COUNTER
12-18-81	SINE BEAT 15 OSC/BEAT "Z" AXIS	
2026	20 HZ 12g PK 20 BEATS	1730-1783
2030	25 HZ " "	1783-1825
2033	30 HZ " "	1825-1865
2035	35 HZ " "	1865-1902
2055	40 HZ 12g PK " 10 OSC/BEAT	1902-1936
2058	45 HZ " 15 BEATS	1936-1960
2100	50 HZ	1960-1983
2102	55 HZ	1983-2004
2104	60 HZ	2004-2026
2106	70 HZ	2026-2048
2108	85 HZ	2048-2070
2110	100 HZ	2070-2108

NOTE: 11 ADDITIONAL BEATS AT 100 HZ  
 CHATTER AT 100 HZ 2m SEC.  
 NO CHATTER AT 100 HZ 4m SEC.

12-18-81 CHANGING TO "Y" AXIS  
 SINE BEAT 10 OSC/BEAT  
 ACCUS 4, 5, 6 & 11 CIA ON 100g RANGE  
 ALL OTHERS ON 30g RANGE

1050	40 HZ 12g PK 20 BEATS	2108-2149
1055	45 HZ " 15 BEATS	2149-2172
1058	50 HZ " 22 BEATS	2172-2200

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ TEST BY JIM FARRIS & Jim Rice DATE \_\_\_\_\_  
 ENGR. Jim Rice GOV'T QAR. \_\_\_\_\_  
 C-40





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-19-81 MJO 548-9291  
 CUSTOMER STONE & WEASTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP # 548-9291 PAR 7, 7

Date	TEST DESCRIPTION	TAPE COUNTER
12-19-81	SINE BEAT 10 OSC/BEAT "Y" AXIS	
1100	55 HZ 12g PK 18 BEATS	2200-2228
1104	60 HZ " 15	2238-2250
1106	70 HZ " 20	2250-2276
1108	85 HZ " 20	2276-2304
1110	100 HZ " 29	2304-2339
	NOTE: ADDITIONAL BEATS AT 50, 55, 70, 85 & 100 HZ PER CUSTOMER REQUEST.	
	50 HZ - CHATTER 2 MSEC NO CHATTER 3 MSEC	
	55 HZ " " " "	
	85 HZ " " " 4 MSEC	
	100 HZ " " " 6 MSEC	
	SINE BEAT 15 OSC/BEAT	
1130	35 HZ 12g PK 20 BEATS	2339-2379
1134	30 HZ " "	2379-2425
1136	25 HZ " "	2425-2469
1138	20 HZ " "	2469-2514
	CHANGING TO "X" AXIS	
	SINE BEAT 15 OSC/BEAT	
1346	35 HZ 12g PK 20 BEATS	2514-2566
1349	30 HZ " "	2566-2609
1352	25 HZ " "	2609-2654
1355	20 HZ " "	2654-2705

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ TEST BY Jim Rice DATE \_\_\_\_\_  
 ENGR. \_\_\_\_\_ GOVT CAR. \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-19-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP # 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPE COUNTER
12-19-81	SINE BEAT 10 osc/BEAT "X" AXIS	
	C/A 4, 5, 6 & 11 ON 100g RANGE. ALL OTHERS 30g	
1400	40 HZ 12 g PK 20 BEATS	2705-2744
1404	45 HZ 15	2744-2768
1406	50 HZ 15	2768-2790
1407	55 HZ 15	2790-2813
1409	60 HZ 20	2813-2839
1410	70 HZ 15	2839-2859
1412	85 HZ 15	2859-2883
1414	85 HZ 15	2883-2902
1416	100 HZ 18	2902-2926
	NOTE: 60 HZ CHATTER AT 2msec NO CHATTER 3msec	
	70 HZ " " " "	
1420	100 HZ 14 g PK 15 BEATS 10 osc/BEAT	2926-2955
1422	85 HZ "	2955-2984
1423	70 HZ "	2984-3011
1424	60 HZ "	3011-3038
1426	55 HZ "	3038-3064
1428	50 HZ 18 BEATS	3064-3097
1430	45 HZ 15	3097-3121
1432	40 HZ 20	3121-3160
1439	35 HZ 20 15 osc/BEAT	3160-3202
1441	30 HZ 10 "	3202-3232

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim Rice DATE \_\_\_\_\_  
 PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ GOVT CAR. \_\_\_\_\_





NTS

A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-19-81 MO 548-9291  
 CUSTOMER STONE & WEASTER  
 TEST ITEM LIMITARQUE VALVE MOTOR PIN SMA-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPE COUNTER
12-19-81	SINE BEAT "X" AXIS	
1510	30 HZ 14gpk 10 BEATS 15 osc/BEAT	3232-3259
1513	25 HZ " 20 " " "	3259-3304
	NOTE: 70 HZ CHATTER AT 2MSEC NO CHATTER 3MSEC	
	55 HZ " " " 4 MSEC	
	50 HZ " " " 4 MSEC	
	CHANGING TO "Y" AXIS	
	SINE BEAT CIA 4, 5, 6, 11 ON 100g RANGE	
	ALL OTHERS ON 30g RANGE	
1605	35 HZ 14gpk 20 BEATS 15 osc/BEAT	3304-3346
1615	30 HZ " " " "	3346-3380
1618	25 HZ " " " "	3380-3430
1636	40 HZ 14gpk 20 BEATS 10 osc/BEAT	3430-3465
1638	45 HZ " " 15 BEATS	3465-3495
1640	50 HZ " " " "	3495-3528
1642	55 HZ " " " "	3526-3550
1643	60 HZ " " " "	3550-3579
1645	70 HZ " " " "	3579-3606
1647	85 HZ " " " "	3606-3631
1648	100 HZ " " " "	3631-3657

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ TEST BY Jim Rice DATE \_\_\_\_\_  
 ENGR. \_\_\_\_\_ C-43 GOVT CAR. \_\_\_\_\_







A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev. 1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-19-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMA-000-5 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPE COUNTER
12-19-81	SINE BEAT "Y" AXIS 14g PK NOTE: 25HZ CHATTER AT 2MSEC NO CHATTER AT 4MSEC	
	50HZ " " " "	--
	55HZ " " " "	
	85HZ " 4msec " 5msec	
	100HZ " " " "	
	CHANGING TO "Z" AXIS CIA 4,5,6,11 ON 100g RANGE. ALL OTHERS 30g.	
1704	40HZ 14g PK 20 BEATS 10 OSC/BEAT	3657-3694
1706	45HZ 15 BEATS	3694-3723
1707	50HZ	3723-3753
1708	55HZ	3753-3786
1710	60HZ	3786-3816
1712	70HZ	3816-3855
1714	85HZ	3855-3888
1716	100HZ	3888-3922
	NOTE: 50HZ CHATTER AT 2MSEC NO CHATTER AT 3MSEC	
	55HZ " " " "	
	85HZ " 3msec " 4msec	
1722	35HZ 14g PK 20 BEATS 15 OSC/BEAT	3922-3961
1724	25HZ " " " "	3961-3999
1726	20HZ " " " "	3999-END

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim Rice DATE \_\_\_\_\_  
 PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. C-44 GOV'T CAR. \_\_\_\_\_





F.M. TAPE AND OSCILLOGRAPH SET-UP

Customer STONE & WEBSTER

MJO# 548-9291

Test Item LIMITORQUE VALVE MOTOR

P/N SMB-000-5 & SMB-0-25

S/N

Date 12-21-81

7 1/2 IPS

VISICORDER #1					VISICORDER #2					TAPE #1			TAPE #2		
Ch.	Accel	Trace	G/in	Sens.	Ch.	Accel	Trace	G/in	Sens.	Ch.	Mv/g	Accelerometer	Ch.	Mv/g	Accelerometer
1	R1				1					1	R1		1		
2	R2				2					2	R2		2		
3	R3				3					3	R3		3		
4	R4				4					4	R4		4		
5	R5				5					5	R5		5		
6	R6				6					6	R6		6		
7	R7				7					7	R7		7		
8	R8				8					8	R8		8		
9	R9				9					9	R9		9		
10	R10				10					10	R10		10		
11	R11				11					11	R11		11		
12	R12				12					12	R12		12		
13	R13	CONTROL			13					13	R13 CONTROL		13		
14					14					14	Voices		14		
15					15										
16					16										
17					17										
18					18										

ACCELEROMETER LOCATIONS

Accel.	I.D. #	SURVEYS			AXES		Location
		X	Y	Z	XY	YZ	

Technician \_\_\_\_\_ Date \_\_\_\_\_



BOOK NO. \_\_\_\_\_

LOCATION \_\_\_\_\_ I. O. NO. \_\_\_\_\_

REPORT NO. \_\_\_\_\_ PG. NO. \_\_\_\_\_

DATE \_\_\_\_\_ BY \_\_\_\_\_


SINE BEAT

"C"

TEST AXIS

11. TEST AXIS

NOTE:  
R9 - TEST AXIS  
R10 - OTHER AXIS



*internal  
claw bar/pair of claws  
(control unit)*

Y ≡ || to axis of motor  
X ≡ vertical  
Z ≡ ⊥ to axis of motor

COPIES TO-1 \_\_\_\_\_

COPIES TO-2 \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-21-81 MJO 548-9291  
 CUSTOMER STONE & WEASTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMR-0-25 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPE COUNTER
12-21-81	SETTING UP IN "Z" AXIS	7 1/2 ips
	C/A 4,5,6,11 ON 100g RANGE. ALL OTHERS 30g.	
	SINE BEAT	CUE TAPE 000-054
1117	20 HZ 12g PK 20 BEATS 150SC/BEAT	054-112
1124	CHECKED ACCEL'S # 12	
1144	25 HZ 12g PK 20 BEATS	112-158
	ENCOUNTERED A HOLLOW SOUNDING NOISE AT APPROX. 8g PK. REPLACED BLOCK UNDER LEG OF STEEL BASE PLATE.	
1202	30 HZ 12g PK 20 BEATS	158-206
	STILL TOO HIGH AN INDICATION ON ACCEL#12. CHECKED LIMIT SWITCH MOUNTING BLOCK. RAN DYNAMIC CAL ON ACCEL#12. OK	
1305	35 HZ 12g PK 20 BEATS	206-252
1317	40 HZ " " 100SC/BEAT	252-292
	MOVED ACCEL#7 TO SAME LOCATION AS ACCEL#12. SAME INDICATION ON BOTH ACCEL'S. MOVED ACCEL#7 BACK TO ORIGINAL LOCATION. CUSTOMER FELT THAT ACCEL#12 WAS INDICATING TOO HIGH A LEVEL AND WANTED VERIFICATION THAT THE ACCEL. & CHARGE AMP. WERE OK.	

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ TEST BY Jim FARRIS DATE \_\_\_\_\_  
 ENGR. \_\_\_\_\_ C-47 GOVT CAR. \_\_\_\_\_







NTS

A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-21-81 MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-0-25 SIN \_\_\_\_\_  
 SPECIFICATION NTS TPE 548-9291 PAR 2.7

Date	TEST DESCRIPTION	TAPE COUNTER
12-21-81	SINE BEAT "Z" AXIS 10 OSC/BEAT	7 1/2 1P5
1324	45 HZ 12g PK 15 BEATS	292-319
1326	50 HZ	319-343
1328	55 HZ	343-366
1329	60 HZ	366-389
1330	70 HZ	389-412
1335	85 HZ	412-437
1340	100 HZ	437-460
CHANGING TO "Y" AXIS		
SINE BEAT "Y" AXIS 10 OSC/BEAT		
1420	40 HZ 12g PK 20 BEATS	460-496
1425	45 HZ 15 BEATS	496-529
1426	50 HZ "	529-556
1427	55 HZ "	556-580
1429	60 HZ "	580-606
1431	70 HZ "	606-631
1433	85 HZ 21 BEATS	631-664
1435	100 HZ 20 BEATS	664-706
NOTE: 55 HZ NO CHATTER AT 3 msec		
	60 HZ " "	
	70 HZ " "	
	85 HZ " "	
	100 HZ " "	

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY JIM FARRIS DATE \_\_\_\_\_  
 ENGR. \_\_\_\_\_ GOV'T GAR. \_\_\_\_\_

PAGE \_\_\_\_\_ OF \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-31-81 WJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMA-D-25 SIN \_\_\_\_\_  
 SPECIFICATION NTS TPE 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPE COUNTER
12-21-81	SINE BEAT "Y" AXIS 15 OSC/BEAT	7 1/2 195
1447	20 HZ 12g PK 20 BEATS	706-757
1449	25 HZ " "	757-802
1451	30 HZ " "	802-845
1453	35 HZ " "	845-888
	CHANGING TO "X" AXIS	
	SINE BEAT "X" AXIS 15 OSC/BEAT	
1615	20 HZ 12g PK 20 BEATS	888-940
1620	25 HZ " "	940-990
1623	30 HZ " "	990-1034
1626	35 HZ " "	1034-1075
	REPLACED CHARGE AMP. #9 - PAN DYNAMIC.	
	CAL. SET UP GALVO & TAPE OUTPUT.	
1700	SINE BEAT 10 OSC/BEAT	1075-1113
1702	40 HZ 12g PK 20 BEATS	/ 1113-1142
1704	45 HZ 15 BEATS	/ 1142-1174
1705	50 HZ	/ 1174-1202
1706	55 HZ	/ 1202-1224
1707	60 HZ	/ 1224-1246
1708	70 HZ	/ 1246-1266
1710	85 HZ	/ 1266-1290
1711	100 HZ	/

NOTE: C/A #11 ON 30g RANGE 20 HZ - 100 HZ

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY Jim Farrell DATE \_\_\_\_\_  
 PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ C-49 \_\_\_\_\_ GOVT QAR. \_\_\_\_\_





NTS

A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-21-81 MJO 548-9291  
 CUSTOMER STONE & WEASTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-0-25 SIN \_\_\_\_\_  
 SPECIFICATION NTS TR# 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPE COUNTER
12-21-81	NOTE: CIA #11 CHANGED FROM 30 TO 100 RANGE SINE BEAT "X" AXIS 10 OSC/BEAT	7 1/2 IPS
1720	40 HZ 14 g PK 20 BEATS	1290 - 1325
1724	45 HZ 15 BEATS	1325 - 1351
1726	50 HZ	1351 - 1380
1728	55 HZ	1380 - 1403
1730	60 HZ	1403 - 1434
1732	70 HZ	1434 - 1458
1734	85 HZ	1458 - 1480
1736	100 HZ	1480 - 1501
	SINE BEAT 15 OSC/BEAT	
1747	35 HZ 14 g PK 20 BEATS	1501 - 1546
1750	30 HZ " "	1546 - 1589
1754	25 HZ " "	1589 - 1632
1758	20 HZ " "	1632 - 1674
1830	CHECKED "O" GRAPH TRACES	
12-22-81	CHANGING TO "Y" AXIS SINE BEAT "Y" AXIS 10 OSC/BEAT	
1005	40 HZ 14 g PK 20 BEATS	1674 - 1737
1007	45 HZ " 18 "	1737 - 1771
1010	50 HZ " 15 "	1771 - 1797
	NOTE: AT 45 HZ NO CHATTER AT 2.4 msec	

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. JIM FARRIS DATE \_\_\_\_\_  
 C-50 GOVT CAR. \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-22-81 MO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-0-25 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPE COUNTER
12-22-81	SINE BEAT "Y" AXIS 10 OSC/BEAT	7 1/2 IPS
1015	55HZ 8gPK 6 BEATS	1797-1885
"	10 5 "	--
"	12 21 "	
"	10 8 "	
"	11 11 "	
"	14 27 "	
NOTE: NO CHATTER AT 11gPK 5 msec.		
1020	60HZ 8gPK 7 BEATS	1885-1955
"	10 14 "	
"	12 14 "	
"	10 7 "	
"	14 21 "	
NOTE: NO CHATTER AT 10, 12 & 14gPK AT 5 msec.		
1025	70HZ 8gPK 5 BEATS	1955-2008
"	10 4 "	
"	11 16 "	
"	14 22 "	
NOTE: NO CHATTER AT 11 & 14gPK AT 2.5 msec.		

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

PAGE \_\_\_\_\_ OF \_\_\_\_\_ TEST BY JIM FARRIS DATE \_\_\_\_\_  
 ENGR. \_\_\_\_\_ C-51 \_\_\_\_\_ GOVT QAR. \_\_\_\_\_







A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev.1

GENERAL DATA SHEET

TEST SINE BEAT DATE 12-22-PI MJO 548-9291  
 CUSTOMER STONE & WEASTER  
 TEST ITEM LIMITORQUE VALVE MOTOR PIN SMB-0-25 SIN \_\_\_\_\_  
 SPECIFICATION NTS TP# 548-9291 PAR 7.7

Date	TEST DESCRIPTION	TAPE COUNTER
12-22-PI	SINE BEAT "Y" AXIS 10 OSC/BEAT	7 1/2 IPS
1030	8.5 HZ 8g PK 5 BEATS	2008-2057
"	" 10 " 3 "	--
"	" 11 " 14 "	
"	" 14 " 18 "	
NOTE: NO CHATTER AT 11 & 14 g PK 2.5 MSEC		
1035	100 HZ 8g PK 7 BEATS	2057-2109
"	" 11 " 24 "	
"	" 14 " 22 "	
NOTE: NO CHATTER AT 11 & 14 g PK AT 4 MSEC.		
SINE BEAT 15 OSC/BEAT		
1042	35 HZ 14g PK 20 BEATS	2109-2154
1045	30 HZ " 11 "	2154-2183
NOTE: NO CHATTER AT 35 HZ AT 5 MSEC.		
SHUT DOWN AFTER 11 BEATS AT 30 HZ TO		
CHECK LEG ON STEEL BASE PLATE.		
ADJUSTED BASE PLATE AND CHECKED FOR		
PROPER CLEARANCE BETWEEN SLIP PLATE		
& BASE PLATE.		
1110	30 HZ 14g PK 9 BEATS	2183-2211
1115	25 HZ " 20 "	2211-2264

AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE	AETL ID	CALIB DUE DATE

TEST BY JIM FARRIS DATE \_\_\_\_\_

PAGE \_\_\_\_\_ OF \_\_\_\_\_ ENGR. \_\_\_\_\_ GOVT QAR. \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev. 1

GENERAL LOG SHEET

TEST SEISMIC MJO 548-9291  
 CUSTOMER STONE + WEBSTER  
 TEST ITEM LIMITORQUE OPERATOR P/N SMB-0-25 SIN \_\_\_\_\_  
+ MODIFIED LIMIT SWITCHES 12B + 12C  
 SPECIFICATION \_\_\_\_\_ PAR \_\_\_\_\_

DATE	TIME	LOG ENTRIES	INITIAL
12-2-81		EQUALIZED SIMULATOR, CALIBRATED 23 RESPONSE ACCELS + 2 CONTROL ACCELS ONTO FM TAPE + OSCILLOGRAPH. CHATTER SHALL BE MONITORED ACROSS THE SWITCH CONTACTS DURING THE TEST @ 2 MS. MOUNTED THE OPERATOR TO THE SIMULATOR IN THE XZ AXES, AND ATTACHED 23 RESPONSE ACCELS TO SPECIMEN AS DESCRIBED BY THE SKETCH. A.C. Power IS CONNECTED to the operator motor.	JH
12-3-81	0800	Re-calibrated control accelerometers.	JH
	1300	Ran XZ axis seismic @ 80% power (468 volts) to operator motor, 35 seconds duration. NOTE - No response from the Horizontal control accel due to a bad cable. The cable was replaced, and this run shall be repeated.	JH
	1515	Repeated XZ axis seismic @ 80% power (468 volts). During this run, accel #19, located on switch 12C in Z axis, broke loose. Following this run, accel #15 was re-located from switch 12B (Z) to 12C (Y).	JH
	1607	Ran XZ axis seismic @ 100% power (575 volts), 35 seconds duration.	JH
	1620	Ran XZ axis seismic @ 110% power (633 volts), 35 seconds duration.	JH
	1630	Rotated specimen 90° around its vertical centerline to the XY axis.	JH

\*  
Whiff  
operation

PAGE 1 OF 8  
 TEST BY Jay R. Hall DATE 12-3-81  
 ENGR. Richard E. Jones GOV'T QAR \_\_\_\_\_





NTS

A NATIONAL TECHNICAL SERVICES CO.

GENERAL LOG SHEET

Report 548-9291, Rev 1

TEST SEISMIC MJO 548-9291  
 CUSTOMER STONE + WEBSTER  
 TEST ITEM LIMITORQUE OPERATOR PIN SMB-0-25 SIN \_\_\_\_\_  
 SPECIFICATION \_\_\_\_\_ PAR \_\_\_\_\_

DATE	TIME	LOG ENTRIES	INITIAL
12-3-81	1745	Ran XY axis seismic @ 80% power (468 volts) # At approximately 26 seconds into this run, the operator came loose due to the loosening of the 4 mounting bolts (from under the fixture). These bolts were re-torqued.	#
	1838	Ran XY seismic @ 100% power (575 volts). At 1 second into this run, chatter on switch 12B - possibly due to an accelerometer breaking loose and hitting the contacts of switch 12B. We repaired the loose accel, and will re-run this run.	#
	1842	Ran XY seismic #2 @ 100% power. Chatter is still present on switch 12B. The chatter detector will be switched from 2 ms to 10 ms.	#
	1850	Ran XY seismic @ 110% power. Chatter is still present on switch 12B (10 ms). Accelerometers 12, 16, + 20 (TRIAxIAL) fell off during this run.	#
	1908	Repeated XY seismic @ 80% power, as directed by the customers. Switch 12B still shows chatter @ 10 ms.	#
12-4-81	0800	Removed operator # SMB-0-25. Prior to mounting*, we fabricated and installed steel washers in the fixture to prevent the bolts from pulling through the magnesium fixture. *(operator # SMB-000-5.)	#
	1100	Ran XY axis seismic @ 80% power. Stopped @ 5 seconds - the operator came loose. 2 bolts broke off, 1 loosened, and	#

PAGE 2 OF 8  
 TEST BY Jay R Hill DATE 12-4-81  
 ENGR. Richard E Jones GOV'T QAR \_\_\_\_\_





A NATIONAL TECHNICAL SERVICES CO.

NTS

## GENERAL LOG SHEET

TEST <u>SEISMIC</u>		MJO <u>548-9291</u>
CUSTOMER <u>STONE &amp; WEBSTER</u>		
TEST ITEM <u>LIMITORQUE OPERATOR</u>		P/N <u>SMB-000-5</u> S/N _____
SPECIFICATION _____		PAR _____

DATE	TIME	LOG ENTRIES	INITIAL
12-4-81		the bolt with the load washer was tight. It was the customers decision at this time to discontinue testing on this operator. The specimen was removed.	JH
X	1200	Mounted the specimen (SMB-0-25 and limit switches 12B+12C) in XY axis. Mounted accelerometers.	JH
	1950	Ran Y axis sine beat (HORIZ) @ 100% power of 575 volts. Beat frequency is 15 Hz, test frequency is 5.0 Hz. Table input is 6g's peak, for a total of 6 beats. 3 seconds between beats. Note - the switch block was loose, causing high spikes in the control's response data. The block was tightened, and another attempt was made at this level. The 2 <sup>ND</sup> try showed identical spikes. The control accelerometers were recalibrated, and this level was repeated. It was decided by the customers to measure the levels at the peak of the spikes.	JH
	2138	Ran sine beat @ 6.3 Hz, 6g peak, 6 beats. Level is achieved by slowly bringing up the level until 6g's peak is achieved.	JH
	2251	Ran 7.9 Hz sine beat, 6g peak, 6 beats.	JH
	2300	Ran 10.0 Hz sine beat, 6g peak, 6 beats.	JH
	2316	Ran sine beat @ 5.0 Hz in X axis (VERT).	JH
V		Operator voltage is 575 volts (100%)	

PAGE <u>3</u> OF <u>8</u>	TEST BY <u>Jay Phall</u>	DATE <u>12-4-81</u>
ENGR. <u>Richard E Jenkins</u>	GOVT QAR _____	







A NATIONAL TECHNICAL SERVICES CO.

GENERAL LOG SHEET

Report 548-9291, Rev.1

TEST SEISMIC MJO 548-9291  
 CUSTOMER STONE + WEBSTER  
 TEST ITEM LIMITORQUE OPERATOR P/N SMB-0-25 S/N \_\_\_\_\_  
 SPECIFICATION \_\_\_\_\_ PAR \_\_\_\_\_

DATE	TIME	LOG ENTRIES	INITIAL
12-4-82	2325	Ran sine beat @ 6.3 Hz, 6 g's peak, 6 beats.	JH
	2330	Ran sine beat @ 7.9 Hz, 6 g's peak, 6 beats.	JH
	2335	Ran sine beat @ 10.0 Hz, 6 g's peak, 6 beats.	JH
	2340	Rotated specimen 90° around its vertical centerline to the XZ axes.	JH
	0100	Ran sine beat @ 5.0 Hz, 6 g's peak, 6 beats.	JH
	0104	Ran sine beat @ 6.3 Hz, 6 g's peak, 6 beats.	JH
	0106	Ran sine beat @ 7.9 Hz, 6 g's peak, 6 beats.	JH
✓	0110	Ran sine beat @ 10.0 Hz, 6 g's peak, 6 beats.	JH
12-5-81	1242	Ran XZ axes seismic @ 80% power on #SMB-000-5, 35 seconds duration.	JH
	1257	Ran XZ seismic @ 100% power, 35 secs.	JH
	1315	Ran XZ seismic @ 110% power.	JH
	1321	Ran XZ seismic @ 80% power.	JH
	1417	Ran Z axis sine beat @ 5.0 Hz, 6 g's peak, 6 beats.	JH
	1419	Ran Z sine beat @ 6.3 Hz, 6 g's peak, 6 beats.	JH
	1421	Ran Z sine beat @ 7.9 Hz, 6 g's peak, 6 beats.	JH
	1423	Ran Z sine beat @ 10.0 Hz, 6 g's peak, 6 beats.	JH
	1425	Began rotating specimen 90° around its vertical centerline to the X-Y axes.	JH
	1550	Ran X-Y axes seismic @ 80% power.	JH
	1551	Ran X-Y axes seismic @ 100% power.	JH
	1552	Ran X-Y axes seismic @ 110% power.	JH
	1625	Ran X-Y axes seismic @ 80% power, repeat.	JH
	1638	Ran Y sine beat @ 5.0 Hz, 6 g's peak, 6 beats.	JH
	1640	Ran Y sine beat @ 6.3 Hz, 6 g's peak, 6 beats.	JH
✓	1641	Ran Y sine beat @ 7.9 Hz, 6 g's peak, 6 beats.	JH

PAGE 4 OF 8 TEST BY Jay R. Hall DATE 12-5-81  
 ENGR. Richard E. Jones GOV'T QAR \_\_\_\_\_





NTS

A NATIONAL TECHNICAL SERVICES CO.

GENERAL LOG SHEET

Report 548-9291, Rev. I

TEST SEISMIC MJO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE OPERATOR PIN SMB-0-25 SIN \_\_\_\_\_  
 SPECIFICATION \_\_\_\_\_ PAR \_\_\_\_\_

DATE	TIME	LOG ENTRIES	INITIAL
12-5-81	1643	Ran Y sine beat @ 10.0 Hz, 6 ga peak, 6 beats.	JH
	1645	Ran X sine beat @ 5 Hz, 6 ga peak, 6 beats.	JH
	1647	Ran X sine beat @ 6.3 Hz, 6 ga peak, 6 beats.	JH
	1649	Ran X sine beat @ 7.9 Hz, 6 ga peak, 6 beats.	JH
✓	1651	Ran X sine beat @ 10.0 Hz, 6 ga peak, 6 beats.	JH
12-15-81	0800	Mounted operator # SMB-0-25, & the modified limit switches P/N-12B + 12C	JH
	1300	Ran Y sine beat @ 5 Hz, 4 ga peak, 6 beats.	JH
	1304	Ran Y sine beat @ 6.3 Hz, 4 ga peak, 6 beats.	JH
	1306	Ran Y sine beat @ 7.9 Hz, 4 ga peak, 6 beats.	JH
	1310	Ran Y sine beat @ 10.0 Hz, 4 ga peak, 20 beats.	JH
	1313	Ran Y sine beat @ 12.6 Hz, 4 ga peak, 20 beats.	JH
	1322	Ran X sine beat @ 5 Hz, 4 ga pk, 6 beats.	JH
	1324	Ran X sine beat @ 6.3 Hz, 4 ga pk, 6 beats.	JH
	1326	Ran X sine beat @ 7.9 Hz, 4 ga pk, 6 beats.	JH
	1329	Ran X sine beat @ 10 Hz, 4 ga pk, 20 beats.	JH
	1333	Ran X sine beat @ 12.6 Hz, 4 ga pk, 20 beats.	JH
	1405	Ran X sine beat @ 5 Hz, 8 ga pk, 6 beats.	JH
	1408	Ran X sine beat @ 6.3 Hz, 8 ga pk, 6 beats.	JH
	1411	Ran X sine beat @ 7.9 Hz, 8 ga pk, 6 beats.	JH
	1415	Ran X sine beat @ 10 Hz, 8 ga pk, 20 beats.	JH
	1421	Ran X sine beat @ 12.6 Hz, 8 ga pk, 20 beats.	JH
	1426	Ran Y sine beat @ 5 Hz, 8 ga pk, 6 beats.	JH
	1430	Ran Y sine beat @ 6.3 Hz, 8 ga pk, 6 beats.	JH
	1440	Ran Y sine beat @ 7.9 Hz, 8 ga pk, 6 beats.	JH
	1447	Ran Y sine beat @ 10 Hz, 8 ga pk, 20 beats.	JH
	1450	Ran Y sine beat @ 12.6 Hz, 8 ga pk, 20 beats.	JH
✓	1620	Ran Z sine beat @ 5 Hz, 8 ga peak, 6 beats.	JH

PAGE 5 OF 8 TEST BY Ray R Hall DATE 12-15-81  
 ENGR. Richard E Jones GOV'T QAR \_\_\_\_\_





NTS

A NATIONAL TECHNICAL SERVICES CO.

GENERAL LOG SHEET

Report 548-9291, Rev. 1

TEST SEISMIC NO 548-9291  
 CUSTOMER STONE & WEBSTER  
 TEST ITEM LIMITORQUE OPERATOR PIN SMB-0-25 SIN \_\_\_\_\_  
 SPECIFICATION \_\_\_\_\_ PAR \_\_\_\_\_

DATE	TIME	LOG ENTRIES	INITIAL
12-15-81	1639	Ran Z sine beat @ 6.3 Hz, 8 g's pk, 6 beats	JH
	1641	Ran Z sine beat @ 7.9 Hz, 8 g's pk, 6 beats	JH
	1644	Ran Z sine beat @ 10 Hz, 8 g's pk, 20 beats	JH
	1646	Ran Z sine beat @ 12.6 Hz, 8 g's pk, 20 beats	JH
	1652	Ran Z sine beat @ 5 Hz, 10 g's pk, 6 beats	JH
		Note - The level achieved was the maximum capability of the seismic simulator, hereafter indicated as *	JH
	1655	Re-ran Z sine beat @ 5 Hz, 10 g's pk*, 6 beats	JH
	1657	Ran Z sine beat @ 6.3 Hz, 10 g's pk*, 6 beats	JH
	1659	Ran Z sine beat @ 7.9 Hz, 10 g's pk*, 6 beats	JH
	1702	Ran Z sine beats @ 10.0 Hz, 10 g's pk*, 20 beats	JH
	1705	Ran Z sine beat @ 12.6 Hz, 10 g's pk*, 20 beats	JH
	1720	Ran X sine beat @ 6.3 Hz, 10 g's pk*, 6 beats	JH
	1723	Ran X sine beat @ 7.9 Hz, 10 g's pk*, 6 beats	JH
	1727	Ran X sine beats @ 10 Hz, 10 g's pk*, 20 beats	JH
	1731	Ran X sine beat @ 12.6 Hz, 10 g's pk*, 20 beats	JH
	1735	Ran 6 additional beats, X axis @ 12.6 Hz, 10 g's pk*, per the customer's request.	JH
	1744	Ran X sine beat @ 15.9 Hz, 10 g's pk*, 20 beats	JH
	1750	Rotated fixture/specimens 90° around its vertical centerline to the XY axes.	JH
		Note - Per customer's request, we will delete Y axis sine beat @ 5.0 Hz	
	1901	Ran Y sine beat @ 6.3 Hz, 10 g's pk*, 6 beats.	JH
	1911	Ran Y sine beat @ 7.9 Hz, 10 g's pk*, 6 beats.	JH
	1915	Ran Y sine beat @ 10 Hz, 10 g's pk*, 20 beats.	JH
↓	1919	Ran Y sine beat @ 12.6 Hz, 10 g's pk*, 20 beats.	JH

PAGE 6 OF 8  
 TEST BY Jay R. Hall DATE 12-15-81  
 ENGR. Richard E. Jones GOVT QAR \_\_\_\_\_





NTS

A NATIONAL TECHNICAL SERVICES CO.

GENERAL LOG SHEET

Report 548-9291, Rev. 1

TEST SEISMIC MJO 548-9291  
 CUSTOMER STONE + WEBSTER  
 TEST ITEM LIMITORQUE OPERATOR PIN SMB-0-25 SIN \_\_\_\_\_  
 SPECIFICATION \_\_\_\_\_ PAR \_\_\_\_\_

DATE	TIME	LOG ENTRIES	INITIAL
12-15-81	1921	Ran Y sine beat @ 15.9 Hz, 10g pk*, 20 beats.	JH
	1930	Per customer's request, we ran X axis sine beat @ 15.9 Hz, 11-12 g pk*, 6 beats	JH
	1935	Per customer's request, we ran X axis sine beat @ 12.6 Hz, 11-12 g pk*, 3 beats.	JH
	1940	Removed operator # SMB-0-25	JH
12-16-81	0800	Mounted operator # SMB-000-5, with the modified limit switches # 3B + 3C. Re-calibrated the control accelerometers.	JH
	1206	Ran Y axis sine beat @ 5 Hz, 8g pk, 6 beats	JH
	1210	Ran Y sine beat @ 6.3 Hz, 8g pk, 6 beats.	JH
	1212	Ran Y sine beat @ 7.9 Hz, 8g pk, 6 beats	JH
	1215	Ran Y sine beat @ 10.0 Hz, 8g pk, 20 beats	JH
	1219	Ran Y sine beat @ 12.6 Hz, 8g pk, 20 beats	JH
	1223	Ran Y sine beat @ 15.9 Hz, 8g pk, 20 beats	JH
	1233	Ran Y sine beat @ 20 Hz, 8g pk, 20 beats	JH
	1236	Ran Y sine beat @ 25 Hz, 8g pk, 20 beats	JH
	1250	Ran X sine beat @ 5 Hz, 8g pk, 6 beats	JH
	1253	Ran X sine beat @ 5 Hz (repeated per customer's request), 8g pk, 6 beats.	JH
	1256	Ran 6.3 Hz X sine beat, 8g pk, 6 beats	JH
	1258	Ran 7.9 Hz X sine beat, 8g pk, 6 beats	JH
	1302	Ran X sine beat @ 10 Hz, 8g pk, 20 beats	JH
	1305	Ran X sine beat @ 12.6 Hz, 8g pk, 20 beats	JH
	1310	Ran X sine beat @ 15.9 Hz, 8g pk, 20 beats	JH
	1312	Ran X sine beat @ 20.0 Hz, 8g pk, 20 beats	JH
	1315	Ran X sine beat @ 25.0 Hz, 8g pk, 20 beats	JH
	1319	Rotated fixture/specimens 90° around its	JH

PAGE 7 OF 8  
 TEST BY Jay R. Hall DATE 12-16-81  
 ENGR. Richard E. Forlue GOV'T QAR \_\_\_\_\_







A NATIONAL TECHNICAL SERVICES CO.

Report 548-9291, Rev. 1

NTS

GENERAL LOG SHEET

TEST SEISMIC MO 548-9291  
 CUSTOMER STONE + WEBSTER  
 TEST ITEM LIMITORQUE OPERATOR PIN SMB-000-5 S/N \_\_\_\_\_  
 SPECIFICATION \_\_\_\_\_ PAR \_\_\_\_\_

DATE	TIME	LOG ENTRIES	INITIAL
12-16-81		CONTINUED vertical centerline to the XZ axes.	JH
	1418	Ran Z sine beat @ 5 Hz, 8+g <sub>pk</sub> , 6 beats	JH
	1421	Ran Z sine beat @ 6.3 Hz, 8+g <sub>pk</sub> , 6 beats	JH
	1423	Ran Z sine beat @ 7.9 Hz, 8+g <sub>pk</sub> , 6 beats	JH
	1428	Ran Z sine beat @ 10 Hz, 8+g <sub>pk</sub> , 20 beats	JH
	1433	Ran Z sine beat @ 12.6 Hz, 8+g <sub>pk</sub> , 20 beats	JH
		The customer has requested the following additional testing to satisfy the required quantity of sine beats at the specified levels.	JH
	1642	Ran Y sine beat @ 7.9 Hz, 9 g <sub>pk</sub> , 6 beats	JH
	1645	Ran Y sine beat @ 10.0 Hz, 10 g <sub>pk</sub> , 6 beats	JH
	1647	Ran Y sine beat @ 15.9 Hz, 10 g <sub>pk</sub> , 6 beats	JH
	1653	Ran X sine beat @ 10 Hz, 10 g <sub>pk</sub> , 6 beats	JH
		NOTE - All sine beats had a 3000 ms interval between beats. Testing was completed.	

PAGE 8 OF 8 TEST BY Jay R. Hall DATE 12-16-81  
 ENGR. Richard E. Jones GOV'T QAR \_\_\_\_\_

ABB PTC - 211



**DOCUMENTATION CHECK LIST**

REV: 4

CUSTOMER: Stone & Webster

ORDER NO: NMP2-P-304R

PROJECT: Nine Mile Point - 2

S&W VALVE MARK NO: 2CCP-MOV 18A

SPECIFICATION NO: NMP2-P304R REV. 1 ADD. 4 REQUIRED

DRAWING NO: P3-7026-N6 REV: F

DATA PACKAGE NO: **W800004** *ETM*

VELAN ORDER NO: P3-7026-N 17. 38

CODE APPLICABILITY: Section III, Class 1, 2 & 3

VGW015-P-32Q  
DOCUMENT

**CLASS**

	1	2	3
Manufacturer's Data Report	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
**Certificate of Compliance	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Seismic Certificate (MOV Only)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
*Certified Material Test Reports Including for S/S	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
a) Sol. Anneal. Cert. for Body, Bonnet, Disc,			
b) Delta-ferrite for Weld Metal			
***Certificate of NDE Approval	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Hydrostatic Test Record	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
M.O. Test Report (Limitorque)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
M.O./Valve Operability Test Report (Velan)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wall Thickness Documentation (Over 1")	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Heat Treatment Records (Velan-P/R Parts)(when req'd.)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> <i>n/a</i>
Weld Record Documentation	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Weld Repair Record (If Required)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Cert. of Compliance for Grade II Water	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Deviation Request Approvals (If Required)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Pneumatic Seat Leak. Test Reports	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Stress Certificate (Class 1 only)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**ITEMS NOT PART OF DATA PACKAGE (Check Off Only By ESI)**

Weld Procedures	(x)	Heat Treatment Procedures	(x)
NDE Procedures	(x)	Pneumatic Seat Leak. Procedure	(x)
M/O Test Procedures	(x)	Calculations MOV	(x)
Performance Test Procedures	(x)	Forty (40) Copies of Instal. and Oper. Inst.	(x)
Cleaning/Packaging Procedure	(x)	Stress Report	( )
Operability Test Procedure	(x)		
Wall Thick. Meas. Procedure	(x)		

*INSPECTED*  
  
 Class.....  
 \*Certified Material Test Reports....  
 \*\*Cert. of Material Compliance.....  
 \*\*\*NDE.....

BODY	BONNET			WEDGE/DISC			BOLT-ING			WELD FILLER METAL			WELD END			SEAL WELD			HARD FACING		
	1	2	3	1	2	3	1	2	3	1	2	3	1	2	3	1	2	3			
*Certified Material Test Reports....	x	x	x	x	x	x	x	x	x	x	x	x									
**Cert. of Material Compliance.....																					
***NDE.....																					
RT.....																					
UI.....	x			x			x						x								
MI.....	x	x		x			x						x	x		x	x				
PI.....	x	x											x	x	x	x	x	x	x	x	x
Charpy Impact..	6			6			6		1												

- LEGEND**
- X - all
  - 0 - 1" & less
  - 1 - over 1"
  - 2 - over 2"
  - 3 - 2"-4"
  - 4 - over 4"
  - 5 - full weld
  - 6 - over 6"

**NOTE:** Unmarked boxes are not applicable to this specification.

S&W Certificate of Conformance  
 Number: \_\_\_\_\_

Data Package Prepared By: *[Signature]*

DATE: 2-28-80



-----  
-----  
-----  
-----  
-----  
-----  
-----


FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES\*

(As Required by the Provisions of the ASME Code, Section III, Div. 1)

W 800004

1. Manufactured by Velan Valve Corporation Avenue "C" Williston, Vermont  
(Name and Address of Manufacturer)
2. Manufactured for Niagara Mohawk Power Corporation, Scriba, New York  
(Name and Address of Purchaser or Owner)
3. Location of Installation Nine Mile Point Station, Rt. 104 Oswego, New York  
(Name and Address)
4. Pump or Valve Gate Valve Nominal Inlet Size .12 Outlet Size 12  
(inch) (inch)

	(a) Model No., Series No. or Type	(b) Manufacturers' Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l Std. No.	(g) Year Built
(1)	B18-0054B-02WN	004	-----	P3-7026-N6	3	----	1980
(2)				Rev. F			
(3)							
(4)							
(5)							
(6)							
(7)							
(8)							
(9)							
(10)							



5. \_\_\_\_\_  
(Brief description of service for which equipment was designed)

6. Design Conditions 200 psi 250 °F or Valve Pressure Class \_\_\_\_\_ (1)  
(Pressure) (Temperature)

7. Cold Working Pressure 300 psi at 100°F.

8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
(b) Forgings			H/C
Body	ASME-SA-105	Cameron Iron Works	L2030
Bonnet	ASME-SA-105	Galt British Forge	J2114
wedge	ASME-SA-105	Galt British Forge	F5098
DRAIN PIPE	ASME-SA-106 GR. B	TUBULAR STEEL	D64994

(1) For manually operated valves only.

\* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11", (2) information in items 1, 2 and 5 on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

(3/77) This form (E00037) may be obtained from the Order Dept., ASME, 345 E. 47 St., New York, N.Y. 10017



1  
2  
3  
4  
5  
6  
7  
8  
9  
10

# VELAN ENGINEERING COMPANIES

FORM VE-48-4-73A

## CERTIFICATE OF COMPLIANCE

W800004

1. CUSTOMER: Niagara Mohawk Power Corp.  
 2. CONTRACT NO.: NMP2-P304R  
 3. CUSTOMER SPEC. NO.: NMP2-P304R Rev.1 Add. 4  
 4. CUSTOMER I.D. NO.: VGW 015-P-320  
 (TAG NO.) P3-7026-N6  
 5. DWG. NO.: REV. F  
 6. DATE: January 5, 1980

7. VELAN ORDER NO.: P3-7026-N ITEM: 38  
 8. VALVE DESCRIPTION: 12" - 150 #  
Bolted Bonnet Gate Valve  
 9. OPERATOR SERIAL NO.: 293419  
 10. QUANTITY: 1  
 11. NUCLEAR CLASS: N1  N2  N3


2 CCP max 18A

(REQ. - REQUIRED) (ENCL. - ENCLOSED)		QUALITY CONTROL CHECK LIST				(P&C - PHYSICAL - CHEM. CERTIFICATE)							
PART	SERIAL NO.	MATERIAL SPECIFICATION	HEAT CODES	P & C		RT		UT		PT		MT	
				REQ.	ENCL.	REQ.	PERF.	REQ.	PERF.	REQ.	PERF.	REQ.	PERF.
FRONTS 1. BODY	176	ASME-SA-105	L2030	X	X								
2. BODY REAR	W439	ASME-SA-105	J2114	X	X								
DRAIN PIPE		ASME SA-106 GR. B	D64994	X	X								
DRAIN CAP		ASME SA-105	RS129	X	X								
FRONTS 1. WEDGE SEAT	7322	ASME-SA-105	F5098	X	X								
Wedge Seat	Guide welds	SFA 5.18	A09004	X	X					X	X		
Drain Weld	Pipe	SFA 5.18	A09004	X	X					X	X		
BARS 1. STEM		ASTM-A-276-410	H 22										
2. STEM		ASME SA 193 B7	15878	X	X								
2. NUT		ASME SA 194 2H	239149	X	X								
BACKSEAT SEAL WELD		SFA 5.18	A09004	X	X					X	X		
FRONTS 1. HAND- FACING SEATS		STELLITE	54-35734							X	X		
Backseat HDFG		STELLITE	GRM-6-77 GRM-6-85							X	X		
FRONTS 1. WEDGE REPAIR		SFA 5.1	73702	X	X					X	X		

APPLICABLE VELAN NDT QC SPECIFICATION AS APPROVED	REV:
RADIOGRAPHY	N/A
ULTRASONIC	N/A
PENETRANT	VEL-NDT-564B 0
MAGNETIC PARTICLE	VEL-NDT-543B 0
PRODUCTION AND HYDROSTATIC TESTS	VEL-NDT-640A 10
CLEANING	VEL-P-672 1
WALL THICKNESS	VEL-QC-665A 12
	VEL-OCT-482 4

(WHEN APPLICABLE ONLY)  
 SWORN AND SUBSCRIBED  
 BEFORE ME THIS

DAY OF \_\_\_\_\_ 19\_\_\_\_  
J.O. # 12177



WE HEREBY CERTIFY THAT  
 THE ABOVE STATEMENTS  
 AND VALUES SPECIFIED  
 ARE TRUE AND CORRECT  
 AS CONTAINED IN THE  
 RECORDS OF THE CORPO-  
 RATION.

VELAN ENGINEERING CO.

X [Signature]  
 MANAGER OF INSPECTION

X \_\_\_\_\_

CUSTOMER REPRESENTATIVE

X \_\_\_\_\_  
 DATE






# VELAN ENGINEERING COMPANIES

CERTIFICATE OF NDT APPROVAL

W 800004

FORM VE-48-4-73A

PART	SERIAL NO. OR HEAT CODE	QUANTITY ACCEPTED	LIQUID PENETRANT		MAGNETIC PARTICLE	
			NDT INSPTR.	DATE	NDT INSPTR.	DATE
BODY						
BODY BUTTWELD	176	2 Ends	69	FEB 15, 1980		
<del>SEWER (COVER)</del> BACKSEAT HYDROSTATIC	GRM-6-77	1	56	FEB. 9, 1979		
<del>WEDGE</del>	GRM-6-85					
STEM						
BACKSEAT SEAL WELD	A09004	1	56	SEPT. 29, 1979		
DRAIN PIPE WELD	A09004	1	56	SEPT. 29, 1979		
WELD SEATS AND GUIDE	A09004	2	56	SEPT. 29, 1979		
HARDFACE SEAT	54-35734	2	56	JAN. 4, 1979		
HARDFACE <del>WEDGE</del>	54-35734	1	69	DEC. 28, 1978		
WEDGE REPAIR	73702	1	69	DEC. 28, 1978		
BODY REPAIR	73702	1	52	OCT 13, 1978		



INSP. 56 LEVEL  
69 } 2  
52

CERTIFICATE OF PRODUCTION (HYDROSTATIC) TEST

TYPE OF TEST	SHELL	WEDGE	'A' SIDE SEAT	'B' SIDE	BACK SEAT	PACKING
DURATION MINS.	10	1	1		1	2
PRESSURE P.S.I.	425	300	150		42.5	300
RESULT C.C.	0	O.K.	.1 ml	.2 ml	0	0

GAUGE NO. G16-3860, G16-3636

TEST DATA FOR MOTOR - OPERATED VALVES			
OPERATOR TYPE	SMB-0-25	RATED VOLTS	575
SERIAL NO.	293419	DIFFERENTIAL PRESSURE	150
	FULL RATED VOLTS		RATED VOLTS
TIME TO OPEN (SECS)	63		
TIME TO CLOSE (SECS)	63		
PEAK STARTING CURRENT (AMPS)	OPEN 3	CLOSE	4
NORMAL OPERATING CURRENT (AMPS)	OPEN 3	CLOSE	3
	OPEN		CLOSE
TORQUE SWITCH SETTING	OPEN 2	CLOSE	2
LIMIT SWITCH SETTING	SET OPEN	SET	CLOSED

DATE OF TEST  
FEB. 14, 1980

TESTED BY  
L. GARRISON

CERTIFIED BY  
[Signature]

CUSTOMER'S REPRESENTATIVE  
\_\_\_\_\_



# Cameron

## IRON WORKS, INC.

B13

P. O. BOX 1212 HOUSTON, TEXAS 77001

### CERTIFICATE OF TESTS

# W 800004

Date 14 June 1977

D R O S  
T O

VELAN ENGINEERING LTD.  
LARGE STEEL VALVE DIVISION  
2125 Ward Avenue  
Montreal, Quebec, Canada


S H I P  
T O

Customer Order No. C1217	C.I.W. Sales Order No. F-17370-1	ASTM A105-73/ASME SA105 (ASME Section II, Part A, 1974 thru Winter '75 Addenda)
-----------------------------	-------------------------------------	---

Description of Material 12" L.P. Valve Body Dwg. # F00-007-002	ASME QUALITY SYSTEM CERTIFICATE (MATERIALS) NO. N-1261 EXPIRES 10-27-78.
--	---

C.I.W. Part Number	Heat No.	CHEMICAL ANALYSIS												
		C	MN	P	S	SI	CR	NI	MO	V	V	CU		
66142-14	L 2030	.26	.98	.017	.019	.26								

material or components shipped under the above part number has not come in direct contact with mercury or any of its compounds, or with any mercury containing devices employing a single cry of containment during the manufacturing process, tests, inspection or storage.



C.I.W. Part No. or Size	Heat No.	2% Offset Yield PSI	MECHANICAL PROPERTIES			Test Lots	Hardness
			Tensile PSI	% Elong. in 2"	% Red. Area		
66142-14	L 2030	57,400	80,900	30.0	60.3	169	

Forg. Ser. #	Test Lot #	Forg. Ser. #	Test Lot #
#0169 ✓	169	#0174	169
0170 ✓	169	0175	169
0171 ✓	169	0176 ✓	169
0172 ✓	169	0177	169
0173 ✓	169	0178 ✓	169

I CERTIFY THAT THE CONTENTS OF THIS REPORT ARE IN COMPLIANCE WITH THE REQUIREMENTS OF SPECIFICATION ASME SA-105 EDITION 1974 AND ADDENDA THROUGH WINTER 1975 EXCEPT AS NOTED

VELAN ENGINEERING LTD.  
*[Signature]*  
PER MANAGER OF INSPECTION


C.I.W. Heat No. 1565°F., held 2.83 hrs. at temp. Air cooled.  
Jeminy Hardenability  
Heat-Treat Furnace report attached.

Subscribed and Sworn to before me this 4th Day of June 1977

AUG - 4 1977

*[Signature]*  
Notary Public  
U.S.A.

*[Signature]*  
H. O. WRIGHT, Metallurgist /gt



# GALT-BRITISH FORGE COMPANY

204 BEVERLY STREET — CAMBRIDGE (GALT), ONT. N1R 1Z8

C50

**DESCRIPTION**

**Velan Valve Corp., Vermont P.O. W0689F**

OCT 30 1978

ASME SA105 & ASME B. & P.V. Code Sect. 2 Part A & Sect. 3 1974 Edition & Winter 75 Addenda material from Atlas Steels

8 Discs 19" diameter x 8" thick **W 800004**

12" - 600 lb. Bonnets Part No. 0019-008-002

*mt 30  
YW*

Material produced according to our Q.A. Manual approved by Velan Engineering

## CERTIFICATE OF TEST

NORMALIZED

### CHEMICAL ANALYSIS

HEAT NO	C	MN	P	S	SI	CR	MO	NI	CU	CB	TA
<b>J2114</b>	✓ .24	✓ .98	✓ .009	✓ .002	✓ .18						

### PHYSICAL PROPERTIES

2"

HEAT NO.	YIELD STRENGTH P <sub>0.2</sub> (1% OFFSET)	TENSILE STRENGTH P <sub>0.2</sub>	ELONG. & RED. OF AREA (%)	IMPACT FT. LB.	BRAVELL HARDNESS
T846 J2114	✓ 50,500	✓ 79,500	✓ 39.1	✓ 68.3	

### JOMINY HARDENABILITY


DISTANCE (16ths)				I CERTIFY THAT THE CONTENTS OF THIS REPORT ARE IN COMPLIANCE WITH THE REQUIREMENTS OF SPECIFICATION <u>ASME SA-105</u> EDITION <u>1974</u> AND ADDENDA THROUGH <u>WINTER 1975</u> EXCEPT AS NOTED				
1	2	3	4		9	10	11	12
13	14	15	16		26	28	30	32

VELAN ENGINEERING LTD.  
*[Signature]*  
PER MANAGER OF INSPECTION

MAGNETIC PARTICLE INSPECTION TO AMS2201

**GRAIN SIZE**

1. Furnace No. 5.
2. Charge 1200° F.
3. 100° F./hr.
4. Hold 1650° F./7½ hrs.
5. Air cool.



These forgings have not come into direct contact with mercury or any of its components, nor with any mercury containing devices during manufacture, testing, inspection or storage.

The contents of this report are correct and accurate and comply with the material specification

GALT-BRITISH FORGE COMPANY  
QUALITY ASSURANCE

*[Signature]*

DATE October 18, 1978



# GALT-BRITISH FORGE LIMITED

204 BEVERLY STREET — CAMBRIDGE (GALT), ONT. N1R 3Z8

W800004

E53

**DESCRIPTION**

Velan (C1405) material: from Atlas Steels

ASME SA 105 & ASTM A105-71.

18 - 12" 600 lb. B.B. Gate Valve Wedges to Dwg. E00-020 Rev. 0  
Pt. # E00-020-002

## CERTIFICATE OF TEST

### CHEMICAL ANALYSIS

HEAT NO	C	MN	P	S	SI	CR	MO	NI	CU	CS	TA
F5098	.30	.69	.010	.033	.17						

0.2%

### PHYSICAL PROPERTIES 2"


BRINNELL

HEAT NO	YIELD STRENGTH F <sub>0.2</sub>	TENSILE STRENGTH F <sub>U</sub>	ELONG. @ RED. OF AREA %	IMPACT FT. LB.	HARDNESS
F5098	55,000	83,000	29.0	53.9	170
	Normalized 1650°F ± 25°F Air cooled still air.				

### JOMINY HARDENABILITY

DISTANCE (16ths)

1	2	3	4	5	6	7	8	9	10	11	12
13	14	15	16	18			24	26	28	30	32



MAGNETIC PARTICLE INSPECTION TO AMS2101

F/S =

GRAIN SIZE

I CERTIFY THAT THE CONTENTS OF THIS REPORT ARE IN COMPLIANCE WITH THE REQUIREMENTS OF SPECIFICATION ASME SA-105 EDITION 1974 AND ADDENDA THROUGH Winter 1975 EXCEPT AS NOTED

VELAN ENGINEERING LTD.  
*[Signature]*  
PER MANAGER OF INSPECTION

These forgings have not come into direct contact with mercury or any of its components, nor with any mercury containing devices during manufacture, testing, inspection or storage.

November 6, 1975.

NOV 11 1975

GALT-BRITISH FORGE LIMITED  
QUALITY ASSURANCE

DATE \_\_\_\_\_

*[Signature]*

*[Signature]*







W 800004

204 BEVERLY STREET, CAMBRIDGE, CANADA N1R 3Z8 • (519) 621-8140 • TELEX 069-69380


May 7, 1979.

Test Report Supplement

Reference purchase orders:

C1405	C7028	C8994	W0544
C2633	C7303		W1001
C3554	C7355	W0025	W1009
C4658	C7357	W0026	W1079
C4659	C7726	W0029	
C4668	C7737	W0033	
C4935	C7754	W0261	
C5071	C7757	W0530	

Please add the following: "Material produced according to our Q.A. Manual approved by Velan Engineering."



*N. W. Gray*  
N. W. Gray,  
Q.A. Manager.



HOBART BROTHERS COMPANY FILLER MATERIALS ACTUAL TESTING REPORT  
WELD TEST LABORATORY

5 JULY 1978

W800004

Job No. As Welded Q8-142, 142C  
 Job No. Stress Relieved

HBC Type 718 Size 5/32"

Serial Number 90156Z117 Lot (73702)

For Velan Valve  
(Purchaser)

Purchase Order Number C-7787

Conduct the following test to meet the requirements of:  
FM Specification Velan Spec's Re. Mil E 22200/1E Class E-7018  
and ASME SFA 5.1 Chem. analysis to ASME Sect. III NB 2432.2.


INSTRUCTIONS

- 1) Use ink or type only.
- 2) Sign full name.
- 3) Make no erasures.
- 4) Retest: Designate by -1 and -2.

CHEMICAL ANALYSIS

<input checked="" type="checkbox"/> C .043	<input checked="" type="checkbox"/> Cr .069
<input checked="" type="checkbox"/> Mn .67	<input checked="" type="checkbox"/> V .020
<input checked="" type="checkbox"/> P .018	<input checked="" type="checkbox"/> Ni .044
<input checked="" type="checkbox"/> S .012	<input checked="" type="checkbox"/> Mo .017
<input checked="" type="checkbox"/> Si .35	<input checked="" type="checkbox"/> Al .002
<input checked="" type="checkbox"/> Cu .016	<input checked="" type="checkbox"/> Ti .012

WELDING DATA




CERTIFY THAT THE FORESIDES OF THIS REPORT ARE IN COMPLIANCE WITH THE REQUIREMENTS OF SPECIFICATION ASME SFA 5.1 EDITION 1974 THROUGH WATER 1975 EXCEPT AS NOTED  
 CHEMISTRY  
 SIGNED AND  
 WITNESSED  
 VELAN ENGINEERING CO. INC.  
 PER MANAGER OF INSPECTION

Tested by I. Shroyer Date 5-19-78  
Lab Analysis No. 5642

Volts 26 Amp 190 Gas None  
Preheat 225-25 Interpass Temp. 225-25  
Power Source M-300  
Current or Polarity DCEP  
Other Comments \_\_\_\_\_

ROUTE TO: \_\_\_\_\_ Sender \_\_\_\_\_ Date Sent \_\_\_\_\_  
Weld Test Lab PLAZ \_\_\_\_\_ Date Sent 5-18-78  
EM R & D \_\_\_\_\_  
FMQC Jerry Hester \_\_\_\_\_ Date 6-2-78



Radiographic Test Conforms  
Tested by J. Foust SNT Level II Date 5-24-78

Moisture Test (Free) \_\_\_\_\_ (Total) .23  
Tested by: I. Shroyer Date 5-19-78

Concentricity Test Conforms Max. 1.146% Length 14" dia .155  
Tested by D. Warner Date 5-19-78

Fillet Tests  Horizontal \_\_\_\_\_  Vertical OK  Overhead OK  
Tested by: D. Warner Date 5-22-78

Transverse Tensile \_\_\_\_\_ PSI  
 Longitudinal Bend \_\_\_\_\_

(See Other Side)



HOBART BROTHERS COMPANY FILLER MATERIALS ACTUAL TESTING REPORT  
WELD TEST LABORATORY

W82

FEB 28 1979

W 800004

Job No. As Welded Q9-1, IC-1  
 Job No. Stress Relieved

HBC Type 25 Size 3/32"  
For Valve Valve

Serial Number A09004

Purchase Order Number W0048

(Purchaser)


Conduct the following test to meet the requirements of:

FM Specification Valve Valve Spec VEL-PS-028 w/ Reference to Class E70S-3  
ASME SFA 5.18 and Sect. III NB 2432.2

INSTRUCTIONS

- 1) Use ink or type only.
- 2) Sign full name.
- 3) Make no erasures.
- 4) Retest: Designate by -1 and -2.

WELDING DATA



I CERTIFY THAT THE CONTENTS OF THIS REPORT ARE IN COMPLIANCE WITH THE REQUIREMENTS OF SPECIFICATION ASME SFA 5.18 EDITION 1974 THROUGH JANUARY 1975 EXCEPT AS NOTED HEREIN.  
 WELT INDUSTRIES LTD.  
 PERMANENT OF INSPECTION

CHEMICAL ANALYSIS

<input checked="" type="checkbox"/> C .093 ✓	<input checked="" type="checkbox"/> Cr .063
<input checked="" type="checkbox"/> Mn 1.23 ✓	<input checked="" type="checkbox"/> Va .003
<input checked="" type="checkbox"/> P .024 ✓	<input checked="" type="checkbox"/> Ni <.001
<input checked="" type="checkbox"/> S .025 ✓	<input checked="" type="checkbox"/> Mo .020
<input checked="" type="checkbox"/> Si .60 ✓	<input checked="" type="checkbox"/> Al <.001
<input checked="" type="checkbox"/> Cu .11	<input checked="" type="checkbox"/> Ti .006

Tested by I. Shroyer Date 9/12/78  
Lab Analysis No. 7078

Volts 15 Amp 160 Gas Argon

Room Temp. 65 min Interpass Temp. 300 ± 25°F

Power Source CT-300

Current or Polarity DCEN

Other Comments GTAW 1/8" dia. 2% Thoriated Tungsten

Welded by J. Faust Date 1-15-79

Route to: Sender Date Sent

Weld Test Lab Platz 1/8/79

Pfister 1/11/79

FM R & D

FMQC Jerry Pfister 1/22/79

Radiographic Test Conforms

Tested by J. Faust SNT Level II Date 1-16-79

Moisture Test (Free)

Tested by: \_\_\_\_\_

Concentricity Test

Tested by: \_\_\_\_\_

Fillet Tests  Horizontal

Tested by: \_\_\_\_\_

Transverse Tensile \_\_\_\_\_ PSI

Longitudinal Bend \_\_\_\_\_

(Total)

Date \_\_\_\_\_

Length \_\_\_\_\_

Date \_\_\_\_\_


Vertical

Date \_\_\_\_\_

Overhead

Cast 17-3/8"

Helix 1/8"



(See Other Side)



**Tubular Steel** Incorporated  
 502 Earth City Plaza, Earth City (St. Louis County), Missouri 63045  
 Mailing address: P.O. Box 65 Hazelwood, Mo. 63042  
 Telephone 314/524-1500 Telex 44-2336



P 9  
 PAGE 1 of 3

800004

Performance  
 you can  
 count on.

HOLDER OF ASME QUALITY SYSTEMS CERTIFICATE (MATERIALS) NO. N-1550

Expiration Date: December 29, 1979

MATERIAL SHIPPED ON YOUR  
 P.O. # W2485 UNDER SECTION  
 III NCA3800 IS IN COMPLIANCE WITH  
 TUBULAR STEELS QUALITY SYSTEM  
 ASME CERTIFICATE #N1550

CERTIFICATION TRANSMITTAL

I CERTIFY THAT THE CONTENTS OF THIS REPORT ARE  
 IN COMPLIANCE WITH THE REQUIREMENTS OF  
 SPECIFICATION ASME SA-106 Gr. B  
 EDITION 1974 AND ADDENDA  
 THROUGH WINTER 1975 EXCEPT AS NOTED

VELAN ENGINEERING LTD.

*[Signature]*  
 PER. MANAGER OF INSPECTION

The material supplied on P.O. # W2485

on our Shipping # 20931 is certified by our supplier to be in  
 accordance with the requirements of ASTM A-106 Gr. B ASME SA-106 Gr. B

Copies of the mill certificate(s) for this material are attached.  
 8.840" OD x 0.187" Wall Heat No. D64994 Velan Valve Part No. H-516-246

*[Signature]*

This is to certify that the contents of this report are correct and that  
 all the operations performed are in compliance with the requirements of  
 the material specification and the purchase order. This is to certify that the  
 piping material described herein is in accordance with the specification,  
 Section III Class 3, of the ASME Boiler and Pressure Vessel Code, 1974 Edition  
 Summer 1975 addenda.

Quality Assurance Mgr.


State of Missouri  
 County of St. Louis

Certified and subscribed before me, a Notary Public, in and for the above state and city, this  
 day and date.

My commission expires 10/3/81

Dated 7/5/79

*[Signature]*



JUL 14 1979







**SHARON TUBE COMPANY, SHARON, PENNA.**  
Cold Draw Department

Report of CHEMICAL and PHYSICAL Tests for

**W80004**

January 11, 1979

Order No. 5265-78

Customer Order No. 25112

DESCRIPTION	LOT NO.	HEAT NUMBER	CHEMICAL ANALYSIS						HARDNESS		YIELD PSI	ULTIMATE PSI	ELONGATION		BEND TEST
			C	Mn	P	S	SI						IN - IN	PERCENT	
1/2" Schedule 80	1	M62617	.20	.66	.009	.020	.15		69	RB	47200	65800	2	45.0	OK
	2	D63809	.19	.75	.015	.022	.16		68	RB	50670	67560	2	43.5	OK
	3	E70393	.19	.70	.006	.013	.17		72	RB	48430	67030	2	44.5	OK
1/2" Schedule 160		D66270	.22	.71	.010	.017	.19		75	RB	50880	68900	2	43.0	OK
		D64994	.21	.70	.007	.018	.16		68	RB	49750	67450	2	46.0	OK
3/4" Schedule 160	1	E71810	.22	.75	.010	.015	.17		71	RB	50820	69920	2	44.5	OK
MATERIAL SHIPPED ON YOUR P.O. # <u>W245</u> UNDER SECTION III NCA3800 IS IN COMPLIANCE WITH TUBULAR STEELS QUALITY SYSTEM ASME CERTIFICATE #N1590															



Cold Drawn Stress Relieved Carbon Steel Seamless Pressure Pipe Meeting the Requirements of ASTM A-106 Grades A&B and ASME SA-106 Grades A&B; Each Length of Pipe Hydrostatically Tested to 2500 P.S.I.

STATE OF PENNSYLVANIA, COUNTY OF MERCER

Subscribed and sworn to before me this 11th day of January, A. D., 19 79

Richard K. Loo Notary Public



**JUN 14 1979**

**500098**

E. G. PALKO

being duly sworn according to law, deposes and says that the figures set forth above are correct, as contained in the records of the Company.

E. G. Palko



SHARON TUBE COMPANY, SHARON, PENNA.  
Cold Draw Department

PAGE 3 OF 3  
RECERTIFICATION

W 800004

79

Report of CHEMICAL and PHYSICAL Tests for Midland Pipe and Supply Company July 17 19 78


Shop Order No. 5265-78

Cicero, Illinois

Customer Order No. 25112

REFERENCE NO.  
(W2485S020931)

ITEM NO.	DESCRIPTION	LOT NO.	HEAT NUMBER	CHEMICAL ANALYSIS					HARDNESS		YIELD PSI	ULTIMATE PSI	ELONGATION		BEND TEST
				C	Mn	P	S	SI					IN IN.	PERCENT	
5	1/2" SCHEDULE 160	1	D64994	.21	.70	.007	.018	.16	68	BB	49750	67450	2.	46.0	OK
COLD DRAWN CARBON STEEL, SEAMLESS PRESSURE PIPE STRESS RELIEVED AT 1750°F FOR 10 MINUTES.															



Cold Drawn Stress Relieved Carbon Steel Seamless Pressure Pipe Meeting the Requirements of ASTM A-106 Grades A&B and ASME SA-106 Grades A&B; Each Length of Pipe Hydrostatically Tested to 2500 P.S.I.

STATE OF PENNSYLVANIA,  
COUNTY OF MERCER

Subscribed and sworn to before me this 16th day  
of July, A. D., 19 79

*Hennrich F. Lett*  
Notary Public

My Commission expires April 7, 1980


E. G. PALKO


, being  
duly sworn according to law, deposes and says that  
the figures set forth above are correct, as contained  
in the records of the Company.

*E. G. Palko*





	<b>VELAN ENGINEERING COMPANIES</b>		<b>Q.C. INSTRUCTION</b>	
	WALL THICKNESS INSPECTION		VEL-QC-665A SECTION I	
VALVE TYPE	<i>B.B. Gate</i>	BODY SERIAL NO.	<i>W 800004</i>	<i>0176</i>
VALVE SIZE	<i>12"</i>	BONNET SERIAL NO.		
PRESSURE RATING	<i>150#</i>	BODY MIN. WALL THICKNESS REQ'D ( $t_m$ )		<i>.375</i>
NUCLEAR CLASS	<i>3</i>	BONNET MIN. WALL THICKNESS REQ'D ( $t_f$ )		
MATERIAL	<i>C15</i>	PACKING CHAMBER MIN. WALL THICKNESS REQ'D ( $t_{pc}$ )		



ACTUAL MEASUREMENTS (FINISHED/MACHINED CONDITION)

*.289 at .489*


	$t$ INLET	$t$ OUTLET	$t$ NECK	$t$ BOWL	$t$ BONNET FLANGE	$t$ PACKING CHAMBER	$t$ SOCKET (.77 $t_m$ )	
	( $t_m$ )	( $t_m$ )	( $t_m$ )	( $t_m$ )	( $t_f$ )	( $t_{pc}$ )	Inlet	Outlet
A	<i>1.640</i>	<i>1.560</i>	<i>1.780</i>	<i>1.812</i>			<i>.476</i>	<i>.473</i>
B	<i>1.605</i>	<i>1.545</i>	<i>1.687</i>	—			<i>.476</i>	<i>.473</i>
C	<i>1.500</i>	<i>1.545</i>	<i>1.740</i>	—			<i>.476</i>	<i>.473</i>
D	<i>1.640</i>	<i>1.560</i>	<i>1.875</i>	—			<i>.476</i>	<i>.473</i>

Values above are lowest measured in each four quadrants. For end connections, quadrants start at top and progress clockwise, facing the end. For neck and bonnet, quadrants start at side over manufacturers symbol and progress clockwise facing down.


INSPECTOR	<i>U. Beav</i>	DATE	<i>2/20/80</i>
ACCEPTABLE	<input checked="" type="checkbox"/>	REJECTED	<input type="checkbox"/>

NOTE: 0.77  $t_m$  minimum measured at a distance of 1.33  $t_m$  from weld end.



	<b>VELAN ENGINEERING COMPANIES</b>	<b>Q.C. INSTRUCTION</b>
	WALL THICKNESS INSPECTION	VEL-OC-665A SECTION I


VALVE TYPE	<b>B.B. GATE</b>	BODY SERIAL NO.	<b>800004</b>
VALVE SIZE	<b>12"</b>	BONNET SERIAL NO.	<b>439</b>
PRESSURE RATING	<b>150</b>	BODY MIN. WALL THICKNESS REQ'D ( $t_m$ )	
NUCLEAR CLASS	<b>3</b>	BONNET MIN. WALL THICKNESS REQ'D ( $t_f$ )	<b>3.076</b>
MATERIAL	<b>C/S</b>	PACKING CHAMBER MIN. WALL THICKNESS REQ'D ( $t_{pc}$ )	<b>.195</b>



ACTUAL MEASUREMENTS (FINISHED/MACHINED CONDITION)

	$t$ INLET	$t$ OUTLET	$t$ NECK	$t$ BOWL	$t$ BONNET FLANGE	$t$ PACKING CHAMBER	$t$ SOCKET (.77 $t_m$ )	
	( $t_m$ )	( $t_m$ )	( $t_m$ )	( $t_m$ )	( $t_f$ )	( $t_{pc}$ )	Inlet	Outlet
A	/	/	/	/	3.687	1.001	/	/
B	/	/	/	/	3.687	1.001	/	/
C	/	/	/	/	3.687	1.001	/	/
D	/	/	/	/	3.687	1.001	/	/

Values above are lowest measured in each four quadrants. For end connections, quadrants start at top and progress clockwise, facing the end. For neck and bonnet, quadrants start at side over manufacturers symbol and progress clockwise facing down.

INSPECTOR *Maynard* DATE *Feb 23-79*  
 ACCEPTABLE  REJECTED

NOTE: 0.77  $t_m$  minimum measured at a distance of 1.33  $t_m$  from weld end.



100  
100  
100  
100  
100  
100  
100



*Velan Code*  
*RS 129*

DATE 31TH.AUG.1978

**#800004**

**CERTIFICATE OF TESTS**

S  
O  
L  
D  
T  
O

VELAN ENGINEERING LTD.  
2125 WARD AVENUE  
MONTREAL 378 QUEBEC CANADA

VIA : TAKARA INDUSTRIES CO.,LTD.

S  
H  
I  
P  
T  
O

VELAN ENGINEERING LTD.  
2125 WARD AVENUE  
MONTREAL 378 QUEBEC CANADA

VIA : VANCOUVER

CUSTOMER ORDER NO <b>C-8553</b>	DRAFT NO <b>EX-860</b>	<b>48</b> PCS	SPECIFICATIONS <b>ASME A-105</b>
------------------------------------	---------------------------	---------------	-------------------------------------

DESCRIPTION **4" BODY FORGING TO DWG. NO. 89054**  
OF **RAW MATERIAL CONFORMS TO THE REQUIREMENTS OF ASME BOILER AND**  
MATERIAL **PRESSUER VESSEL CODE, SECTION 11 AND 111, FOR CLASS 1 COMPONENTS.**

HEAT IDENTIFICATION CODE AS ON PART	HEAT NO.	CHEMICAL ANALYSIS											
		C	Si	Mn	P	S	Ni	Cr	Mo	Cu	As	Ti	
A-3	6C239	.25	0.27	1.04	.018	.016	-	-	-	-	-	-	-

The material or components shipped under the above order number did not come in direct contact with mercury or any of its components, or with any mercury containing devices employing a single boundary of containment, during the manufacturing process, tests, inspection or storage.


DWG. NO. PART AS APPROVED	THIS CERTIFICATE COVERED BY	HEAT NO.	MECHANICAL PROPERTIES					
			YIELD PSI	TENSILE PSI	% ELONG	% REDUC AREA	CHARPY. IMPACT Kgm/cm <sup>2</sup>	HARD. NESS H.B
DWG. NO. 89054	48 PCS	2924E	47653	79516	22.2	53.0	156	

I CERTIFY THAT THE CONTENTS OF THIS REPORT ARE IN COMPLIANCE WITH THE REQUIREMENTS OF

SPECIFICATION ASME-PA-10.5  
EDITION 1974 AND ADDENDA  
THROUGH WINTER 1975 and found acceptable EXCEPT AS NOTED

UT + ASTM A-370 + ASME-A-105 AS PER DWG. NO. 89054  
Inspected and tested according to W. E.

HEAT TREATMENT Temp(F) 1050 Deg.  
Back Heat Deg.  
Temp(F) 1150 Deg.



Mr. [Signature]  
VELAN ENGINEERING LTD.  
PER MANAGER OF INSPECTION

**TREPANED BODY STOCK FOR 1/2 NPT DRAIN PLUGS**

ALL MATERIAL SUPPLIED ON THIS ORDER IS CERTIFIED TO BE FREE FROM MERCURY CONTAMINATION. THE RAW MATERIAL AND FINISHED ITEMS DID NOT COME IN DIRECT CONTACT WITH MERCURY OR MERCURY BEARING COMPOUNDS DURING MANUFACTURE, ASSEMBLY OR TEST.

DATE 31TH.AUG.1978

I CERTIFY THESE TESTS TO BE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY

*Feb 27-78*

..... T. Higuchi  
G. C. MANAGER





**PROVE MECCANICHE**  
mechanical test  
**ANALISI MATERIALE**  
material analysis

W800004

CONTRATTO  
Inpezione

DATA  
date

SHEET 2/3

CERTIFICATO  
certificate

Internal

1.2.79

169/79

CLIENTE  
purchase  
ORDER No  
order  
**VELAN VALVE**  
W 1269 Pos. From 12 to 26

PROVA No TEST No	LOTTO Lot No	PROVA No TEST No	CARATTERISTICHE characteristics		VALORI RICHIESTI E OTTENUTI NELLE PROVE MECCANICHE SECONDO NORME required and obtained values in tests carried out according with standards												IMPACT TEST						
			MATERIALE material	DESCRIZIONE description	PROVA test specimen						VALORI RICHIESTI required values							VALORI OTTENUTI obtained values					
					Ø mm	AREA mm²	LONG. length mm	R <sub>EL</sub> R <sub>e</sub> MPa	R <sub>m</sub> R <sub>m</sub> MPa	A %	C %	VALORES VALUES	IMPACT TEST	YIELD STRENGTH By R <sub>e</sub>	TENSILE STRENGTH	ELONGATION A		IMPACT VALUES					
5			SA 193	Ø7	1" x 6 1/4"	12.7	126.7	30.8	724	862	16	50			290	12.7	21.3	59					
6			"	"	1 1/8" several	"	"	"	"	"	"	"			281.5	10.8	20.4	60					
7			"	"	1 3/8" x 9 1/2"	"	"	"	"	"	"	"			273	14.9	21.6	60					

This is to certify that the contents of this report are correct and accurate and that all operations performed are in compliance with the requirements of the material specification and the purchase order.

I CERTIFY THAT THE CONTENTS OF THIS REPORT ARE IN COMPLIANCE WITH THE REQUIREMENTS OF SPECIFICATION A 205-28-198-Ø7  
 1979/1 AND ADDENDUM THROUGH 1/11/79  
 VELAN ENGINEERING LTD.  
 PER MANAGER OF INSPECTION

LOTTO Lot No	COSTA Cost No	C	M <sub>s</sub>	M	P	S	C	N	M <sub>s</sub>	V	LOTTO Lot No	COSTA Cost No	C	M <sub>s</sub>	M	P	S	C	N	M <sub>s</sub>	
5	56902	.42	.83	.18	.015	.006	.90		.18		6	15878	.39	.88	.27	.015	.011	.97		.16	
7	967379	.42	.85	.31	.015	.016	.96		.16												



NOI  
we  
DIMENSIONAL AND VISUAL CONTROL ON 5% OF THE PIECES: SATISFACTORY  
ALL STUDBOLTS HAVE BEEN STAMPED Ø7-Ø PLUS LOT NUMBER.

INFORMAZIONE  
INFORMATION


S.P.A.  
ERBA  
ERBA (Como)





800004

SHEET 3/3

		PROVE MECCANICHE <small>mechanical test</small> ANALISI MATERIALE <small>material analysis</small>	CONTAUDO <small>Inspection</small>	DATA <small>data</small>	CERTIFICATO <small>certificate</small>
Internal		No. 169/79			
YBLAN VALVE					
V. 1269 POS. FROM 12 TO 26					
VASO SOTTO CARICO MUST BE IN COMPLIANCE WITH SECTION II PART 6 AND SECT. III 1974 EDITION WITH QUINCY NUMBER 1975 ADD.					
PORTATA <small>load capacity</small>		VASO SOTTO CARICO <small>working pressure</small>		APPROVED REPORT	
S <small>mm</small>	A <small>mm</small>	C <small>mm</small>	H <small>mm</small>	N <small>mm</small>	M <small>mm</small>
SA_194_20 <small>mm</small>	1 1/8" nuts <small>mm</small>	1 3/8" "	1 1/8" nuts after 24 h. a. T. 50°C HR1=from 94 to 100 HR2=from 93 to 100	1 1/8" nuts after 24 h. a. T. 50°C HR1=from 94 to 100 HR2=from 93 to 100	1 1/8" nuts after 24 h. a. T. 50°C HR1=from 94 to 100 HR2=from 93 to 100
This is to certify that the contents of this report are correct and accurate and that all operations performed are in compliance with the requirements of the material specifications and the purchase order.					
015 017 015 028	015 017 015 028	015 017 015 028	015 017 015 028	015 017 015 028	015 017 015 028
MATERIAL HAS BEEN CURISHED AND TEMPERED. ALL NUTS HAVE BEEN STAMPED 1 2 - D FIN. LOT NUMBER.					
APR 18 1979					
METALLOGRAPHY					

I CERTIFY THAT THE CONTENTS OF THIS REPORT ARE IN COMPLIANCE WITH THE REQUIREMENTS OF SPECIFICATION ~~AS PER 1974~~ AND ADDENDA ~~1974~~ THROUGH ~~1974~~ EXCEPT AS NOTED.  
 YEAN FABRICATIONS LTD.  
 PER MANAGER OF INSPECTION



NO. 1 - PROOF LOAD TEST ON NUTS (LOT R-9) - SATISFACTORY.  
 DIMENSIONAL AND VISUAL CONTROL ON 5% OF THE PIECES SATISFACTORY.





**VELAN ENGINEERING COMPANIES**

Form #VE37-11-71 Rev. 2

Page 1 of 1  
No. of Supp. N/A  
Report No.: NR-1158

**DEVIATION REPORT**

**E 800004**

Material Review Report

Vendor Waiver Request

NUCLEAR CLASS 3	SUPPLIER & F.O. NO. Velan Valve Corp. P3-7026-N
--------------------	--

QUANTITY 6	PART NO. B18-00548-02WN	DESCRIPTION 12"-150# Bolted Bonnet Gate Valve M/D	MATERIAL C/S SA-105
---------------	----------------------------	---	------------------------


ACC	REV.	INSPECTOR	SHOP ORDER	SERIAL NO.	DETAIL DWG. NO.	DATE RECEIVED IN INSPECTION
0	6	K. Osborn	18 BGAN 1268 18 BGAN 1342 18 BGAN 1343	169,170,171 173,176,180	8929-101/106 8949-134/135	2-21-80

CUSTOMER NAME Niagara Mohawk	P.O. NO. NMP2-304R	ITEM NO. 37,38,39	CUSTOMER APP. DWG. NO. P3-7026-N6 (F)	HEAT NO. N/A
---------------------------------	-----------------------	----------------------	--	-----------------

<b>SPECIFICATION REQUIREMENTS</b> OCI 482 Rev. 4 Project Drawing P3-7026-N6 Rev. F	<b>ACTUAL DIMENSIONS OF CONDITIONS</b>
1) Item 14 calls for 12 Bonnet Stud to be 1"-8un x 6 1/2" Long	1) Bonnet Studs and Nuts used are 1 1/8" Dia. 12 only.
2) Item 22 Calls for 4 1"-8unc x 3" Long Hex Hd Cap Screws	2) Yoke Cap. Screws 6-7/8"x2 3/4" Long NOTE: 2- valves not assembled yet Body S/N 169, 170, 171, 173, 176, 180
	NOTE: Body-Dwg. 8949-134/135 Rev. 0 Assembly Dwg. 8890-047 150-600#

PERCENTAGE COMPLETE 6 VALVES 100%	INSPECTOR, DATE <i>[Signature]</i> 2-26-80	CHIEF INSPECTOR, DATE <i>[Signature]</i> 2-26-80
--------------------------------------	---	---

<b>JUSTIFICATION FOR ACCEPTANCE</b> Design calls for # 1 1/8" Qty. of 12 Bonnet studs & # 7/8 Qty. of 6 Yoke Cap screws, project drawing will reflect this in next revision.	<b>CORRECTIVE ACTION</b> Error in Project Engineering Drawing. Engineering advised to reconcile project drawing with design drawings.
---	--



TELECOPIED  
TO L. Panchison  
FROM [Signature]  
NO. 12746 DATE 2-26-80

**DISPOSITION**  
Accept as is.  
Will not affect form, fit, function or interchangeability.  
due to using standard design.

ENGINEERING <i>[Signature]</i>	DATE 2-26-80	QUALITY ASSURANCE <i>[Signature]</i>	DATE 2-26-80	CUSTOMER <i>[Signature]</i>	DATE 2/28/80
-----------------------------------	-----------------	---	-----------------	--------------------------------	-----------------

DISTRIBUTION: President, Plant Manager, Engineering Manager, Inspection Manager, O.A





**velan  
engineering  
companies**



Plants:  
Williston, Vermont  
Montreal, Quebec  
Granby, Quebec  
Leicester, England  
Paris, France

**Velan Valve Corporation**

Ave. "C", Griswold Industrial Park  
Williston, Vermont 05495  
Telephone: (802) 863-2561  
Telex: 954613

**W 800004**

WELD RECORD

VELAN ENGINEERING COMPANIES hereby certify the following excerpts from its Weld Record Book:

Stone & Webster Job No: 12177

Customer: Niagara Mohawk


Velan Order No: P3-7026-N

Item No: 38

Valve Serial No: 004

Stone & Webster P.O. No: NMP2-P304R

Stone & Webster Spec. No: NMP2-P304R Rev.1 Add.4



WORK DONE	WELD PROCEDURE	WFM HEAT CODE	WELDER'S NAME	SYMBOL
1. Seat Welds to Body	Vel.P.631 (5)	A09004	S. BUSIER	WA41
2. Leak off pipe to body	N/A	---	---	---
3. Tack-Weld Disc & Union	N/A	---	---	---
4... Drain pipe to body	Vel.P.631 (5)	A09004	P. BERGERON	WA 2
5. Leak off pipe to bonnet	N/A	---	---	---
6. Wedge guide to body	Vel.P.631 (5)	A09004	P. BERGERON	WA 2

*[Signature]*  
Q. C. MANAGER



100-100-100

**velan  
engineering  
companies**



Plants:  
Williston, Vermont  
Montreal, Quebec  
Granby, Quebec  
Leicester, England  
Paris, France

**Velan Valve Corporation**  
Ave. "C", Griswold Industrial Park  
Williston, Vermont 05495  
Telephone: (802) 853-2551  
Telex: 954613

**W 800004**

**WELD REPAIR RECORD**

VELAN ENGINEERING COMPANIES hereby certify the following excerpts from its Weld Record Book:

Stone & Webster Job No: 12177

Customer: Niagara Mohawk


Velan Order No: P3-7026-N

Item No: 38

Valve Serial No: 004

Stone & Webster P.O. No: NMP2-P304 R

Stone & Webster Spec. No: NMP2-P304 R Rev.1 Add.4



REJECT. REPORT NO:	PART	WELD PROCEDURE	WFM HEAT CODE	WELDER'S NAME	SYMBOL	NDE INSP/DATE
NR-821	WEDGE	VEL-P-591(6)	73702	P. BERGERON	WA 2	69 DEC 29 1979
NR-053	BODY	VEL-P-591(6)	73702	J. McKINNEY	WA 42	52 OCT 13 1978

*[Signature]*  
Q.C. Manager



VELAN ENGINEERING COMPANIES

FORM #0029 Rev. 4

800004

PAGE 1 OF 2

REJECTION REPORT

EXHIBIT 35

REPORT NO. NR-053


DATE 10/10/78

LOT QUANTITY 1		PART NO. 8929-106-002		DESCRIPTION Body 12"-150"		MATERIAL C/S SA-105	
ACC. 0	REJ. 1	INSPECTOR W. Dowling	SHOP ORDER 188GAN 112F	SERIAL NO. 176	DETAIL DWG.# 8929-101-10 0	DATE REC'D IN INSPECTION 10/10/78	
CUSTOMER NAME Niagara Mohawk		P.O. NO. P3-7026-N	ITEM NO. 37-38-39		CUSTOMER APP. DWG.# N/A	HEAT NO. L2030	

<p>SPECIFICATION REQUIREMENTS (LIST BY ITEM)</p> <p>I/P Insp. Opr 060</p> <p>1) The 14 5/8 ± 1/64 φ</p>	<p>CAUSE OF REJECTION (LIST BY ITEM)</p> <p>1) is 14 1/4 φ</p> <p>.150 UNDERSIZE ON RADII.</p>
---	--

INSPECTOR W.R. Dowling	DATE 10/10/78	CHIEF INSPECTOR D.F. Windsor	DATE 10-10-78
---------------------------	------------------	---------------------------------	------------------

<p>CORRECTIVE ACTION</p> <p>HUMAN ERROR: OPERATOR HAS BEEN ADVISED TO RESPECT DRAWING.</p>	<p>DISPOSITION (LIST BY ITEM)</p> <p>1) MINOR REPAIR.</p> <p>1) Weld repair using VEL-P-591. REV. 6.</p> <p>2) Remachine to dwg.</p> <p>3) P.T. Exam to VEL-NDT-564A REV. 6.</p>
--	--



DEPT. RESPONSIBLE <i>[Signature]</i>	DATE OCT 10 78	CAUSE CODE 1	ACCEPT AS IS —	REPAIR 1	REWORK —	SCRAP —	REQUEST WAIVER —
---	-------------------	-----------------	-------------------	-------------	-------------	------------	---------------------

<p>DISTRIBUTION:</p> <p>A.N.I. (CODE RELATED)</p> <p>PLANT MANAGER</p> <p>INSPECTION MANAGER</p> <p>QA &amp; AUDITOR</p> <p>PRODUCT SUPERVISOR</p> <p>PRODUCT PLANNER</p> <p>FILE</p>	<p>QUALITY ASSURANCE</p> <p>D.F. Windsor 10-10-78</p>
	<p>DESIGN ENGR.</p> <p>D.F. Windsor 10/10/78</p>
	<p>CUSTOMER REPRESENTATIVE IF APPLICABLE</p> <p><i>[Signature]</i> 10/11/78</p>




NUCLEAR SECTION III	CLASS	SHOP ORDER	PART NO.	DRAWING NO.	REV.
	3	18BGAN 1163	8959-090-002	8959-090	0
OWNER	VALVE DESCRIPTION (Wedge)		PART		
Magara Motawak	12" 150# Gate Valve BB		Wedge		
P.O. NO.	MATERIAL SPEC.	ASTM.		HEAT CODE	
P3-7026N.	C/S	A9-105		F5098	
ITEM NO.	SHAPE	SIZE		SERIAL NO.	
37-(38)-39	Forging			7322	
		SUPPLIER & P.O. N: Montreal Steel			

QUANTITY	ACC	REJ.	INSPECTOR	Page	of	Report No.
1	0	1	AP Maynard	1	1	821

SPECIFICATION REQUIREMENTS (LIST BY ITEMS)	CAUSE OF REJECTION (LIST BY ITEMS)
1) 1.218 slot Width <sup>TYP</sup> Purchasing (WEDGE GUIDES)	1) 1.450/1.470
2) 1 1/16 +1/32 - 0 STEM SLOT (T-HEAD)	2) 1.240
3) .29 @ 13/32 DEPTH OF SLOT (T-HEAD)	3) 2.045

INSPECTOR	DATE	CHIEF INSPECTOR	DATE
AP Maynard	11-6-79	[Signature]	11-6-79

CORRECTIVE ACTION	DISPOSITION (LIST BY ITEMS)
Subcontractor error. Wrong drawing revision used. Subcontractor to be advised.	1 & 2 WELD REPAIR & REM/CK TO DRAWING. 3) ACCEPTED AS IS WILL NOT AFFECT FORM FIT FUNCTION OR INTERCHANGEABILITY.



DEPT RESPONSIBLE	DATE	CAUSE CODE	REJECT AS IS	REPAIR	REWORK	SCRAP	REQUEST WAIVER
Watts	13 Nov 79			1			


DISTRIBUTION: 11/21/79	ANI (Code related)	QUALITY ASSURANCE	DATE
	Plant Manager	[Signature]	11/14/79
	Inspection Manager	DESIGN ENGINEER	[Signature]
	Q.A. Auditor	CUSTOMER REPRESENTATIVE / ANI	DATE
	Product Supervisor	IF APPLICABLE	
	Planner	[Signature]	11.21.79
	File		



VELAN ENGINEERING CO.

Form #89-9-78  
Rev. 0

Rejection Report





Velan No.: P3-7026-N  
 Items: 37, 38, 39, 45  
 Tags: 2SWP-MOV17A, B  
 2CCP-MOV14A, B  
 2CCP-MOV18A, B  
 2SWP-MOV18A, B  
 2RHS-MOV116

RELIANCE ELECTRIC COMPANY

W800004

REV. 107

Madison Indiana

REPORT OF ROUTINE TESTS

Induction Motor

Customer P.O. NMP2-P304R  
 Purchaser

Date of Test 1-19-79

Limitorque Corporation  
 5114 Woodall Road  
 Lynchburg, Va. 24502

Manufacturer's Order No. 20431047-1A

Purchaser's Order No. 3C8974 DE, P. 1

NAMEPLATE DATA

Style No. 713116  
 Special Markings: A.BOVE

No	Service Factor	Rpm	Phase	Hertz	Volts	Amperes
1.6	1.00	1700	3	60	575	3.2

Type	Frame	(Temp Rise By Method Indicated)	(Ambient Temp and Insulation Class)	Time Rating	Design Letter	Code Letter for Locked Rva. 110
P	RE	60°C	CLASS RH	SMIN	—	—

TEST CHARACTERISTICS

SERIAL NUMBER	NO LOAD				LOADED MOTOR (STANDARD FLANGE)			WOUND ROTOR OPEN CIRCUIT VOLTAGE	HIGH POTENTIAL TEST VOLTAGE
	VOLTS	HERTZ	RPM	AM- PHASES	VOLTS	HERTZ	AM- PERES		
1.	575	60	1791	2.2	575	60	17.0		2500
2.	575	60	1790	2.6	575	60	16.0		2500
3.	575	60	1798	2.3	575	60	17.0		2500
4.	575	60	1799	2.7	575	60	17.0		2500
5.	575	60	1796	2.4	575	60	17.0		2500
6.	575	60	1785	2.6	575	60	16.0		2500
7.	575	60	1785	2.6	575	60	17.0		2500
8.	575	60	1797	2.7	575	60	17.0		2500
9.	575	60	1794	2.3	575	60	17.0		2500
10.	575	60	1796	2.3	575	60	17.0		2500



NOTES: Data on test from THIS motor.  
 (This or duplicate)

Approved by Warren R. Waters

1-29-79



4000082M

Date 12-29

Unit Size S126-0-25


LIMITOR TEST DATA

Ref. P3-7026-TT38C

Order No. 3497

Cust. P.O. No. 21251

Parameters	Test 1	Test 2	Test 3	Test 4	Test 5	Test 6	Test 7	Notes
T.S. SETTING	1	1½	2	2½	3	3½	4	
THRUST OUTPUT	6400	10900						POUNDS
VOLTAGE	461	460						VOLTS
CURRENT	4.3	4.5						AMPS
CYCLES	60	60						HERTZ
NORMAL SETTING	1 ½	LOAD 10900	VOLTS	460	AMPS 4.5	HERTZ 60		
MAXIMUM SETTING	1 7/8	LOAD 17400	VOLTS	460	AMPS 7.7	HERTZ 60		
STALL VOLTAGE	100 %	LOAD 28700	VOLTS	572	AMPS 18.6	HERTZ 60		



W.A. Moore

W.A. Moore  
Test Lab. Manager

Serial No. S126-293419  
VALVE No. 2 CCP-MOV-18A  
P3-7026-N  
ITEM: 38

Tested by [Signature]  
Title Test Lab. Tech.

TF





5.0 CERTIFICATION OF SEISMIC REPORT SR-6393 W 800004

We hereby certify that the design of the valve(s) meets the seismic requirements of the Stone & Webster Specification No. NMP2-P304R and the ASME Boiler and Pressure Vessel Code, Section III, Class 2 & 3, 1974 Edition with addenda through Winter 1975.

Report Prepared By: Thanh Nguyen-Dinh

*Wilson*  
Nov. 27/1978


Report Certified By:

Approved by:  
S. ISBITSKY, Chief Stress  
Analyst:  
Signature: *[Signature]*  
Date: Nov. 30, 1978



Report Certified By:

Independent Review by:  
A.K. VELAN, P.E.  
Signature: *[Signature]*  
Date: 30.11.78





*Lat 2/11/77*  
 1177  
 VALVE FROM HALL  
 (enc)

**Valve Valve Corporation**  
 2125 Ward Avenue  
 Montreal, Quebec H4M 1Y5

TO

Attention Mr. M. Ristafano

DEAR SIR:

THE FOLLOWING ARE  ATTACHED  COPY SEPARATELY

<input type="checkbox"/> COPIES	<input type="checkbox"/> FEES	<input type="checkbox"/> REPRODUCIBLES	<input type="checkbox"/> SPECIAL APPOINTMENT CASES
<input type="checkbox"/> COMMENTS	<input type="checkbox"/> DOCUMENTS	<input type="checkbox"/> DRAWINGS	<input type="checkbox"/> OTHER DATA
<input type="checkbox"/> DOCUMENTS	<input type="checkbox"/> NOTES OF CONFERENCE		

STATUS	PLEASE NOTE	SENT FOR YOUR
<input type="checkbox"/> FINAL	<input type="checkbox"/> APPROVED	<input type="checkbox"/> APPROVAL
<input type="checkbox"/> PRELIMINARY	<input type="checkbox"/> APPROVED AS REVISED	<input type="checkbox"/> COMMENT
<input type="checkbox"/> NO COMMENT	<input type="checkbox"/> UNREPRODUCIBLE	<input type="checkbox"/> USE
<input type="checkbox"/> SUPERSEDED BY NEWER	<input type="checkbox"/> AS REVISED	<input type="checkbox"/> FILE
	<input type="checkbox"/> IN SPECIFICATION	<input type="checkbox"/> REVISION
	<input type="checkbox"/> IN SPECIFICATION	<input type="checkbox"/> CORRECTION

**YOUR ATTENTION IS DIRECTED TO THE FOLLOWING:**

RELEASED FOR:  PERMISSION  PURCHASE OF NECESSARY MATERIALS

PLEASE REFER AND QUOTE \_\_\_\_\_ FEES \_\_\_\_\_ REPRODUCIBLES \_\_\_\_\_ SPECIAL APPOINTMENT CASES

PLEASE QUOTE \_\_\_\_\_ FEES \_\_\_\_\_ REPRODUCIBLES \_\_\_\_\_ SPECIAL APPOINTMENT CASES OF  COMMENTS  DRAWINGS  OTHER DATA

PLEASE RETURN ONE COPY EACH OF THE MATERIAL, BEARING YOUR APPROVAL OR COMMENTS

PLEASE ACKNOWLEDGE RECEIPT OF THE MATERIAL BY RETURNING AND RETURNING THE ENCLOSED COPY OF THIS FORM

WE TRUST THAT THESE NOTES ARE IN ACCORDANCE WITH YOUR UNDERSTANDING. IF NOT, PLEASE ADVISE US.

**IMPORTANT** SHOULD ANY DEFECTS TO EQUIPMENT OR CHANGES BETWEEN EQUIPMENT BECOME A PRIZE CONCERN, THE SUPPLIER MUST NOTIFY USER & RESEARCH PURCHASING DEPARTMENT WITHIN TEN (10) DAYS FROM THROUGH A DEFECTIVE EQUIPMENT REPORT BE GIVEN AT THE TIME OTHERWISE THE PURCHASER WILL CONSIDER THE EQUIPMENT BEING WITHOUT DEFECT.

**PURCHASE ORDER NUMBER HSP2-**  
 P304E: Carbon Steel Valves, 2 1/2 Inch and Larger  
 P304H: Forged Carbon Steel Valves, 2 Inch and Smaller  
 P304J: Forged Stainless Steel Valves, 2 Inch and Smaller  
 P304L: Stainless Steel Valves, 2 1/2 Inch and Larger  
 P304R: Motor Operated Carbon Steel Valves  
 P304S: Motor Operated Stainless Steel Valves  
 NIAGARA POINT NUCLEAR STATION - UNIT 2  
 NIAGARA POWER CORPORATION

VEL-NPT-543A (10) **100% MAGNETIC PARTICLE EXAMINATION** **REVISION 1/77**  
 VEL-NPT-543A **Magnetic Particle Examination for ASME B4PV Code, Section III, Nuclear Power Plant Components.** **Rev. 9 3/2/77**

Very truly yours,


*P.C. Z...*  
 C. C. Zappala  
 Lead Power Engineer

NOTED SEP 27 1977  
*Chappa*  
 NOTED SEP 27 1977  
 Records Mgt.  
 JJDore (enc)  
 CCZohrer (enc)  
**SEP 27 1977**

JJD:EFM

Copies to: JHilka (enc)

RAFplant-3  
 WJStoop-3  
 AReynolds  
 Document Control Systems/81ts





STONE & WEBSTER ENGINEERING CORPORATION  
 JUL 14 1977 REVIEW OF SUPPLIER'S TECHNICAL DOCUMENT

A2040518

SUPPLIER <b>VELAN ENG.</b>	P.O. NO. <b>Sec</b>	DOCUMENT TITLE <b>TESTING OF NUCLEAR VALVES</b>	DOC. I.D. NO. <b>VEL-NOT-640(57)</b>	REV. <b>8</b>	DATE <b>7/1/77</b>
-------------------------------	------------------------	--	---	------------------	-----------------------

DATE RECEIVED OR NEW SUBMITTAL REQUISITTAL	SPEC. NO. / DATE <b>Sec 6000</b>	REV. / ADDEN. <b>Sec 6000</b>	SPEC. TITLE <b>Sec 6000</b>
--	-------------------------------------	----------------------------------	--------------------------------

GOVERNING CODES & DATES <b>ASME III, C1, 2, 3 P3046, 2, 3 - 1971, W7044 ENR 1.2.5 - 1972, W7044</b>	SPECIAL REQUIREMENTS <b>NA</b>	DRS REFERENCES <b>S&amp;W SUPPLIER NA</b>
--	-----------------------------------	--

SPECIALIST <b>A. Joyce</b>	PROJECT <b>NMP2</b>	J.O. NO. <b>12177</b>	RESPONSIBLE ENG. <b>J. J. Dece</b>	LOCATION <b>5/5</b>	EXT. <b>3722</b>	DATE <b>7/1/77</b>
-------------------------------	------------------------	--------------------------	---------------------------------------	------------------------	---------------------	-----------------------

COMMENTS: **Due date July 19, 1977**  
 RD/SAFE # **Spec Date Rev. App. Spec Title**


<b>NMP2-P304E</b>	<b>9-21-73</b>	<b>0</b>	<b>5</b>	<b>Carbon Steel Valves, 2 1/2 Turn &amp; Lapped</b>
<b>NMP2-P304H</b>	<b>10-15-73</b>	<b>0</b>	<b>5</b>	<b>FORGED CARBON STEEL VALVES, 2 TURN AND LAPPER</b>
<b>NMP2-P304J</b>	<b>10-25-73</b>	<b>0</b>	<b>5</b>	<b>FORGED STAINLESS STEEL VALVES, 2 TURN AND LAPPER</b>
<b>NMP2-P304L</b>	<b>4-24-76</b>	<b>0</b>	<b>1</b>	<b>STAINLESS STEEL VALVES, 2 1/2 TURN AND LAPPER</b>
<b>NMP2-P304R</b>	<b>9-17-76</b>	<b>1</b>	<b>1</b>	<b>MATCH OPERATED CARBON STEEL VALVES</b>
<b>NMP2-P304S</b>	<b>9-17-76</b>	<b>1</b>	<b>1</b>	<b>MATCH OPERATED STAINLESS STEEL VALVES</b>

*Subject procedure meets the requirement of specifications and governing Code.*

<input type="checkbox"/> APPROVED AS DEFINED IN THE SPECIFICATIONS <input type="checkbox"/> UNACCEPTABLE <input type="checkbox"/> APPROVED AS NOTED IN THE COMMENTS SPEC. <input type="checkbox"/> REJECTED	P304H, P304J, P304L, P304R, P304S - APPROVED - AS DEFINED IN SPEC. NO. NMP2-P304E <b>STONE &amp; WEBSTER ENGINEERING CORPORATION</b> SIGNED: <i>[Signature]</i> DATE: <b>9-15-77</b>
--	---

SUBMITTAL REQUIRED <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	REVIEWER <b>A. Reynolds</b>	DEPT./DIV. <b>QA/NDT</b>	DATE <b>9-15-77</b>	LOCATION <b>245/5</b>	EXTENSION <b>0813</b>
---	--------------------------------	-----------------------------	------------------------	--------------------------	--------------------------



	VELIN ENGINEERING COMPANIES	PROCESS PROGRESS

BA7706220004

TESTING

OR

NUCLEAR VALVES

VEL-MVT-640A (HT)

- APPROVED - <sup>P3040</sup>  
 AS DEFINED IN <sup>P3042</sup>  
 SPEC. NO. NMP2-P3045 <sup>P3042</sup> P3045  
**STONE & WEBSTER**  
 ENGINEERING CORPORATION  
 \_\_\_\_\_ DATE SEP 10 1977




VELAN ENGINEERING COMPANIES	Q.C. PROCEDURE
TESTING OF NUCLEAR VALVES	VEL-NOT-640A (REV)

DATE/ ISSUE	CHANGES PARA/PAGE	DESCRIPTION	PREPARED/ APPROVED
March 28/72	Original Issue	Rev. 0	C. MacLean/ A.K. Velan
Feb. 28/73	See Marginal Note	Rev. 1	C. MacLean/ A.K. Velan
Apr. 17/74	See Marginal Notarion	Rev. 2	E.I. Francois/ A.K. Velan
May 21/74	See marginal notes	Rev. 3	E.I. Francois/ J.A. Simpson/ A.K. Velan
July 29/74	See Marginal Notes	Rev. 4	E.I. Francois/ J.A. Simpson/ A.K. Velan
July 22/75	Rewritten to meet ASME Section III	Rev. 5	Checked: [Signature] Approved: [Signature] Ind. Rev: [Signature]
Jan. 21/76	See marginal Notes	Rev. 6	Checked: [Signature] Approved: [Signature] Ind. Rev: [Signature]
Oct. 6/76	See Marginal Notes	Rev. 7	By: [Signature]
March 3/77	See Marginal Notes	Rev. 8	By: [Signature]

DATE: March 3/77	BY: E.I. Francois	REV.: 9	PAGE No.: 2 of 12
------------------	-------------------	---------	-------------------



	VELAN ENGINEERING COMPANIES	Q.C. PROCEDURE
	TESTING OF NUCLEAR VALVES	VEL-NDT-640A (REV)

1. SCOPE


This procedure establishes all requirements for hydrostatic testing of Velan Nuclear Valves manufactured to conform to ASME Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components with respect to Class 1, Class 2 and Class 3 Valves.

2. REFERENCED DOCUMENTS

- 2.1 ASME Boiler and Pressure Vessel Code, Sec. III, and current Addenda
- 2.2 ANSI Standard B16.5
- 2.3 MSS Standard Practice MSS-SP-61. Hydrostatic Testing of Steel Valves (1).
- 2.4 Calibration of Measuring and Test Equipment, VEL-QC-503.

3. TESTING REQUIREMENTS

- 3.1 Test fluid for hydrostatic testing shall be demineralized "Grade A" water. Water temperature shall not exceed 100°F.
- 3.2 When hydrostatic tests are being conducted with water, the valve shall be relieved of all air.
- 3.3 The valve shall not be painted before shell pressure tests are completed.
- 3.4 If hydrostatic tests in the presence of the purchaser's representative are required by their specification, the test shall be conducted prior to painting the valves.
- 3.5 If hydrostatic tests in the presence of the purchaser's representative are requested after the valves have been tested and painted the valves may be retested without the removal of paint.





## TESTING OF NUCLEAR VALVES.

VEL-NDT-640A(N)

- 3.6. Pressure gauges shall have a range of not less than  $1 \frac{1}{2}$  times or more than 4 times the intended maximum test pressure.
- 3.7. Test pressures shall be observed on Pressure gauges calibrated and controlled in accordance with VEL-QC-503.
- 3.8. Hydrostatic test gauges shall be checked against a master test gauge, installed and protected by a shut-off valve at the test stand, prior to each series of tests.  
Note: Check at each change of valve type, size or pressure class or daily, whichever occurs first.

4. TEST METHODS4.1 Shell, Backseat and Packing Chamber Test

The hydrostatic test pressures shall be applied with both ends of the valves closed.

4.1.1. Gate & Globe Valves (Classes 1, 2 & 3)

The valve shall be given a hydrostatic shell test in the fully open position (back seat in contact) with the packing removed for valves shipped without packing rings and loosened gland bolts for packed valves.

The back seat shall then be removed from contact and the packing compressed (install packing in valves tested without) by tightening the gland so that the stuffing box will be subjected to the hydrostatic shell test pressure.

4.1.2. Check Valves (Class 1, 2 & 3)

The valve shall be given a hydrostatic shell test with the pressure applied under the disc. (to open the seat)

4.1.3. Test Pressures and Duration (Gate, Globe & Check Valves Classes 1, 2 & 3)

The test pressure for Class 1 valves shall be as shown in table 1.  
The test pressure for Class 2 & 3 valves shall be as shown in table 11.  
The duration of the test shall be 15 minutes for each inch of design minimum wall thickness but not less than 10 minutes for Class 1, 2 & 3. (See Table III). The duration of the packing chamber test shall be 5 minutes maximum.

DATE: March 3'77

BY: E. I. Francois

REV: 9

1

PAGE No. 1  
of 12



#### 4.1.4. Examination for Leakage

Following the application of the hydrostatic test pressure, the valve shall be examined with the hydrostatic pressure still being applied. Any leakage or permanent deformation shall be cause for rejection.

### 4.2 SEAT LEAKAGE TESTS

#### 4.2.1. Gate Valves (Classes 1, 2 & 3)

The valves shall be given a hydrostatic seat test applied successively on each side of the closed seat with the opposite side connected to a leakage collection system.

The collection system is filled with water to a zero level to permit leakage to be measured.

#### 4.2.2. Globe Valves (Classes 1, 2 & 3)

The valves shall be given a hydrostatic seat test in accordance with parag. 4.2.1 except that the pressure shall be applied below the seat with the opposite side connected to the collection system.


#### 4.2.3. Check Valves (Classes 1, 2 & 3)

The valves shall be given a hydrostatic seat test in accordance with parag. 4.2.1 except that the pressure shall be applied on the down stream side (to close seat) of the disc with the opposite side connected to the collection system.

#### 4.2.4. Test Pressures and Duration (Gate, Globe & Check, Class 1, 2 & 3)

Test pressures for all valves shall be in accordance with Table IV.



	VELAN ENGINEERING COMPANIES	PROCESS PROCEDURE
	TESTING OF NUCLEAR VALVES	VEL-NDT-650A (REV. 1)

The duration of the test shall be 1 minute for each inch of design minimum wall thickness but not less than 1 minute for Class 1, 2 and 3 (see Table V).

**4.2.5. Examination For Leakage**

In the absence of custom's specifications, the leakage rate should not exceed 2cc per hour per inch of diameter of nominal valve size.

**4.3 Disc Hydrostatic Test**

**4.3.1. Test Pressure and Duration**

The valves shall be given a disc hydrostatic test with the valve disc in the fully closed position. The test pressure shall be applied across the valve disc and be in accordance with Table IV. The duration of the test shall be one minute per inch of minimum wall thickness, with a minimum duration of one minute (Table V).


**4.3.2. Leakage**

During this test, seat leakage is permitted unless the Contract Instruction states otherwise.

**4.3.3. This test may be done concurrently with the seat leakage test.**

DATE: 11-11-77	BY: J. P. ...	REV: 1	PAGE No: 13
----------------	---------------	--------	-------------



	VELAN ENGINEERING COMPANIES	PROCESS PROCEDURE
	TESTING OF NUCLEAR VALVES	VEL-HDT-640A(HT)

**5.0 AUTHORIZED INSPECTION**

The witnessing of hydrostatic tests on all valves over 4" NPS by the Authorized Inspector is required. Valves 4" NPS and under may be witnessed by the Authorized Inspector at his option but it is not mandatory.

**6.0 ACCEPTANCE MARKING**

Valves passing hydrostatic tests shall be marked "HT" meaning testing has been successfully completed.

**7.0 TEST REPORTS**

Results of Hydrostatic testing shall be recorded in logbooks by the testing personnel to permit the preparation of the appropriate certification.

DATE:	BY:	REV.:	PAGE No.:
-------	-----	-------	-----------





**TESTING OF NUCLEAR VALVES**

VEL-507-640A(10)

**VALVE MATERIAL SPECIFICATIONS**

Chemical Property Classification	Applicable Specification No.	
	Flange	Body
Carbon Steel	SA-105	SA-105 Grade BCC
Stainless Steel	SA-182 Grade H	SA-182 Grade BCC
Stainless Steel	SA-321 Grade LP1	SA-321 Grade LDC
Carbon Steel	SA-408 Grade P1	SA-408 Grade WC1
Carbon Steel		SA-508 Grade LC1
Low Alloy Steel		
1 Cr - 1/2 Mn	SA-105	SA-105
1 Cr - 1/2 Mn	SA-182 Grade P12	SA-182 Grade P12
1 Cr - 1/2 Mn	SA-321 Grade P12	SA-321 Grade P12
1 Cr - 1/2 Mn	SA-408 Grade P12	SA-408 Grade P12
1 Cr - 1/2 Mn	SA-508 Grade P12	SA-508 Grade P12
1 Cr - 1/2 Mn	SA-105	SA-105
1 Cr - 1/2 Mn	SA-182 Grade P12	SA-182 Grade P12
1 Cr - 1/2 Mn	SA-321 Grade P12	SA-321 Grade P12
1 Cr - 1/2 Mn	SA-408 Grade P12	SA-408 Grade P12
1 Cr - 1/2 Mn	SA-508 Grade P12	SA-508 Grade P12

Valve Size	Valve Type	Material	Flange				Body				
			SA-105	SA-182	SA-321	SA-408	SA-105	SA-182	SA-321	SA-408	
1/2"	Ball	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105
1/2"	Ball	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182
1/2"	Ball	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321
1/2"	Ball	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408
1/2"	Ball	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508
1/2"	Ball	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105
1/2"	Ball	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182
1/2"	Ball	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321
1/2"	Ball	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408
1/2"	Ball	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508
1/2"	Ball	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105
1/2"	Ball	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182
1/2"	Ball	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321
1/2"	Ball	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408
1/2"	Ball	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508
1/2"	Ball	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105	SA-105
1/2"	Ball	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182	SA-182
1/2"	Ball	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321	SA-321
1/2"	Ball	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408	SA-408
1/2"	Ball	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508	SA-508

NOTE: 1 - Flange and valves over 4" NPS (6" and larger)  
 2 - Flange and valves and welding end valves 4" NPS and under



TABLE II

SHELL TEST PRESSURE  
 CLASS 2 & 3 VALVES (ALL SIZES)  
ALL PRESSURES ARE IN PSIG.

(7)

CLASS. TEHP/PRESS. RATING	M A T E R I A L						
	FERRITIC STEEL			AUSTENITIC STEEL			
	1Cr-1/2Ni 1-1/4 Cr-1/2Ni 2-1/4 Cr-1 Ni	C/S	C/S LOW TEHP	CARBON MNDY.	321, 367 316, 310	304	304L 316L
150	425	425	425	425	425	425	425
300	1100	1100	1100	1100	1100	925	775
400	1450	1450	1450	1450	1450	1250	1050
600	2175	2175	2175	2175	2175	1875	1550
900	3250	3250	3250	3250	3250	2775	2325
1500	5400	5400	5400	5400	5400	4650	3875
2500	9000	9000	9000	9000	9000	7725	6450

1. The figures are derived from B16.5, Hydrostatic Test Pressures  
 (Ref. ASME Section III NC6111.1(b) & ND6111.1(b))

(7)  
(6)

TESTING OF NUCLEAR VALVES

VALVE ENGINEERING DEPARTMENT  
 NUCLEAR REACTOR DIVISION  
 VEI-NOT-204(12)



TABLE III

TIME FOR SHELL TEST IN MINUTES  
FOR ASME CLASS 1, 2 & 3 VALVES

NOMINAL SIZE	PRESSURE CLASS					
	150	300	600	900	1500	2500
2 1/2	10	10	10	10	10	15
3	10	10	10	10	10	20
4	10	10	10	10	15	25
6	10	10	10	15	20	35
8	10	10	10	15	25	45
10	10	10	15	20	30	55
12	10	10	15	20	35	65
14	10	10	15	25	35	75
16	10	10	20	30	50	85
18	10	15	20	30	55	95
20	10	15	25	35	60	105
24	10	15	30	40	70	130

NOTE: Pressure shall be applied for such additional time as necessary to permit a thorough examination for leakage.

DATE: 11-11-57  
BY: [Signature]  
REV: [Signature]  
PAGE No: 11 of 15

HEAVY ENGINEERING CONSULTANTS  
TESTING OF NUCLEAR VALVES  
NORTH AVENUE  
MELBOURNE, AUSTRALIA



**TABLE IV**  
**SEAT LEAKAGE AND DISC HYDROTATIC LEAK TESTS**  
**FOR ASME CLASS 1, 2 & 3 VALVES**  
**ALL PRESSURES ARE IN P.S.I.G.**


(6)

CLASS TEMP/PRESS RATING	M A T E R I A L				
	FERRITIC STEEL		CARBON NO.	AUSTENITIC STEEL	
	C/S, 1 1/4 Cr-1/2Mo 2 1/4 Cr-1Mo	C/S LOW TEMP.		321, 304 347, 316 310, 316L	304L
150	300	300	300	300	300
300	750	750	750	750	670
400	1000	1000	1000	1000	890
600	1500	1500	1500	1500	1335
900	2250	2200	2200	2250	2005
1500	3750	3600	3600	3750	3345
2500	6250	6000	6000	6250	5570

NOTE: The figures are derived from ASME Section III (Tables M3531-1 to 7 (6) References: M3531.2, MC 3514) and MSS-SP-61 (Table II and IV). The higher corresponding valve of the two Tables (ASME & MSS) has been reproduced above.

DATE: MARCH 31 1977  
 BY: E. J. FRANCOIS  
 REV: 1  
 PAGE No.: 11 OF 12

TESTING OF NUCLEAR VALVES  
 VEL-101-680A(M)





**TABLE V**  
**TIME FOR SEAT AND DISC TESTS IN MINUTES**  
**FOR ASME CLASS 1, 2 & 3 VALVES**

NOMINAL SIZE	PRESSURE CLASS					
	150	300	600	900	1500	2500
2 1/2"	1	1	1	1	1	1
3"	1	1	1	1	1	1 1/2
4"	1	1	1	1	1	1 1/2
6"	1	1	1	1	1 1/2	2 1/2
8"	1	1	1	1	2 1/2	3
10"	1	1	1	1 1/2	2	4
12"	1	1	1	1 1/2	2 1/2	4 1/2
14"	1	1	1 1/2	2 1/2	3 1/2	5
16"	1	1	1 1/2	2	3 1/2	6
18"	1	1	1 1/2	2	3 1/2	6 1/2
20"	1	1	1 1/2	2 1/2	4	7
24"	1	1	2	3	5	8 1/2

NOTE: Pressure shall be applied for such additional time as necessary to permit a thorough examination for leakage.

▲

NELAN ENGINEERING COMPANIES

TESTING OF NUCLEAR VALVES

PROCESS PROCEDURE


NEL-101-640A (M1)


DATE

BY:




REV:

PAGE NO.:






# VELAN



**Maintenance Manual** VEL-FBBM  
For **2 1/2" - 24" FORGED**  
**Bolted Bonnet Gate and Globe Valves**  
And  
**Bolted Cover Check Valves**



Stone & Webster Engineering I.O. No. 12177 Spec. No. <b>73042</b>	
PREPARED FOR: RETURN TO SUPPLIER <input checked="" type="checkbox"/> DESIGN <input type="checkbox"/> LOCATION <input type="checkbox"/>	DIRECTIONS TO SITER FOR CONSTRUCTION <input type="checkbox"/> NOT FOR CONSTRUCTION <input checked="" type="checkbox"/>
<input checked="" type="checkbox"/> APP <input type="checkbox"/> ABR <input type="checkbox"/> UPR <input type="checkbox"/> UBT <input type="checkbox"/> FIO	Approved, Acceptable For Use Approved As Revised Unacceptable As-Built For Information Only
Date <b>12/11/84</b> By <b>H. J. [Signature]</b>	

# TABLE OF CONTENTS

	Page
<b>SECTION I</b>	
- LIST OF ILLUSTRATIONS, TABLES, DIAGRAMS .....	4
INTRODUCTION AND TYPES OF VALVES .....	5
<b>SECTION II</b>	
- RECEIVING AND PREPARATION FOR INSTALLATION .....	10
1.0 Receiving Inspection	
1.1 Quality Control Documentation	
1.2 Storage	
1.3 Handling and Preparation	
1.4 Special Instruction for Gate Type Valves	
1.5 Special Instruction for Globe Type Valves	
1.6 Special Instruction for Check Type Valves	
<b>SECTION III</b>	
- OPERATION .....	11
1.0 General	
1.1 Smoothness of Operation	
1.2 Seat Tightness - Closing Torques	
<b>SECTION IV</b>	
- MAINTENANCE .....	13
TROUBLE SHOOTING CHART .....	13
(A) PACKING CHAMBER LEAKAGE .....	14
1.0 General	
1.1 Removal of Packing Rings	
1.2 Removal of Special Tools	
1.3 Removal with Blow-Out	
1.4 Repacking with Uncompressed Packings	
1.5 Repacking with Precompressed Packings	
1.6 Packing Torques	
(B) BODY-BONNET AND BODY-COVER LEAKAGE .....	20
1.0 General	
1.1 Body-Bonnet and Body-Cover Torquing	
1.2 Torque Procedure	
1.3 Application of Torque	
1.4 Replacement of Spiral Wound Asbestos Stainless Gasket	
1.5 Seal Weld Removal	

TWX1840919

Telex  
western union

STNE WBST LYCO

VELAN P2 MTL

SEPT. 19/84

MSG 5904

ATTN.: MR. CHRISTOPHER JAS (SES)

SUBJECT: NIAGARA MOHAWK  
BOLTING TORQUE  
VELAN MAINTENANCE MANUAL VEL-FPSM + VEL-FBEM

THIS CONFIRMS OUR TELECON OF LAST WEEK WHEN WE ADVISED YOU THE  
TORQUE VALUE OF 20 FT.-LBS. FOR BOLTING OF THREAD SIZE  
5/16 - 18UNF IN B7/A574/530

PLS BUST WILL RESTART

For Specs.

P302E P304E  
P302L P304L  
P302R P304R  
P304S

RECEIVED VIA TWX  
DATE 9-19-84  
TIME 7:30  
NINE MILE POINT UNIT?

Telex/TWX  
western union

STNE WBST LYCO

VELAN P2 MTL

SEPT. 19/84

MSG 5904

NOTED SEP 20 1984 C. GASS

RECEIVED  
J. O. NO. 12187


SEP 19 1984

STINE & WEBSTER  
ENG CORP.  
CONTROL LEVEL 3

western union

TWX

Ases  
x 4514



(C) SEAT LEAKAGE ..... 26

- 1.0 General
- 1.1 Wedge & Disc Repairs
- 1.2 Seat Repairs – Gate Parallel Slide Valves
- 1.3 Fitting of Repaired Parts – Gate, Parallel Slide Valves
- 1.4 Disc & Seat Repairs – – Globe, Stop Check, Piston Check Valves
- 1.5 Fitting of Repaired Parts – Globe, Stop Check, Piston Check Valves
- 1.6 Disc Repairs – Swing Check
- 1.7 Seat Repairs – Swing Check
- 1.8 Fitting of New Disc – Swing Check
- 1.9 Backseat Repairs

SECTION V – DISASSEMBLY ..... 36

- 1.0 General
- 1.1 Disassembly Area 1-Valve Internal Problems
- 1.2 Disassembly Area 2-Valve Mid-Section
- 1.3 Disassembly Areas 1 & 2 – Parallel Slide Valve Internal and Mid-Section Problems
- 1.4 Disassembly Area 3 – Valve Top Works
- 1.5 Disassembly Area 1 – Valve Internal Problems Check Valves

SECTION VI – REASSEMBLY ..... 50

- 1.0 General
- 1.1 Reassembly Area 3 – Valve Top Works
- 1.2 Torque Value – Operator, Yoke/Bonnet Bolting
- 1.3 Reassembly Areas 1 & 2 – Valve Internal & Mid-Section
- 1.4 Reassembly Areas 1 & 2 – Parallel Slide Valve Internal and Mid-Section
- 1.5 Reassembly Area 1 – Valve Internal Check Valves

APPENDIX A ..... 56

- 1.0 Procedure for Removing Manual Gear Actuator
- 1.1 Removing Style I
- 1.2 Removing Style II

APPENDIX B ..... 59

- 1.0 Procedure for Removing Motor Actuator

APPENDIX C ..... 62

- 1.0 Procedure for Removing Hydraulic or Pneumatic Actuator

APPENDIX D ..... 63

- 1.0 Spare Parts

## LIST OF ILLUSTRATIONS

DESCRIPTION	FIGURE NUMBERS	PAGE
Key to Velan Steel Valve Figure Numbers	1	6
Gate Valves	2	7
Parallel Slide Valves	3	7
Globe Valves	4	8
Stop Check Valves	5	8
Swing Check Valves	6	9
Piston Check Valves	7	9
Live Loading	8(a), 8(b)	14
Blow-Out Fitting	9	15
Repacking Procedure	10(a), 10(b), 10(c), 10(d)	16, 17
Braided Asbestos Packings	11	18
Pre-Formed Graphite Ribbon	12	18
Packing Sequence	12(a), 12(b)	18
Gasket Compression	13	20
Boit Tightening Sequence	14	21
Gasket Installation	15, 16	23
Cutting of Weld	17(a)	24
Welding Process	17(b), 17(c), 17(d), 17(e)	25
Lapping	18	26
Valve Reseater for Gate Valves	19	27
Valve Grinders	20	27
Lapping of Seating Faces	21	28
Blueing of Wedge	22	28
Grinding and Lapping of Wedge	23	29
Fitting of Wedge	24(A), 24(b)	29
Repairing of Seat	25(a), 25(b)	30
Lapping Machine for Globe Valves	26	31
Grinders	27	31
Fitting of Disc	28(a), 28(b), 28(c)	32, 33
Lapping of Swing Check Disc	29	34
Repairing of Back Seat	30, 31	35
Exploded View of Gate Valve	32	37
Yoke-Bonnet Assembly – Gate & Globe	33(a), 33(b)	39
Disassembly of Globe or Needle Valves	34	40
Disassembly of Stop Check Valves	35	40
Valve Mid-Section Disassembly	36, 37	41
Disassembly of Parallel Slide Valves	38, 39	42, 43
Parallel Slide Disc Clamp	40, 41, 42	44, 45
Basic Disassembly of Valve Designs	43, 44	47
Disassembly of Swing Check	45(a), 45(b), 46(a), 46(b)	48
	47(a), 47(b), 48(a), 48(b)	49
Reassembly Procedures	49	50
Removal of Manual Gear Actuators	50, 51, 52, 53	56, 57, 58
Removal of Motor Actuators	54, 55, 56	59, 61
Removal of Hydraulic or Pneumatic Actuators	57, 58, 59	62, 63

## LIST OF TABLES/DIAGRAMS

Recommended Lubrication	Table A	11
Closing Torques	Diagram A	12
Trouble-Shooting Chart	Table B	13
Packing Flange Nut Torques	Table C	19
Torque Values for Body/Bonnet Bolting	Table D	22
Torque Values for Operator, Yoke/Bonnet Bolting	Table E	51



## **INTRODUCTION**

This manual has been prepared by Velan Engineers, Designers and Maintenance Personnel to assist you in obtaining many more years of satisfactory service with your Bolted Bonnet or Bolted Cover Valves. It will also assist you in restoring your valve to the best working condition with a minimum of time and expense.

Velan Valves are designed and manufactured using many years of constant development and improvement.

Before beginning any major work, we recommend that you carefully read this booklet at least once to understand the valve's physical construction.


Please note that if the reason for the service problem is not understood, we suggest that you get in touch with your local Velan representative or call the Head Office for more technical assistance.

On beginning any major work, we recommend that you carefully check the nameplate on the valve and record the figure number to identify the type and size of valve with which you are dealing. See Figure 1 to understand how the "Key to Velan Steel Valve Figure Numbers" works.

# VELAN VALVES



Velan Figure Numbers are designed to cover essential features. When ordering please show Figure Numbers to preclude misunderstanding of your requirements. A detailed description for SPECIALS must always accompany order.



## A TYPE OF CONNECTION

- |                 |                         |
|-----------------|-------------------------|
| A - SPECIAL     | R - Flanged, Ring Joint |
| B - Butt Weld   | S - Screwed             |
| C - Combination | U - Undrilled Flanges   |
| F - Flanged     | W - Socket Weld         |

## B SIZE OF CONNECTION

01 - 1/4	09 - 2 1/2	18 - 12	28 - 28
02 - 3/8	10 - 3	19 - 14	30 - 30
03 - 1/2	11 - 3 1/2	20 - 18	32 - 32
04 - 3/4	12 - 4	21 - 18	34 - 34
05 - 1	13 - 5	22 - 20	36 - 36
06 - 1 1/4	14 - 6	23 - 22	
07 - 1 1/2	15 - 8	24 - 24	
08 - 2	16 - 10	26 - 26	

## C PRESSURE RATING

0 - 150 lb.	3 - 1500 lb.	6 - 400 lb.
1 - 300 lb.	4 - 2500 lb.	7 - 900 lb.
2 - 600 lb. or API 800 (as required)	5 - 4500 lb.	

## D TYPE

- 01 Flow Control Valve OS & Y.
- 02 Ball Check Valve.
- 03 Piston Check Valve.
- 04 Strainer.
- 05 Conventional Port Gate Valves OS & Y.
- 06 Full Bore Gate Valve OS & Y.
- 07 Stop Valve OS & Y. (Globe)
- 08 Stop Check Valve OS & Y.
- 09 Needle Valve OS & Y.
- 10 Continuous Blow-Down Valve with venturi OS & Y.
- 11 Swing Check Valve.
- 12 'End' Entry Ball Valve.
- 13 'Top' Entry Ball Valve.
- 14 Parallel Slide Valve.
- 15 Instrument Valve.
- 16 By-pass Valve (Inlet).
- 17 By-pass Valve (Outlet).
- 18 Drain Valve.
- 19 Conventional Port Gate Valve ISRS.
- 99 SPECIAL

## E BODY STYLE

- |            |  |
|------------|--|
| 4 Vertical | A SPECIAL                              |
| 5 Angle    | B Bolted Bonnet (Forged)               |
| 6 Inclined | C Bolted Bonnet (Cast)                 |
|            | D Diaphragm                            |
|            | P Pressure Seal                        |
|            | S Bellows Seal                         |
|            | W Welded Bonnet                        |
|            | X Bonnetless (Welded Seat/Bottom Plug) |
|            | Z Bonnetless (New Style)               |

## F BODY MATERIAL

- |                                 |                                |
|---------------------------------|--------------------------------|
| 01 SPECIAL                      | 15 Stainless Steel, F347, CF8C |
| 02 A105, WCB                    | 16 Stainless Steel, F304H      |
| 03 Carbon Moly, F1, WC1         | 17 Stainless Steel, F430       |
| 04 Chr. Moly, F5, C5            | 18 Stainless Steel, F321       |
| 05 Chr. Moly, F11, WC8          | 19 Monel                       |
| 06 Chr. Moly, F22, WC9          | 20 Inconel                     |
| 07 -                            | 21 Hastelloy                   |
| 08 -                            | 22 Titanium                    |
| 11 Stainless Steel, F304, CF8   | 23 Alloy 20                    |
| 12 Stainless Steel, F304L, CF3  | 24 LF-1                        |
| 13 Stainless Steel, F316, CF8M  | 25 LCB                         |
| 14 Stainless Steel, F316L, CF3M | 26 LF-2                        |

## G TRIM MATERIAL

PLANT/PRODUCTS	CODE	WEDGE/DISC	SEAT	STEM
ALL PLANTS	AA	SPECIAL	SPECIAL	SPECIAL
1/4"-2" Forged Steel Valves	TX	13% Cr.	13% Cr.	13% Cr.
	TY	13% Cr.	13% Cr. (H1)	13% Cr.
	TS	13% Cr. (H1)	13% Cr. (H1)	13% Cr.
	TN	13% Cr. (H1)	13% Cr. (H1)	630 or 316B
	MY	SS316	SS316 (H1)	630 or 316B
	MS	SS316 (H1)	SS316 (H1)	630 or 316B
2-1/2" - 24" Forged Steel Valves	TS	A105 (H1)	A105 (H1)	13% Cr.
	MS	SS316 (H1)	SS316 (H1)	630
	LS	LF2 (H1)	LF2 (H1)	13% Cr.
	FM	F11 (H1) or SS316 (H1)	F11 or SS316 (H1)	13% Cr.
	FR	F22 (H1) or SS316 (H1)	F22 or SS316 (H1)	13% Cr.
	XY	Monel S	A105 (H1)	Monel or Monel K
1/2"-24" Cast Steel Valves	TY	CA 15 or WCB (H2)	A105 or A106 (H1)	13% Cr.
	TS	WCB (H1)	A105 or A106 (H1)	13% Cr.
	LS	LCB (H1)	A105 or A106 (H1)	13% Cr.
	MX	WCB (H3)	A105 or A106 (H3)	SS316
	MY	WCB (H3)	A105 or A106 (H1)	SS316
	MS	WCB (H1)	A105 or A106 (H1)	SS316
	XY	WCB (H4) or Monel S	A105 or A106 (H1)	Monel or Monel K
	SX	CF8M	CF8M (Integral)	SS316

## NOTES:


1. Hardfacing Code: H1 = Stellite, H2 = 13% Cr., H3 = 316, H4 = Monel.
2. Non-standard trims are available on request and should be coded AA (detailed description required).
3. TS, TN, MS trims may have solid stellite Wedge/Disc.
4. All 1/2" - 2" Forged globes and piston checks have integral stellite seats.
5. NACE Service: Special trim available on request. (Code NC)

Fig. 1

# TYPES OF VALVES

## PARTS DESCRIPTION

- |                      |                            |                              |
|----------------------|----------------------------|------------------------------|
| 1 - BODY             | 13 - GLAND BUSHING         | 25 - BEARING                 |
| 2 - BONNET           | 14 - PACKING FLANGE        | 26 - YOKE NUT                |
| 3 - STEM             | 15 - GUIDE SLEEVE          | 27 - HOUSING COVER           |
| 4 - SPIRAL GASKET    | 16 - BELLEVILLE WASHER     | 28 - GREASE FITTING          |
| 5 - BODY-BONNET STUD | 17 - PACKING FLANGE STUD   | 29 - HANDWHEEL               |
| 6 - BODY-BONNET NUT  | 18 - PACKING FLANGE NUT    | 30 - HANDWHEEL KEY           |
| 7 - LEAK-OFF PIPE    | 19 - TORQUE ARM            | 31 - HANDWHEEL NUT           |
| 8 - BLOW-OUT PLUG    | 20 - TORQUE ARM CAP SCREW  | 32 - HANDWHEEL NUT SET SCREW |
| 9 - BLOW-OUT GASKET  | 21 - TORQUE ARM KEY        | 33 - YOKE HOUSING CAP SCREW  |
| 10 - JUNK RING       | 22 - TORQUE ARM BEARING    | 34 - SEAT                    |
| 11 - PACKING RING    | 23 - YOKE                  | 35 - WEDGE GUIDE             |
| 12 - LANTERN RING    | 24 - YOKE-BONNET CAP SCREW | 36 - WEDGE                   |




**Fig. 2**  
**Gate Valve**

Forged Bolted Bonnet Gate Valves 2 1/2" - 24". The hardfaced seats are seal welded.

## PARTS DESCRIPTION

- |                          |                            |                             |
|--------------------------|----------------------------|-----------------------------|
| 1 - BODY                 | 20 - TORQUE ARM CAP SCREW  | 32 - HANDWHEEL NUT SET SCW  |
| 2 - BONNET               | 21 - TORQUE ARM KEY        | 33 - YOKE HOUSING CAP SCRE  |
| 3 - STEM                 | 22 - TORQUE ARM BEARING    | 34 - SEAT                   |
| 4 - SPIRAL GASKET        | 23 - YOKE                  | 39 - DISC                   |
| 5 - BODY-BONNET STUD     | 24 - YOKE-BONNET CAP SCREW | 40 - LOCK BRACKET           |
| 6 - BODY-BONNET NUT      | 25 - BEARING               | 41 - HEX HD BOLT            |
| 11 - PACKING RING        | 26 - YOKE NUT              | 42 - HEX HD NUT             |
| 13 - GLAND BUSHING       | 27 - HOUSING COVER         | 43 - SPRING                 |
| 14 - PACKING FLANGE      | 28 - GREASE FITTING        | 44 - CENTER PIECE           |
| 17 - PACKING FLANGE STUD | 29 - HANDWHEEL             | 45 - STROKE LIMITER         |
| 18 - PACKING FLANGE NUT  | 30 - HANDWHEEL KEY         | 46 - STROKE LIMITER CAP SCW |
| 19 - TORQUE ARM          | 31 - HANDWHEEL NUT         | 47 - STROKE LIMITER STUD    |




**Fig. 3**  
**Parallel Slide Valve**

Forged Bolted Bonnet Parallel Slide 2 1/2" - 24". The hardfaced seats are seal welded.

PARTS DESCRIPTION

- |                        |                              |                               |
|------------------------|------------------------------|-------------------------------|
| 1 • BODY               | 15 • GUIDE SLEEVE            | 27 • HOUSING COVER            |
| 2 • BONNET             | 16 • BELLEVILLE WASHER       | 28 • GREASE FITTING           |
| 3 • STEM               | 17 • PACKING FLANGE STUD     | 29 • HAMMER WHEEL             |
| 4 • SPIRAL GASKET      | 18 • PACKING FLANGE NUT      | 30 • HAMMER WHEEL KEY         |
| 5 • BODY • BONNET STUD | 19 • TORQUE ARM              | 31 • HAMMER WHEEL NUT         |
| 6 • BODY • BONNET NUT  | 20 • TORQUE ARM CAP SCREW    | 32 • HAMMER WHEEL SET SCREW   |
| 8 • BLOW • OUT PLUG    | 21 • TORQUE ARM KEY          | 33 • YOKE • HOUSING CAP SCREW |
| 9 • BLOW • OUT GASKET  | 22 • TORQUE ARM BEARING      | 37 • DISC                     |
| 10 • JUNK RING         | 23 • YOKE                    | 48 • STEM COLLAR              |
| 11 • PACKING RING      | 24 • YOKE • BONNET CAP SCREW | 49 • DISC UNION               |
| 13 • GLAND BUSHING     | 25 • BEARING                 | 50 • THRUST PAD               |
| 14 • PACKING FLANGE    | 26 • YOKE NUT                |                               |




**Fig. 4**  
**Globe Valve**

Forged Bolted Bonnet Globe Valves 2 1/2" - 12" have an integral hardfaced seat. The forged disc has a hardfaced seat and guide surface. It is guided at the top and bottom.

PARTS DESCRIPTION

- |                        |                              |                               |
|------------------------|------------------------------|-------------------------------|
| 1 • BODY               | 15 • GUIDE SLEEVE            | 26 • YOKE NUT                 |
| 2 • BONNET             | 16 • BELLEVILLE WASHER       | 27 • HOUSING COVER            |
| 3 • STEM               | 17 • PACKING FLANGE STUD     | 28 • GREASE FITTING           |
| 4 • SPIRAL GASKET      | 18 • PACKING FLANGE NUT      | 29 • HANDWHEEL                |
| 5 • BODY • BONNET STUD | 19 • TORQUE ARM              | 30 • HANDWHEEL KEY            |
| 6 • BODY • BONNET NUT  | 20 • TORQUE ARM CAP SCREW    | 31 • HANDWHEEL NUT            |
| 7 • LEAK • OFF PIPE    | 21 • TORQUE ARM KEY          | 32 • HANDWHEEL NUT SET SCREW  |
| 11 • PACKING RING      | 22 • TORQUE ARM BEARING      | 33 • YOKE • HOUSING CAP SCREW |
| 12 • LANTERN RING      | 23 • YOKE                    | 37 • DISC                     |
| 13 • GLAND BUSHING     | 24 • YOKE • BONNET CAP SCREW | 38 • SPRNG                    |
| 14 • PACKING FLANGE    | 25 • BEARING                 |                               |




**Fig. 5**  
**Stop Check Valve**

Forged Bolted Bonnet Stop Check Valves 2 1/2" - 12" have an integral hardfaced seat. The forged disc has a hardfaced seat and guide surface. It is guided at the top and bottom.

PARTS DESCRIPTION

- 1 - BODY
- 2 - COVER
- 3 - BODY-COVER STUD
- 4 - BODY-COVER NUT
- 5 - SPIRAL GASKET
- 6 - DISC
- 7 - HANGER
- 8 - BUSHING
- 9 - HANGER PIN
- 10 - HEX BOLT,
- 11 - LOCK BRACKET
- 12 - DISC NUT
- 13 - COTTER PIN
- 14 - HANGER BRACKET
- 15 - ROLL PIN
- 16 - SEAT




**Fig. 6 - Swing Check**

Forged Bolted Cover Swing Check Valve 2 1/2" - 24". The hardfaced seat is seal welded.

PARTS DESCRIPTION

- 1 - BODY
- 2 - COVER
- 3 - BODY-COVER STUD
- 4 - BODY-COVER NUT
- 5 - SPIRAL GASKET
- 6 - DISC
- 17 - SPRING



**Fig. 7 - Piston Check**

Forged Bolted Cover Piston Check Valves 2 1/2" - 12" have a hardfaced integrally deposited seat. The light disc piston ensures maximum lift and low pressure drop.

## II RECEIVING AND PREPARATION FOR INSTALLATION

### 1.0 Receiving Inspection

All valves must be examined for signs of damage that may have occurred during transportation. Any damage which may have been caused to the valve during transportation should be analysed and a damage report should be issued. Any serious damage should be reported to your local Velan representative or a call should be made to the Head Office so that a suitable arrangement for repairs can be made without delay.

### 1.1 Quality Control Documentation

For valves purchased with Quality Control (Q.C.) certification, check the package of documents to see that Quality Control certificates are complete as per the purchase order.

### 1.2 Storage

Valves should be stored in a suitably sheltered place to prevent contamination by weather, dirt or dampness. The valve is shipped with end protectors on the inlet and outlet which should stay on the valve until it is ready for installation.

**Note:** If actuators are involved, please refer to the applicable actuator manufacturer's instruction for storage.

### 1.3 Handling and Preparation

On large valves, a hoist is needed to assist installation. A sling should be placed under the valve body so that the unit can be lifted vertically to meet its final destination. From all types of valves, end protectors must be removed and connections checked for cleanliness. Any visible foreign matter must be removed from end connections on weld end valves. The weld end preparation must be cleaned properly with a suitable solvent such as acetone or alcohol. Do not use chloride or fluoride bearing solvents.

### 1.4 Special Instruction for Gate Type Valves

The flow through gate valves can be from either end. There may be exceptions to this when bypass piping is welded to the valve body. Check your piping layout drawing to ensure correct position and direction of flow. Gate valves should be installed and welded into the pipeline with the wedge or disc in the fully closed position. If the valve is left open or partially open, the valves could distort and may leak during operation. Also, leaving the valve in a fully closed position helps prevent weld spatter from falling directly onto the mating faces of the seats.

### 1.5 Special Instruction for Globe Type Valves

Globe type valves are usually installed with the inlet below the valve seat (Fig. 4). This has to be checked carefully to prevent incorrect installation. If throttling service is particularly severe, it is recommended that consideration be given to installing the valve so that the flow enters over the top of the seat and goes down through it. In this case, the valve is maintained in a more stable condition.

Consequently, the amount of wear is minimized and the external noise which is sometimes heard is reduced. The valve operation becomes easier due to reduced torque required when closing the valve.

Globe type valves should be installed and welded with the disc in a fully closed position to prevent damage to the valve during installation. Also, leaving the disc in a fully closed position helps prevent weld spatter from falling directly onto the mating faces of the seat and disc.

**Precaution:** Allow time for welding to cool before trying the valve for the first time in the pipeline.

### 1.6 Special Instruction for Check Type Valves

Check type valves must be installed with the inlet in direction of arrow (Figs. 5, 6 and 7). This has to be checked carefully before installing the valve. The placing of a check valve in the opposite direction to the flow will prevent the disc from swinging free and therefore prevent normal operation of the valve.

### III OPERATION

#### 1.0 General

All valves require checking before being put into operation. In addition, regular inspection is recommended during operation. Prompt attention should be paid when trouble arises. As a general rule, valves should be subjected to scheduled maintenance.

#### 1.1 Smoothness of Operation

Lubrication of stem threads, gearing and other working components outside the fluid area should be performed frequently and at least once every six months. Specific lubricants and frequency of application are shown in Table A. Valves that are not operated frequently and which may remain open or closed for long periods of time should be worked even if only partially about once a month.

**Important:** Excessive handwheel effort can indicate the following.

- a) Improperly lubricated or damaged valve stem.
- b) Valve packing compression too tight (check torques to Table C).
- c) Faulty or damaged valve parts.

**TABLE A  
RECOMMENDED LUBRICATION**

PART	LUBRICATION	APPLICATION	FREQUENCY
Stem threads	Shell: Abrasia No. 3 Molykote Corp: Molykote "G" or equal	Directly to threads.	When threads appear dry.
Yoke nut	Shell: Abrasia No. 3 Molykote Corp: Molykote "G" or equal	Inject through grease fitting at hub of yoke.	Concurrently with stem thread lubrication
Spiral Wound Asbestos Gasket	Neolube (graphite and mineral spirits)	Thin coating on all surfaces.	On valve assembly only.
All threaded parts except stem and yoke nut.	Anti-seize compound No. 425-A made by Crane Co. or equal.	Thin coat on threads.	On valve assembly only.

## 1.2 Seat Tightness - Closing Torques

Even a new valve with seating faces lapped to perfection and a full seatwedge or disc contact will be pressure tight only when sufficient stem load is applied. The minimum stem load for each size of valve and operating pressure varies, of course, but should be known by the operating personnel in order to seat the valve properly. Slight over-torquing should not damage a properly designed valve.

**Caution:** Do not use cheaters on handwheel.

Diagram A indicates the approximate minimum torques required to close a valve tightly for any given operating pressures. Take your operating pressure multiplied by the K factor for a given size of valve and add K<sub>2</sub> factor. This will give you an approximate torque to seat a standard Velan Valve.

$$\text{Torque} = (\text{Pressure} \times K_1) + K_2$$




DIAGRAM A

(e.g.) Torque = (1125 x .29) + 100 = 426

Type	=	Gate
Valve Size	=	10"
Pressure	=	1125 lb.
K <sub>1</sub>	=	.29
K <sub>2</sub>	=	100
Torque	=	426 ft./lb.



## IV MAINTENANCE

### TROUBLE SHOOTING CHART

**TABLE B**

AREA	GENERAL PROBLEMS	PROCEDURE FOR REPAIR
<b>Packing Chamber Leakage</b>	<ul style="list-style-type: none"> <li>•Packing compression</li> <li>•Gland bushing binding</li> </ul>	<ul style="list-style-type: none"> <li>•Packing chamber leakage Section IVa Para. 1.0</li> </ul>
	<ul style="list-style-type: none"> <li>•Packing worn</li> <li>•Stem, packing chamber damaged</li> </ul>	<ul style="list-style-type: none"> <li>•Repacking procedure Section IVa Para. 1.1</li> </ul>
<b>Body-Bonnet Joint Leakage</b>	<ul style="list-style-type: none"> <li>•Spiral gasket damaged</li> <li>•Body or bonnet damaged</li> </ul>	<ul style="list-style-type: none"> <li>•Replacement of gasket Section IVb Para. 1.4</li> </ul>
	<ul style="list-style-type: none"> <li>•Tightness of bolting</li> </ul>	<ul style="list-style-type: none"> <li>•Body-bonnet stud torquing Section IVb Para. 1.1</li> </ul>
<b>Seat Leakage</b>	<ul style="list-style-type: none"> <li>•Lack of seating torque</li> </ul>	<ul style="list-style-type: none"> <li>•Closing torque Section III Para. 1.2</li> </ul>
	<ul style="list-style-type: none"> <li>•Damaged seat faces</li> </ul>	<ul style="list-style-type: none"> <li>•Seat Repair Section IVc Para. 1.0</li> </ul>
	<ul style="list-style-type: none"> <li>•Disc movement restricted</li> </ul>	<ul style="list-style-type: none"> <li>•Disassembly &amp; reassembly swing check valves Section V Para. 1.5 Section VI Para. 1.5</li> </ul>
<b>Operation Smoothness</b>	<ul style="list-style-type: none"> <li>•Lubrication</li> </ul>	<ul style="list-style-type: none"> <li>•Lubrication Section III Para. 1.1</li> </ul>
	<ul style="list-style-type: none"> <li>•Packing compression</li> </ul>	<ul style="list-style-type: none"> <li>•Packing torque Section IVa Para. 1.5</li> </ul>
	<ul style="list-style-type: none"> <li>•Stem thread yoke nut thread</li> </ul>	<ul style="list-style-type: none"> <li>•Disassembly &amp; reassembly Section V Para. 1.4 Section VI Para. 1.1</li> </ul>

## IV MAINTENANCE


### IV(a) Packing Chamber Leakage

#### 1.0 General

If moisture or dripping occurs around the stem or the I.D. packing chamber, the following points must be investigated before removing the packing.

1. Check if the packing flange is torqued down to the correct torque as shown in Table C.
2. Check if the live load arrangement is in correct order. Compare your live loading arrangement with Fig. 8 (a) and (b). If the live loading arrangement is not correct, open the valve to the backseat position and tighten up on the seat firmly.

**CAUTION:** One must determine the effectiveness of the backseat seal as you dismantle the live loading arrangement. If leakage occurs during disassembly, line pressure must be shut off. Reassemble live loading arrangement in correct order then torque down to the correct torque as shown in Table C.



3. Check if the gland bushing is binding against the packing chamber wall or stem. If so, open valve to backseat position and firmly tighten up on seat. Loosen the packing flange and realign the gland bushing. Tighten up the packing flange a little at a time on each side, then torque down to the correct torque as shown in Table C.
4. After retightening, cycle the valve 3 to 5 times and retighten nuts to original torque value (Table C), slacken the nuts slightly if torque is too high. If Steps 1 to 4 do not stop leakages, proceed with the removal and replacement of packing rings.

## 1.1 Removal of Packing Rings

### Use of Backseat

Normally, it is practical to repack Velan Valves under line pressure as all backseats are lapped and factory-leak tested. However, valve manufacturers in general do not recommend this practice due to the inability of determining the effectiveness of the backseat seal. The decision of the effectiveness basically lies with the user. To backseat a valve it is necessary to open the valve fully and tighten the stem against the backseat firmly.

## 1.2 Removal with Special Tools

1. Remove the packing flange nut and live loading assemblies.
2. Lift packing flange and gland bushing up as high as possible and secure.
3. Remove old packing using special flexible removal tools. The removal tools have special hooks which screw into the packing ring. Removal of the packing rings is a difficult and time consuming operation. Care has to be taken not to scratch the stem or the walls of the packing chamber during the removal of the packing rings.
4. If the valve is equipped with a leak-off pipe there is a lantern ring after the third packing ring. To remove the lantern ring, insert two hooks into the holes at the top of the lantern ring or insert screwed in extracting wires where the tapped holes are provided.
5. After the lantern ring is lifted, the last five packing rings can be removed using the same procedure as described in Step 3.


**Note:** All of our designs can be equipped with a blow-out plug option. If this connection is provided, the packing rings can be removed by apply gas or hydraulic pressure from below as shown schematically in Fig. 9. Proceed as follows.

## 1.3 Removal with Blow-Out - Alternative

1. Fully open the valve and tighten the stem against the backseat firmly.
2. Loosen packing flange nut and live loading assemblies.
3. If valve is equipped with a leak-off pipe, block off connection.
4. Remove blow-out plug and gasket. Attach the pressure source to the connection. The packing rings will be pushed out of the packing chamber.

**Note:** When applying gas pressure, this operation will happen quite quickly and it is possible that trapped liquids will spray out.

5. All packing rings can be removed simultaneously. This is a fast and efficient operation.



## 1.4 Repacking with Uncompressed Packings

1. Velan generally uses three types of packings: braided asbestos reinforced wire with Inconel (e.g. John Crane 187-1) or pre-formed graphite ribbon (e.g. Grafoll) or Teflon (e.g. Chesterton). The repacking procedure is basically the same for all types of packing.
2. Before repacking, check the stem and the packing chamber wall for damage. Scratches no greater than .010" can be removed by polishing the surfaces with a fine emery cloth or special lapping.
3. To insert the first packing ring, squeeze the ring manually and place as deep into the chamber as possible. Fig. 10(a).
4. Insert the split ring and adaptors. Push the packing ring to the bottom of the chamber ensuring that the lap joint does not become reversed during the operation.




Fig. 10(a)

5. Place the gland bushing and packing gland into position and compress the bottom packing by tightening the nuts using the torque shown in Table C Fig. 10(b).
6. Remove the nuts and split packing adaptors, insert the next packing and repeat the procedure as above. **Note:** The split lap joints of each consecutive ring must be staggered at 120° so that the 4th ring installed has its lap back at the starting point (Fig. 10c). Subsequent packing rings are repacked in the same manner until the point is reached whereby the special packing adaptors are not required anymore and the standard gland bushings can be used.




Fig. 10(b)




Fig. 10(c)





Fig. 10(d)

7. Valves with a leak-off pipe connection will require the lantern ring to be inserted after the 5th packing is compressed. Ensure that the lantern ring lines up with the leak-off connection - Fig. 10(d).
8. Insert the next three packings in the same manner as before.
9. Carefully align the gland bushing into the packing chamber and return the packing flange to its correct position. Mount the live loading assemblies in the correct order and tighten packing flange nuts on each side to the recommended torque found in Table C. See Fig. 8(a) and (b) for correct assembly order of live loading parts.
10. Cycle valve at least 5 times from full closed to full opened position, whenever possible under line pressure. After cycling is completed, retighten packing flange nuts to required torque - Table C.

**1.5 Repacking with Pre-Compressed Packings  
Braided Asbestos Packings (Fig. 11)**


1. Braided Asbestos packings can be pre-compressed because of the construction of the packing.
2. When using advanced pre-compressed braided asbestos packing, two packing rings can be installed simultaneously by stagger lapping joints 120° apart. This is considerable time saving and results are very satisfactory.



**Fig. 11**

**Pre-Formed Graphite Ribbon (Fig. 12)**


1. The pre-compressing of graphite ribbon is not required because this packing is already preformed and compressed.
2. Just stagger the two lap joints so that the laps are 120° apart. Two packing rings can be installed simultaneously.



**Fig. 12**

**Packing Placement Sequence**

The installation of graphite ribbon packing in any part of the packing chamber where larger clearances are found; (e.g.) first and last packing, is not recommended. This is due to the possibility that the graphite ribbon will extrude through the clearance provided for the stem. Therefore, Velan recommends braided packings be placed first and last in the packing chamber (Fig. 12a), and if required, the placement of two braided packings at the top and bottom of the lantern ring (Fig. 12b).



## 1.6 Packing Torques

**Step 1:** Clean all studs and nuts. Visually inspect all threads to ensure removal of all foreign matter, rust, corrosion, burrs, and previous lubricants.

**Step 2:** Liberally cover the stud threads and the female threads of the nuts with an antiseize compound of Felpro, type CSA HI-Temp Antiseize compound or approved equal.

**Step 3:** With nuts hand tight, tighten up the packing flange nuts a little at a time on each side, then torque down to the correct torque in accordance with valve type, size, pressure class and type of packing in valve, as shown in Table C.

**Note:** Values given in Table C are approximate for standard Velan Valves. Whenever possible, one should refer to project engineering drawings for particular valve items and their required torques.

**TABLE C**  
**PACKING FLANGE NUT TORQUES**

VALVE SIZE	BRAIDED ASBESTOS				GRAPHITE RIBBON OR TEFLON	
	150	600	900	1500	150	1500
	GATE	GLOBE	GATE	GLOBE	GATE	GLOBE
2 1/2	25	25	40	40	25	25
3	30	30	50	50	30	30
4	40	40	65	65	40	40
6	80	75	150	175	80	75
8	90	110	205	200	90	110
10	100	115	250	245	100	115
12	105		300		105	
14	115		325		115	
16	125		350		125	
18	125		350		125	
20	155		375		155	
24	200		420		200	
26	200				200	
28	200				200	
30	200				200	

**NOTE:** FOR SIZES WHERE NO VALUE IS GIVEN, CONSULT MANUFACTURER.

#### IV(b) Body/Bonnet & Body/Cover Leakage

##### 1.0 General

To maintain the tightness of a factory tested bolted bonnet or cover valve, it is essential that sufficient bolt tension exists at all times by having the proper torque on the nuts. The original torque might be lost due to vibration, relaxation of material caused by frequent temperature and pressure fluctuation of material caused by frequent temperature and pressure fluctuations, or by creep in high temperature application. It is recommended that the gasket joint be inspected for leakage periodically. The tightness of the joint bolt tension should be checked at approximately one year intervals.


##### 1.1 Body/Bonnet & Body/Cover Torquing

The following recommendations in this section are for ideal conditions. However, because of the many interacting tolerances, some latitude must be given in the acceptance standards as follows.

1. The gasket may be fully compressed (e.g.) zero gap between interfaces of the joint at a torque either less than or greater than the torque given in Table D. The following criteria should be used. See Fig. 13.

The bolt torque is satisfactory if:

- a) the gasket is fully compressed at 90% of the recommended bolt torque, provided that 100% torque value is finally applied.
- b) The gasket is fully compressed at 100% torque.
- c) The gap between the interfaces of the joint is no more than 0.003" after 125% torque has been applied and the bolts have been slackened individually and re-torqued to 100% torque.



Dimension 'A' (Inches)	Valve Size	Gasket Size
.085-.090	up to 16" Inclusive	1/8" (nominal thickness)
.125-.135	18" and above	3/16" (nominal thickness)

**Note:** Bonnet machining does not control gasket compression. Any repair to the body recess should maintain the above dimensions.



## 1.2 Torque Procedure

**Step 1:** Clean all studs and nuts. Visually inspect all threads to ensure removal of all foreign matter, rust, corrosion, burrs and previous lubricants.

**Step 2:** Liberally cover the stud threads and surface under the nut head with an antiseize compound of Felpro, type C5A HI-Temp Antiseize compound or approved equal. Also, lubricate the female threads of the nuts and wipe off any excess lubricant that may adhere to any of the stainless steel parts with approved solvents. Approved solvents for this work are:

- a) unused or re-distilled acetone
- b) alcohol
- c) Freon PCA

**Note:** The use of other solvents is prohibited.

**Step 3:** With bolts hand tight, follow the bolt tightening sequence shown in Fig. 14. This sequence is dependent upon the number of bolts employed and the sketch is only an illustration as to possible tightening sequence. The bolts shall be torqued to recommended values in Table D.




Fig. 14

### 1.3 Application of Torque

When applying the torque to the bolts, each bolt should be torqued in steps of approximately 20% of the final torque. It will be found that as the final torque is approached, the required step will become much less than 20%.

**TABLE D**

STUD SIZE	TORQUE VALUES	
	Bolting Material	
	87, 630	660
	100%	100%
3/8-16UNC 7/16-14UNC 1/2-13UNC 9/16-12UNC 5/8-11UNC 3/4-10UNC 7/8-9UNC 1-8UNC	20 30 50 70 95 170 270 410	20 30 45 62 85 150 240 360
1-1/8-8UN 1-1/4-8UN 1-3/8-8UN 1-1/2-8UN 1-5/8-8UN 1-3/4-8UN 1-7/8-8UN 2-8UN	600 845 1150 1520 1955 2475 3075 3765	535 750 1020 1350 1740 2200 2735 3345
2-1/8-8UN 2-1/4-8UN 2-1/2-8UN	4500 5440 7545	4045 4835 6710

**Note:** All values are in ft./lb.

**Precaution:**

1. If tightening sequence is not followed, it is possible that the gasket will not be compressed evenly therefore causing the joint to leak.
2. Over torquing can cause deformation of the bonnet or cover flange and cause the joint to leak.
3. Do not use Impacting device to draw up the bolting on body to bonnet or body to cover closures. There are many satisfactory torquing machines on the market which are useful for large valves.

4. Use standard wrenches – If torque wrenches are not available you can use standard wrenches and the following guideline will apply.

1/2"	-	Bolts	-	6" Wrench
9/16"	-	Bolts	-	9" Wrench
5/8"	-	Bolts	-	12" Wrench
3/4"	-	Bolts	-	18" Wrench
7/8"	-	Bolts	-	24" Wrench
1-1/8"	-	Bolts	-	36" Wrench

On sizes of bolts larger than 1-1/8", special torque multiplier with ratio(s) 1:7 or 1:6 should be used for torquing.

#### 1.4 Replacement of Spiral Wound Asbestos – Stainless Steel

1. The gasket recess seating faces on the body and bonnet must first be checked for scratches, which can normally be removed with an emery cloth. The faces should then be solvent degreased and dried before assembly. Approved solvents are Acetone, Alcohol or Freon PCA.

2. Install the gasket. On valves 4" and larger, it is recommended to lubricate the gasket (Fig. 15) with an approved lubricant such as Neolube or equal to prevent damage to the gasket and seating faces when aligning the heavy bonnet assembly or cover on the body (Fig. 16). The valve is now ready for installation of the bonnet assembly and tightening up of bolting in accordance with the torquing procedure Section IV(b), Para. 1.1. **Precaution:** Valve must not be closed or seated when torquing bolts.




Fig. 15




Fig. 16

## 1.5 Seal Weld Removal

### 1. General

Seal welding of the body-bonnet or body-cover flange joints shall be performed when necessary to prevent leakage. This joint is not intended to carry the mechanical load on the flange due to internal pressure, gasket compression, thermal stresses or stem thrust. All these forces are taken up by the bolting. Bolting must be maintained under torques shown in Table D Section IV(b), Para. 1.3.

### 2. Cutting of the Weld (Fig. 17a)

In order to disassemble a bolted bonnet or cover valve with a seal welded body-bonnet joint, all the nuts and studs must be removed first. Grind off the seal weld using the body flange surface as a guide for the grinding to control the height of engagement.




Fig. 17a

### 3. Preparation for Welding

Before welding, the valve must be drained and the flange lips cleaned with suitable solvent such as Acetone, Alcohol or equal.

### 4. Qualifications

The welding procedure and welder should be qualified in accordance with the requirements of Section IX of the ASME Boiler and Pressure Vessel Code.

### 5. Actual Welding Process (Fig. 17b)

Remove two nuts and studs in sequence as shown in Fig. 17c. This sequence is dependent upon the number of bolts employed. The sketch is only an illustration as to possible welding sequence. After removing two studs, the seal weld should be applied in the area exposed by the removal of the two studs. Complete the seal welding. Before proceeding to weld the next section, reinstall the two stud nuts and torque down in accordance with torque values given in Table D. Continue the same process for the remaining circumference of valve body-bonnet joint.

#### Note:

When the weld is complete, it should be examined by a liquid penetrant method according to the requirements of the recommended codes. Refer to Figs. 17d and 17e.




Fig. 17b




Fig. 17c




Fig. 17d




Fig. 17e

## IV(c) Seat Leakage

### 1.0 General

An indication that a valve leak exists after a valve has been properly closed may be found by observing the pressure loss in the high pressure line side of the valve. In the case of hot water or steamlines, by noting if the downstream pipe remains hot beyond the usual length of time. This type of leak may be the result of a distorted seat caused by improper welding of the valve into the pipeline, or by stress relieving temperatures that may have been used during installation.

Also, leaks can develop by failure to close the valve tightly resulting in a flow through a small opening at high velocity. In spite of the fact that the hardfacing material (e.g. Stellite 6) is corrosion and erosion resistant, it is still possible to form grooves, pit marks or other surface irregularities on the mating faces. Valves which leak should be repaired as soon as possible to prevent greater damage caused by high velocity.

### 1.1 Wedge and Disc Repairs – Gate, Parallel Slide Valves

1. Disassemble valve as described in Section V, Para. 1.1, and inspect the wedge or disc for scratches or damages.

2. If seating faces are scratched they sometimes can be polished with very fine emery cloth on perfectly flat surface.

3. If polishing is not quite sufficient, the wedge must be lapped. Only slight pitting, grooving or indentations not deeper than .005" can be removed by lapping. If defects cannot be corrected by lapping the wedge or disc, they can be ground. Valan recommends that a maximum of only .005" be removed per side. After grinding is done, lap the wedge or disc again.

4. For the lapping, a flat plate, preferably cast iron, should be used and an abrasive lapping compound mixed with olive oil evenly distributed over the plate as shown in Fig. 18. Only light even pressure should be applied on the plate, lifting the wedge or disc as often as possible to prevent accumulation of particles in one area and to allow for proper distribution of lapping compound. The lapping plate position should be turned slightly every few strokes to keep a flat surface. The part should be lapped until seating faces are smooth. Valan recommends the use of Clover Compound (silicon carbide) Grade D or C or an approved equivalent.




Fig. 18

5. Thoroughly clean off the lapping compound with a suitable cleaning fluid such as acetone or alcohol. Do not use chloride or fluoride bearing solvents.

**Precaution:** Lapping may be slow due to the erosion resistant surface, but too much lapping must be avoided.

## 1.2 Seat Repairs – Gate, Parallel Slide Valves

1. Automatic grinding and lapping can be done by one man using one of the following machines.
  - a) Dexter Gate Valve Reseater – Fig. 19
  - b) Unislip Gate and Parallel Slide Valve Grinders – Fig. 20

Both machines can regrind and lap seats within one hour by one man. These machines can be mounted directly onto a valve which is already welded in the pipeline. Both machines automatically set themselves to the correct seat surface angle. These two types of machines are available for different sizes of valves and are suitable for almost all of Velan's gate and parallel slide valves.




Fig. 19




Fig. 20

Model 2000N will regrind gate valves 2½"–4".

Model 4000N will regrind gate valves 4½"–8".

Model 8000N will regrind gate valves 8½"–12".

Air motor operates at 90 PSI pressure (recommended).

Special Valve Reseating Machines can be furnished for Valve Sizes over 12" upon request.

2. If the automatic grinding and lapping machine is not available, seat faces must be repaired by using a lapping plate, cast iron if possible, and large enough to cover the face of the seat (Fig. 21). Apply lapping compound mixed with olive oil and evenly distribute on plate. Lap seat by moving lapping plate in a circular motion on seat face. Lift the plate as often as possible to prevent accumulation of particles in one area and to allow for proper distribution of the lapping compound. Lap until both seats have smooth faces and then clean off the lapping compound very thoroughly with a suitable cleaning fluid such as acetone or alcohol.




Fig. 21

**Precaution:** Do not remove too much hard-facing deposit material because the seat cannot be replaced when valve is in pipe system.

### 1.3 Fitting of Repaired Parts – Gate, Parallel Slide Valves

1. After the seating faces of the wedge, discs or seats have been relapped and cleaned, a blueing test is recommended before reassembly. A blueing ink should be placed smoothly and equally over the full circumferential surface of both sides of the wedge or discs (Fig. 22). Place the marked up side of the wedge or disc together with the marked up side of the seat. Slowly lower the part into the body and find the correct mating point of the faces.




Fig. 22



2. If a part cannot be repaired, new parts must be fitted and installed. All spare part wedges are supplied slightly oversized. They must be ground and lapped as much as needed in order to fit over the full circumference of the seat. Refer to Fig. 23.

**Note:** If the outside diameter of hardface and top and bottom face-to-face dimensions of the old wedge are given, it is possible that there will be very little lapping or fitting required at the site when replacing the part.




Fig. 23

3. In some cases it is possible that the seat angle is lost when grinding the seat in the body. Therefore, one must shim the wedge while grinding it. Shim only as much as required to have a full fit over the full circumference of the seating faces. Fig. 24a illustrates a wedge with a full seating circumference. This must be achieved whenever fitting a wedge.
4. When fitting a wedge, it is also important that the wedge guide slot has sufficient clearance to allow the wedge to move freely along the wedge guide, as shown in Fig. 24b.




Fig. 24a




Fig. 24b

#### 1.4 Seat Repairs – Globe, Needle, Stop, Piston Check Valves

1. Disassemble the valve as described in Disassembly Section V, Para. 1.1, and inspect the disc and seat for scratches, pitting marks or other damages.
2. Where indentations or pitting marks are deeper than .010", a cast iron lapping disc – Fig. 25 (a), with the proper seat angle must be used with a suitable lapping compound to roughen the surface first. With the use of a new or already pre-finished original disc – Fig. 25 (b), you can use a finer lapping compound to finish lapping the disc and seat together.

**Important:** A guiding plate for the stem is required to maintain alignment during the lapping operation – refer to Fig. 25 (b). It can be made from wood or any suitable material to the same gasket dimensions as the bonnet. The section of the plate where the stem extends through is to be made 1/64" larger than the outside diameter of the stem.

3. Place a small quantity of lapping compound mixed with olive oil and evenly distribute on the two mating surfaces.
4. It is important to apply slight pressure when lapping seats and to rotate in reciprocally. For best results, use an air or electric hand tool with adjustable speed and reciprocal movement. The lap should be lifted frequently and turned to a new starting position so that the lapping will be rotated over a new area.
5. In order to assure that the pressure is applied evenly, it is necessary, on some valves, to suspend the disc and stem assembly from a coil spring in such a manner as is shown in Fig. 25 (a).




Fig. 25 (a)





Fig. 25 (b)

6. Automatic grinding and lapping can be done by one man using the same machines, possibly a different model, as mentioned in Para. 1.4.

a) Dexter Globe Valve Reseater, Fig. 26.


b) Unislip Globe and Safety Valve Grinders, Fig. 27.

Both machines can regrind and lap a seat within one hour by one man. These machines can be directly mounted onto a valve which is already welded in the pipeline. Both machines can be supplied with different grinding heads or discs to refinish any one of Velan's globe seat angles. These two types of machines are available for different sizes of valves and are suitable for almost all of Velan's globe, needle, stop check or piston check valves.



**MODEL 400**  
for Globe-Type Valves

**Fig. 26**



**Fig. 27**

Model 400 will regrind globe valves 4" to 12".  
(Model 100R will regrind globe valves 2 1/2" to 4".

## 1.5 Fitting of Repaired Parts – Globe, Stop Check, Piston Check Valves

1. After the seating faces of the disc and seat have been relapped and cleaned with a suitable cleaning fluid such as acetone or alcohol, it is essential that the results of the lapping be verified by a blueing test to check for full circumferential contact. A blueing ink should be placed smoothly and equally over the seating diameter of the disc. Slowly lower the part into the body and find the correct mating point of the faces. Fig. 28a illustrates a disc with a full seating circumference. This must be achieved whenever fitting a disc.




Fig. 28a

2. When fitting the disc, it is also important that the body inside diameter be checked for sufficient clearance to allow the disc to move freely up and down. It is recommended to make a visual examination of the body wall. Any groove or scratches should be polished with a fine emery cloth.

3. Verification of contact between the valve disc and the stem is made by a radius on the end of the valve stem and is designed to give center loading for the disc as close as possible. A hard thrust pad, Fig. 28b, which can be found in some designs will help prevent galling. On valves without a thrust pad, the bearing surface in the disc has a hardface deposit on it, Fig. 28c. If particles get between the end of the valve stem and the disc, the center loading of the stem can be destroyed and the disc will not seat tightly.

The contact surfaces of the stem and the disc must be checked first in leaky valves in order to ensure that the disc-stem contact is in proper condition.




Fig. 28b




Fig. 28c

## 1.6 Disc Repairs – Swing Check

1. Disassemble the valve as described in the disassembly Section V, Para. 1.5, and inspect the disc and seat for scratches, pitting marks or other damages.
2. If the seating face of the disc is scratched, it can sometimes be polished with a very fine emery cloth on a perfectly flat surface.
3. If polishing is not quite sufficient, the disc must be lapped. Only slight pitting, grooving or other indentations not deeper than 0.010" can be removed by lapping. If defects cannot be corrected by lapping, the disc can be ground but Velan recommends the only a maximum of 0.020" be removed. After grinding is completed, lap the disc.
4. For the lapping, a flat plate, preferably cast iron, should be used and the abrasive lapping compound mixed together with olive oil and evenly distributed over the plate as shown in Fig. 29. Only light even pressure should be applied when the disc is moved in a circular motion on the plate, lifting the disc as often as possible to prevent accumulation of particles in one area and to allow for proper distribution of the lapping compound. The lapping plate position should be turned slightly every few strokes to keep a flat surface. The part should be lapped until seating faces are smooth.




Fig. 29

5. Thoroughly clean off the lapping compound with a suitable cleaning fluid such as acetone or alcohol. Do not use chloride or fluoride bearing solvents.

## 1.7 Seat Repairs – Swing Check

If repairs are required on the seat of a swing check, the procedure is the same as described in Para. 1.2 on seat repairs – gate, parallel slide valves. The only difference between these seats is the angle of the seat face. One can repair with an automatic grinding or lapping machine or by the use of the manual method.

## 1.8 Fitting of New Disc – Swing Check

When damage on the disc seating face cannot be removed by grinding or lapping, the disc must be replaced. All new discs coming from the factory are already ground and should be lapped before installation. See installation procedures described in Reassembly of Swing Check, Section VI, Para. 1.5.

## 1.9 Backseat Repairs

1. All of the following valves are equipped with an integral or welded in backseat in the bonnet (Fig. 30).
  - a) Gate Valve
  - b) Parallel Slide Valve
  - c) Globe Valve
  - d) Needle Valve
  - e) Stop Check Valve

The above list of valves have a stem with a backseat shoulder. This should sit perfectly against the bonnet backseat to make a perfect seal. It is possible that this seal may leak due to many reasons (e.g. scratches or pitting). Therefore, this seal must be repaired by relapping the mating faces.




Fig. 30

2. Dismantle the valve in accordance with valve disassembly procedures found in Section V, Para. 1.2.
3. Place the bonnet and stem upside down as shown in Fig. 31 and insert two or three packing rings in the packing chamber to serve as a guide for the centralizing of the stem to the backseat. Add a fine mixture of lapping compound and olive oil between the two mating faces. Gently rotate the stem to a new position circularly around the backseat so that lapping will be rotated over a new area. This can be done by hand or with a suitable air or electric tool.




Fig. 31

**Note:** On larger valves, stem must be supported so that the weight of the stem does not cause a groove or galling on the backseat.

4. After the lapping procedure is finished, all lapping compound must be removed with a suitable cleaning fluid such as acetone or alcohol.
5. It is recommended that the lapping procedure be verified for full contact by blueing one of the two faces. After verification is done the surfaces must be cleaned again.

## **V DISASSEMBLY**

### **1.0 General Disassembly**

There are two basic methods by which Velan Valves can be disassembled.

- a) A total disassembly – see Fig. 32.
- b) A partial disassembly to allow access to the area which requires maintenance.

The decision on which method to use depends on the nature of the problem and the space availability.

First, determine where the problem lies. Maintenance problems for these valves can be divided into three major areas.

**Area 1** – Valve internal problems, spiral gasket, wedge, disc, seat, etc.

**Area 2** – Valve mid-section, stem, torque arm, gland bushing, etc.

**Area 3** – Valve top works, handwheel or operator, etc.

**Caution:** Make sure all pressure has been relieved from both sides of the valve before any specific disassembling work is started. Exceptions to this caution are noted below.

#### **Area 1 Service**

Line pressure must be relieved with no exception.


#### **Area 2 Service**

Line pressure must be relieved with exception to torque arm removal with yoke-bonnet body intact.

#### **Area 3 Service**

Line pressure can remain in valve. Valve must be fully opened and backseated. The upward force on the stem due to pressure in the line will keep the stem on the backseat.





**Fig. 32**  
**Typical Exploded View Gate Valve**

## 1.1 Disassembly Area 1 – Valve Internal Problems

The disassembly instructions that are described below will cover three of Velan's basic valve designs – Gate, Globe and Stop-Check. As a general disassembly process, place matching marks on parts so that the same orientation of parts can be maintained as reassembly.

Refer to Figures 2, 3, 4 and 5.

1. The valve should be in a partially open position.
2. Before proceeding with disassembly of valves, check if the valve is equipped with a leak-off pipe option (7). If so, then disconnect first. Leak-off pipes should be cut approximately 6" from the bonnet side and not at the welded joint on the bonnet.
3. Remove body-bonnet nuts (6).

**Note:** If a valve has been in high temperature service for extensive periods of time, the nuts sometimes become seized to the stud. Tight nut threads can sometimes be loosened by applying penetrating oil or applying heat to the nut and working it free. As a last resort, a hacksaw, a cutting torch or cold chisel can be used to cut nut away from stud.

4. Once all the nuts are removed, the entire yoke-bonnet assembly can be lifted from the valve body as shown in Fig. 33a and Fig. 33b.

**Note:** When lifting the yoke-bonnet assembly, care should be taken to prevent internal parts from disengaging from the stem. (e.g.) The wedge (36) is attached to the stem (3) with a T slot and as soon as it is disengaged from the guides in the body, it can slip off the stem. Make certain that wedge is match marked.

5. Remove used spiral wound asbestos stainless steel gasket (4).
6. The valve is now ready for inspections and repairs of wedge, disc, seat, etc.
7. During inspection check the body-bonnet stud (5) for damage. Studs may have been damaged when removing seized nuts or when lifting the yoke-bonnet assembly. If studs are damaged, remove and replace them.
  - a) Screw on the two nuts.
  - b) Lock the bottom nut to the top nut.
  - c) Turn the bottom nut to remove the stud.
  - d) Take the new stud and apply antiseize compound to it. See Section III, Para. 1.1 for recommended compound.
  - e) Screw in the stud and tighten.

- |                      |                            |                              |
|----------------------|----------------------------|------------------------------|
| 1 - BODY             | 13 - GLAND BUSHING         | 25 - BEARING                 |
| 2 - BONNET           | 14 - PACKING FLANGE        | 26 - YOKE NUT                |
| 3 - STEM             | 15 - GUIDE SLEEVE          | 27 - HOUSING COVER           |
| 4 - SPIRAL GASKET    | 16 - BELLEVILLE WASHER     | 28 - GREASE FITTING          |
| 5 - BODY-BONNET STUD | 17 - PACKING FLANGE STUD   | 29 - HANDWHEEL               |
| 6 - BODY-BONNET NUT  | 18 - PACKING FLANGE NUT    | 30 - HANDWHEEL KEY           |
| 7 - LEAK-OFF PIPE    | 19 - TORQUE ARM            | 31 - HANDWHEEL NUT           |
| 8 - BLOW-OUT PLUG    | 20 - TORQUE ARM CAP SCREW  | 32 - HANDWHEEL NUT SET SCREW |
| 9 - BLOW-OUT GASKET  | 21 - TORQUE ARM KEY        | 33 - YOKE HOUSING CAP SCREW  |
| 10 - JUNK RING       | 22 - TORQUE ARM BEARING    | 34 - SEAT                    |
| 11 - PACKING RING    | 23 - YOKE                  | 35 - WEDGE GUIDE             |
| 12 - LANTERN RING    | 24 - YOKE-BONNET CAP SCREW | 36 - WEDGE                   |




Fig. 33(a)  
Gate Valve

- |                      |                            |                             |
|----------------------|----------------------------|-----------------------------|
| 1 - BODY             | 15 - GUIDE SLEEVE          | 27 - HOUSING COVER          |
| 2 - BONNET           | 16 - BELLEVILLE WASHER     | 28 - GREASE FITTING         |
| 3 - STEM             | 17 - PACKING FLANGE STUD   | 29 - HAMMER WHEEL           |
| 4 - SPIRAL GASKET    | 18 - PACKING FLANGE NUT    | 30 - HAMMER WHEEL KEY       |
| 5 - BODY-BONNET STUD | 19 - TORQUE ARM            | 31 - HAMMER WHEEL NUT       |
| 6 - BODY-BONNET NUT  | 20 - TORQUE ARM CAP SCREW  | 32 - HAMMER WHEEL SET SCREW |
| 8 - BLOW-OUT PLUG    | 21 - TORQUE ARM KEY        | 33 - YOKE HOUSING CAP SCREW |
| 9 - BLOW-OUT GASKET  | 22 - TORQUE ARM BEARING    | 37 - DISC                   |
| 10 - JUNK RING       | 23 - YOKE                  | 48 - STEM COLLAR            |
| 11 - PACKING RING    | 24 - YOKE-BONNET CAP SCREW | 49 - DISC UNION             |
| 13 - GLAND BUSHING   | 25 - BEARING               | 50 - THRUST PAD             |
| 14 - PACKING FLANGE  | 26 - YOKE NUT              |                             |




Fig. 33(b)  
Globe Valve

8. If the type of valve you are disassembling is a globe or needle valve (Fig. 34), the stem (3) and disc (37) will come out in one piece with the yoke-bonnet assembly. This can be disassembled with the stem remaining in the yoke-bonnet assembly or the stem and disc assembly can be removed. For removal of stem, see Disassembly Area 2.
9. The connection between the stem (3) and the disc (37) is made by the use of a disc union (49) and the stem collar (48). To remove this connection, break the tack welds by using a saw or a small sharp chisel.




Fig. 35




Fig. 34

10. After the tack welds are removed, unscrew the disc union from the disc, pull the disc off the stem and remove the stem collar (two pieces) from the stem. Check inside the disc. Some discs will have a hardfacing deposit at the bottom centre or they will have a small thrust pad (50).
11. Now the disc can be repaired or replaced.
12. If the type of valve you are disassembling is a stop check, refer to Fig. 5, the stem is not attached to the disc. The disc (37) and spring (38) must be lifted from the valve body after the yoke-bonnet assembly has been removed. See Fig. 35.


## 1.2 Disassembly Area 2 Valve Mid-Section – Gate, Globe, Stop-Check

The disassembly instructions that are described below will cover the removal of stem and torque arm as long as the valve has been disassembled in accordance with the disassembly procedures found in Disassembly Area 1.

1. Remove packing flange nut (18) and live loading option.

**Note:** If the valve is equipped with a live loading option, such as guide sleeves (15), Belleville washers (16) as shown in Figs. 8a and 8b, one must make note of the order of these parts so that at reassembly, the parts will return in the same order.

- 2a. Remove torque arm. There are two types of torque arms. Type I (Fig. 36) is a one piece torque arm and Type II (Fig. 37) is a two piece torque arm which can be removed under line pressure.



- 2b. Removal of Type I, loosen capscrew (20), and remove. Slide torque arm (19) up along stem and remove torque arm key (21) from stem. Torque arm will not come off at this point, but you must make sure that the torque arm slides free over the stem.
- 2c. Removal of Type II, loosen hex nuts (c) and pull torque arm apart and remove torque arm key (21) from stem. Torque arm will come totally off assembly at this point.

3. Remove packing rings (11) in accordance with Section IV(a), Para. 1.1 – Removal of Packing Rings.
4. Remove stem (3) by turning it out of the yoke nut (26). When the stem is disengaged from the yoke nut, pull the stem out through the bottom of the yoke-bonnet assembly.

**Note:** When removing the stem, Type I, torque arm (19), packing flange (14), gland bushing (13), lantern ring (12) and junk ring (10) will be free and can be removed from the assembly.

5. The valve and parts are now ready for inspection, repairs and replacement of stem, torque arm etc.

### 1.3 Disassembly Areas 1 and 2 – Parallel Slide Valve – Valve Internal & Mid-Section Problems

Refer to Fig. 3.

The disassembly instructions that are described below will cover two of Velan's basic Parallel Slide Valve designs.

1. The valve should be in a partially open position.
2. Before proceeding with disassembling of valves, check if the valve is equipped with a leak-off pipe option (7). If so, disconnect this first. Leak-off pipes should be cut approximately 6" from the bonnet side and not at the welded joint on the bonnet.
3. Loosen packing flange nuts (18) and remove packing rings (11) in accordance with Section IVa, Para. 1.1, Removal of Packing Rings.
4. One of Velan's Parallel Slide Valve designs has a stroke limiter (45) mounted on the top of the valve stem as shown in Fig. 38. The important point one must note is the distance the stud (47) extends out of the stroke limiter (45) as shown in Fig. 38. This distance regulates the position of the two discs in this style of Parallel Slide Valve.




Fig. 38

5. After the distance has been noted, remove stroke limiter (45).
6. Remove the small handwheel nut set screw (32) in handwheel nut (31) before removing handwheel nut and then unscrew handwheel nut.
7. After the handwheel nut has been removed, pull off the handwheel (29).
8. Loosen and remove housing cover bolting (33). Lift housing cover (27) up over yoke nut (26) and stem (3).
9. Remove first set of bearings (25), (3 pieces).
10. Unscrew yoke nut (26) from stem (3).
11. After the yoke nut has been removed, remove second set of bearings (25), (3 pieces).
12. Remove body-bonnet nuts (6).
13. Once all the nuts are removed, the entire yoke-bonnet assembly can be lifted from the valve body as shown in Fig. 39.

**Note:** When lifting the yoke-bonnet assembly, the stem and discs must stay in the valve body. It is possible that the springs, which are between the two discs, could fall into the valve body. One must be careful of not allowing the discs to open up.




Fig. 39


14. Before removing the discs from the stem, note the orientation of the discs with respect to the torque arm keyway in the stem. Each disc has an identification mark on it which corresponds to an equivalent mark on a seat in the body. These seats and discs must be mated when reassembling.
15. For removal of the stem and discs, use a parallel slide disc clamp. Fig. 40 shows the general principle of the clamp.

Adjusted screws (1) should be slackeden (counter-clockwise rotation) sufficiently to allow the tips of the arm (2) to be placed over the two discs. The tips should be placed slightly below the centreline of the discs. Tighten the adjusting screws until the discs are free from seats. Now lift total stem, discs and clamp out of the valve body.


16. (a) **Style I Fig. 41**

Disassemble discs from the stem. The lock brackets (40) must be opened by prying the tab upwards. The discs (39) can be removed for lapping, if required, by removing bolt (41) and nut (42).

**NOTE:** If the bolt and nut are removed, carefully store the springs (43) and centering piece (44). These should be identified for the valve size involved.



**Fig. 40**



**Fig. 41**



16. (b) Style II Fig. 42

Disassemble discs from the stem and disengage the stem (3) from the disc carrier (51) by pushing stem T out of slot in the disc carrier. Remove the disc retainer (52) and disc will spring apart. Carefully store the springs (43). These should be identified for the valve size involved.




Fig. 42

17. The valve is now ready for inspection and repairs of seat, disc, stem, etc.

#### 1.4 Disassembly Area 3 – Valve Top Works

The disassembly instructions that are described below will cover four of Velan's basic valve designs (Gate, Globe, Stop-Check, Parallel Slide).

1. If line pressure is maintained in the valve, backseat the valve in full open position before starting any disassembly in Area 3.

2. Remove small set screw (32) in handwheel nut (31), then unscrew handwheel nut.

**Note:**

Important – see Step 4 of Section V, Para. 1.3, Disassembly Area 1 and 2 Parallel Slide Valve, before removing stroke limiter. If the type of valve you are disassembling is a parallel slide, Style I, remove stroke limiter (45) at the top of the stem.

3. Remove handwheel (29).
4. Remove housing cover bolting (33) and remove housing cover (27).
5. Remove first set of bearing (25) (3 pieces).
6. Unscrew yoke nut (26) from the stem (3).

7. After the yoke nut has been removed, remove second set of bearings (25).

8. Now valve and parts are ready for inspection, repairs and replacement of yoke nut, bearing, etc.




Fig. 43

## 1.5 Disassembly Area 1 - Check Valves Valve Internal Problems

1. Remove body-cover nuts (4).
2. Once all the nuts are removed, the cover (2) and spiral gasket can be lifted from the valve body as shown in Fig. 44.
3. The valve is now ready for inspection. At this point of the disassembling procedure, inspect the rotation of the disc on the hanger alignment between the disc and seat. Ensure that the hanger has free movement and is not seized or cannot be restricted by any internal part.
4. After inspecting all points mentioned above, remove all internal parts by unfolding the lock bracket or tab washer (11) around the hex HD bolt (10) in body.
5. After hex HD bolts (10) have been removed, the internal assembly can be lifted from the body.

### Note:

Velan has four major styles of swing checks.

- a) Style I Fig. 45 (a) (b)
- b) Style II Fig. 46 (a) (b)
- c) Style III Fig. 47 (a) (b)
- d) Style IV Fig. 48 (a) (b)

All four styles can be disassembled in the same manner.

6. If the type of valve you are disassembling is a piston check, refer to Fig. 44. The disc (6) and spring (17) must be lifted from the valve body after the cover has been removed.




Fig. 44

6. (a) Style I, Fig. 45 (a) (b)

Hanger Pin (9) can be pushed out of hanger (7) and hanger bracket (14). Hanger will disengage from hanger bracket. There are four bushings (8) in this style. Two bushings in the hanger and two in the bracket.




Fig. 45 (a)




Fig. 45 (b)

6. (b) Style II, Fig. 46 (a) (b)

Push hanger pin (9) out of the hanger (7). Remove two washers (19) from the pin. Push bushing (8) out of hanger.




Fig. 46 (a)





Fig. 46 (b)


6. (c) **Style III Fig. 47 (a) (b)**

Hanger Pin (9) can be pushed out of the hanger (7) and hanger ring (14). Hanger will disengage from hanger ring. There are four bushings (8) in this style - two bushings in the hanger and two in the hanger ring.

**Fig. 47 (a)**




**Fig. 47 (b)**



6. (d) **Style IV Fig. 48 (a) (b)**


Push hanger pin (9) out of hanger ring (14) and hanger (7). Push bushing (8) out of hanger (8).

- To remove disc (6) from hanger (7), remove cotter pin (13) from disc nut (12). Unscrew disc and remove disc washer (18) and disc (6). Now all parts are ready for inspection and repairs of disc, seat, bushing, etc.



**Fig. 48 (a)**

**Fig. 48 (b)**



## VI REASSEMBLY

### 1.0 General

The reassembly procedures are not as detailed as the disassembly procedures since, in most cases, the reverse procedure is required.

1. The most important fact to be considered is the cleanliness of all parts. All rust and dirt should be removed from all parts with a wire brush or emery cloth. Oil and grease should have been removed with suitable solvents.
2. All threaded parts (capscrew, nuts, studs) must be well re-lubricated. The stem and yoke nut threads should be clean of old grease before a new application of grease is applied to the threads. All recommended lubricants can be found in Section III, Para. 1.1.

**Note:** Use correct lubricant for each individual part.

3. Repaired or replacement parts must be checked to see if all repair procedures have been done and that all replacement parts (e.g. packing rings, spiral gasket, etc.), have been checked for size so that they will fit into the valve you are servicing.
4. All orientation marks assigned during disassembly must be observed so that correct orientation is maintained.

### 1.1 Reassembly Area 3 - Valve Top Works

The reassembly procedures in Area 3 are, in most cases, the reverse procedure of Disassembly Area 3.

1. Apply new grease to threaded portion of stem (3) above top flange on yoke (23).
2. Mount second set of newly greased bearings (25) in recess of yoke.

**Note:** Bottom race must fit loosely around yoke nut and top race must be tight around yoke nut. See Fig. 49.

3. Apply new grease to internal thread in yoke nut (26) and turn yoke nut on stem.
4. Mount first set of newly greased bearings (25) on yoke nut.

**Note:** Bottom race must fit tightly around yoke nut and top race must be loose.




Fig. 49

5. After the bearing and yoke nut are in place, mount housing cover (27) on top. Tie down housing cover with the use of housing cover bolting (33). Bolting must be torqued down in accordance with torque values found in Table E.
6. Insert handwheel key (30) in keyway in yoke nut and mount handwheel (29).
7. Return handwheel nut (31) and tighten. Use handwheel nut set screw (32) to lock handwheel nut in place.
8. Inject more new grease into housing cover by the use of grease fitting found on side of housing cover.
 

**Note:** If the type of valve being reassembled is a parallel slide, return stroke limiter (45) to the top of the stem.  
**Important:** The distance the stud extends out of the top of the stroke limiter must be the same as noted when disassembling valve.
9. Verify operation by cycling at least once from fully open to fully closed position.

#### 1.2 Torque Values – Operator, Yoke/Bonnet Bolting

The torque values given in Table E are for all other bolting except body-bonnet, body-cover or packing flange stud.

**TABLE E**

	TORQUE VALUES	
Thread Size	Bolting Material	
	B7, A-574, 630	B8, B8M
3/8-16UNC	30	10
7/16-14UNC	45	15
1/2-13UNC	75	25
9/16-12UNC	105	35
5/8-11UNC	145	50
3/4-10UNC	255	85
7/8- 9UNC	405	135
1- 8UNC	615	205
1-1/8- 8UN	900	300
1-1/4- 8UN	1270	425
1-3/8- 8UN	1725	575
1-1/2- 8UN	2280	760
1-5/8- 8UN	2935	980
1-3/4- 8UN	3715	1240
1-7/8- 8UN	4615	1540
2- 8UN	5650	1885

### 1.3 Reassembly Areas 1 and 2 – Valve Internal & Mid-Section Gate, Globe, Stop-Check Valves

The reassembly instructions that are described below will cover three of Velan's basic valve designs (gate, globe, stop-check). The reassembly procedures in Areas 1 and 2 are, in most cases, the reverse procedures of Disassembly Areas 1 and 2.

#### 1. (a) Gate Valve Fig. 33(a)

Place wedge on T-head of stem making sure that the marked up side of the wedge mates with the marked up seat in the body. This is extremely important on valves with welded in seats to ensure optimum sealing.

#### (b) Globe Valve Fig. 34

Install small thrust pad (50) into disc so that it fits into recess in bottom of disc (37). Place stem collar (48) around groove on stem (3). Install stem and stem collar in disc and tighten down with disc union. Check if disc can be rotated. If disc can be rocked, it is correctly installed on stem. The rocking will allow the disc to self-align itself to the seat.

Tack weld disc union to disc in three or four places depending on the valve size. Check again to see if the disc can rock after tack welding has cooled.

#### (c) Stop-Check Valve Fig. 35

Insert disc (37) into valve body and then insert spring (38) into disc.

2. Insert stem through the bottom of the bonnet placing junk ring (10), with the knurled side downward into the packing chamber. The lantern ring (12), gland bushing (13), packing flange (14), and Type I torque arm (19) must be in correct positions before turning stem into yoke nut (26).

**Note:** Turn stem into yoke nut one turn only and then apply new grease to thread portion of stem below top flange of yoke. After new grease has been applied, turn stem into the yoke nut until approximately one inch of stem extends out of top of yoke nut.

3. Place new spiral gasket in recess on top mounting face of body, follow cleanliness and lubrication instruction as described in Section IV(b), Para. 1.4
4. Line up bonnet-yoke assembly with body and lower onto the body. It is extremely important to prevent the gasket from getting damaged when aligning a heavy bonnet assembly on the body.
5. Apply recommended lubricant to the body-bonnet (5) stud and then install body-bonnet nuts (6). Tighten body-bonnet nuts in strict accordance with Section IV(b), Para. 1.2.

**Caution:** Do not tighten body-bonnet nuts when wedge, disc, etc., is in fully closed position.



6. Mount packing flange nut (18) and live loading option and torque down in accordance with Section IV(a), Para. 1.6

**Note:** If the valve is equipped with a live loading option, live loading parts must return in the same order as noted in disassembly.

7. Mount torque arm on stem (3) and make sure the key (21) is fitting properly in the stem and torque arm keyway.
8. Verify operation by cycling at least three times from fully opened to fully closed position.

#### 1.4 Reassembly Areas 1 and 2 – Parallel Slide Valves Valve Internal and Mid-Section

The reassembly instructions that are described below will cover Velan's basic parallel slide valve designs.

##### Refer to Fig. 41 Style I

1. a) Install the three springs (43) and centering piece (44) into the respective holes in the discs (39). Slip T-head of stem (3) into the machined grooves.

**Note:** The discs should be orientated about the torque arm keyway as noted during disassembly.

Insert the bolt and lock bracket. The two discs should be pressed together against the stem with the bolt head firmly pressed against its lock bracket, thread nut on to the bolt until there is a gap of .060-.070 between the nut and the lock bracket. Lock both brackets.

##### Refer to Fig. 42 Style II

1. b) Install the springs (43) into the respective holes in the discs (39).  
Install disc into the disc carrier (51), use disc retainer (52) and lock disc (39) into place. Discs shown have a gap of .060"-.070" between them.

The discs are now assembled with the proper "float" allowance.

Slide T-head on the stem(3) into T-slot on top of disc carrier (51).

2. In order to assemble some valves it is necessary to use a clamp to keep the discs together when guiding them into the seats. Refer to Fig. 40.
3. With the clamp in place, the discs can be lowered into the seats. As soon as the discs are engaged in the seats (about 1"), the clamp can be removed. The discs can now be inserted fully into the seats by means of the stem.
4. Place new spiral gasket in recess on top mounting face of body. Follow cleanliness and lubrication instruction as described in Section IV(b), Para. 1.4. Refer to Fig. 39.

5. Line up the bonnet-yoke assembly with the body and lower onto the body. It is extremely important that one prevents the gasket from becoming damaged when aligning the heavy bonnet assembly onto the body.

**Note:** When lowering the bonnet-yoke assembly, place the junk ring (10) with the knurled side downward into the packing chamber. The lantern ring (12), gland bushing (13), packing flange (14), and Type 1 torque arm (19) must be in correct positions before stem enters top flange on yoke.

6. Apply recommended lubricant to body-bonnet studs (5) and then install body-bonnet nuts (6). Tighten body-bonnet nuts in strict accordance with Section IV(b), Para. 1.2.

**Caution:** Do not tighten body-bonnet nuts when discs are in a fully closed position.

7. Now continue step-by-step reassembly procedures as described in Section VI, Para. 1.1 – Reassembly Area 3.

8. Repack valve in accordance with Section IV(a), Para. 1.4.

9. Mount packing flange nut (18) and live loading option and torque down in accordance with Section IV(a), Para. 1.6.

**Note:** If the valve is equipped with a live loading option, live loading parts must return in the same order as noted in disassembly.

10. Mount torque arm on stem and make sure the key is fitting properly in the stem and torque arm keyway.

11. Verify operation by cycling at least three times from fully open to fully closed position.

## 1.5 Reassembly Area 1 – Check Valves

### Valve Internal

1. Mount disc (6) on hanger (7), tighten disc nut (12) and lock in place with cotter pin (13). Check if disc can rotate freely on hanger.

2. a) **Style I, Figs. 45 (a) (b)**

Place two bushings (8) in hanger and two bushings in hanger bracket (14). Insert hanger pin (9) into hanger (7) and push pin through the hanger bracket into opposite side of hanger.

- b) **Style II, Figs. 46 (a) (b)**

Push bushing (8) into hanger and insert hanger pin (9) into bushing. Place one washer on each side of hanger pin.

**c) Style III, Figs. 47 (a) (b)**

Place two bushings (8) in hanger and two bushings in hanger ring (14). Insert the hanger pin (9) into the hanger (7) and push pin through the hanger ring to the opposite side of the hanger.

**(d) Style IV, Figs. 48 (a) (b)**

Push bushing (8) into the hanger (7) and insert the hanger pin (9) into the hanger ring (14). Push pin through the bushing to the opposite side of the hanger ring.

3. Place entire assembly carefully back into the body making sure that the hanger pin can move freely in an axial direction.
4. Insert lock bracket or tab washer (11) and tighten down with hex bolts (10). Lock the bolts by turning up the ears on the lock brackets.
5. After installation is finished, check the rotation of the disc on the hanger and the alignment between the disc and seat.
6. With regard to the piston check valve (Fig. 44), insert the disc (6) and the spring (17) back into the valve body.
7. Place the new spiral gasket (5) in the recess on the top mounting of the body. Follow cleanliness and lubrication instruction as described in Section IV(b), Para. 1.4.
8. Line up the cover with the body and lower onto the body. It is extremely important to prevent the gasket from becoming damaged when aligning the heavy cover to the body.
9. Apply the recommended lubricant to the body-cover studs (3) and then screw on the body-cover nuts (4). Tighten the body-cover nuts in strict accordance with Section IV(b) Para. 1.2.


## APPENDIX A

### 1.0 Procedure for Removing Manual Gear Actuator

Velan valves can be equipped with a variety of manual gear actuators. Actuators of this type come in two main styles.


#### a) Style I (Fig. 50)

Applications where only rotary torque is required.



#### b) Style II (Fig. 51)

Applications where both rotary torque and linear thrust are required.



Generally, all pressure must be relieved from both sides of the valve before removal of the manual gear actuator is started. Exceptions to this rule can be found when valves have a self-contained thrust unit.

**Important:** Determine the style actuator that is mounted on the valve you are servicing. If it is not possible to determine the style of actuator, it is best to refer to the actuator manufacturer's maintenance and instruction manual or get in touch with your local Velan representative for more technical assistance.

### 1.1 Removing Style I - (Fig. 52)

1. With the Style I manual gear actuator, the valve will be equipped with a self-contained thrust unit. This actuator can be removed under line pressure.
2. Remove housing-actuator bolting (56).
3. Using a hoist, raise the actuator (53) above the stem (3) and yoke nut (26).
4. For repairs to the actuator, refer to the manufacturer's maintenance and instruction manual. If there is further work to do on the valve, refer to the proper valve disassembly and maintenance section in this manual.
5. The disassembly of the self-contained thrust unit will follow the same procedure as described in Area 3 Valve Top Works.




Fig. 52

## 1.2 Removing Style II – (Fig. 53)

1. With the Style II manual gear actuator, the actuator will be equipped with a self-contained thrust unit and will be removed with the actuator. Therefore, this actuator cannot be removed under line pressure. The pressure must be relieved.
2. The valve should be in a partially open position.
3. Make sure that the packing flange nuts (18) are tight.
4. Remove the yoke-actuator bolting (56).
5. Turn the actuator handwheel to close the valve. This will cause the actuator (53) to rise and unthread from the valve stem. As this takes place, the weight of the actuator should be supported by a hoist to prevent any damage to the stem thread or any internal part of the valve.
6. For repairs to the actuator, refer to the manufacturer's maintenance and instruction manual. If there is further work to be done on the valve, refer to the proper valve disassembly and maintenance section in this manual.




Fig. 53

## APPENDIX B

### 1.0 Procedures for Removing Motor Actuator

Velan valves can be equipped with a variety of electrical motor actuators. Motor actuators are mounted through two different methods. Some units are directly attached to the yoke (Fig. 54), and some units are attached to an adaptor plate and then to the valve yoke (Fig. 55). Both methods have the same removal procedure.




Fig. 54




Fig. 55

## **IMPORTANT POINTS**

The torque switch of the motor actuated valve is set during factory assembly to close the valve against the specified differential pressure and requires the same special attention for resetting.

## **WARNING**

Should it become necessary to change the torque switch setting, for any reason, your local Velan representative should be contacted in order that a correct new setting can be obtained from the factory.

## **CAUTION**

- If for any reason the valve packing type is changed, it may be necessary to change the torque switch setting.
- Upon reassembly of a valve equipped with an electro-mechanical actuator, the open and close limit switches must be reset. Please refer to the maintenance and instruction manual provided by the actuator manufacturer for appropriate instruction.
- - 1) When checking for proper rotation of the electrical actuator, make sure that the valve is in its mid stroke position. If the three phase wiring connection is incorrect, the valve will close when the open button is pressed, and the close torque switch will not function, thus causing possible damage to the valve. If the valve does not travel in the correct direction, then simply interchange any two of the three power connections.
  - 2) When checking for full stroke of the valve without pressure in the line, it is strongly recommended that the closing torque switch is set to its minimum value which will close the valve, until all testing is finished. The torque switch should then be reset to its recommended value.
  - 3) It is customary to bypass the torque switch at the beginning of the opening stroke on gate type valves. This allows the full torque of the motor to be developed in case the wedge has become excessively tight in the seats. This is accomplished with a jumper between a closed limit switch and the open torque switch.

Refer to the actuator manual for complete details. If problems are encountered, call the valve or the actuator manufacturer.



Refer to Fig. 56

1. All pressure must be relieved from both sides of the valve before the removal of the motor actuator is started.
2. The valve should be in a partially open position.
3. Disconnect the electrical wiring from the actuator.
4. Tighten the packing flange nuts (18).
5. Remove all actuator bolting (56) from the underside of the yoke flange.
6. All electrical actuators have an automatic handwheel declutching arrangement. In most cases, move the lever from the motor operation position to hand operation position.

**Note:** Do not try to force declutch lever into an operating position.

7. Turn the actuator handwheel to close the valve. This will cause the actuator to rise and unthread itself from the valve stem. As this takes place, the weight of the actuator should be supported by a hoist to prevent damage to the stem or to internal parts of the valve.
8. If further disassembly of the actuator is required, refer to the maintenance manual provided by the actuator manufacturer.

9. If there is further work to be performed on the valve, refer to the proper valve disassembly... and maintenance section in this manual.




Fig. 56

## APPENDIX C

### 1.0 Procedure for Removing Hydraulic or Pneumatic Actuator

Refer to Fig. 57

The following instructions will give you a general guide to the removal and re-installation of a hydraulic or pneumatic actuator.

All hydraulic or pneumatic actuators have a connection between the valve stem and the stem of the actuator. All these connections are formed by some type of coupling. Fig. 58 illustrates some examples of coupling used on Velan valves. As a rule, examine this connection first to understand how the coupling works.




Fig. 57




Fig. 58

## Removal of Actuators:

### Refer to Fig. 59

1. All pressure must be relieved from both sides of the valve before removal of actuator is started.
2. All pressure must be relieved from actuator before disassembling is started.
3. Remove yoke-actuator bolting (67).
4. Loosen coupling (62).  
**Precaution:** Examine coupling (62) for set screw (66) or any locking device before loosening it.  
**Note:** On some actuators, it is necessary to rotate the actuator stem to remove this connection.
5. When the stem threads are disengaged, lift the actuator (65) clear of the yoke and place it down on a clean area for further disassembly, if required. If further disassembly on the actuator is required, refer to the actuator manufacturer's maintenance and instruction manual.
6. If there is further work to be performed on the valve, refer to the proper valve disassembly section in this manual.

## APPENDIX D

### 1.0 Spare Parts

All parts on any valve can be ordered, but Velan does not recommend the changing of all parts in the field (e.g. integral seat, integral backseat, wedge guides, etc.). The changing of these parts will in some cases require special machining equipment and special fitting. In these cases, it is best to get in touch with your local Velan representative. The representative will assist you in determining the way to restore your valve with a minimum of time and expense.


When ordering spare parts, correctly determine which parts are required. After this is done, present Velan with some of the following information.

1. Velan order number.
2. Velan item number (if more than one item).
3. Velan figure number.

OR

1. Customer order number.
2. Customer item number.
3. Valve size, type and pressure class.

Fig. 59



## SALES OFFICES

### CANADA

MONTREAL H4M 1T6  
VELAN INC.  
2125 Ward Avenue  
Tel. (514) 748-7743  
TX: 05-825668  
TWX: 610-421-3673  
Telecopier: (514) 748-8635

### U.S.A.

WILLISTON, VT., 94495  
VELAN VALVE CORPORATION  
Griswold Industrial  
Park, Ave. "C"  
Tel: (802) 863-2562  
TX: 0095-4613  
Telecopier: (802) 862-4014

ROSELAND, NEW JERSEY,  
07068  
5 Pine Road  
(E. Baerenrodt)  
Tel. (201) 228-5224

BROOKHAVEN,  
PENNSYLVANIA, 19015  
700 Lincoln Drive  
(R. Cunnion)  
Tel. (215) 872-4520

SUGAR LAND TEXAS,  
77478  
13411 Greenbriar  
(F. Laitkep)  
Tel. (713) 491-2790

ANAHEIM, CALIFORNIA,  
92807  
5157 E. Crescent Drive  
(R. Smith)  
Tel. (714) 637-3021

### EUROPE

ENGLAND, LEICESTER  
LE4 7SS VELAN  
ENGINEERING CO. LTD.  
308 Melton Road  
(P. Groggs)  
Tel. (05133)-61845  
TX: (51)34693

FRANCE PARIS 93123  
SOCIÉTÉ VELAN-RATEAU  
141-Rue Bateau  
(J. Chamoux)  
Tel. (01)838-92-03  
TX: (42)212795

WEST GERMANY, WILlich  
VELAN G.m.b.H.  
Daimierstr. 8  
4156 Willich 1  
(M. Hanke)  
Tel. (02154)  
427001-04  
TX: (41)853 1977

## MANUFACTURING PLANTS

### CANADA

MONTREAL H4M 1T6  
VELAN INC.  
2125 Ward Avenue  
Tel. (514) 748-7743  
Tel.: 05-825668  
TWX: 610-421-3673

MONTREAL H4T 1W8  
VELAN INC.  
255 Migneron Street  
Tel. (514) 748-7743  
Tel.: 05-825668  
TWX: 610-421-3673

GRANBY, QUEBEC  
J2J 1E7  
VELAN INC.  
1010 Cowie Street  
Tel. (514) 378-2305  
Tel.: 05-832585

### U.S.A.

WILLISTON, VER-  
MONT 05495  
VELAN VALVE  
CORPORATION  
Avenue "C"  
Griswold Industrial  
Park  
Tel. (802)863-2562  
Tel.: 0095-4613

PLATTSBURGH  
NEW YORK 12901  
VELAN VALVE  
CORPORATION  
Beekmantown Rd.  
P.O. Box 220  
Tel.: (518) 561-3830

### ENGLAND

LEICESTER LE4 7SS  
VELAN ENGINEERING  
CO. LTD.  
308 Melton Road  
Tel. (05) 33-61845  
Tel.: (51)34693

### FRANCE

LA BAULE 44500  
SOCIÉTÉ VELAN-  
RATEAU  
2, ave des Noëllés  
Tel. (40)24-23-40  
Tel.: (42)710546

### WEST GERMANY

WILlich 1  
Velan G.m.b.H.  
Daimierstr. 8  
4156 Willich 1  
Tel. (02154)  
427001-04  
Tel.: (41) 853 1977



## TERMS AND CONDITIONS OF SALE

**CONTRACT:** Orders are subject to acceptance by the Velan Companies hereinafter referred to as the Seller. No terms or conditions of Purchaser's order contrary to the Seller's terms and conditions shall be binding upon the seller unless specifically agreed to by the Seller in writing.

**MINIMUM:** order charge \$150.00.

**PRICES:** All quoted prices are subject to change by the Seller without prior notice and, unless otherwise stipulated by Seller, are understood to be F.O.B. Seller's plant, with delivery to carrier constituting delivery to purchaser. Right to possession of the material to secure the payment of the purchase price shall remain in Seller until all payments therefor shall have been fully made. For the protection of the buyer and the seller, verbal customer orders must be confirmed by a formal written purchase order. If a written purchase order is not received within ten days of a verbal order product descriptions, quantities, specification, etc., as set forth in Seller's acknowledgement and Invoice shall be conclusive and binding on both parties. Any order that is shipped before receipt of confirmation which might have been entered incorrectly and would require remedial action would be for the buyer's account.

**TAXES:** All prices are exclusive of taxes. Sales, use and other taxes, by whomsoever levied, are to be paid by the Purchaser, and unless invoiced, are to be paid by the Purchaser direct to the appropriate governmental agency.

**DELIVERY:** Delivery or shipment specified is Seller's best estimate and Seller shall not be liable for delay in deliveries resulting from any cause whatsoever. Failure to ship on or near the estimated date shall not entitle Purchaser to cancel his order without charge.

**RETURN OF MATERIALS:** Materials may be returned only with prior written agreement of seller.

**CANCELLATION:** Cancellation of orders may be made only with the Seller's written consent and Purchaser shall be subject to cancellation charges.

**PRODUCT WARRANTY:** Seller warrants the equipment of its own manufacture to be free of defects in material and workmanship, under normal use and proper operation, for a period of one year from date of shipment from Seller's plant. Seller's obligation under this warranty shall be strictly limited, at Seller's option, to: (i) furnishing replacement parts for or repairing without charge to Purchaser, B.O.B. Seller's Plant, or (ii) issuing written authorization for Purchaser or others to replace or repair, without charge to Purchaser, at costs comparable to Seller's normal manufacturing costs those parts proven defective; or (iii) in discharge of Seller's maximum liability herewith, refunding all monies paid by Purchaser to Seller for the Product and, at discretion of Seller, having the product removed and returned to Seller at Purchaser's expense. All transportation charges relative to corrective work, defective parts or replacement parts shall be borne by Purchaser. Purchaser shall give Seller immediate notice upon discovery of any defect. The undertaking of repairs or replacement by Purchaser or its agents without Seller's written consent shall relieve Seller of all responsibility herewith.

Finished materials and accessories purchased from other manufacturers are warranted only to the extent of the manufacturer's warranty to Seller.

Any alteration in material or design of Seller's product or component parts thereof by purchaser or others without written authorization by Seller voids all obligations of Seller regarding the product and any associated warranty herein stated or implied.

Seller's sole liability shall be exclusively as set forth herein, and Seller shall not be liable for any incidental or consequential damages due to its breach of any warranty here in contained, or otherwise. Without limitation to the foregoing, in no event shall Seller be liable for the loss of use of the product or for the loss of use of any other product, process, plant, equipment, or facilities of the Purchaser or the end-user whether partially or wholly due to defects in material and/or workmanship and/or design of Seller's product, and in no event shall Seller be liable for removal of appurtenances or incidentals such as connections, pipe work and similar items of obstruction or for any cost brought about by the necessity of removing the product from its point of installation.

Seller makes no warranty of any kind whatsoever, expressed or implied, other than as specifically stated herein; and there are no warranties of merchantability and/or fitness for a particular purpose which exceed the obligations and warranties specifically stated herein.

Parts furnished without charge as replacements for original parts under warranty are warranted for that period of time during which the original parts warranty is effective.

**ALL SHIPMENTS WILL BE F.O.B. PLANT LOCATION.**

**SHIPMENTS WILL BE MADE VIA MOST ECONOMICAL CARRIERS UNLESS OTHERWISE REQUESTED.**

**TERMS: NET 30 DAYS FROM DATE OF INVOICE. 1 1/2% PER MONTH ON ALL OVERDUE ACCOUNTS, ALL TAXES EXTRA.**

**PRICES SUBJECT TO CHANGE WITHOUT NOTICE.**