



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Harold W. Keiser
Vice President-Nuclear Operations
215/770-7502

NOV 14 1986

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Project Director
BWR Project Directorate No. 3
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
POSTULATED PIPE RUPTURE
PLA-2756 FILE R-26,R41-2

Dear Ms. Adensam:

Attached you will find calculations M-MSS-010 and M-MSS-006 as requested by Mr. M. Thadani during a telecom on November 12, 1986.

If you have any additional question, please contact us.

Very truly yours,

H.W. Keiser

H. W. Keiser
Vice President-Nuclear Operations

Attachment

cc: L. R. Plisco - NRC
M. C. Thadani - NRC

*A001
11*

8611190331 861114
PDR ADOCK 05000387
PDR

8611/9033-1



CALCULATION COVER SHEET

CALC. NO. M-MSS-010
FILE NO. R-26
SUPERSEDED BY

SAFETY-RELATED ASME III OR XI
OTHER QUALITY
NON QUALITY

PROJECT SUSQUEHANNA STEAM ELECTRIC STATION
DESIGN ACTIVITY/PMR NUMBER IREIR 101155
TITLE/DESCRIPTION JET IMPINGEMENT ON MSIV'S

ER/CTN NO. 741058-003
PAGE 1 OF 29

STATEMENT OF PROBLEM
DETERMINE IF THE INBOARD MSIV'S WILL FAIL DUE TO THE JET IMPINGEMENT FROM A POSTULATED BREAK OF THE 28" RECIRC. SUCTION LINE AT NOZZLE N1A AT THE PIPE-TO-SAFE-END WELD. IF FAILURE DOES OCCUR DETERMINE THE JET PRESSURE FOR WHICH THE VALVES DO NOT FAIL.

DESIGN BASIS (DC020.0 OR DC020.1)
THIS CALC. IS PERFORMED ASSUMING THAT THE JET EXIT ANNULUS CONFIGURATION CAN BE REPRESENTED AS AN OPEN ENDED PIPE OF THE SAME AREA.

- REFERENCES/FORMULAE
1. DESIGN MEMO # MDE 145-0685, SUPPLEMENT #1 ATTACHED TO G.E. LTR. G-KR-6-028, 1/21/86
 2. MPR ASSOCIATES LTR. RPT. DATED 6-24-85 (ATTACHMENT 5 TO CALL M-MS-006, REV. 1)
 3. GE DWG. FF 113011, SH 6101, REV. 1, N1 RECIRC. OUTLET NOZZLE SAFE END.
 4. ANS 58.2-1980, DESIGN BASIS FOR PROTECTION OF LIGHT WATER REACTOR POWER PLANTS AGAINST EFFECTS OF POSTULATED PIPE RUPTURE.
 5. ASME PUB. 69-HT-31, F.T. MOODY, PREDICTION OF BLOWDOWN THRUST AND JET FORCES
 6. FSAR TABLES 6A-1 (a) & (b).
 7. ATWOOD & MORRILL CO. DWG. 21140-H, SHEETS 1 & 2, 26" W.E. MAIN STEAM ISOLATION VALVE.
 8. ATWOOD & MORRILL CO. MSIV INSTRUCTION MANUAL, FILE 204-03, IOM 17.
 9. GE MSIV DYNAMIC QVAL. REPORT, KR1-821-F022, F023, REV. 2, MPL REF. 230X113AE, REV. 25

- SUMMARY/CONCLUSIONS
10. ATWOOD & MORRILL CO. DWG. 21283-H, FF 114510, SH. 3291.
 11. LTR. FM. ATWOOD & MORRILL TO G.D. MILLER, 4-3-85 (ATTACHMENT 3).
 12. BAUMEISTER & MARKS, STANDARD HANDBOOK FOR MECHANICAL ENGINEERS, SEVENTH EDITION
 13. METALS PROGRESS HANDBOOK - 2ND EDITION
 14. MSIV ACTUATOR DYNAMIC QVAL. TEST REPORT, NEDC-22177A, AUGUST, 1975.
 15. GE PLANT PIPING DESIGN MEMO # MDE 31-028 TRANSMITTED BY G-KR-6-135 OF APRIL 11, 1986

MSIV OPERATORS ON THE A & D INBOARD VALVES WILL FAIL DUE TO THE JET IMPINGEMENT LOAD. THE MAXIMUM JET PRESSURE THEY CAN WITHSTAND IS 17.8 PSIG.

THIS CALCULATION SUPERSEDES CALC. # M-MSS-008.

REV. NO.	DATE	PREPARED BY	REVIEWED/CHECKED BY	DATE	APPROVED BY	DATE
1	3-25-86	AC Perotti	David J. Kitchin	4/16/86	JP Gullerott	4-28-86

10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



Dept. NPE-MECH
Date 3-25 19 86
Designed by RJR
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET
PROJECT CALC. M-MSS-010
LOOP A RECIRC. OUTLET
0° AZIMUTH

ER No. _____
Sht. No. 2 of 29





FIG. 1



2-7A

2-7A

HV
8212F022D

HV
8212F022A

26'MST-222-H57

26'MST-222-H51

26'MST-222-H51

26'MST-222-H53

ASYMPTOTIC PLANE

26'MST-222-H17

B.O.D. EL. 739'-8"

26'(BY)G

26'(BY)G

1'DBA-219.4

1'DBA-220.2

12'x24'

12'x26'

12'x26'


12'x24'

19'-9 1/2"
(TYP)

NIA

FIG. 2

26' DBA



Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date 3-25 1986 CALCULATION SHEET
 Designed by DEP PROJECT M-MSS-019 Sht. No. 4 of 29
 Approved by _____

FIGURE 1 DESCRIBES THE PHYSICAL SITUATION THAT WOULD EXIST AT THE TIME THE RECIRC PUMP SIDE OF THE BREAK COMES TO REST AT A STEADY STATE CONDITION. SATURATED WATER ESCAPING FROM THE TWO OPEN ENDS WOULD MEET AND TURN RADially OUTWARD WHERE IT WOULD ENCOUNTER THE I.D. OF THE SACRIFICIAL SHIELD DOORS, THESE WOULD TURN THE FLOW AXIALLY ALONG THE OUTSIDE OF THE PIPE IN BOTH DIRECTIONS. THE INSULATION IS ASSUMED TO BLOW AWAY. THE FLOW TOWARD THE RPV WOULD PRESSURIZE THE ANNULUS BETWEEN THE RPV AND THE SACRIFICIAL SHIELD. THE OUTWARD FLOW WOULD EXIT INTO THE AREA OF THE INBOARD MSIV'S PER FIGURE 2. ASSUME EQUAL FLOW IN BOTH DIRECTIONS.

FROM REF 1 THE AT-REST SEPERATION OF THE PIPE ENDS IS 12 INCHES.

FROM REF. 2 THE FLOW FROM THE VESSEL SIDE OF THE BREAK IS 8,344 lb/SEC, FROM THE PUMP SIDE 5,481 lb/SEC. TOTAL FLOW IS 23,830. FLOW OUTWARD IS HALF TOTAL OR 11,915 lb/SEC.

CIRCUMFERENTIAL AREA OF THE GAP BETWEEN THE BREAK ENDS IS :

$$A_{GAP} = (\text{INSIDE CIRCUMFERENCE})(GAP) = \pi (I.D.)(GAP) = \pi (25.469 \text{ IN})(12 \text{ IN})$$

$$A_{GAP} = 960.16 \text{ IN}^2 = 6.668 \text{ FT}^2 \quad \text{FROM REF. 3}$$

EXIT ANNULUS AREA BETWEEN PIPE O.D. AND SHIELD DOOR I.D. :

$$A_{EXIT} = \frac{\pi}{4} [I.D.^2 - O.D.^2] = \frac{\pi}{4} [(3'10")^2 - (28")^2]$$

$$A_{EXIT} = 1046.15 \text{ IN}^2 = 7.265 \text{ FT}^2$$

FROM REF. 4, PAGE 10, EQUATION 6-2, THE STEADY STATE THRUST FORCE IS :

$$T = \rho_e U_e^2 A_e + P_e A_e$$

WHERE: ρ_e = EXIT MASS DENSITY = 3.182 lb/FT³ (REF. 2.)
 U_e = EXIT VELOCITY
 A_e = A_{EXIT} = EXIT AREA
 P_e = EXIT PRESSURE = 282.3 lb/IN² (REF. 2)

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

100



Dept. _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date 3-25 1986

Designed by SP

PROJECT M-MSS-010

Sht. No. 5 of 29

Approved by _____

$$\text{VOLUMETRIC FLOW RATE} = \frac{\text{MASS FLOW RATE}}{\text{DENSITY}} = \frac{11,915 \text{ lb/SEC.}}{3,18.2 \text{ lb/FT}^3} = 3,744.5 \text{ FT}^3/\text{SEC}$$

$$U_e = \frac{\text{VOLUMETRIC FLOW RATE}}{A_e} = \frac{3,744.5 \text{ FT}^3/\text{SEC}}{7.265 \text{ FT}^2} = 515.4 \text{ FT/SEC}$$

SUBSTITUTING INTO THE THRUST EQUATION:

$$T = P_e U_e^2 A_e + P_e A_e$$

$$T = \frac{(3,18.2 \text{ lb/FT}^3)(515.4 \text{ FT/SEC})^2(7.265 \text{ FT}^2)}{32.2 \text{ FT/SEC}^2} + (282.3 \text{ lb/IN}^2)(7.265 \text{ FT}^2)(144 \text{ IN}^2/\text{FT}^2)$$

$$T = 190,708 \text{ lb} + 295,331 \text{ lb}$$

$$T = 486,039 \text{ lb}$$

FROM REF. 5, EQUATION 29, THE JET PRESSURE AT THE ASYMPTOTIC PLANE IS:

$$P_{\infty} = \frac{F_J}{A_{\infty}} = \frac{g_c \left(\frac{T}{A_e}\right)^2}{G_e^2 V_{\infty}^2}$$

WHERE: $F_J = T =$ FORCE AT ASYMPTOTIC PLANE

$A_{\infty} =$ AREA OF ASYMPTOTIC PLANE

$$g_c = 32.2 \text{ FT/SEC}^2$$

$A_e =$ EXIT AREA

$$G_e = \text{MASS FLUX AT EXIT PLANE} = \frac{\dot{m}}{A_e} = \frac{11,915 \text{ lb/SEC}}{7.265 \text{ FT}^2} = 1,640.1 \text{ lb/SEC FT}^2$$

$V_{\infty} =$ ASYMPTOTIC JET SPECIFIC VOL.

$$= \left[x V_g + (1-x) K V_f \right] \left(x + \frac{1-x}{K} \right)$$

WHERE: $V_g =$ STEAM SP. VOL. AT AMBIENT = 26.80 FT³/lb

Dept. _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date 3-25-1980

Designed by _____

PROJECT M-MSS-010

Sht. No. 6 of 29

Approved by _____

$$V_f = \text{WATER SPECIFIC VOL AT AMBIENT} = .0167 \text{ FT}^3/\text{lb}$$

$$K = U_g / U_f = \text{VELOCITY RATIO (REF. 5, EQ. 5)}$$

$$U_g = \frac{x}{\alpha} G V_g$$

$$U_f = \frac{1-x}{1-\alpha} G V_f$$

$$\alpha = \text{VAPOR VOL. FRACTION} = \frac{V_g}{V_f + V_g} = \frac{26.80}{26.80 + .0167} = .999$$

$$x = \text{STEAM JET QUALITY} = \frac{\text{ENTHALPY CHANGE (STAG. TO AMBIENT)}}{\text{ENTHALPY CHANGE (TOTAL CHANGE OF STATE)}}$$

ASSUME CONSTANT ENTHALPY PROCESS. FROM REF. 6 VESSEL STAGNATION CONDITIONS:

$$h_0 = 527.85 \text{ BTU/lb}$$

$$P_0 = 1031.2 \text{ PSIA}$$

AT AMBIENT FROM ASME STEAM TABLES:

$$h_f = 180.2 \text{ BTU/lb.}$$

$$h_{fg} = 970.3 \text{ BTU/lb}$$

$$x = \frac{h_0 - h_f}{h_{fg}} = \frac{527.9 \text{ BTU/lb} - 180.2 \text{ BTU/lb}}{970.3 \text{ BTU/lb}} = .358$$

$$U_g = \frac{x}{\alpha} G V_g = \left(\frac{.358}{.999} \right) (1640.1 \text{ lb/SEC FT}^2) (26.80 \text{ FT}^3/\text{lb}) = 15,751.5 \text{ FT/SEC}$$

$$U_f = \frac{1-x}{1-\alpha} G V_f = \left(\frac{1-.358}{1-.999} \right) (1640.1 \text{ lb/SEC FT}^2) (.0167 \text{ FT}^3/\text{lb}) = 17,584.2 \text{ FT/SEC}$$

$$K = \frac{U_g}{U_f} = \frac{15,751.5 \text{ FT/SEC}}{17,584.2 \text{ FT/SEC}} = .896$$

Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date 3-25 1986 CALCULATION SHEET
 Designed by DES PROJECT M-1985-010 Sht. No. 7 of 29
 Approved by _____

$$V_{m\infty} = \left[.358 (26.80 \text{ FT}^3/\text{lb}) + (1-.358)(.896)(.0167 \text{ FT}^3/\text{lb}) \right] \left(.358 + \frac{1-.358}{.896} \right)$$

$$V_{m\infty} = 10.320 \text{ FT}^3/\text{lb}$$

$$P_{\infty} = \frac{(32.2 \text{ FT/SEC}^2) \left(\frac{486,039 \text{ lb}}{7.265 \text{ FT}^2} \right)^2}{\left(\frac{1640.1 \text{ lb}}{5 \text{ SEC FT}^2} \right)^2 (10.320 \text{ FT}^3/\text{lb})} = 5,191 \text{ lb/FT}^2 = \underline{\underline{36.05 \text{ lb/IN}^2}}$$

$$A_{\infty} = \frac{F_T}{P_{\infty}} = \frac{486,039 \text{ lb}}{5,191 \text{ lb/FT}^2} = 93.6 \text{ FT}^2$$

FROM REF. 4, EQ. C-2, THE DISTANCE FROM THE EXIT TO THE ASYMPTOTIC PLANE IS:

$$\frac{L_a}{D_e} = \frac{1}{2} \left(\sqrt{\frac{A_a}{A_e}} - 1 \right)$$

WHERE: L_a = DISTANCE TO ASYMPTOTIC PLANE
 D_e = EXIT DIA.

THE EQUIVALENT DIAMETER FOR THE ANNULAR EXIT IS:

$$D_e = 2 \sqrt{\frac{A_e}{\pi}} = 2 \sqrt{\frac{7.265 \text{ FT}^2}{\pi}} = 3.041 \text{ FT}$$

DISTANCE FROM EXIT TO ASYMPTOTIC PLANE:

$$L_a = .5 (3.041 \text{ FT}) \left(\sqrt{\frac{93.6 \text{ FT}^2}{7.265 \text{ FT}^2}} - 1 \right) = 3.94 \text{ FT}$$

FROM REF. 4, PAGE E-6, CASE 2, REGION 2 OF THE JET BLAST IS DEFINED BY:

$$L_a \leq L \leq \frac{1}{2} \left[\sqrt{\frac{4A_a}{\pi}} - D_e \right] \cot 10^\circ$$

$$L \leq \frac{1}{2} \left[\sqrt{\frac{4(93.4 \text{ FT}^2)}{\pi}} - 3.041 \text{ FT} \right] \cot 10^\circ$$

$$L \leq 22.3 \text{ FT}$$

Dept. _____
Date 3-25 1986
Designed by NCR
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

PROJECT M-MSS-010

ER No. _____
Sht. No. 8 of 29

SINCE THE VALVE AND OPERATOR ARE AT APPROXIMATELY 8 FT RANGE, THEY ARE IN REGION 2 AND SUBJECTED TO THE SAME JET PRESSURE AS THE ASYMPTOTIC PLANE.


THE AREA OF THE ASYMPTOTIC PLANE IS REPRESENTED BY:

$$A_{TOTAL} = A_{CO} + A_{PIPE}$$

$$\frac{\pi D^2}{4} = 93.6 \text{ FT}^2 + \frac{\pi (29 \text{ IN})^2}{4} \cdot \frac{1 \text{ FT}^2}{144 \text{ IN}^2}$$

$$D = 11.16 \text{ FT}$$

FIG. 3



FROM REF. 4, EQ. D-5, THE IMPINGEMENT FORCE IS:

$$\vec{F}_{IMP} = K_0 P_{JET} A_{TARGET}$$

WHERE: K_0 = SHAPE FACTOR FOR THE TARGET

A_{TARGET} = TARGET AREA

P_{JET} = JET PRES. AT THE TARGET.




FIG. 4

Vertical text on the left side of the page, possibly bleed-through from the reverse side. The text is faint and difficult to decipher but appears to contain several lines of characters.

Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date 3-25 1984 CALCULATION SHEET
 Designed by DEP PROJECT M-MSS-D10 Sht. No. 9 of 29
 Approved by _____

BY INSPECTION OF REF. 7 IT IS LIKELY THAT THE MAXIMUM STRESSES IN THE VALVE DUE TO LOADS ON THE OPERATOR WOULD BE IN THE THREADED PORTION OF THE YOKE RODS WHERE THEY SCREW INTO THE BONNET AND WHERE THEY ARE BOLTED TO THE TOP SPRING SEAT.

F_{JY} = FORCE OF JET ON OPERATOR IN Y-DIRECTION.

F_{JX} = FORCE OF JET ON OPERATOR IN X-DIRECTION

F_w = WEIGHT FORCE OF OPERATOR = 2440 lb (REF 8., PAGE 26, ITEM 14)

FROM REF. 4, PAGE 20, A DYNAMIC LOAD FACTOR MUST BE APPLIED. THIS FACTOR IS THE INVERSE FUNCTION OF THE STIFFNESS OF THE TARGET. ASSUME 1.0 IN THE Y-DIRECTION SINCE THE RODS ARE VERY STIFF IN COMPRESSION AND 2.0 IN THE X-DIRECTION SINCE THEY ARE RELATIVELY FLEXIBLE IN THAT DIRECTION.

FIND THE FORCE DOWN ON THE TOP PLATE OF THE OPERATING CYLINDER:

$$F_{y1} = \overline{K_{\phi}} P_{JET} A_{TARGET} D.L.F.$$

FROM REF. 1, FIG. D-1, $\overline{K_{\phi}}$ FOR FLAT PLATE = SIN INCIDENCE ANGLE

FROM REF. 7, $A_{TAR} = 22 \text{ IN} \times 22 \text{ IN} = 484 \text{ IN}^2$

$$F_{y1} = (\sin 45^\circ)(36.05 \text{ lb/IN}^2)(484 \text{ IN}^2) = \underline{12,338 \text{ lb.}}$$

FIND THE FORCE ON THE SIDE OF THE OPERATING CYLINDER. SINCE THE AIR CONTROL MANIFOLD IS LOCATED ON THE SIDE OF THE OPERATING CYLINDER, IT IS TREATED AS A FLAT PLATE.

BY MEASUREMENT, $A = 22 \frac{9}{16} \text{ IN} \times 21 \frac{3}{4} \text{ IN} = 490.7 \text{ IN}^2$

$$F_{x1} = (\sin 45^\circ)(36.05 \text{ lb/IN}^2)(490.7 \text{ IN}^2)(2.0) = \underline{25,017 \text{ lb.}}$$

FIND THE FORCE ON THE SIDE OF THE SPRINGS IN THE OPEN POSITION. BACK SPRINGS WOULD BE ESSENTIALLY SHADOWED. ASSUME TOTAL EFFECT OF ALL THESE BY MODELING THE FRONT SPRINGS ONLY. SINCE THE FLOW THROUGH THE SPRINGS IS VERY CIRCUITOUS, ASSUME ALL OF THE INCIDENT ENERGY OF THE JET IS ABSORBED. THEREFORE, THEY WOULD ACT AS FLAT PLATES WITH AN

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date 3-25 1986 CALCULATION SHEET
 Designed by ACP PROJECT M-755-010 Sht. No. 10 of 29
 Approved by _____

AREA EQUAL TO THE PROJECTED AREA.

$$\left. \begin{array}{l} \text{SPRING LENGTH, VALVE OPEN} = 21.67 \text{ IN} \\ \text{SPRING O.D.} = 6.33 \text{ IN} \end{array} \right\} \text{SCALED FROM REF. 7}$$

$$\text{PROJECTED AREA} = (21.67 \text{ IN})(6.33 \text{ IN})(2)(\sin 45^\circ) = 194.0 \text{ IN}^2$$

$$F_{x2} = \frac{F_{y2}}{2} = P_{\text{JET}} \cdot A_{\text{PROJ}} \cdot \sin 45^\circ \cdot 2$$

$$F_{x2} = \frac{F_{y2}}{2} = (36.05 \text{ lb/IN}^2)(194 \text{ IN}^2)(.707)(2) = \underline{9,891 \text{ lb/IN}^2}$$

FIND FORCE ON LIMIT SWITCH MOUNTING PLATES:

$$\begin{aligned} \text{AREA OF PLATES} &= (2 \text{ PLATES})(24 \text{ IN})(55 \text{ IN}) \text{ BY ACTUAL MEASUREMENT} \\ &= 264 \text{ IN}^2 \end{aligned}$$

$$F_{x3} = (36.05 \text{ lb/IN}^2)(264 \text{ IN}^2)(\sin 45^\circ)(2) = \underline{13,459 \text{ lb}}$$

FIND FORCE ON JUNCTION BOX:

$$\text{AREA OF BOX SIDE} = (5 \text{ IN})(12 \text{ IN}) = 60 \text{ IN}^2 \text{ BY MEASUREMENT}$$

$$F_{x4} = (36.05 \text{ lb/IN}^2)(60 \text{ IN}^2)(\sin 45^\circ)(2) = \underline{3,059 \text{ lb}}$$

$$\text{AREA OF BOX TOP} = (5 \text{ IN})(9 \text{ IN}) = 45 \text{ IN}^2$$

$$F_{y3} = (36.05 \text{ lb/IN}^2)(45 \text{ IN}^2)(\sin 45^\circ)(1) = \underline{1,147 \text{ lb}}$$

FIND THE MOMENT AT THE TOP OF THE BONNET DUE TO THE JET LOADS.

$$M_{\text{APPLIED JET}} = (F_{x1})(y_1) + (F_{x2})(y_2) + (F_{x3})(y_3) + (F_{x4})(y_4)$$

WHERE $y_1, y_2, y_3, \& y_4$ ARE THE RESPECTIVE LEVER ARMS FROM APPROX. CENTERS OF AREA TO THE BONNET TOP. THEY ARE FOUND BY ACTUAL MEASUREMENT AND INSPECTION OF PHOTOS.

$$M_{\text{APPLIED JET}} = (25,017 \text{ lb})(67 \text{ IN}) + (9,891 \text{ lb})(37 \text{ IN}) + (13,459 \text{ lb})(21 \text{ IN}) + (3,059 \text{ lb})(20 \text{ IN})$$

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

[Faint, illegible text or markings]



Dept. _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date 3-25 1986

Designed by APP

PROJECT M-MS-010

Sht. No. 11 of 29

Approved by _____

$$M_{\text{APPLIED JET}} = 2,385,925 \text{ in lb}$$

FIND TOTAL JET APPLIED FORCES:

$$F_{\text{JET X}} = F_{x1} + F_{x2} + F_{x3} + F_{x4} = (25,017 \text{ lb}) + (9,891 \text{ lb}) + (13,459 \text{ lb}) + (3,059 \text{ lb})$$

$$F_{\text{JET X}} = \underline{51,426 \text{ lb}}$$

$$F_{\text{JET Y}} = F_{y1} + F_{y2} + F_{y3} = 12,338 \text{ lb} + 4,945 \text{ lb} + 1,147 \text{ lb}$$

$$F_{\text{JET Y}} = \underline{18,430 \text{ lb}}$$

FIND THE MOMENTS AND FORCES DUE TO VIBRATORY MOTIONS. ASSUME THE JET LOAD IS COINCIDENT WITH SSE. FROM REF. 9, ATTACHMENT 1, FOR THE FAULTED CONDITION, SSE, IN THE X-DIRECTION (ATTACHMENT 1), THE RRS PEAK IS 1.44 G'S. FOR SSE IN THE Y-DIRECTION (ATTACHMENT 2), THE RRS PEAK IS 8.6 G'S. (HERE X & Y DENOTE DIRECTIONS FOR TEST REPORT ONLY.) FOR THE X-COMPONENT THE ACCELERATION PERPENDICULAR TO AND PARALLEL TO THE ACTUATOR AXIS ARE:

$$G_{xy} = (\sin 45^\circ)(1.44 \text{ G's}) = 1.01 \text{ G's}$$

FOR THE Y-COMPONENT:

$$G_{xy} = (\sin 45^\circ)(8.6 \text{ G's}) = 6.08 \text{ G's}$$

$$\text{TOTAL } G\text{-LOAD}_{xy} = 1.01 + 6.08 = 7.09 \text{ G's}$$

FROM REF. 6, PAGE 26, ITEM 14, WEIGHT OF OPERATOR IS 2,440 lb.

FORCE $F_{\text{SSE } xy}$ DUE TO SSE ACCELERATIONS:

$$F_{\text{SSE } xy} = (7.09 \text{ G's})(2,440 \text{ lb}) = 17,300 \text{ lb}$$

FROM REF 10. CENTER OF GRAVITY OF OPERATOR IS $45 \frac{12}{16}$ " ABOVE BONNET TOP.
FROM REF 7, SCALING, YOKE RODS JOIN BONNET 2.67 INCHS ABOVE BONNET TOP.

11.

12.

13.

14.

15.

16.

17.

18.

19.

20.

21.

22.

23.

24.

25.

26.



Dept. _____
Date 3-25 1984
Designed by DRP
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

PROJECT M-MSS-010

ER No. _____
Sht. No. 12 of 29

LEVER ARM OF C.G. TO POINT OF YOKE ROD ATTACHMENT :

$$L = 45.8125 \text{ in} - 2.6667 \text{ in} = 43.1 \text{ in.}$$

MOMENT AT ATTACHMENT DUE TO SSE :

$$M_{SSE} = (17,300 \text{ lb})(43.1 \text{ in.}) = 745,630 \text{ in. lb}$$

SINCE IT IS EXTREMELY UNLIKELY THAT THE PEAK JET FORCE AND THE PEAK SSE ACCELERATION WILL OCCUR SIMULTANEOUSLY, THE TWO FORCES AND RESULTANT MOMENTS ARE COMBINED AS THE SQUARE ROOT OF THE SUM OF THE SQUARES (SRSS).

$$M_{TOTAL APPLIED} = (M_{APPLIED JET}^2 + M_{SSE}^2)^{1/2}$$

$$M_{TOTAL APPLIED} = (2,385,925^2 + 745,630^2)^{1/2}$$

$$M_{TOTAL APPLIED} = 2,499,720 \text{ in lb}$$

$$F_{Y TOTAL} = (F_{JET Y}^2 + F_{SSE Y}^2)^{1/2}$$

$$F_{Y TOTAL} = (18,430 \text{ lb}^2 + 17,300 \text{ lb}^2)^{1/2}$$

$$F_{Y TOTAL} = 25,278 \text{ lb}$$

$$F_{X TOTAL} = (F_{JET X}^2 + F_{SSE X}^2)^{1/2}$$

$$F_{X TOTAL} = (51,426 \text{ lb}^2 + 17,300 \text{ lb}^2)^{1/2}$$

$$F_{X TOTAL} = 54,258 \text{ lb}$$

FIND LOADING OF YOKE RODS AT CONNECTION TO BONNET.

1. ALL OF THE APPLIED MOMENT AND FORCE MUST ULTIMATELY BE ABSORBED/RESISTED BY THE VALVE BODY, THROUGH THE VALVE BONNET, THROUGH THE YOKE RODS.

$$M_{TOTAL APPLIED} = M_{VALVE} = M_{BONNET} = M_{RODS}$$

2. THERE ARE TWO POSSIBLE MECHANISMS FOR THE APPLIED MOMENT TO BE TRANSMITTED TO THE BONNET - a) THROUGH MOMENTS TRANSMITTED BY THE INDIVIDUAL RODS, AND b) THROUGH A COUPLE BETWEEN THE UPPER AND LOWER RODS.

上 在 中 國 史 上 的 意 義

： 一 次 的 試 驗

Dept. _____
Date 3-25 1986
Designed by DGP
Approved by _____


PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

PROJECT M-MSS-010

ER No. _____
Sht. No. 13 of 29

3. THE RODS ARE FIXED AT THE BONNET END.
4. THE RODS ARE FIXED AT THE TOP SPRING SEAT END.
5. THE SPRING RATES OF THE BONNET AND TOP SPRING SEAT IN BENDING AND THE YAKE RODS IN TENSION AND COMPRESSION ARE VIRTUALLY INFINITE COMPARED TO THE SPRING RATE OF THE RODS IN BENDING. THEREFORE, WHEN ACTED ON BY A LATERAL FORCE, BENDING TAKES PLACE IN THE RODS AND THE TOP SPRING SEAT IS DISPLACED LATERALLY PARALLEL TO THE BONNET. THE RODS BEND IN AN S-SHAPED CURVE. THIS IS CONFIRMED BY OBSERVATION OF THE G.E. SEISMIC QUALIFICATION TEST MOVIE.

FIG. 5




6. THE RODS HAVE ESSENTIALLY A UNIFORM X-SECTION, TOP TO BOTTOM. WHEN DISPLACED THE CURVATURE OF THE RODS IS THE SAME AT THE TOP AS AT THE BOTTOM. IF THE X-SECTION AND THE CURVATURE ARE THE SAME, THEN THE MOMENT AT THE TOP AND BOTTOM ENDS MUST BE THE SAME.

FREE BODY DIAGRAM OF ROD SHOWING
LATERAL FORCES AND RESULTING MOMENTS.

$$M_1 = M_2$$

$$\sum F_x = 0 = F_{2x} - F_{1x}$$

$$\sum M_A = M_1 + M_2 - F_{2x}Y = 0$$



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



Dept. _____
Date 3-25 1986
Designed by APP
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____
Sht. No. 14 of 24

PROJECT M-MSS-010

7. ASSUME ALL FOUR RODS REACT THE SAME.

8. ASSUME LATERAL DISPLACEMENT IS SMALL COMPARED TO ROD LENGTH. THEREFORE, MOMENTS INDUCED BY AXIAL FORCES TIMES DISPLACEMENT ARE NOT CONSIDERED.

9. DETERMINE THE EFFECTIVE LEVER ARM OF THE JET FORCE:

$$Y_{JET} = \frac{M_{APPLIED\ JET}}{F_{JET,x}} = \frac{2,385,925\ \text{IN}\cdot\text{LB}}{51,420\ \text{LB}} = 46.4\ \text{IN.}$$


10. DETERMINE THE TOTAL EFFECTIVE LEVER ARM OF THE JET & SSE FORCE:

$$Y_{TOTAL} = \frac{M_{TOTAL}}{F_{x\ TOTAL}} = \frac{2,499,720\ \text{IN}\cdot\text{LB}}{54,258\ \text{LB}} = 46.1\ \text{IN}$$

11. SCALING FROM REF. 7, DISTANCE FROM BONNET TOP TO TOP SPRING SEAT BOTTOM IS 48 IN. THEREFORE TOTAL EFFECTIVE FORCE IS 1.9 INCHES BELOW THE TOP SPRING SEAT.

12. DRAW FREE BODY DIAGRAM OF TOP SPRING SEAT

FIG. 7



$$\sum F_x = 0 = 4F_{ix} - F_{x\ TOTAL}$$

$$\sum M_b = 0 = -4M_i + 2F_{iy}X$$

$$+(\dots F_{x\ TOTAL})(1.9\ \text{IN}) - F_{y\ TOTAL}\left(\frac{X}{2}\right)$$

$$\sum F_y = 0 = 2F_{iy} - 2F_{iy} - F_{y\ TOTAL}$$

$$F_{sy} = F_{iy} - \frac{F_{y\ TOTAL}}{2}$$

第 一 章 緒 論

一

二




Dept. _____
Date 3-25 1986
Designed by ASR
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

PROJECT M-MSS-010

ER No. _____
Sht. No. 15 of 24

13. DRAW A FREE BODY DIAGRAM OF THE BONNET :



14. SUM MOMENTS AND FORCES ON THE BONNET

$$\sum F_y = 0 = 2F_{5y} - 2F_{4y} - F_{\text{BONNET } Y}$$

$$\sum F_x = 0 = F_{\text{BONNET } X} - 4F_{1x}$$

$$\sum M_z = 0 = M_{\text{BONNET}} - 4M_1 - 2F_{4y} X$$

$$M_{\text{BONNET}} = 4M_1 + 2F_{4y} X$$

15. FROM STEP 1, $M_{\text{APPLIED}} = M_{\text{BONNET}}$

$$\therefore M_{\text{APPLIED}} = 4M_1 + 2F_{4y} X$$

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50

Dept. _____
Date 3-26 1984
Designed by DJR
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

PROJECT M-MSJ-810

ER No. _____
Sht. No. 16 of 29

BUT FROM STEP 12:

$$2 F_{4Y} X = 4 M_1 - F_{X\text{TOTAL}} (1.9 \text{ IN}) + F_{Y\text{TOTAL}} \left(\frac{X}{2}\right)$$

$$\therefore M_1^{\text{APPLIED}} = 4 M_1 + 4 M_1 - F_{X\text{TOTAL}} (1.9 \text{ IN}) + F_{Y\text{TOTAL}} \left(\frac{X}{2}\right)$$

$$M_1 = \frac{M_1^{\text{APPLIED}} + F_{X\text{TOTAL}} (1.9 \text{ IN}) - F_{Y\text{TOTAL}} \left(\frac{X}{2}\right)}{8}$$

16. SUBSTITUTING:

$$M_1 = \frac{2,499,720 \text{ in/lb} + 54,258 \text{ lb} (1.9 \text{ IN}) - 25,278 \text{ lb} \left(\frac{17.67 \text{ IN}}{2}\right)}{8}$$

$$M_1 = 297,435 \text{ in/lb}$$

DRAW FREE BODY DIAGRAM OF FRONT ROD END. WHEN A MOMENT IS APPLIED TO THE ROD IT WILL TEND TO PIVOT ABOUT POINT "C". THIS MOTION WILL BE RESISTED BY THE DOWNWARD COMPONENTS OF THE JET & SSE PLUS THE PRELOAD TENSION IN THE THREADS.




FIG. 9

$$\sum M_c = (F_{\text{THREAD}} - F_{SY}) \frac{3 \text{ IN}}{2} - M_1 = 0$$

SUBSTITUTING FOR F_{SY} FROM STEP 12:

$$(F_{\text{THREAD}} - F_{4Y} + \frac{F_{Y\text{TOTAL}}}{2}) \frac{3 \text{ IN}}{2} - M_1 = 0$$

$$F_{\text{THREAD}} = \frac{2}{3 \text{ IN}} M_1 + F_{4Y} - \frac{F_{Y\text{TOTAL}}}{2}$$

FROM STEP 16 ABOVE:

$$2 F_{4Y} X = 4 M_1 - F_{X\text{TOTAL}} (1.9 \text{ IN}) + F_{Y\text{TOTAL}} \left(\frac{X}{2}\right)$$

$$F_{4Y} = \frac{4 M_1 - F_{X\text{TOTAL}} (1.9 \text{ IN}) + F_{Y\text{TOTAL}} \left(\frac{X}{2}\right)}{2X}$$

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40



Dept. _____
Date 3-26 1980
Designed by DJL
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____
Sht. No. 17 of 29

PROJECT n-MSS-010

$$F_{\text{THREAD}} = \frac{2}{31N} M_1 + \frac{4 M_1 - F_{x\text{-TOTAL}} (1.9 \text{ IN}) + F_{y\text{-TOTAL}} \left(\frac{x}{2}\right) - F_{y\text{-TOTAL}}}{2x}$$

FROM REF. 7, SCALING $\lambda = 17.67 \text{ IN}$

SUBSTITUTING:

$$F_{\text{THREAD}} = \frac{4 (297,435 \text{ IN LB}) - (54,258 \text{ LB}) (1.9 \text{ IN}) + 25,278 \left(\frac{17.67 \text{ IN}}{2}\right) - \frac{25,278 \text{ LB}}{2} + (297,435 \text{ IN LB}) \left(\frac{2}{31N}\right)}$$

$$F_{\text{THREAD}} = 222,719 \text{ LB}$$

$$\text{STRESS} = \frac{\text{FORCE}_{\text{THREAD}}}{\text{AREA}_{\text{THREAD}}}$$

FROM REF. 11 THREADED PORTION OF YAKE ROD IS 2 IN - 8 UN - 3A THREADS (ATTACHMENT 3, SKETCH WITH LETTER). MATERIAL IS 1018 COLD DRAWN STEEL.

FROM REF. 12, PAGE 8-17, TABLE 4, MINOR DIA. IS 1.8466 IN.

$$\text{STRESS} = \frac{222,719 \text{ LB}}{\frac{\pi (1.8466 \text{ IN})^2}{4}}$$

$$\text{STRESS} = 83,161 \text{ LB/IN}^2$$

FROM REF. 13, YIELD STRENGTH OF THE MATERIAL IS 45,000 PSI, ULTIMATE STRENGTH IS 55,000 PSI (SEE ATTACHMENT 4, COPY OF APPLICABLE PAGE.)

FROM TESTING (REF. 14, SECTION 3.6.2) YIELDING WAS OBSERVED IN THE RODS FOR THE T.R.S. YET THE VALVES OPERATED AS DESIGNED. THEREFORE, ANY STRESS UP TO YIELD WILL BE SATISFACTORY.

FIND JET PRESSURE AT WHICH YIELDING OCCURS:

1

2

3

4

5

6

7



Dept. _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date 3-26 1986

Designed by DP

PROJECT M-MSS-010

Sht. No. 18 of 29

Approved by _____

FORCE IN THREADS TO CAUSE YIELDING

$$F_{YIELD} = (45,000 \text{ lb/in}^2) (\pi) \frac{(1.84 \text{ in})^2}{4}$$

$$F_{YIELD} = \underline{120,017 \text{ lb}}$$

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18



Dept. _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date 3-25 1986

Designed by DR

PROJECT M-MSS-010

Sht. No. 19 of 29

Approved by _____

RATIO PRESSURE DOWN BY FORCE IN THREAD TO YIELD:

$$P = \frac{120,017 \text{ lb}}{222,719 \text{ lb}} \cdot 36.05 \text{ lb/in}^2 = 19.43 \text{ lb/in}^2$$

TRY THIS PRESSURE. USE EQUATIONS ON PAGES 9 THRU 17:

$$F_{y1} = 6,650 \text{ lb}$$

$$F_{x1} = 13,484 \text{ lb}$$

$$F_{x2} = 5,331 \text{ lb}$$

$$F_{y2} = 2,665 \text{ lb}$$

$$F_{x3} = 7,254 \text{ lb}$$

$$F_{x4} = 1,649 \text{ lb}$$

$$F_{y3} = 618 \text{ lb}$$

$$M_{\text{APPLIED JET}} = (13,484 \text{ lb})(67 \text{ in}) + (5,331 \text{ lb})(57 \text{ in}) + (7,254 \text{ lb})(21 \text{ in}) + (1,649 \text{ lb})(20 \text{ in})$$

$$M_{\text{APPLIED JET}} = 1,285,989 \text{ lb}\cdot\text{in}$$

$$F_{\text{JETX}} = (13,484 \text{ lb} + 5,331 \text{ lb} + 7,254 \text{ lb} + 1,649 \text{ lb}) = 27,718 \text{ lb}$$

$$F_{\text{JETY}} = (6,650 \text{ lb} + 2,665 \text{ lb} + 618 \text{ lb}) = 9,933 \text{ lb}$$

$$M_{\text{TOTAL APPLIED}} = (1,285,989 \text{ lb}\cdot\text{in}^2 + 745,630 \text{ lb}\cdot\text{in}^2)^{1/2}$$

$$M_{\text{TOTAL APPLIED}} = 1,486,517 \text{ in}\cdot\text{lb}$$

$$F_{\text{TOTAL}} = (9,933 \text{ lb}^2 + 17,300 \text{ lb}^2)^{1/2} = 19,949 \text{ lb}$$

Dept. _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date 3-25 1986

Designed by DEP

PROJECT M-MSS-010

Sht. No. 20 of 29

Approved by _____

$$F_{x\text{TOTAL}} = (27,718 \text{ lb}^2 + 17,300 \text{ lb}^2)^{1/2} = 32,674 \text{ lb}$$

$$y_{\text{SET}} = \frac{1,285,989 \text{ in lb}}{27,718 \text{ lb}} = 46.4 \text{ in}$$

$$y_{\text{TOTAL}} = \frac{1,486,517 \text{ in lb}}{32,674 \text{ lb}} = 45.5 \text{ in}$$

EFFECTIVE FORCE IS 2.5 IN. BELOW TOP SPRING SEAT

$$M_1 = \frac{1,486,517 \text{ in lb} + 32,674 \text{ lb}(2.5 \text{ in}) - 19,949 \text{ lb}(\frac{17.67 \text{ in}}{2})}{9}$$

$$M_1 = 173,994 \text{ in lb}$$

$$F_{\text{THREAD}} = \frac{4(173,994 \text{ in lb}) - (32,674 \text{ lb})(2.5 \text{ in}) + (19,949 \text{ lb})(\frac{17.67 \text{ in}}{2})}{2(17.67 \text{ in})} - \frac{19,949 \text{ lb}}{2} + \frac{(2/3M)(173,994 \text{ in lb})}{3M}$$

$$F_{\text{THREAD}} = 128,391 \text{ lb} \quad \text{TOO HIGH}$$

RATIO PRESSURE AGAIN:

$$P = \frac{120,017 \text{ lb}}{128,391 \text{ lb}} \cdot 19.43 \text{ lb/in}^2 = 18.16 \text{ lb/in}^2$$

TRY .18 lb/in²

$$F_{x1} = 6,160 \text{ lb}$$

$$F_{x4} = 1,527 \text{ lb}$$

$$F_{x1} = 12,491 \text{ lb}$$

$$F_{y3} = 573 \text{ lb}$$

$$F_{x2} = 4,938 \text{ lb}$$

$$F_{y2} = 2,469 \text{ lb}$$

$$F_{x3} = 6,720 \text{ lb}$$

Dept. _____
Date 5-25 1980
Designed by ACE
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

PROJECT M-MSS-010

ER No. _____
Sht. No. 21 of 29

$$M_{\text{APPLIED JET}} = (12,491 \text{ lb})(67 \text{ in}) + (4,938 \text{ lb})(31 \text{ in}) + (6,720 \text{ lb})(21 \text{ in}) + (1,527 \text{ lb})(20 \text{ in})$$

$$M_{\text{APPLIED JET}} = 1,191,263 \text{ in lb}$$

$$F_{\text{JET X}} = 25,676 \text{ lb}$$

$$F_{\text{JET Y}} = 9,202 \text{ lb}$$

$$M_{\text{TOTAL APPLIED}} = 1,405,372 \text{ in lb}$$

$$F_{\text{Y TOTAL}} = 19,595 \text{ lb}$$

$$F_{\text{X TOTAL}} = 30,960 \text{ lb}$$

$$Y_{\text{JET}} = \frac{1,191,263 \text{ in lb}}{25,676 \text{ lb}} = 46.4 \text{ in}$$

$$Y_{\text{TOTAL}} = \frac{1,405,372 \text{ in lb}}{30,960 \text{ lb}} = 45.4 \text{ in}$$

EFFECTIVE FORCE IS 2.4 IN BELOW TOP SPRING SEAT.

$$M_1 = \frac{1,405,372 \text{ in lb} + (30,960 \text{ lb})(2.6 \text{ in}) - 19,595 \text{ lb} \left(\frac{17.67 \text{ in}}{2} \right)}{8}$$


$$M_1 = 164,093 \text{ in lb}$$

$$F_{\text{THREAD}} = \frac{4(164,093 \text{ in lb}) - 30,960 \text{ lb}(2.6 \text{ in}) + 19,595 \text{ lb} \left(\frac{17.67 \text{ in}}{2} \right) - \frac{19,595 \text{ lb}}{2} \left(\frac{2}{3 \text{ in}} \right) (164,093 \text{ in lb})}{2(17.67 \text{ in})}$$

$$F_{\text{THREAD}} = 120,792 \text{ lb}$$

RATING PRESSURE AGAIN

$$P = \frac{120,017 \text{ lb}}{120,792 \text{ lb}} \cdot 18 \text{ lb/in}^2 = 17.9 \text{ lb/in}^2$$



Dept. _____
Date 3-25 1986
Designed by D.P.P.
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

PROJECT M-MSS-010

ER No. _____
Sht. No. 22 of 29

$$\text{TRY } 17.8 \text{ lb/in}^2$$

$$F_{x1} = 12,352 \text{ lb}$$

$$F_{y1} = 6,092 \text{ lb}$$

$$F_{x2} = 4,884 \text{ lb}$$

$$F_{y2} = 2,442 \text{ lb}$$

$$F_{x3} = 6,646 \text{ lb}$$

$$F_{x4} = 1,510 \text{ lb}$$

$$F_{y3} = 566 \text{ lb}$$

$$M_{\text{APPLIED JET}} = 1,178,058 \text{ in lb}$$

$$F_{\text{JETX}} = 25,392 \text{ lb}$$

$$F_{\text{JETY}} = 9,100 \text{ lb}$$

$$M_{\text{TOTAL APPLIED}} = 1,394,197 \text{ in lb}$$

$$F_{y\text{TOTAL}} = 19,547 \text{ lb}$$

$$F_{x\text{TOTAL}} = 30,725 \text{ lb}$$

$$y_{\text{JET}} = \frac{1,178,058 \text{ in lb}}{25,392 \text{ lb}} = 46.4 \text{ in}$$

$$y_{\text{TOTAL}} = \frac{1,394,197 \text{ in lb}}{30,725 \text{ lb}} = 45.4 \text{ in}$$

EFFECTIVE FORCE IS 2.6 IN BELOW TOP SPRING SEAT.

Dept. _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date 3-25 1980

Designed by DP

PROJECT M-MSS-010

Sht. No. 23 of 29

Approved by _____

$$M_1 = \frac{1,394,197 \text{ in lb} + 30,725 \text{ lb} (2.6 \text{ in}) - 19,547 \text{ lb} \left(\frac{17.67 \text{ in}}{2} \right)}{8}$$

$$M_1 = 162,673 \text{ in lb}$$

$$F_{\text{THREAD}} = \frac{4(162,673 \text{ in lb}) - (30,725 \text{ lb})(2.6 \text{ in}) + 19,547 \text{ lb} \left(\frac{17.67 \text{ in}}{2} \right)}{2(17.67 \text{ in})} - \frac{19,547 \text{ lb}}{2} + \left(\frac{2}{3 \text{ in}} \right) (162,673 \text{ in lb})$$

$$F_{\text{THREAD}} = 119,714 \text{ lb}$$

SINCE THIS IS LESS THAN F_{YIELD} OF 120,017 lb, THE VALVE CAN WITHSTAND UP TO 17.8 lb/in² JET PRESSURE.


Vertical text on the left margin, possibly bleed-through from the reverse side of the page.

Small, faint mark or text located in the upper left quadrant of the page.



FAULTED COND. SSE-X TRS & RRS COMPARISON

FEBRUARY 1983



ATTACHMENT 1
SHEET 24 OF 24

100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

100

101

102

103

104

105

106

107

108

109

110

111

112


113

114



FAULTED COND. SSE-Y TRS o RRS COMPARISON

FEBRUARY 1983



ATTACHMENT 2
SHEET 25 OF 29

SCALES USED Y 8.0X10 UNITS/IN



ATWOOD & MORRILL CO. INC.

DESIGNERS AND MANUFACTURERS SINCE 1900

285 CANAL STREET • SALEM, MASSACHUSETTS 01970 • 617 744-5690 • TELEX 94-0299 X ~~XXXXXX~~ X ~~XXXXXX~~ X ~~XXXXXX~~

April 3, 1985

Pennsylvania Power & Light Company
Two North Ninth Street
Allentown, PA 18101

Attention: Mr. G.D. Miller

Subject: Susquehanna MSIV's

Gentlemen:

The following is the information you requested on your letter dated March 29, 1985 to Mr. Webber:

- 1 - See enclosed drawing detail for yoke rod threaded portion.
- 2 - The material of the yoke rod is steel 1018. *COLD DRAWN PER TELECON 5/1/85
WITH V.L. BRIGHT. JP*
- 3 - The inside diameter of the hole in the poppet for the pilot valve is *3.500.
- 4 - The maximum diameter of the valve stem at the end which forms the pilot poppet is *4.000.
- 5 - The diameter of the valve stem at the point where it passes through the bonnet is 2.000 +.000 -.002.
- 6 - The dimension of the opening formed between the pilot poppet and its seat in the valve poppet whenever the valve is in the open position is one inch.
- 7 - The outside diameter of the poppet at its upper end stellite facing is *21.475 +.000 -.005.
- 8 - The inside diameter of the valve body against which the stellite facing of the poppet slides is *21.500 +.010 -.000.

NOTE: All dimensions marked * are to be concentric within .003 total indicated reading (TIR).

Vertical text on the left side of the page, possibly a page number or title.




Pennsylvania Power & Light Company
Allentown, PA. 18101
April 3, 1985
Page Two

The dimensions given are proprietary information of Atwood & Morrill Co. and are to be kept confidential. Reproduction of any part thereof or use for purposes other than those expressly designated by Atwood & Morrill Co. is not permitted.

Should you have any questions, please feel free to contact us.

Very truly yours,

ATWOOD & MORRILL CO., INC.



Virgil L. Bright
Supervisor, Product Service

VLB/dab

Enclosure

100

100

100


100

100

100



THIS SURFACE IS TO BE PERPENDICULAR
TO THE ROD AXIS WITHIN .005 TIR.



FOR PLANNING PURPOSES ONLY

Mechanical Properties of Cold-Drawn, Carbon-Steel Bars

AISI No. Size, In.	As Cold Drawn					Cold Drawn Followed by Low-Temperature Stress Relief					Cold Drawn Followed by High-Temperature Stress Relief				
	Strength		Elongation in 2 In., %	Reduction in Area, %	Hardness, Bhn	Strength		Elongation in 2 In., %	Reduction in Area, %	Hardness, Bhn	Strength		Elongation in 2 In., %	Reduction in Area, %	Hardness, Bhn
	Tensile, 1,000 Psi	Yield, 1,000 Psi				Tensile, 1,000 Psi	Yield, 1,000 Psi				Tensile, 1,000 Psi	Yield, 1,000 Psi			
1018, 1025															
½ to ¾ incl.	70	60	18	40	143						65	45	20	45	131
Over ¾ to 1¼ incl.	65	55	16	40	131						60	45	20	45	121
Over 1¼ to 2 incl.	60	50	15	35	121						55	45	16	40	111
Over 2 to 3 incl.	55	45	15	35	111						50	40	15	40	101
1117, 1118															
½ to ¾ incl.	75	65	15	40	149	80	70	15	40	163	70	50	18	45	143
Over ¾ to 1¼ incl.	70	60	15	40	143	75	65	15	40	149	65	50	16	45	131
Over 1¼ to 2 incl.	65	55	13	35	131	70	60	13	35	143	60	50	15	40	121
Over 2 to 3 incl.	60	50	12	30	121	65	55	12	35	131	55	45	15	40	111
1025															
½ to ¾ incl.	85	75	13	35	170	90	80	13	35	179	80	60	16	45	163
Over ¾ to 1¼ incl.	80	70	12	35	163	85	75	12	35	170	75	60	15	45	149
Over 1¼ to 2 incl.	75	65	12	35	149	80	70	12	35	163	70	60	15	40	143
Over 2 to 3 incl.	70	60	10	30	143	75	65	10	30	149	65	55	12	35	131
1040, 1140															
½ to ¾ incl.	90	80	12	35	179	95	85	12	35	187	85	65	15	45	170
Over ¾ to 1¼ incl.	85	75	12	35	170	90	80	12	35	179	80	65	15	45	163
Over 1¼ to 2 incl.	80	70	10	30	163	85	75	10	30	170	75	60	15	40	149
Over 2 to 3 incl.	75	65	10	30	149	80	70	10	30	163	70	55	12	35	143
1045, 1140, 1145															
½ to ¾ incl.	95	85	12	35	187	100	90	12	35	197	90	70	15	45	179
Over ¾ to 1¼ incl.	90	80	11	30	179	95	85	11	30	187	85	70	15	45	170
Over 1¼ to 2 incl.	85	75	10	30	170	90	80	10	30	179	80	65	15	40	163
Over 2 to 3 incl.	80	70	10	30	163	85	75	10	25	170	75	60	12	35	149
1050, 1137, 1151															
½ to ¾ incl.	100	90	11	35	197	105	95	11	35	212	95	75	15	45	187
Over ¾ to 1¼ incl.	95	85	11	30	187	100	90	11	30	197	90	75	15	40	179
Over 1¼ to 2 incl.	90	80	10	30	179	95	85	10	30	187	85	70	15	40	170
Over 2 to 3 incl.	85	75	10	30	170	90	80	10	25	179	80	65	12	35	163
1141															
½ to ¾ incl.	105	95	11	30	212	110	100	11	30	223	100	80	15	40	197
Over ¾ to 1¼ incl.	100	90	10	30	197	105	95	10	30	212	95	80	15	40	187
Over 1¼ to 2 incl.	95	85	10	30	187	100	90	10	25	197	90	75	15	40	179
Over 2 to 3 incl.	90	80	10	20	179	95	85	10	20	187	85	70	12	30	170
1144															
½ to ¾ incl.	110	100	10	30	223	115	105	10	30	229	105	85	15	40	212
Over ¾ to 1¼ incl.	105	95	10	30	212	110	100	10	30	223	100	85	15	40	197
Over 1¼ to 2 incl.	100	90	10	25	197	105	95	10	25	212	95	80	15	35	187
Over 2 to 3 incl.	95	85	10	20	187	100	90	10	20	197	90	75	12	30	179

The tensile and yield strengths of carbon-steel bars are improved by cold drawing. By comparison, the tensile strength of hot-rolled bars is about 10% less, and their yield strength is some 40% less. For example, a low-carbon steel with a yield-to-tensile-strength ratio of about 0.55 in the form of hot-rolled bars will have a ratio of about 0.85 after cold drawing. While there is some sacrifice in elongation, reduction in area, and impact strength, these changes are relatively insignificant in most structural applications or engineering components.

This improvement is of interest to the design engineer seeking a better strength-to-weight ratio or a reduction in costs by the elimination of alloy contents and heat treatment. The enhanced properties may also be useful in applications involving threads, notches, cut-outs, and in other design requirements that might effect strength adversely.

Turned and polished and turned, ground, and polished bars have the mechanical properties of hot-rolled bars.

Minimum values rounds, squares, and hexagons.

Source: AISI Committee of Hot Rolled and Cold Finished Bar Producers.



CALCULATION COVER SHEET

CALC. NO. 17-MSS-006
 FILE NO. 922-60
 SUPERSEDED BY

SAFETY-RELATED
 ASME III OR XI
 OTHER QUALITY
 NON QUALITY

PROJECT SUSQUEHANNA STEAM ELECTRIC STATION

ER/CTN NO. 741058-003

DESIGN ACTIVITY/PMR NUMBER IREIR 101155

PAGE 1 OF 27X

TITLE/DESCRIPTION JET IMPINGEMENT ON MISC. MSIV HARDWARE

STATEMENT OF PROBLEM DETERMINE THE JET IMPINGEMENT EFFECTS OF A 28" RECIRCULATION LINE BREAK AT WELD S1 ON THE HARDWARE ASSOCIATED WITH THE INBOARD MAIN STEAM ISOLATION VALVES WITH RESPECT TO THE PERFORMANCE OF ITS SAFETY FUNCTIONS.

DESIGN BASIS (DC020.0 OR DC020.1)

IT IS ASSUMED THAT AFTER THE BREAK THE PIPE ENDS SEPERATE BY ^{10"} 14 INCHES. THE CALCULATION IS PERFORMED ASSUMING THAT THE JET EXIT ANNULUS CONFIGURATION CAN BE REPRESENTED AS AN OPEN ENDED PIPE OF THE SAME AREA AND THAT THE RESULTS YIELDED ARE REASONABLE APPROXIMATIONS OF THE ACTUAL LOADS, SINCE THE BASIC FORMULAE YIELD CONSERVATIVE RESULTS, THIS SUBSTITUTION WOULD PROBABLY BE SIMILARLY CONSERVATIVE.

REFERENCES/FOMULAE

1. BECHTEL DRAWING C-919, SHEET 1, REV. 6, REACTOR SHIELD DOORS
2. G.G. DWG. FF 113011, SH. 6101, REV 1, N1 RECIRC. OUTLET NOZZLE SAFE END
3. G.E. DWG. 4554-M1-B11-149-2, RECIRC OUTLET NOZZLE N1.
4. TELECON BETWEEN MR. HANS GIESECKE OF MPR ASSOCIATES & MR. D.C. PREVATE (ATTACHMENT 1).
5. ANS 58.2-1987 "... EFFECTS OF POSTULATED PIPE RUPTURE."
6. FSAR TABLE 6A-1 (b).
7. HICKS, STANDARD HANDBOOK OF ENGINEERING CALCULATIONS, 1972, MCGRAW-HILL
8. ATWOOD & MORRILL CO. DWG 21190-14, 26 IN W.E. MAIN STEAM ISOLATION VALVE (ATTACHMENT 5)
9. BAYMEISTER & MARKS, STANDARD HANDBOOK FOR MECHANICAL ENGINEERS, 1967
10. RAYMOND J. BARK, FORMULAS FOR STRESS AND STRAIN IN STEEL
11. ANSI B18.3-1977, MACHINE SCREWS AND MACHINE SCREW NUTS
12. LETTER REPORT FM. MPR ASSOCIATES, INC. DATED JUNE 24, 1985.

SUMMARY/CONCLUSIONS

12. AISC SPEC FOR DESIGN, FAB. AND ERECTION OF STRUCTURAL STEEL FOR BLDGS., 1978
13. ASME CODE SECT III, SUBSECT NC-3000, TABLE 3A13.2 (b)-1
14. SUSQUEHANNA PIPING PROGRAM CODES FOR DRYWELL, 5L, 72"

1. FLEX CONDUIT ASSOCIATED WITH MSIVS WOULD FAIL CAUSING LOSS OF CONTROL ROOM INDICATION AND LOSS OF OPERATING PERMISSIVE FOR INBOARD MSIV LEAKAGE CONTROL SYSTEM.
2. LARGE CONDUIT BOX ATTACHMENT TO MOUNTING PLATE WILL NOT FAIL.
3. CONDUIT BETWEEN POSITION SWITCH AND SMALL JUNCTION BOX WOULD FAIL CAUSING FAILURE OF MSIV-LCS PERMISSIVE AT ITS ATTACHMENT TO THE VALVE
4. THE MOUNTING PLATE FOR THE LARGE CONDUIT BOX WILL FAIL CAUSING A LOSS OF CONTROL ROOM POSITION INDICATION. THE SMALL BOX MOUNTING BRACKET WILL NOT FAIL.
5. LIMIT SWITCHES WILL NOT FAIL
6. HYDRAULIC SPEED CONTROL HARDWARE WILL NOT FAIL.
7. IF BRAIDED FLEX CONDUIT IS SUBSTITUTED FOR REGULAR FLEX CONDUIT, ITEM 1 FAILURE WILL NOT OCCUR.
8. IF 1" XXS PIPE IS SUBSTITUTED FOR 1" CONDUIT ON SMALL JUNCTION BOX, ITEM 3 FAILURE WILL NOT OCCUR.

NO.	DATE	PREPARED BY	REVIEWED/CHECKED BY	DATE	APPROVED BY	DATE
0	5/24/85	DC Prevate	J.S. Wales	6-25-85	Frank J. Cypko	6/28/85
1	10/14/85	DC Prevate	J.S. Wales	10-18-85	Frank J. Cypko	10/21/85

DC110.0-A REV. 0

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

海

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



Dept. NPE-MECH
Date 5/24, 1985
Designed by [Signature]
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. 741058-003
Sht. No. 2 of 27x

PROJECT JET IMPINGEMENT ON
MSIV HARDWARE, CALC. # M-
MSS-006




FIGURE 1

SCALE: $\frac{3}{4}" = 1'$

(SKETCHED FROM DIMENSIONS GIVEN ON REFS. 1, 2, & 3.)

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200



Dept. NPE-MECH

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. 741058-003

Date 5/24 1985

Designed by R. R. Smith

PROJECT JET IMPINGEMENT ON

Sht. No. 9 of 27X

Approved by _____

M51V HARDWARE, CALC # M-
MSS-006

FIGURE 1 DESCRIBES THE PHYSICAL SITUATION THAT EXISTS AT THE TIME THE RECIRC. PUMP SIDE OF THE BREAK COMES TO REST AT A STEADY STATE CONDITION. STEAM ESCAPING FROM THE TWO OPEN ENDS WOULD MEET AND TURN RADially OUTWARD. WHERE IT WOULD ENCOUNTER THE INSIDE DIAMETER OF THE BIOLOGICAL SHIELD DOORS WHICH WOULD TEND TO DEFLECT THE FLOW AXIALLY ALONG THE PIPE OUTWARD IN BOTH DIRECTIONS. IT IS ASSUMED THE INSULATION WOULD BE BLOWN AWAY. THE FLOW TOWARD THE REACTOR VESSEL WOULD PRESSURIZE THE ANNULUS BETWEEN THE VESSEL AND THE BIO SHIELD. THE FLOW OUTWARD WOULD EXHAUST INTO THE DRYWELL. DUE TO THE HIGHER BACK PRESSURE IN THE BIO SHIELD ANNULUS AND THE LOCATION OF THE BREAK GAP AT THE DRYWELL SIDE OPENING IN THE SHIELD DOOR, MOST OF THE FLOW WOULD BE IN THE DIRECTION AWAY FROM THE REACTOR VESSEL. ADDITIONALLY, BECAUSE OF THE RELATIVELY LOW FLOW RESISTANCE THROUGH THE NOZZLE N1 COMPARED TO THE RESISTANCE THROUGH THE PUMP SIDE PIPING, THE FLOW FROM THE VESSEL SIDE WOULD BE THE PREDOMINANT SOURCE, AND PART OF ITS MOMENTUM WOULD CARRY OVER TO THE JET MOVING AWAY FROM THE VESSEL.

FROM REF. ¹⁵ ~~A~~ THE FLOW IN THE OUTWARD DIRECTION IS ^{11,541} ~~10,544~~ lb/sec, AND THE PRESSURE IN THE ANNULUS AROUND THE BREAK IS ³²⁵ ~~325~~ PSIG. FOR A BREAK SEPARATION OF ¹⁰ ~~14~~ INCHES. 279

CIRCUMFERENTIAL AREA OF THE GAP BETWEEN THE BREAK ENDS:

$$A_{GAP} = \pi (d)(gap) = \pi (28 \text{ in})(14 \text{ in})$$

$$A_{GAP} = 1231.50 \text{ in}^2 = 8.552 \text{ FT}^2$$

EXIT ANNULUS AREA BETWEEN PIPE O.D. AND SHIELD DOOR I.D.:

$$A_e = \pi/4 [(3'10")^2 - (28")^2]$$

$$A_e = 1046.15 \text{ in}^2 = 7.265 \text{ FT}^2$$

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

Dept. NYE-MECH
Date 10-17 1985
Designed by DePue
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

PROJECT CALC M-155-006, REV 1

ER No. 741058-003

Sht. No. 4 of 27X


FROM REF. 5, PAGE 10, EQUATION 6-2, THE THRUST FORCE FOR STEADY STATE IS:

$$T = \rho_e U_e^2 A_e + P_e A_e$$

WHERE: ρ_e = MASS DENSITY OF THE FLUID AT EXIT = 3.122 lb/ft^3 (PER REF. 15)
 U_e = EXIT VELOCITY OF THE FLUID
 A_e = EXIT AREA = 7.265 FT^2
 P_e = EXIT PRESSURE = 279 PSIG (PER REF. 15)

$$\text{VOLUOMETRIC FLOW RATE} = \frac{\text{MASS FLOW RATE}}{\text{DENSITY}} = \frac{\dot{m}}{\rho_e} = \frac{11,541 \text{ lbm/SEC}}{3.122 \text{ lbm/ft}^3} = 3696.7 \text{ ft}^3/\text{SEC}$$





Dept. NPE-MECH
Date 5/24/1985
Designed by AL. Savatka
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET
PROJECT JET IMPINGEMENT ON
MSIV HARDWARE, CALC # M-
MSS-006

ER No. 747058-003
Sht. No. 5 of 27 X

$$\text{exit velocity, } U_e = \frac{\text{volumetric flow rate}}{\text{exit area, } A_e} = \frac{3,696.7}{7.265 \text{ ft}^2} = \frac{508.8}{326.2} \text{ ft/sec}$$

SUBSTITUTING INTO THRUST EQUATION:

$$T = \rho_a U_e^2 A_e + P_e A_e$$

$$T = \left(\frac{3.122}{4.4739} \text{ lbm/ft}^3 \right) (508.8 \text{ ft/sec})^2 (7.265 \text{ ft}^2) + \left(\frac{279}{3256} \text{ lb/in}^2 \right) \times$$

$$T = \left(\frac{5,871,685}{5,457,743} \text{ ft}^2 \text{ lbm/sec}^2 \right) \times \frac{1 \text{ lb} \times}{32.2 \text{ ft}^2 \text{ lbm/sec}^2} + \frac{291,879}{540,002} \text{ lb}$$

$$T = \frac{182,350}{107,383} \text{ lb} + \frac{291,879}{540,002} \text{ lb}$$

$$T = \frac{474,229}{441,385} \text{ lb}$$

ASSUME THE JET IS EQUIVALENT TO AN OPEN ENDED PIPE WITH AN AREA EQUAL TO THE ACTUAL ANNULUS EXIT AREA, A_e . SINCE THE LENGTH OF TRAVEL OF THE STEAM IN THE AXIAL DIRECTION AFTER LEAVING THE BREAK GAP IS VERY SHORT, AND SINCE THE PUMP SIDE END IS ACTUALLY SLIGHTLY OUTSIDE THE SHIELD DOOR, ASSUME THE MAXIMUM EXPANSION GIVEN BY FIGURE C-2 OF REF. 5 FOR SATURATED WATER.

$$\frac{A_a}{A_e} = 100 \quad \text{where } A_a = \text{area of asymptotic plane per Appendix C of Ref. 5.}$$

$$A_a = 100 A_e = 100 (7.265 \text{ ft}^2)$$

$$A_a = 726.5 \text{ ft}^2$$

Find exit and asymptotic plane diameters.

$$D_e = \sqrt{\frac{4 A_a}{\pi}} = \sqrt{\frac{4 (726.5 \text{ ft}^2)}{\pi}} = 3.0414 \text{ ft}$$

100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120

121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142

143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164



Dept. NPE-MECH

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. 741058-003

Date 5/24/1985

Designed by [Signature]

PROJECT JET IMPINGEMENT ON

Sht. No. 6 of 27 X

Approved by _____

MSIV HARDWARE, CALC # M-
MSS-006

$$D_a = \sqrt{\frac{4 A_a}{\pi}} = \sqrt{\frac{4(726.5 \text{ ft}^2)}{\pi}} = 30.414 \text{ ft}$$

From equation C-2, Ref. 5,

$$\frac{L_a}{D_e} = \frac{1}{2} \left(\sqrt{\frac{A_a}{A_e}} - 1 \right)$$

$$L_a = 4.5 D_e = 4.5 (3.0414 \text{ ft})$$

$$L_a = 13.686 \text{ ft}$$

BY ACTUAL MEASUREMENT, THE DISTANCE TO IMPINGEMENT TARGETS ON INSD. MSIV'S RANGES FROM APPROXIMATELY 8' TO 13' FROM THE EXIT AREA. PER APPENDIX C, REF. 5, THE EXPANSION IS ASSUMED TO BE LINEAR OUT TO THE ASYMPTOTIC PLANE. THE AREA GIVEN BY EQUATION C-4 IS (USE T SUBSCRIPT FOR TARGETS):

$$A_{JET} = A_e + \frac{L_T}{L_a} (A_a - A_e)$$

$$A_{JET} = 7.265 \text{ ft}^2 + 52.55 \text{ ft} (L_T)$$

FOR $L_T = 8'$, $D_T = 23.335 \text{ ft}$, $A_T = 427.67 \text{ ft}^2$

$L_T = 9'$, $D_T = 24.727 \text{ ft}$, $A_T = 480.22 \text{ ft}^2$

$L_T = 10'$, $D_T = 26.045 \text{ ft}$, $A_T = 532.79 \text{ ft}^2$

$L_T = 11'$, $D_T = 27.300 \text{ ft}$, $A_T = 585.32 \text{ ft}^2$

$L_T = 12'$, $D_T = 28.500 \text{ ft}$, $A_T = 637.87 \text{ ft}^2$

$L_T = 13'$, $D_T = 29.650 \text{ ft}$, $A_T = 690.42 \text{ ft}^2$

ASSUMING THE TOTAL FORCE AT ANY TARGET DISTANCE IS CONSTANT AND EQUAL TO THE THRUST FORCE (A CONSERVATIVE ASSUMPTION), THEN THE PRESSURE ON ANY TARGET IN THE TARGET PLANE WOULD BE THE THRUST

Dept. NPE-MECH

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. 741058-003

Date 5/24/1985

Designed by DR. [Signature]

PROJECT JET IMPINGEMENT ON

Sht. No. 7 of 27X

Approved by _____

MSIV HARDWARE, CALC # M-
MSS-006

DIVIDED BY THE TARGET PLANE AREA:

$$P_T = \frac{T}{A_T} = \frac{474,229}{447,385} \text{ lb/in}^2$$

For $L_T = 8'$, $P_T = 7.7 \text{ lb/in}^2$

$L_T = 9'$, $P_T = 6.9 \text{ lb/in}^2$

$L_T = 10'$, $P_T = 6.2 \text{ lb/in}^2$

$L_T = 11'$, $P_T = 5.6 \text{ lb/in}^2$

$L_T = 12'$, $P_T = 5.2 \text{ lb/in}^2$

$L_T = 13'$, $P_T = 4.8 \text{ lb/in}^2$

MISC. MSIV TARGETS POTENTIALLY AFFECTING SAFETY FUNCTION:

1. CONDUIT (FLEX & RIGID), SIZES $\frac{3}{4}$ ", 1", & $1\frac{1}{2}$ ".
2. JUNCTION BOXES (LARGE & SMALL).
3. JUNCTION BOX MOUNTING PLATES.
4. LIMIT SWITCHES.
5. HYDRAULIC SPEED CONTROL HARDWARE.
6. I-BEAM IN FRONT OF OPERATOR

CONDUIT

THE CLOSEST CONDUIT TARGET IS AT VALVES A & D AT ≈ 9 FT RANGE. THE MOST EXPOSED CONDUIT IS THE FLEX CONDUIT SUPPLIED BY THE AMERICAN BOA COMPANY. PER THE VENDOR CATALOG, THE FOLLOWING DATA IS APPLICABLE FOR THE THREE SIZES USED:

Dept. NPE-MECH
Date 5/24/1985
Designed by [Signature]
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. 741058-003

PROJECT JET IMPINGEMENT ON
MSIV HARDWARE, CALC # M-
MSS-006

Sht. No. 8 of 27X

<u>NOMINAL</u> <u>DIA.</u>	<u>OUTSIDE</u> <u>DIA.</u>	<u>MAX. ALLOWABLE INTERNAL</u> <u>PRES. (INCLUDES 4 TO 1 SAFETY FACTOR)</u>
3/4"	1.04"	72 PSI
1"	1.24"	60 PSI
1 1/2"	1.91"	40 PSI

THE PRESSURES INDICATED ARE THE PRESSURES AT WHICH THE BELLOWS TUBING STARTS TO STRETCH OUT. THE EQUIVALENT TENSILE LOAD WOULD BE:

$$L_T = P A$$

$$L_{T \frac{3}{4}"} = (72 \text{ lb/in}^2)(\pi)\left(\frac{1.04 \text{ in}}{2}\right)^2 = 61 \text{ lb}$$

$$L_{T 1"} = (60 \text{ lb/in}^2)(\pi)\left(\frac{1.24 \text{ in}}{2}\right)^2 = 72 \text{ lb}$$

$$L_{T 1 \frac{1}{2}"} = (40 \text{ lb/in}^2)(\pi)\left(\frac{1.91 \text{ in}}{2}\right)^2 = 115 \text{ lb}$$

FLEX CONDUIT TYPICAL EXPOSURE LENGTHS \approx 3 FT.

$$\text{TARGET AREA} = A_x = (\text{DIA})(\text{LENGTH})$$

$$A_{x \frac{3}{4}"} = (1.04 \text{ in})(36 \text{ in}) = 37.44 \text{ in}^2$$

$$A_{x 1"} = (1.24 \text{ in})(36 \text{ in}) = 44.64 \text{ in}^2$$

$$A_{x 1 \frac{1}{2}"} = (1.91 \text{ in})(36 \text{ in}) = 68.76 \text{ in}^2$$

FROM EQ D-5 & D-6 REF 5, $F_{imp} = K_\phi P_{JET} A_{target}$

where $K_\phi = \frac{1}{2} C_D$ (DRAG COEF.)

FROM TABLE D-1 FOR CIRCULAR CYLINDER FOR TURBULENT FLOW, $C_D = 1.2$

$$\therefore K_\phi = .6$$

$$F_{imp \frac{3}{4}"} = .6 (62.9 \text{ lb/in}^2)(37.44 \text{ in}^2) = 155.0 \text{ lb}$$



一

二

三

四

五

六

七

八

九

十

十一

十二

十三

十四

十五

十六

十七

十八

十九

二十

二十一

二十二

二十三

二十四

二十五

二十六

二十七

二十八

二十九

三十

Dept. NPE-MECH

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. 74-058-003

Date 5/24 1985

Designed by DC P... ..

PROJECT JET IMPINGEMENT ON

Sht. No. 9 of 27X

Approved by _____


MSNY HARDWARE, CALC # M-
MSS-006

$$F_{imp 1''} = .6 (6.916 / in^2) (44.44 in^2) = 184.8 \text{ lb}$$

$$F_{imp 1\frac{1}{2}''} = .6 (6.916 / in^2) (68.76 in^2) = 284.7 \text{ lb}$$

SINCE FLEX CONDUIT CAN ONLY SUPPORT A TENSILE LOAD, IT WILL FORM A CATENARY WHEN UNIFORMLY LOADED. FROM PAGE 1-17, REF. 7, MID-SPAN TENSION:

$$H = WL^2 / 8d$$



WHERE W = LOAD / UNIT LENGTH HORIZONTAL
 L = LENGTH BETWEEN SUPPORTS
 d = SAG = ASSUME 9" TYPICAL.

$$H_{3/4''} = \frac{(155.016 / 36 in.) (36 in.)^2}{8 (9 in.)} = 77.5 \text{ lb}$$

$$H_{1''} = \frac{(184.8 \text{ lb} / 36 in.) (36 in.)^2}{8 (9 in.)} = 92.4 \text{ lb}$$

$$H_{1\frac{1}{2}''} = \frac{(284.716 / 36 in.) (36 in.)^2}{8 (9 in.)} = 142.4 \text{ lb}$$

SINCE EACH OF THESE LOADS IS SOMEWHAT HIGHER THAN THE MAXIMUM ALLOWABLE FOR THE RESPECTIVE CONDUITS INCLUDING THEIR 4-TO-1 SAFETY FACTORS, THESE CONDUITS WOULD FAIL BY STRETCHING OUT POSSIBLY CAUSING THE CABLE INSIDE TO BREAK OR BE DETERMINATED.

MAXIMUM DISTANCE OF CONDUIT BLAST TARGET \approx 13 FT, $P_T = 4.8 \text{ lb}/in^2$.

$$F_{imp 3/4''} = .6 (4.8 \text{ lb}/in^2) (37.44 in^2) = 107.8 \text{ lb}$$

$$F_{imp 1''} = .6 (4.8 \text{ lb}/in^2) (44.44 in^2) = 128.6 \text{ lb}$$

$$F_{imp 1\frac{1}{2}''} = .6 (4.8 \text{ lb}/in^2) (68.76 in^2) = 198.0 \text{ lb}$$

Handwritten text, possibly a list or index, located on the left side of the page. The text is extremely faint and illegible.

Small handwritten mark or characters.



Dept. NPE-MECH
Date 5/24 1985
Designed by AC P...
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET
PROJECT JET IMPINGEMENT ON
MSIV HARDWARE, CALC # M-
MSS-006

ER No. 741058-003
Sht. No. 10 of 27X

$$H_{3/4}'' = \frac{\left(\frac{108 \text{ lb}}{36 \text{ in}}\right) (36 \text{ in})^2}{8 (9 \text{ in})} = 54 \text{ lb}$$

$$H_1'' = \frac{\left(\frac{124 \text{ lb}}{36 \text{ in}}\right) (36 \text{ in})^2}{8 (9 \text{ in})} = 65 \text{ lb}$$

$$H_{1/2}'' = \frac{\left(\frac{198 \text{ lb}}{36 \text{ in}}\right) (36 \text{ in})^2}{8 (9 \text{ in})} = 99 \text{ lb}$$

FROM REF. 7, PAGE 1-17, TENSION AT SUPPORTS:

$$T = \left[H \frac{WL}{2} \right]^{.5}$$

$$T_{3/4}'' = \left[(54 \text{ lb})^2 + \left(\frac{108 \text{ lb}}{2}\right)^2 \right]^{.5} = 76.4 \text{ lb}$$

$$T_1'' = \left[(65 \text{ lb})^2 + \left(\frac{124 \text{ lb}}{2}\right)^2 \right]^{.5} = 91.9 \text{ lb}$$

$$T_{1/2}'' = \left[(99 \text{ lb})^2 + \left(\frac{198 \text{ lb}}{2}\right)^2 \right]^{.5} = 140.0 \text{ lb}$$



EACH OF THESE LOADS IS LESS THAN THE ALLOWABLE LOAD IF THERE IS NO FACTOR OF SAFETY. HOWEVER, THE TENSION AT THE END CONNECTIONS MAY BE HIGHER.


SINCE THESE FORCES ARE GREATER THAN THE RESPECTIVE ALLOWABLES, THE CONDUITS WOULD FAIL.

JUNCTION BOXES

LOADS ON JUNCTION BOXES = DIRECT BLAST LOADS + LOADS IMPOSED BY FLEX CONDUIT DUE TO BLAST.

FROM REF. 8 DIMENSIONS OF LARGE JUNCTION BOX - 10" X 12" X 5"

RANGE TO JUNCTION BOX, VALVED \approx 9 FT, $P_T = 6.9 \text{ lb/in}^2$



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200



Dept. NPE-MECH

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. 741056-003

Date 5/24/1985

Designed by DC Powell

PROJECT JET IMPINGEMENT ON

Sht. No. 11 of 27

Approved by _____

MS1V HARDWARE, CALC # M-
MSS-006

FOR FLAT SURFACE $K_{\phi} = \cos \phi$ (FM FIG D-1, REF 5)

IMPINGEMENT FORCE ON 12" SIDE OF BOX:

$$F_{imp} = (\cos 45^{\circ}) (\text{AREA}) (\text{PRES.})$$

$$F_{imp} = (.707) (12" \times 5") (6.916 \text{ lb/in}^2)$$

$$F_{imp} = 293 \text{ lb}$$

VALVE D'S LARGE JUNCTION BOX HAS ONE 1 1/2" FLEX CONDUIT ATTACHED, THREE 1 INCHERS, & ONE 3/4 INCHER. FORCES APPLIED BY THESE CONDUITS TO THE BOX ARE GIVEN BY REF 7, PAGE 1-17.

TENSION AT SUPPORTS (CONNECTIONS TO BOX) = $T = [H^2 + (WL/2)^2]^{0.5}$

$$T_{3/4"} = \left[(77.5 \text{ lb})^2 + \left(\frac{155.0 \text{ lb}}{2} \right)^2 \right]^{0.5} = 109.6 \text{ lb}$$

$$T_{1"} = \left[(92.4 \text{ lb})^2 + \left(\frac{184.8 \text{ lb}}{2} \right)^2 \right]^{0.5} = 130.7 \text{ lb}$$

$$T_{1 1/2"} = \left[(142.4 \text{ lb})^2 + \left(\frac{284.7 \text{ lb}}{2} \right)^2 \right]^{0.5} = 201.4 \text{ lb}$$

RESUME THAT DUE TO SHADOWING ANGLE, ETC., ONLY HALF THE FORCE IS TRANSMITTED TO THE BOX. THEN, FORCE IN JET DIRECTION ON BOX IS:

$$F_{cond} = \frac{109.6 \text{ lb} + 3(130.7 \text{ lb}) + 201.4 \text{ lb}}{2} = 351.6 \text{ lb}$$

$$\begin{aligned} \text{COMPONENT OF } F_{cond} \text{ PERPENDICULAR TO 12" SIDE} &= 351.6 \text{ lb} \times \cos \phi \\ &= 248.6 \text{ lb} \end{aligned}$$

TOTAL FORCE IN DIRECTION PERPENDICULAR = DIRECT JET + CONDUIT FORCE TO MOUNTING PLATE

$$= 293 \text{ lb} + 249 \text{ lb} = 542 \text{ lb}$$

Vertical text on the left side of the page, possibly bleed-through from the reverse side. The text is faint and difficult to decipher but appears to be organized into several lines.



Dept. NPE-MECH

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. 741058-003

Date 5/24 1985

Designed by J.C. Penno

PROJECT JET IMPINGEMENT ON

Sht. No. 12 of 27 X

Approved by _____

MSIV HARDWARE, CALC # M-
MSS-006

LOOKING AT THE ATTACHMENT OF THE BOX TO THE MOUNTING PLATE (SEE REF 8, SHEET 2) THE FORCE ON THE 12" SIDE WOULD CREATE A MOMENT WHICH WOULD BE RESISTED PRIMARILY BY A COUPLE BETWEEN THE TWO TOP LIMIT SWITCHES' CONDUITS (1") (SEE REF 14.)

LEVER ARM FROM CENTER OF AREA OF 12" SIDE TO CONDUIT THREADS AT LIMIT SWITCHES = 4.5 IN.

$$\text{MOMENT} = (\text{FORCE}) (\text{LEVER ARM}) = (542 \text{ lb}) (4.5 \text{ in}) = 2439 \text{ in lb}$$

SEPARATION BETWEEN CONDUIT CENTERS = 3.5 IN

$$\text{FORCE IN CONDUIT} = \frac{\text{MOMENT}}{\text{SEPARATION}} = \frac{2439 \text{ in lb}}{3.5 \text{ in}} = \pm 697 \text{ lb}$$

ATTACHMENTS 2 & 3 ARE PAGES FROM AN ELECTRICAL SUPPLY CATALOG. ASSUME THAT THE PROPERTIES GIVEN ARE TYPICAL FOR RIGID CONDUIT. FOR 1" RIGID CONDUIT:

$$\text{O. D.} = 1.315 \text{ "}$$

$$\text{I. D.} = 1.049 \text{ "}$$

$$\text{WALL THICKNESS} = .133 \text{ "}$$

MATERIAL - MILD STEEL, 35,000-40,000 YSI YIELD STRENGTH

ASSUME THAT FAILURE OF CONDUIT WOULD BE MOST LIKELY TO OCCUR IN THE THREADS AT THE MINOR DIAMETER.

ASSUME CONDUIT THREADS ARE "FREE FITTING" PER TABLE 15, PAGE 8-25, OF REF. 9. MINOR DIAMETER = 1.181", 11 1/2 THREADS / IN.

$$\text{MINIMUM AREA} = \frac{\pi}{4} [\text{O. D.}^2 - \text{I. D.}^2] = \frac{\pi}{4} [(1.315 \text{ in})^2 - (1.181 \text{ in})^2] = .2027 \text{ in}^2$$

$$\text{ASSUME RADIUS AT BOTTOM OF THREADS} = \frac{1}{8} \text{ PITCH} = .125 \left(\frac{1}{11.5 \text{ THDS/IN}} \right)$$

$$= .01087 \text{ in}$$

$$\text{RATIO OF ROOT RADIUS TO MINOR DIA.} = \frac{r}{d} = \frac{.01087 \text{ in}}{1.181 \text{ in}} = .0092$$

72

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27



Dept. NPE-MECH
Date 5/24 1985
Designed by [Signature]
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET
PROJECT JET IMPINGEMENT ON
MSIV HARDWARE, CALC # M-
MSS-006

ER No. 741058-003
Sht. No. 17 of 27X

FM. REF. 10, TABLE XIII, CASE 12, FOR ELASTIC STRESS IN TENSION, THE STRESS CONCENTRATION FACTOR, $K = 3.4$ FOR $\frac{r}{d} = .05$, THE HIGHEST K SHOWN.

FROM REF. 13, STRESS CONCENTRATION FACTOR FOR THREADED PIPE IS 2.3. USE 3.0

$$\text{THEN STRESS} = \sigma = \frac{P}{A} \cdot K = \frac{697,116}{.2027 \text{ in}^2} \cdot 3 = 1,046,000 \text{ lb/in}^2$$

SINCE THIS IS LESS THAN THE YIELD STRENGTH OF THE MATERIAL, WE WILL HAVE NO FAILURE.

SMALL JUNCTION BOX (SEE REF. 14)

DIMENSIONS OF EXPOSED SURFACE (FROM PICTURE BOXES) $\approx 5" \times 4" = 20 \text{ in}^2$

TARGET DISTANCE $\approx 9 \text{ FT.}$, PRESSURE = 6.9 lb/in^2

ANGLE OF TARGET $\approx 0^\circ$

$$\text{FORCE} = PA = (6.9 \text{ lb/in}^2)(20 \text{ in}^2) = 138 \text{ lb.}$$

DUE TO SHADOWING, ASSUME ONLY HALF THE CONDUIT LOAD IS TRANSMITTED TO THE BOX. THERE IS ONE 1" CONDUIT ATTACHED.

$$F_{\text{COND}} = \frac{130.7 \text{ lb}}{2} \text{ (FM. SHEET 11)} = 65.4 \text{ lb}$$

TOTAL FORCE ON BOX = PRES. FORCE + CONDUIT FORCE

$$= 138 \text{ lb} + 65 \text{ lb} = 203 \text{ lb}$$

THIS FORCE WOULD CREATE A MOMENT IN THE 1" CONDUIT ATTACHING IT TO THE LIMIT SWITCH. STRESS IN THE CONDUIT WOULD BE:

$$\sigma = \frac{MC}{I}$$

where $M = \text{MOMENT} = 203 \text{ lb} \times 4.5 \text{ in} = 913.5 \text{ in lb}$
 $C = \text{MINOR DIA.} = 1.181 \text{ in}$

Vertical text on the left side of the page, possibly bleed-through from the reverse side. The text is faint and difficult to decipher but appears to contain several lines of characters.

Small, faint mark or character located in the upper left quadrant of the page.

Small, faint mark or character located in the upper right quadrant of the page.



Dept. NPE-MECH
Date 5/24/1985
Designed by DC Pomeroy
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET
PROJECT JET IMPINGEMENT ON
MSIV HARDWARE, CALL # M-
MSS-006

ER No. 741058-003
Sht. No. 14 of 27X

$$I = .25 \pi [r_o^4 - r_i^4] = .25 \pi \left[\left(\frac{\text{MIN DIA.}}{2} \right)^4 - \left(\frac{I.D.}{2} \right)^4 \right]$$

$$I = .25 \pi \left[\left(\frac{1.181 \text{ IN}}{2} \right)^4 - \left(\frac{1.049 \text{ IN}}{2} \right)^4 \right]$$

$$I = .03605 \text{ IN}^4$$



$$\sigma = \frac{(913.5 \text{ IN LB})(1.181 \text{ IN})}{.03605 \text{ IN}^4} = 29,926 \text{ LB/IN}^2$$

APPLYING A STRESS CONCENTRATION FACTOR AT THE THREADS OF 3.0;

$$\sigma = 3.0 \times 29,926 \text{ LB/IN}^2 = 89,779 \text{ LB/IN}^2 \text{ MAX.}$$

SINCE THIS STRESS IS GREATER THAN THE YIELD STRESS OF THE MATERIAL BY A FACTOR OF APPROXIMATELY 129%, THIS CONDUIT WOULD BEND AND POSSIBLY CAUSE FAILURE OF THE CABLE INSIDE.

JUNCTION BOX MOUNTING PLATE



AREA OF MOUNTING PLATE IN X-DIRECTION = $5.5 \text{ IN} \times 24 \text{ IN} = 132 \text{ IN}^2$

RANGE OF MOUNTING PLATE \approx 9 FT, $P = 6.9 \text{ LB/IN}^2$

FORCE IN X-DIRECTION = $F_x = PA \sin \phi = (6.9 \text{ LB/IN}^2)(132 \text{ IN}^2)(\sin 45^\circ) = 644.0 \text{ LB}$

11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100




Dept. NPE-MECH
 Date 5/24 19 85
 Designed by DC [Signature]
 Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
 CALCULATION SHEET

ER No. 741058-003

PROJECT JET IMPINGEMENT ON
MSIV HARDWARE, CALL # M-
MSS-006

Sht. No. 15 of 27 X



THE BOTTOM ATTACHMENT FOR THE SWITCH PLATE CAN PROVIDE VERY LITTLE MOMENT RESISTANCE IN X DIRECTION. ∴ ASSUME ALL MOMENT IS ABSORBED BY TOP PLATE. MOMENT AT BOLT SLOT HOLES DUE TO FORCE F_x IS:

$$M_x = (F_x)(\text{LEVER ARM}) = (644 \text{ lb})(11.25 \text{ in}) = 7,245 \text{ in lb}$$

MOMENT DUE TO LARGE CONDUIT BOX FORCES IN X-DIRECTION IS:

$$M = (F)(\text{LEVER ARM})$$

where $F = 542 \text{ lb}$ (FROM SHEET II)

$$\begin{aligned} \text{LEVER ARM} &= 4.5 \text{ in (FROM SHT. 12)} + 14 \text{ in (FROM SKETCH ABOVE)} \\ &= 18.5 \text{ in} \end{aligned}$$

$$M = (542 \text{ lb})(18.5 \text{ in}) = 10,027 \text{ in lb}$$

$$\text{TOTAL MOMENT} = M_T = M_x + M = 7,245 \text{ in lb} + 10,027 \text{ in lb} = 17,272 \text{ in lb}$$

TWO BOLTS $\approx 5 \frac{1}{2}$ " APART IN THE SLOTS SHOWN IN THE SKETCH ABOVE RESIST THIS MOMENT WITH A COUPLE WHICH GENERATES A FORCE WHICH TENDS TO OPEN THE SLOT ON THE SAME SIDE AS THE APPLIED FORCE.

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44



Dept. NPE-MECH

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. 741058-003

Date 5/24/1985

Designed by [Signature]

PROJECT JET IMPINGEMENT ON

Sht. No. 16 of 27X

Approved by _____

MSIV HARDWARE, CALC. # M-
MSS-006

$$\text{THIS FORCE IS} = \frac{M_T}{\text{DISTANCE BETWEEN CTRS.}} = \frac{17,272 \text{ in lb}}{5.5 \text{ in}} = 3,140 \text{ lb.}$$

THIS FORCE CREATES A SHEAR PLANE ACROSS THE EAR OF THE SLOT. THE PLATE IS $\frac{1}{4}$ " THICK BY $\frac{3}{4}$ " WIDE.

$$\text{SHEAR AREA} = \frac{1}{4} \times \frac{3}{4} = .1875 \text{ in}^2$$

FROM REF. 10, TABLE XVII, CASE 8, ASSUME STRESS CONCENTRATION FACTOR FOR BENDING AND SHEAR ARE THE SAME, $k_f = 2$, $\frac{r}{A} = .5$. THEN $k = 1.23$.

$$\text{SHEAR STRESS} = \left(\frac{3,140 \text{ lb}}{.1875 \text{ in}^2} \right) 1.23 = 20,598 \text{ lb/in}^2$$

FROM TABLE 3.8-8 OF FSAR, FOR NONNORMAL LOADS, ALLOWABLE SHEAR STRESS = $\frac{1}{2}$ YIELD STRESS. PER TELESON WITH ATWOOD & MARRILL, MATERIAL IS A-515, GRADE 70. PER ASME B & PV CODE, SECT II, PART A, SPEC SA-515, YIELD STRENGTH IS 38,000 PSI.

$$\sigma_{\text{ALLOW SHEAR}} = .5 (38,000 \text{ lb/in}^2) = 19,000 \text{ lb/in}^2$$

SINCE THE ACTUAL SHEAR STRESS EXCEEDS THE ALLOWABLE, THE MOUNTING BRACKET WILL FAIL AT THE BOLT SLOTS. SUCH A FAILURE COULD INCAPACITATE THE CONTROL ROOM INDICATION CLOSED LIMIT SWITCH.

FOR SMALL CONDUIT BOX SIDE:

$$M = (203 \text{ lb}) (18.5 \text{ in}) = 3,756 \text{ lb in.}$$

$$\text{TOTAL MOMENT} = M_x + M = 7,245 \text{ lb in} + 3,756 \text{ lb in} = 11,001 \text{ in lb}$$

$$\text{SHEAR FORCE} = \frac{11,001 \text{ in lb}}{5.5 \text{ in}} = 2,000 \text{ lb}$$

$$\text{SHEAR STRESS} = \left(\frac{2,000 \text{ lb}}{.1875 \text{ in}^2} \right) 1.23 = 13,120 \text{ lb/in}^2$$

Vertical text on the left side of the page, possibly a page number or header.



Dept. NPE-MECH

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____

Date 5/19/1985

Designed by PP&L

PROJECT CALC # M-MSS-006

Sht. No. 17 of 27X

Approved by _____

THIS STRESS DOES NOT EXCEED THE ALLOWABLE. THE MOUNTING BRACKET WILL NOT FAIL.

LIMIT SWITCHES

ALL LIMIT SWITCHES ARE MOUNTED IN SUCH A MANNER AS TO BE SHADOWED BY OTHER HARDWARE OR OTHERWISE PROTECTED FROM THE DIRECT JET EFFECTS. HOWEVER, IN THE CASE OF THE "A" & "B" VALVES THE BENDING MOMENT APPLIED BY THE BLAST ON THE SMALL JUNCTION BOX MAY CREATE EXCESSIVE STRESSES IN THE ATTACHMENTS FOR THE SWITCH (4 MACHINE SCREWS).

FROM SHEET 13, TOTAL FORCE ON LIMIT SWITCH FROM SMALL JUNCTION BOX IS 203 lb. ATTACHMENT 4 SHOWS THE DIMENSIONS FOR THE W MOUNTING 2NO-2NC SWITCH USED. USING THESE DIMENSIONS, THE DISTANCE FROM THE CENTER OF FORCE TO THE PIVOT POINT IS: (4.5 IN FROM CENTER OF AREA TO SWITCH.)

$$4.5 \text{ IN} + 7.06 \text{ IN} - .41 \text{ IN} - .6 \text{ IN} - .53 \text{ IN} + .28 \text{ IN} = 10.24 \text{ IN}$$

DISTANCE FROM CENTER OF FORCE TO SCREWS NEAREST BOX IS:

$$4.5 \text{ IN} + 7.06 \text{ IN} - .41 \text{ IN} - .6 \text{ IN} - .53 \text{ IN} - 4.38 \text{ IN} = 5.58$$

$$\text{FORCE AT SCREWS NEAREST BOX IS } = \frac{10.24 \text{ IN}}{5.58 \text{ IN}} (203 \text{ LB}) = 373 \text{ LB}$$

ASSUME EACH SCREW HOLDS HALF THE LOAD. THEN LOAD PER SCREW IS:

$$L = \frac{373 \text{ LB}}{2} = 187 \text{ LB}$$

LIMIT SWITCHES ARE MOUNTED WITH $\frac{1}{4}$ " MACHINE SCREWS (SEE ATTACHMENT 4).

FROM REF 11, SECT. 2.7, MINIMUM TENSILE STRENGTH OF MACHINE SCREW MATERIALS IS 60,000 PSI

FROM REF 12, TABLE 1.5.2.1, ALLOWABLE STRESSES ON FASTENERS, FOR MACHINE SCREWS THE ALLOWABLE STRESS IS .33 TIMES TENSILE STRENGTH BASED ON "STRESS AREA". FOR MACHINE SCREWS THE ALLOWABLE

$$\sigma_{\text{ALLOW}} = .33 (60,000 \text{ PSI}) = 20,000 \text{ PSI}$$

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1

THE UNIVERSITY OF CHICAGO




Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date 5/24 1985 CALCULATION SHEET
 Designed by W. R. [Signature] PROJECT CALC # M-MSS-006 Sht. No. 18 of 27X
 Approved by _____

FROM TABLE 1, PAGE 8-14, REF 9, FOR 1/8" UNC FASTENER, THE "STRESS AREA" IS .0317 IN².

$$\therefore \text{STRESS} = \frac{.187 \text{ lb}}{.0317 \text{ in}^2} = 5,899 \text{ lb/in}^2$$

SINCE THIS IS LESS THAN THE ALLOWABLE, THE SCREENS WILL NOT FAIL.

LOOK AT STRESS ACROSS THE CORNER OF THE SWITCH AT THE MOUNTING HOLE.



WITH SCREW PULLED DOWN TO PROPER TIGHTNESS, ASSUME FAILURE WOULD OCCUR IN SHEAR ACROSS THE PLANE DEFINED BY THE DASHED LINE. LENGTH OF THIS LINE IS 15/16 IN.

$$\text{SHEAR AREA} = \left(\frac{15}{16} \text{ in}\right) (.125 \text{ in}) = .11719 \text{ in}^2$$

LOAD FROM PAGE 17 IS 187 lb

$$\text{STRESS} = \frac{187 \text{ lb}}{.11719 \text{ in}^2} = 1596 \text{ lb/in}^2$$

THIS STRESS IS LOWER THAN STRENGTH OF ANY MATERIAL THAT MIGHT BE USED. THEREFORE, FAILURE IN THIS MODE WOULD NOT OCCUR.

Handwritten text, likely bleed-through from the reverse side of the page, running vertically along the left margin.



Dept. _____ PENNSYLVANIA POWER & LIGHT COMPANY ER No. _____
 Date 5/21 1985 CALCULATION SHEET
 Designed by W. J. [unclear] PROJECT CALC # M-155-006 Sht. No. 19 of 27X
 Approved by _____

HYDRAULIC SPEED CONTROL HARDWARE

THE HYDRAULIC SPEED CONTROL HARDWARE IS MOUNTED ON THE BACK SIDE OF THE OPERATOR WHERE IT IS SHADOWED BY THE OPERATOR FOR VALVES A & D AND PARTIALLY SHADOWED ON VALVES B & C. VALVE C HAS THE MAX. EXPOSED AREA.

- a) APPROXIMATE AREA OF EXPOSED TUBING = (.75" DIA) (14" LENGTH) = 10.5 in²
- b) APPROXIMATE AREA OF ACCUMULATOR = (1.5" DIA) (4" LENGTH) = 6 in²
- c) APPROXIMATE AREA OF FLOW CONTROL VALVE = (2") (3") = 6 in²
- d) TOTAL AREA OF CYLINDRICAL TARGETS = a) + b) = 10.5 in² + 6 in² = 16.5 in²

EFFECTIVE TARGET AREA, CYLINDRICAL TARGETS = (AREA) (sin φ) (K_d)

FROM SHEET 8, K_d = .6. HARDWARE IS AT 45° TO THE VERTICAL PLANE PERPENDICULAR TO THE VALVE &. THE JET BLAST IS AT 45° TO THE VERTICAL PLANE THROUGH THE VALVE &. THE RESULTANT ANGLE OF INCIDENCE OF THE JET TO THE HARDWARE IS 67.5°.

EFFECTIVE CYLINDER TARGET AREA = (16.5 in²) (sin 67.5°) (.6) = 9.15 in²

EFFECTIVE AREA, FLOW CONTROL VALVE = (6 in²) (sin 67.5°) = 5.54 in²

TOTAL EFFECTIVE AREA = 9.15 in² + 5.54 in² = 14.69 in²

RANGE TO HYDRAULIC HARDWARE TARGETS ≈ 12 FT, P_T = ^{5.2}~~4.9~~ lb/in²

FORCE ON TARGET = P × A = (^{5.2}~~4.9~~ lb/in²) (14.69 in²) = ^{76.4}~~72.0~~ lb

BY INSPECTION, THE POINT OF MAXIMUM STRESS DUE TO THIS FORCE WOULD BE AT THE CONNECTIONS TO THE HYDRAULIC CYLINDER - THIS IS THE POINT OF MAXIMUM BENDING MOMENT. ASSUME LOAD IS EVENLY DISTRIBUTED TO THE TWO END CONNECTIONS. THE DISTANCE FROM THE LOAD APPLICATION POINT TO THE CONNECTION POINT IS APPROXIMATELY 8 IN.

∴ MOMENT AT EACH CONNECTION = (^{76.4}~~72.0~~ / 2) (8 in) = ³⁰⁶~~288~~ in lb



11

1

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



Dept. _____
Date 5/24 1985
Designed by PP
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. _____
Sht. No. 20 of 27 X

PROJECT CAL # M-MSS-006

PIPE IS $\frac{1}{4}$ " , ASSUME SCH 80 , O.D. = 1.05" , I.D. = .742 IN . ASSUME THREAD DEPTH $\frac{1}{2}$ WALL THICKNESS FOR SCH 40 . RESULTANT EFFECTIVE D.D. = .937 IN . FROM REF. 13 , STRESS CONCENTRATION FACTOR FOR THREADED PIPE IS 2.3

$$\text{MOMENT OF INERTIA, } I = .25 \pi [r_o^4 - r_i^4]$$

$$C = .937 \text{ IN}$$

$$\text{BENDING STRESS, } \sigma = \frac{M C}{I} \times K$$

$$\sigma = \left(\frac{\overset{306}{\cancel{288}} \text{ .Nlb} (.937 \text{ IN})}{.25 \pi \left[\left(\frac{.937 \text{ IN}}{2} \right)^4 - \left(\frac{.742 \text{ IN}}{2} \right)^4 \right]} \right) \times (2.3)$$

$$\sigma = \frac{28,724}{\cancel{27,034}} \text{ lb/IN}^2$$

FROM ASME B&PV CODE, SECT II, PART A, FOR ASTM A 106, GR C MATERIAL WHICH THIS PIPE IS PER REF 8, YIELD STRENGTH IS 40,000 PSI. SINCE THE BENDING STRESS IS LESS, NO YIELDING WILL OCCURE.

I-BEAM IN FRONT OF OPERATOR

THIS PORTION OF CALCULATION TO BE PERFORMED BY CIVIL GROUP.

$$\text{RANGE IS } \approx 9 \text{ FT, } P_f = 6.9 \text{ lb/IN}^2$$

FROM TABLE D-1, REF. 5, FOR A "SEMITUBULAR" SHAPE WHICH THE SHAPE OF THE I-BEAM APPROXIMATES IN THE WEAK AXIS, THE DRAG COEFFICIENT IS 2.3. PER EQUATION D-6 THE SHAPE FACTOR

$$K_{\phi} = \frac{1}{2} C_D = .5(2.3) = 1.15$$

APPLYING THIS TO THE PRESSURE TO GET THE EFFECTIVE PRESSURE YIELDS:

$$P_{T_{eff}} = (6.9 \text{ lb/IN}^2)(1.15) = 7.9 \text{ lb/IN}^2$$


THIS VALUE IS SUPPLIED TO CIVIL FOR THEIR CALCULATION.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



Date 5/14/85

TELEPHONE CALL



Subject ANALYSIS OF RECIRC. LINE BREAK Route _____

Caller DON PREVATE of PP&L _____

to HANS GIESECKE of MPR ASSOCIATES _____

File No. 922-60

CALL WAS MADE TO HANS TO DETERMINE THE RESULTS OF THE MPR
CALCULATION PERFORMED ON THE FLOWS FROM A POSTULATED 28"
RECIRC. LINE BREAK. THE ATTACHED SKETCHES DESCRIBE THE GIST
OF THE CONVERSATION AND THE RESULTS OF THE CALCULATION.

Don Prevate

Vertical text on the left margin, possibly bleed-through from the reverse side of the page.




Case: Homogeneous - Dual Flow

$A = 5''$
 $K = .128$

$K = .984$

(6)

(100 psi)



$$= \frac{P + \frac{5W^2}{144gA^2}}{P_0}$$

$$= \frac{P + \frac{5W^2}{58238}}{P_0}$$

pressure in red

flow in green

Vertical text or markings on the left side of the page, possibly bleed-through or a margin note.




Case: Homogeneous - Dual Flow

● 11"
 K = .682

K = .975

⑥
 135 psi




$$= \frac{P + \frac{UW^2}{144gA^2}}{P_0}$$

$$= \frac{UW^2}{58238 P_0}$$

pressure in red

Flow in green



1.52" Homogeneous - Dual Flow


● 14"
 K = .610

choked

K = .975

⑥

132 psi



$$K = \frac{P + \frac{vW^2}{144gA^2}}{P_0}$$

$$K = \frac{P + \frac{vW^2}{58238}}{P_0}$$

Pressure in Red
 Flow in Green

How Allied IMC compares

Dimension comparison (nominal) of 3/4" trade sizes

GRC	IMC	EMT
O.D. 1.050"	O.D. 1.029"	O.D. 0.922"
I.D. 0.824"	I.D. 0.863"	I.D. 0.824"
Wall 0.113"	Wall 0.083"	Wall 0.049"


Weight comparison of trade sizes

Approximate Lbs. per 100 Ft.

Trade Size	GRC W/Coupling	IMC W/Coupling*	E.M.T.
1/2"	79	60	28
3/4"	105	82	43
1"	153	116	64
1-1/4"	201	150	95
1-1/2"	249	182	110
2"	332	242	140
2-1/2"	527	401	205
3"	683	493	250
3-1/2"	831	573	325
4"	972	638	370

*Weight specifications are for comparative purposes only. They are not a requirement of U.L. 1242.

Allied IMC Dimensions



Trade Size (in)	A *Nominal Outside Diameter		B Length of Finished Conduit Without Coupling		C **Wall Thickness	
	(in)	(mm)	(ft and in)	(meters)	(in)	(mm)
1/2"	0.815	20.7	9' 11-1/4"	3.03	0.070	1.8
3/4"	1.029	26.1	9' 11-1/4"	3.03	0.075	1.9
1"	1.290	32.8	9' 11"	3.02	0.085	2.2
1-1/4"	1.638	41.6	9' 11"	3.02	0.085	2.2
1-1/2"	1.883	47.8	9' 11"	3.02	0.090	2.3
2"	2.360	59.9	9' 11"	3.02	0.095	2.4
2-1/2"	2.857	72.6	9' 10-1/2"	3.01	0.130	3.3
3"	3.476	88.3	9' 10-1/2"	3.01	0.130	3.3
3-1/2"	3.971	100.9	9' 10-1/4"	3.00	0.130	3.3
4"	4.466	113.4	9' 10-1/4"	3.00	0.130	3.3

side diameter tolerances:
±.005 in (.13 mm) for trade sizes 1/2" and 3/4".
±.0075 in (.19 mm) for trade sizes 1-1/4" through 2".
±.010 in (.25 mm) for trade sizes 2-1/2" through 4".

A Strength Comparison

The results of the various beam strength and deflection tests, which follow later in this brochure, may create questions as to how this relative strength of IMC is achieved.

Allied's method of manufacture increases the average tensile strength of IMC to such an extent that its wall strength is over 50% greater per unit of thickness than that of representative samples of GRC measured by Allied.

The wall strength characteristics are functions of both the yield strength of the material and the section modulus. The accompanying table gives a comparison of IMC and GRC for various trade sizes.

Comparison of Maximum Moments IMC Vs. GRC Calculated from Section Moduli & Yield Strengths

Trade Size	IMC	GRC
1/2"	1905	1424
3/4"	3432	2763
1"	6130	4405
1-1/4"	10423	8915
1-1/2"	14574	12070
2"	24660	19622
2-1/2"	47044	37241
3"	63085	60343
3-1/2"	83641	83785
4"	103000	112507

Average Yield Strengths

GRC 35,000— 40,000 psi: All sizes;

IMC 55,000— 60,000 psi: 3" and under sizes

IMC 50,000— 52,000 psi: over 3" sizes

**Wall thickness tolerance is +.015 in (.38 mm) and -.000 for IMC 1/2" through 2" and +.020 in (.51 mm) and -.000 for IMC 2-1/2" through 4". There is no specific wall thickness or tolerance for rigid conduit.

Vertical text on the left margin, possibly bleed-through from the reverse side of the page.

Small mark or text at the top left of the page.



Series EA700

Snap-Lock® Limit Switches

Specifications

- Enclosure is water, oil and dust tight.
- Enclosure meets NEMA Type 1, 4 and 13 requirements.
Contacts made of silver alloy. Contact shifting mechanism is locked in position by the latches until switch lever is actuated.
- Standard Temperature Range: -20°C TO $+90^{\circ}\text{C}$
- Operating lever is adjustable to any required position.
- Operating Lever Angles (travel either clockwise or counter-clockwise) maximum degrees of trip travel, reset travel, as well as total lever travel, are determined by the cam selected.
- Operating Torques — Trip Torque varies from 15 to 33 in.

lbs. depending on switch size and cam selected.

8. Underwriters' Laboratories, Inc. Listed. File No. E12967. (Except neutral position module)

9. Current ratings:

Voltage		For Neutral Position Only
125V-A.C.	20.0 Amps*	10.0 Amps*
250V-A.C.	15.0 Amps*	7.5 Amps*
480V-A.C.	10.0 Amps*	5.0 Amps*
600V-A.C.	5.0 Amps*	2.5 Amps*
125V-D.C.	5.0 Amps	2.5 Amps
250V-D.C.	1.5 Amps	.75 Amps

*75-100% Power Factor.

For Marine or Off-Shore Requirements, See EA780, EA790 Series.


For Hazardous Location Requirements, See EA800 Series.

Mounting Styles and Dimensions


EA700 Snap-Lock Limit Switches are designed for flexibility in mounting arrangements. Design permits mounting for either side or back. Shown here are the (1) STANDARD for side mounting; (2) W (wide for back mounting); (3) L (long for back mounting). Style W or L mounting plates for back mounting, are available at no extra cost.

CONTACT SEQUENCE	STANDARD SWITCH				MOUNTING STYLE			
	PIPE TAP SIZE	A	B	C	"W"		"L"	
					D	E	F	G
1NO-1NC	1/2-14NPT	4.94	3.00	.62	2.44	3.00	4.22	4.84
2NO-2NC	1-11½NPT	7.06	4.94	.81	4.38	4.94	6.41	7.06
3NO-3NC	1-11½NPT	9.62	7.50	.81	6.94	7.50	8.97	9.62


Standard Mounting



W Mounting



L Mounting



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



Dept. NPE-MECH

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. 741058-005

Date 10-14 1985

Designed by DRB

PROJECT CALC M-155-006, REV 1

Sht. No. 27a of 27x

Approved by _____

CONDUIT RECALCULATION (FLEX CONDUIT)

CONSIDER SUBSTITUTING TBI-1 BRAIDED FLEX CONDUIT FOR THE UNBRAIDED TYPE PRESENTLY USED. FROM THE AMERICAN BSA VENDOR CATALOG:

<u>NOMINAL DIA</u>	<u>O.D.</u>	<u>MAX ALLOWABLE INTERNAL PRES</u> (NOT INCLUDING 4 TO 1 SAFETY FACTOR)	<u>WITH SHOCK</u> (1/2 X MAX ALLOWABLE)
3/4"	1.04"	700 PSI	117 PSI
1"	1.24"	600 PSI	100 PSI
1 1/2"	1.91"	400 PSI	67 PSI

THESE ARE THE PRESSURES AT WHICH THE BELLWS TUBING STARTS TO STRETCH OUT: THE EQUIVALENT TENSILE LOAD WOULD BE:

$$L_T = PA$$

$$L_{T \frac{3}{4}"} = (117 \text{ lb/in}^2)(\pi)\left(\frac{1.04 \text{ in}}{2}\right)^2 = 99.4 \text{ lb}$$

$$L_{T 1"} = (100 \text{ lb/in}^2)(\pi)\left(\frac{1.24 \text{ in}}{2}\right)^2 = 120.8 \text{ lb}$$

$$L_{T 1 \frac{1}{2}"} = (67 \text{ lb/in}^2)(\pi)\left(\frac{1.91 \text{ in}}{2}\right)^2 = 192.0 \text{ lb}$$

FROM SHEET 9, MID-SPAN LOADS ARE:

$$H_{\frac{3}{4}"} = 77.5 \text{ lb} \quad H_{1"} = 92.4 \text{ lb} \quad H_{1 \frac{1}{2}"} = 142.4 \text{ lb}$$

FROM REF. 7, PAGE 1-17, TENSION AT CONDUIT ENDS IS:

$$T = \left[H^2 + \left(\frac{WL}{2} \right)^2 \right]^{.5}$$

$$T_{\frac{3}{4}"} = \left[(77.5 \text{ lb})^2 + \left(\frac{1550 \text{ lb}}{2} \right)^2 \right]^{.5} = 109.6 \text{ lb}$$

$$T_{1"} = \left[(92.4 \text{ lb})^2 + \left(\frac{1848 \text{ lb}}{2} \right)^2 \right]^{.5} = 130.7 \text{ lb}$$



Dept. NYE-M&H
Date 10-14 1985
Designed by ~~W.P. ...~~
Approved by _____

PENNSYLVANIA POWER & LIGHT COMPANY
CALCULATION SHEET

ER No. 741 058-005
Sht. No. 27b of 27x

PROJECT CALC. M-1755-006, REV. 1

$$T_{1/2} = \left[(142.4 \text{ lb})^2 + \left(\frac{284.7 \text{ lb}}{2} \right)^2 \right]^{1/2} = 201.4 \text{ lb}$$

FOR ALL THREE CONDUIT SIZES THE LOADS ARE SLIGHTLY HIGHER THAN THE "ALLOWABLE". HOWEVER, THE "ALLOWABLE" INCLUDES A 4-TO-1 SAFETY FACTOR, THE ACTUAL LOADS YIELD SAFETY FACTORS OF 3.62, 3.70 AND 3.81 RESPECTIVELY WHICH ARE ACCEPTABLE . . .

SMALL JUNCTION BOX CONDUIT RECALCULATION

EXISTING CONDUIT IS 1". CONSIDER SUBSTITUTING 1" XXS PIPE.
FROM REF. 9, PAGE 8-200:

I.D. = .599"

SUBSTITUTING INTO FORMULA FOR I FROM SHEET 14:

$$I = .25 \pi \left[r_o^4 - r_i^4 \right] = .25 \pi \left[\left(\frac{1.181 \text{ in}}{2} \right)^4 - \left(\frac{.599}{2} \right)^4 \right]$$

$$I = .0892 \text{ in}^4$$

SUBSTITUTING INTO FORMULA FOR BENDING STRESS FROM SHEET 14:

$$\sigma = \frac{(9135 \text{ lb/in})(1.181 \text{ in})}{.0892 \text{ in}^4} = 12,095 \text{ lb/in}^2$$

APPLYING A STRESS CONCENTRATION FACTOR OF 3.0:

$$\sigma = (12,095 \text{ lb/in}^2)(3) = 36,284 \text{ lb/in}^2$$

SINCE THIS STRESS IS JUST IN THE RANGE OF YIELD STRENGTHS FOR TYPICAL CARBON STEEL PIPE (35,000 PSI TO 40,000 PSI), YIELDING, IF ANY, WOULD BE VERY SLIGHT AND WOULD NOT HAVE ANY PETRIMENTAL EFFECT ON THE VALVE FUNCTION OR THE FUNCTION OF ANY OF THE MISCELLANEOUS HARDWARE.



100-100000

100-100000



MPR ASSOCIATES, INC.

June 24, 1985

Mr. Frank Czysz
Pennsylvania Power and Light Company
Two North Ninth Street
Allentown, PA 18101

Subject: Susquehanna Nuclear Station -- Recirculation
Piping Blowdown Thrust Loads

Dear Mr. Czysz:

This letter forwards the results of our analyses of thrust loads that would be expected for the Susquehanna BWR recirculation piping in the unlikely event that a complete pipe rupture occurred at the point where the recirculation piping passes through the biological shield surrounding the reactor vessel. Preliminary results of these analyses have been discussed with you, Mr. Herb Clarke, Mr. Don Prevatte, and Ms. Patty Mikus at our meeting at General Electric on May 9, 1985, and were sent to Mr. Prevatte shortly after our return from the meeting.

The purpose in establishing the thrust loads which would act on the pump end of the recirculation piping as a result of a postulated break within the biological shield was to ensure that the pipe whip restraint designed by General Electric was adequate to limit the final separation between the two broken pipe ends at the break such that the pump end of the broken pipe would remain in a position to shield the MSIV's from direct jet impingement from the reactor vessel side of the break. The original analysis for the pipe restraints done by General Electric was based on a generic approach covering several plants and pipe break locations which did not include the special case of a break within the biological shield.

The General Electric analysis modeled the thrust load as a dynamic part associated with the break dynamics and wave propagation effects followed by a steady state part which would occur after full flow has been established at the break. Pipe reaction to this loading sequence was obtained by a time history stress analysis which included the plastic deformation of the pipe and pipe restraint. Due to the active participation of the shield to the flow field around the break and the large resistance to flow in the

1954年10月1日

1954年10月1日

1954年10月1日

17

18



MPR ASSOCIATES, INC.

Mr. Frank Czysz

- 2 -

June 24, 1985

pump side of the recirculation piping, the steady state thrust load on the pump end of the broken pipe would be significantly larger in the presence of the shield than the steady state load which was used in the General Electric generic analysis and which assumed no shield. The higher thrust load occurs because the higher pressure which exists at the break in the presence of the shield will reduce the amount of flow which is expelled from the pump side of the break. For lines with a large amount of resistance (such as the pump and other substantial resistances present in this line) reduced flow at the break tends to increase thrust. Consequently, the generic analysis done by General Electric was considered not to envelope the condition where the break was postulated to occur within the biological shield. In this regard, we understand that General Electric has revised their analysis to include a conservative steady state thrust load and has determined that no significant increase in pipe separation will result as a consequence of the higher steady state load because almost all the pipe and restraint deformation occurs during the period when the dynamic thrust load is acting on the pipe and before the thrust load reaches a steady state value.

Our analyses, which are documented in the enclosure to this letter, include the determination of a realistic steady state thrust load which would act on the pump end of the recirculation line as a result of a break within the biological shield. Several cases were analyzed assuming several different values for the final separation distance between the broken ends of the pipe. These analyses include revisions to remove simplifying assumptions regarding the differences between static and stagnation pressure in determining critical flow rates as discussed with you at our May 9, 1985 meeting at General Electric. A review of the results from these more refined analyses indicates that the thrust loads are similar to those discussed in our meeting of May 9, 1985 and are still well within the values used in the revised General Electric analysis.

Also included in the attachment is a short description of a compressible flow field analysis of the blowdown of an ideal gas from a vessel through an open ended pipe. Results from this analysis are instructive in providing some insight as to why the maximum thrust load that can be established

MPR ASSOCIATES, INC.

Mr. Frank Czysz

- 3 -

June 24, 1985

during a blowdown from a vessel will exceed the product of the original stagnation pressure times the flow area of the broken pipe.

If you should have any questions regarding our results, please call.

Sincerely,

Hans D. Giesecke

Hans D. Giesecke

Enclosure

1952年10月10日

共

22



MPR ASSOCIATES, INC.

Enclosure 1

THRUST LOADS FOR POSTULATED BREAK OF BWR
RECIRCULATION LINE WITHIN BIOLOGICAL SHIELD

I. Introduction

In the event of an unlikely pipe rupture inside containment for a Nuclear Power Plant, adequate pipe restraints must be designed to accept thrust loads acting on the free ends of the broken pipe and prevent damage to other equipment in the containment. As a secondary consideration, the effects of jet impingement loads on equipment must also be considered to ensure that the plant can be reliably secured in the event that any such postulated pipe break accident occurs.

In the design of the piping restraints for the boiler recirculation piping for the Susquehanna Nuclear Power Plant, General Electric used a generic analysis which covered several plants and analyzed a series of worst cases regarding the location of the postulated breaks. An apparently conservative thrust load history was applied by GE to the broken ends of the pipe at the postulated break by using the maximum attainable theoretical value for the thrust load during that period of time when dynamic pressure wave propagation affects the pipe flow, and then reducing this value to the steady state thrust load after a steady state blowdown of the reactor vessel through the two broken pipe ends has been established.

At Susquehanna the recirculation line passes through a biological shield which surrounds the reactor vessel and the pipe to safe-end weld is located near the center of the biological shield. If the postulated break were to occur at this weld the effect of the biological shield, which was not considered in the generic analysis done by General Electric, would tend to increase the steady state value of the thrust load applied to the pump end of the recirculation piping. The thrust load from the pump end of the break is strongly affected by the considerable resistance to flow generated by the recirculation pump and the jet pump which exist in that line. Interference of the shield with the break flow at the break would cause the steady state thrust load on this pipe leg to be higher than it would be if the shield were not there. Consequently, the steady state thrust load used by General Electric would not be conservative for the

special case where the postulated break in the recirculation line occurs within the biological shield.

The Main Steam Isolation Valves at Susquehanna, which are necessary to isolate the containment in the unlikely event of a pipe break accident, are located close to the reactor recirculation lines and would be susceptible to impingement loads from a jet originating from the reactor end of the break if a break were to occur at the point where the piping passes through the biological shield. Shielding from the impingement jet provided by the pump end of the broken line was utilized in the analysis of jet impingement loads on the isolation valves. This was considered acceptable because the General Electric analysis of the pipe restraint showed that the pipe separation between the broken ends of the recirculation lines in the worst case would be less than 11 inches.

The dynamic response of the pipe was determined by General Electric using a detailed time history analysis of the pipe motion with the aforementioned thrust load as input. Plastic deformation of the pipe and pipe restraint were included. Initial restraint to pipe motion is very low because the pipe must be designed to accommodate the effects of thermal expansion. As a result the pipe deflects a considerable amount before the pipe restraint becomes active and the built up kinetic energy obtained early in the transient must be absorbed by plastic deformation of the restraint as the restraint begins to react to the motion of the pipe. Consequently, it is feasible that the steady state thrust load used in the analysis has only a small effect on the final separation that would occur between the broken ends of the pipe in the event of a break. Nevertheless, the actual steady state thrust load which would occur if the postulated break is located within the biological shield should be used to determine the final separation between the pipe ends so that the assumption of shielding for the MSIVs can be properly justified.

Calculated results for the steady state thrust load on the pump end of the recirculation line which were obtained for various amounts of pipe separation at the break when the postulated break is located within the biological shield are discussed in the remainder of this report. These values should be used for the

...

...

...

...

...

steady state thrust load as applied to the pump end of the broken recirculation pump in a revised analysis of the pipe motion.

II. Results of Analysis

A schematic of the model used to determine the flow rates and pressures near the break for a postulated break in the recirculation line where it passes through the biological shield is shown in Figure 1. In this figure the right side of the pipe is attached directly to the reactor vessel with the postulated break occurring at the weld between the pipe and the reactor vessel nozzle safe-end. The left end of the pipe leads to an elbow where the pipe turns down vertically and a pipe restraint is located several feet from the elbow. The pipe continues back to the reactor vessel after passing through the recirculation pump and several other points of high flow resistances. A one-dimensional solution technique which solves the mass, energy, and momentum conservation equations was used to obtain the steady state thrust load for several different values of pipe separation. The model divides the region near the break into six control volumes and six flow paths as shown in Figures 1 and 2. The reactor vessel and the containment are modeled as boundary control volumes at 1000 psi saturated water and 15 psi ambient conditions respectively. Due to the one dimensional nature of the model the exit flow from the annulus around the pipe, although it splits in two different directions, is modeled as a single flow path of twice the area of each individual path. The resistance in the pump end of the line (flow coefficient 56) was obtained from the steady state flow which exists in the loop at full power. This is conservative since the resistance in reverse flow through the pipe would be considerably larger than the resistance for flow in the normal direction and the resistance of the pump is neglected. The flow in each path is determined from the integrated momentum equation and is limited in magnitude by a homogeneous equilibrium thermodynamic critical flow model. The thrust is calculated from the static pressure, static density, and mass flow rate at the pipe exit plane as discussed in Reference 1. Input data and computer results for each case run are provided in Appendix A.

Calculated mass flow rates and static pressures for the model as determined for different values of pipe separation at the break are tabulated in Table 1.

These results are used to obtain the thrust factors, defined as the thrust load divided by the product of reactor vessel stagnation pressure times pipe flow area, given in Table 2 for each pipe end. The results indicate that the thrust force for the pump end of the broken pipe is largest when the separation at the break is smallest and diminishes as a function of the separation distance until choking occurs at the pipe exit plane. In the presence of the biological shield, choking at the exit plane of the pump end of the broken pipe will not occur until the separation distance between the broken ends is well in excess of the eleven inches calculated by General Electric. Consequently, a steady state value of about 0.7 to 0.8 times the product of vessel stagnation pressure times pipe area should be used for the steady state thrust load in the General Electric time history analysis. Although this considerably exceeds the factor of 0.33 that General Electric used in their original generic analysis, the higher steady state thrust load may have only a small effect on the final pipe separation since it is expected that most of that separation is caused by the initial response of the pipe to the dynamic thrust load which occurs before the restraint begins to act to limit the pipe separation.

III. Flow Field Analysis for Blowdown of an Ideal Gas

An axisymmetric flow field analysis for a compressible ideal gas flowing from a short pipe attached to a large vessel was used to obtain some insight as to why the thrust load from a vessel can be larger than the product of the vessel stagnation pressure times the pipe area. Thermodynamic models of the flow predict that the thrust load for an ideal gas would be 1.26 times the product of vessel stagnation pressure and pipe area, and for incompressible flow the factor can become as high as 2.0. A contour plot of the stream function for an axisymmetric model of the region near a pipe attached to a large vessel is shown in Figure 3. An iterative finite difference technique was used to solve the two-dimensional partial differential equation which describes the compressible flow of an ideal gas in terms of a stream function. Boundary conditions imposed on the model included defining the stream function along the axis of the pipe and the wall of the vessel for a particular mass flow rate and requiring that the flow be normal to the spherical surface chosen as a boundary far enough away from the pipe inlet so that the flow field at the inlet was not significantly affected.

Vertical text on the left side of the page, possibly a page number or header.



The difference in the stream function values as imposed at the pipe axis and the vessel wall was used to adjust the mass flow rate flowing through the pipe leaving the vessel. The method of solution used to solve the flow field equations is limited to calculating subsonic flow fields so that the solution at which the exit plane of the pipe begins to choke could only be approached. The thrust load for each case was determined by integrating the pressure over the projected surface normal to the pipe axis along the vessel and pipe boundary and subtracting this value from the integration of the stagnation pressure over the same area which is assumed to be acting over the back wall of the vessel opposite the pipe inlet. The results for the thrust load obtained in this manner for several different values of mass flow are graphed in Figure 4. As can be seen from the figure, as the mass flow is increased such that the exit plane of the pipe approaches a choked value, the thrust load approaches the theoretical value of 1.26 times the product of the vessel stagnation pressure times the pipe flow area. Figure 5 shows the pressure contours which exist at a mass flow near the choked condition value. Thrust loads greater than the product of stagnation pressure times pipe area occur because there is a substantial area in the region of the nozzle at radii larger than the pipe inside radius where a reduction in pressure takes place due to the velocity of the flow as it enters the pipe. This lowered pressure region is offset by an equivalent area on the back side of the vessel which is essentially acted upon by the vessel stagnation pressure. Consequently, thrust loads greater than stagnation pressure times pipe area require that the flow originate in a vessel which has a cross-sectional area much larger than the pipe and where the flow is forced to turn into the pipe. Momentum and energy conservation requires that the momentum imparted to the fluid by pressure variations which accelerate the flow into the nozzle and along the pipe is equivalent to that which crosses the exit plane of the pipe.

IV. References

1. F. J. Moody, "Prediction of Blowdown Thrust and Jet Forces," General Electric Company, ASME, 1969.

TABLE OF VALUES FOR THRUST CALCULATION

(Definitions given in Figure 1)

inches	lb/sec		lbs/sq in				lbs/cu ft		
=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
GAP	W1	W2	P1	P2	PX	PA	DEN1	DEN2	DENA
=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
2	5980	804	990	993	993	102	44	45	.9
4	11523	1606	957	972	973	178	38	41	1.7
6	16178	2426	890	937	938	235	30	35	2.5
8	18349	3590	759	861	863	274	19	26	3.0
10	18348	4733	760	755	760	279	19	18	3.1
12	18349	5481	759	666	676	282	18	14	3.2

TABLE 1

Mass Flow Rates, Pressures, and Densities
 Obtained in Analysis




TABLE OF VALUES FOR THRUST COEFFICIENTS

inches	vessel end	pump end
=====	=====	=====
GAP	K1	K2
=====	=====	=====
2	1.0038	0.9933
4	1.0166	0.9735
6	1.0417	0.9398
8	1.0661	0.8692
10	1.0661	0.7758
12	1.0661	0.7041

TABLE 2

Thrust Coefficients from Calculated Results

100

100

100


100

100

100

100

100






FIGURE 1

Schematic of Break

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100







FIGURE 2
Computer Model of Break






FIGURE 3
Stream Function Contours for
Flow Field Analysis of Pipe from Vessel





FIGURE 4
Asymtotic Solution for Thrust
Coefficient from Series of Flow Field
Analyses








FIGURE 5

Pressure Contours for Flow
Field Analysis of Pipe from Vessel



Appendix A
COMPUTER OUTPUT OF RESULTS



OUTPUT AT TIME .00000

VAR	Y	NAME
1	.597961E+04	W1
2	.804317E+03	W2
3	.996639E+03	PO1
4	.993218E+03	PO2
5	.993156E+03	POX
6	.139203E+03	POA

GEOMETRY DATA

DPIPE	.212200E+01
DIN	.240000E+01
DOUT	.380000E+01
GAP	.166667E+00
APIPE	.353656E+01
ABREAK	.125664E+01
ANUL	.681726E+01

NODE DATA

	VESSEL	NODE 1	NODE 2	NODE X	NODE A	BACK
STAGNATION PRESSURE	.10000E+04	.99664E+03	.99322E+03	.99316E+03	.13920E+03	.15000E+02
CRITICAL PRESSURE		.78931E+03	.78472E+03	.78370E+03	.86805E+02	
STATIC PRESSURE		.98979E+03	.99309E+03	.99316E+03	.10245E+03	
STATIC DENSITY		.44069E+02	.44673E+02	.44685E+02	.85949E+00	
THERMO DENSITY		.44069E+02	.44673E+02	.44685E+02	.85949E+00	
CRITICAL DENSITY		.20965E+02	.20638E+02	.20568E+02	.71777E+00	

FLOW DATA

	FLW V	FLW L	FLW 1	FLW 2	FLW A	FLW B
MASS FLUX	.16908E+04	.22743E+03	.16908E+04	.22743E+03	.00000E+00	.49756E+03
MASS FLOW	.59796E+04	.80432E+03	.59796E+04	.80432E+03	.67839E+04	.67839E+04
					CRITICAL	
CRITICAL MASS FLOW	.19301E+05	.19301E+05	.19199E+05	.19094E+05	.67839E+04	.70611E+04
K-FACTOR	.50000E+00	.56000E+02	.50000E+00	.50000E+00	.30000E+00	.10000E+01
MODIFIED K-FACTOR	.93596E-07	.10483E-04	.97820E-07	.96497E-07	.45645E-06	.26396E-05
THRUST FACTOR			.10038E+01	.99334E+00		

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



SUSQUEHANNA BWR REACTOR RECIRC PIPE BREAK IN BIOLOGICAL SHIELD - 4 INCH GAP

CALC M-MSS-006, REV. 1

ATTACHMENT 5

SHEET 277 OF 27X

OUTPUT AT TIME .00000

VAR	Y	NAME
1	.115227E+05	W1
2	.160568E+04	W2
3	.987573E+03	PO1
4	.972974E+03	PO2
5	.972702E+03	POX -
6	.250694E+03	POA

GEOMETRY DATA


DPIPE	.212200E+01
DIN	.240000E+01
DOUT	.380000E+01
GAP	.333333E+00
APIPE	.353656E+01
ABREAK	.251327E+01
ANUL	.681726E+01

NODE DATA

	VESSEL	NODE 1	NODE 2	NODE X	NODE A	BACK
STAGNATION PRESSURE	.10000E+04	.98757E+03	.97297E+03	.97270E+03	.25069E+03	.15000E+02
CRITICAL PRESSURE		.77833E+03	.76350E+03	.76424E+03	.15914E+03	
STATIC PRESSURE		.95715E+03	.97244E+03	.97270E+03	.17771E+03	
STATIC DENSITY		.38488E+02	.40874E+02	.40916E+02	.16963E+01	
THERMO DENSITY		.38488E+02	.40874E+02	.40916E+02	.16963E+01	
CRITICAL DENSITY		.20192E+02	.19196E+02	.13242E+02	.14885E+01	

FLOW DATA

	FLOW V	FLOW L	FLOW 1	FLOW 2	FLOW A	FLOW B
MASS FLUX	.32582E+04	.45402E+03	.32582E+04	.45402E+03	.00000E+00	.96288E+03
MASS FLOW	.11523E+05	.16057E+04	.11523E+05	.16057E+04	.13128E+05	.13128E+05
					CRITICAL	
CRITICAL MASS FLOW	.19301E+05	.19301E+05	.18922E+05	.18482E+05	.13128E+05	.13347E+05
K-FACTOR	.50000E+00	.56000E+02	.50000E+00	.50000E+00	.30000E+00	.10000E+01
MODIFIED K-FACTOR	.93596E-07	.10483E-04	.11200E-06	.10547E-06	.12517E-06	.13678E-05
THRUST FACTOR			.10166E+01	.97353E+00		



SUSQUEHANNA BWR REACTOR RECIRC PIPE BREAK IN BIOLOGICAL SHIELD - 6 INCH GAP

OUTPUT AT TIME: .00000

VAR	Y	NAME
1	.161778E+05	W1
2	.242572E+04	W2
3	.975504E+03	PO1
4	.938318E+03	PO2
5	.937600E+03	POX
6	.340194E+03	POA

GEOMETRY DATA


DPIPE	.212200E+01
DIN	.240000E+01
DOUT	.380000E+01
GAP	.500000E+00
APIPE	.353656E+01
ABREAK	.376991E+01
APVAL	.681726E+01

NODE DATA

	VESSEL	NODE 1	NODE 2	NODE X	NODE A	BACK
STAGNATION PRESSURE	.10000E+04	.97550E+03	.93832E+03	.93760E+03	.34019E+03	.15000E+02
CRITICAL PRESSURE		.76739E+03	.72601E+03	.72545E+03	.22265E+03	
STATIC PRESSURE		.89008E+03	.93694E+03	.93760E+03	.23459E+03	
STATIC DENSITY		.29765E+02	.35334E+02	.35421E+02	.24518E+01	
THERMO DENSITY		.29765E+02	.35334E+02	.35421E+02	.24518E+01	
CRITICAL DENSITY		.19450E+02	.16914E+02	.16882E+02	.22950E+01	

FLOW DATA

	FLOW V	FLOW L	FLOW 1	FLOW 2	FLOW A	FLOW B
MASS FLUX	.45744E+04	.68590E+03	.45744E+04	.68590E+03	.00000E+00	.13644E+04
MASS FLOW	.16178E+05	.24257E+04	.16178E+05	.24257E+04	.18603E+05	.18603E+05
					CRITICAL	
CRITICAL MASS FLOW	.19301E+05	.19301E+05	.18557E+05	.17472E+05	.16604E+05	.18675E+05
K-FACTOR	.50000E+00	.56000E+02	.50000E+00	.50000E+00	.30000E+00	.10000E+01
MODIFIED K-FACTOR	.93596E-07	.10483E-04	.14483E-06	.12200E-06	.64261E-07	.34636E-06
THRUST FACTOR			.10417E+01	.93581E+00		



SUSLEHAWNA BWR REACTOR REIRC PIPE BREAK IN BIOLOGICAL SHIELD - 8 INCH GAP

OUTPUT AT TIME .00000

VAR	Y	NAME
1	.183486E+05	W1
2	.359037E+04	W2
3	.968489E+03	PO1
4	.864870E+03	PO2
5	.662765E+03	POX
6	.392669E+03	POA

GEOMETRY DATA

DPIPE	.212200E+01
DIN	.240000E+01
DCUT	.380000E+01
GAP	.666670E+00
APIPE	.333666E+01
ABREAK	.502657E+01
ANUL	.681726E+01

NODE DATA

	VESSEL	NODE 1	NODE 2	NODE X	NODE A	BACK
STAGNATION PRESSURE	.10000E+04	.96849E+03	.86487E+03	.86277E+03	.39267E+03	.15000E+02
CRITICAL PRESSURE		.75928E+03	.65187E+03	.64902E+03	.27002E+03	
STATIC PRESSURE		.75928E+03	.86079E+03	.86277E+03	.27433E+03	
STATIC DENSITY		.18921E+02	.26449E+02	.26626E+02	.30430E+01	
THERMO DENSITY		.18921E+02	.26449E+02	.26626E+02	.30430E+01	
CRITICAL DENSITY		.18921E+02	.13198E+02	.13073E+02	.29790E+01	

FLOW DATA

	FLW V	FLW L	FLW 1	FLW 2	FLW A	FLW B
MASS FLUX	.51882E+04	.10152E+04	.51883E+04	.10152E+04	.00000E+00	.16091E+04
MASS FLOW	.18349E+05	.35904E+04	.18349E+05	.35904E+04	.21939E+05	.21939E+05
			CRITICAL		CRITICAL	CRITICAL
CRITICAL MASS FLW	.19301E+05	.19301E+05	.18348E+05	.15489E+05	.21939E+05	.21983E+05
K-FACTOR	.50000E+00	.55000E+02	.50000E+00	.50000E+00	.30000E+00	.10000E+01
MODIFIED K-FACTOR	.93596E-07	.10483E-04	.22783E-06	.16299E-06	.48087E-07	.76247E-06
THRUST FACTOR			.10661E+01	.86320E+00		

SQUELCHING BWR REACTOR RECIRC PIPE BREAK IN BIOLOGICAL SHIELD - 10 INCH GAP

OUTPUT AT TIME .00000

VAR	Y	NAME
1	.183484E+05	W1
2	.473259E+04	W2
3	.968490E+03	PO1
4	.765214E+03	PO2
5	.759916E+03	POX
6	.408974E+03	PCA

GEOMETRY DATA

DPIPE	.212200E+01
DIN	.240000E+01
DOJT	.380000E+01
GAP	.833330E+00
APIPE	.353656E+01
ABREAK	.628316E+01
RANL	.681726E+01

NODE DATA


	VESSEL	NODE 1	NODE 2	NODE X	NODE A	BACK
STAGNATION PRESSURE	.10000E+04	.96849E+03	.76521E+03	.75992E+03	.40897E+03	.15000E+02
CRITICAL PRESSURE		.75904E+03	.55640E+03	.55218E+03	.27485E+03	
STATIC PRESSURE		.75997E+03	.75465E+03	.75992E+03	.27900E+03	
STATIC DENSITY		.18965E+02	.18224E+02	.18525E+02	.31223E+01	
THERMO DENSITY		.18965E+02	.18224E+02	.18525E+02	.31223E+01	
CRITICAL DENSITY		.18906E+02	.95546E+01	.34157E+01	.30604E+01	

FLOW DATA

	FLOW V	FLOW L	FLOW 1	FLOW 2	FLOW A	FLOW B
MASS FLUX	.51882E+04	.13382E+04	.51882E+04	.13382E+04	.00000E+00	.16928E+04
MASS FLOW	.18348E+05	.47326E+04	.18348E+05	.47326E+04	.23081E+05	.23081E+05
			CRITICAL		CRITICAL	
CRITICAL MASS FLOW	.19301E+05	.19301E+05	.18349E+05	.13110E+05	.23081E+05	.23092E+05
K-FACTOR	.50000E+00	.56000E+02	.50000E+00	.50000E+00	.30000E+00	.10000E+01
MODIFIED K-FACTOR	.93596E-07	.10483E-04	.22731E-06	.23655E-06	.44235E-07	.74313E-06
THRUST FACTER			.10661E+01	.77585E+00		

ITERATION 7 FRAC CHANGE .535047E+01 AT POINT 6

YDOT 1	YDOT 2	YDOT 3	YDOT 4	YDOT 5	YDOT 6
.3408E-04	-.5316E-04	.1875E+00	-.2350E-03	.6836E-01	-.5350E+01
Y 1	Y 2	Y 3	Y 4	Y 5	Y 6
.1835E+05	.4733E+04	.9685E+03	.7652E+03	.7599E+03	.4090E+03



SUSQUEHANNA BWR REACTOR RECIRC PIPE BREAK IN BIOLOGICAL SHIELD - 12 INCH GAP

OUTPUT AT TIME .00000

VAR	Y	NAME
1	.183487E+05	W1
2	.548104E+04	W2
3	.968495E+03	PO1
4	.685133E+03	PO2
5	.675546E+03	POX
6	.420013E+03	POA

GEOMETRY DATA

DPIPE	.212200E+01
DIN	.240000E+01
DOUT	.380000E+01
GAP	.100000E+01
APIPE	.353656E+01
ABREAK	.753962E+01
AAUL	.681726E+01

NODE DATA

	VESSEL	NODE 1	NODE 2	NODE X	NODE A	BACK
STAGNATION PRESSURE	.10000E+04	.96849E+03	.68513E+03	.67555E+03	.42001E+03	.15000E+02
CRITICAL PRESSURE		.75857E+03	.47109E+03	.48165E+03	.28226E+03	
STATIC PRESSURE		.75857E+03	.66575E+03	.67555E+03	.28226E+03	
STATIC DENSITY		.18881E+02	.13504E+02	.13912E+02	.31815E+01	
THERMO DENSITY		.18881E+02	.13504E+02	.13912E+02	.31815E+01	
CRITICAL DENSITY		.18877E+02	.70733E+01	.73328E+01	.31784E+01	

FLOW DATA

	FLOW V	FLOW L	FLOW 1	FLOW 2	FLOW A	FLOW B
MASS FLUX	.51883E+04	.15498E+04	.51883E+04	.15498E+04	.00000E+00	.17477E+04
MASS FLOW	.18349E+05	.54810E+04	.18349E+05	.54810E+04	.23830E+05	.23830E+05
			CRITICAL		CRITICAL	
CRITICAL MASS FLOW	.19301E+05	.19301E+05	.18349E+05	.11351E+05	.23831E+05	.23828E+05
K-FACTOR	.50000E+00	.56000E+02	.50000E+00	.50000E+00	.30000E+00	.10000E+01
MODIFIED K-FACTOR	.93596E-07	.10483E-04	.22832E-06	.31922E-06	.40902E-07	.72929E-06
THRUST FACTOR			.10660E+01	.70411E+00		

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56



1. REVIEWERS (CATEGORY) _____ () _____ () <u>T.G. Wales</u> () _____ () _____ () _____ () _____ () _____ () _____ () _____ () _____ ()	
2. DATE SENT: _____ RETURN TO: _____ BY: _____	
3. DOCUMENT (TITLE/NUMBER/REV.): <u>Jet Impingement on Misc. MSIV Hardware</u> <u>Calc. No. M-MSS-806 Rev. 0</u>	
4. ORIGINATOR: <input type="checkbox"/> PP&L <input type="checkbox"/> OTHER	5. <input type="checkbox"/> SAFETY REL. <input type="checkbox"/> ASME <input type="checkbox"/> OTHER _____
6. STATUS: <input type="checkbox"/> PRELIM <input type="checkbox"/> FINAL <input type="checkbox"/> REV. <input type="checkbox"/> FILE NO. _____	
7. REFERENCES ATTACHED: _____	
8. COMMENT: 1. p1 - Calculation is safety-related. 2. p5 - "As" should be "Aa." 3. pp5&6 - State here, or under design basis on the coversheet, that the annular area will be converted to a circular area to allow use of the Reference 5 formulas. Also state that this assumption is conservative, because it will result in higher-than-actual jet pressures. 4. p6 - state that the "T" subscript is for "target." 5. p7 - $T = 447,385 \text{ lb}$, but P_T calculations are correct. 6. The attachment pages should be numbered, and should list the calculation number.	10. RESOLUTION: 1. CHANGED. 2. CHANGED. 3. THE FIRST STATEMENT OF THE PARA. ON PAGE 5 DESCRIBES THE SUBSTITUTION OF A CIRCULAR AREA (DESCRIBED AS OPEN ENDED PIPE) FOR THE ANNULAR AREA. THE LAST STATEMENT OF THIS PARA. AND SUBSEQUENT NOTES AND FORMULAE REFER TO REF. 5. THIS ASSUMPTION IS NOT NECESSARILY CONSERVATIVE. HOWEVER, IT IS THE BEST METHOD OF GETTING A REASONABLE APPROXIMATION OF WHAT IS HAPPENING THAT I AM AWARE OF. (SEE NOTE ADDED IN DESIGN BASIS ON PAGE 1.) 4. ADDED NOTE 5. CORRECTED 6. DONE
9. <u>T.G. Wales</u> <u>6-13-85</u> SUBMITTED DATE	11. <u>DePieratti</u> <u>6-24-85</u> RESOLVED DATE

Vertical text on the left side of the page, possibly a page number or header.

Horizontal text at the top of the page, possibly a title or header.

Horizontal text in the upper middle section of the page.

Horizontal text in the middle section of the page.

Horizontal text in the lower middle section of the page.

Horizontal text in the bottom middle section of the page.

Horizontal text at the bottom of the page, possibly a footer.



1. (CONT.) REVIEWER: T.G. Wales

3. (CONT.) DOCUMENT: Calc. No. M-MSS-806 Rev. 0

8. (CONT.) COMMENT

7. p8 - The heading of "internal pressure" implies hoop stresses, etc., rather than axial or bending loads. Are you sure these pressure ratings apply to the jet impingement loadings?

8. Clarify where the 9" sag comes from. Is it the unloaded deflection, or is the catenary only formed from the jet load? The wording implies that the conduit is straight until loaded from the jet blast.

9. p10 - On the figure, show where the conduit penetration locations are on the junction box. Identify where ϕ is measured.

10. p11 - You seem to be assuming that the conduit penetrates the box at a 45° angle. If so, state this assumption.

11. p12 - Use dimensions for flex conduit rather than rigid conduit.

12. p12 - 3145.5 in-lb should be 2295 in-lb.

10. (CONT.) RESOLUTION:

7. THE FLEX CONDUIT IS ACTUALLY CORRUGATED STAINLESS TUBING. THE ALLOWABLE "INTERNAL PRESSURE" IS THE PRESSURE AT WHICH THE CORRUGATIONS BEGIN TO STRAIGHTEN OUT. HOOP STRESS LIMITATIONS ARE NOT IMPLIED.

8. WHEN FLEX CONDUIT IS INSTALLED, A BIT OF SLACK IS LEFT BETWEEN THE RIGID CONDUIT ON ONE END AND THE EQUIPMENT AT THE OTHER END TO ALLOW RELATIVE MOVEMENT WHICH IS THE REASON FOR FLEX CONDUIT TO BEGIN WITH. THE 9" ASSUMED SAG IS THE TYPICAL AMOUNT OF SLACK IN THIS CASE IN THE INSTALLED, UNLOADED CONDITION. IT IS ALSO THE AMOUNT OF SAG IN THE LOADED CONDITION UNTIL IT BEGINS TO STRETCH WHICH IS THE FAILURE POINT.

4.4.10. THIS CALCULATION IS INTENDED TO BE GENERIC FOR ALL INBOARD VALVES, BOTH WITS. HOWEVER, IN ACTUALITY EACH VALVE IS SLIGHTLY DIFFERENT IN CONDUIT CONFIGURATION. IT ATTACHES TO THE BOXES AT DIFFERENT LOCATIONS AND IS ROUTED IN RANDOM DIRECTIONS. IT IS THEREFORE ASSUMED THAT THE RESULTANT CONDUIT LOAD IS IN THE DIRECTION OF THE JET BLAST WHICH IS AT 45° ANGLE TO THE DIRECTION OF LOADING BEING ANALYZED HERE. THIS RESULTANT LOAD IS REDUCED BY 1/2 TO ACCOUNT FOR THE ANGLE, SHADOWING OF SOME OF THE CONDUIT, ETC.

11. NO. THE ANALYSIS IS OF THE 1" RIGID CONDUIT THAT CONNECTS THE JUNCTION BOX TO THE LIMIT SWITCH PER THE DESCRIPTION ON PAGE 12.

12. DONE.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101

102

103

1. (CONT.) REVIEWER: T.G. Wales

3. (CONT.) DOCUMENT: Calc. No. M-MSS-806 Rev. 0

8. (CONT.) COMMENT

13. p12 - Show the 4.5" dimension on the sketch on p10.
14. p12 - Put parentheses around the numbers for OD and ID in the minimum area equation.
15. p13 - State which reference Table XVII is from.
16. p13 - Be more explicit than "picture books." Does this refer to vendor catalogs, or Drywell photographs?
17. p13 - Will $\sigma = \frac{Mc}{I}$ apply to flexible conduit?
18. p11 states flex conduit, but p14 implies rigid conduit.
19. p15 - Label figure as view A.
20. p10 and 14 - It is not clear how junction box mounts on mounting plate. Is there a vendor drawing which can be referenced?
21. p16 - It is not clear where the $\frac{3}{4}$ " plate width comes from.

10. (CONT.) RESOLUTION:

13. NO. THE CONFIGURATION IS BETTER ILLUSTRATED BY REF. 8, SHEET 2 PER THE DESCRIPTION ON PAGE 12.
14. DONE.
15. DONE.
16. THESE ARE THE PICTURE PROGRAM BOOKS IN THIS CASE OF THE DRYWELL OF COURSE. THEY HAVE NO MORE EXPLICIT DESIGNATION.
17. NO, IT DOES NOT. HOWEVER, AGAIN, THIS IS RIGID CONDUIT AS CAN BE SEEN IN THE "PICTURE BOOKS" REFERRED TO. THEREFORE, $\sigma = \frac{Mc}{I}$ DOES APPLY.
18. THEY ARE TWO DIFFERENT CASES, FLEX AND RIGID RESPECTIVELY.
19. DONE.
20. THERE IS NO VENDOR DRAWING. HOWEVER, THE "PICTURE BOOKS" GIVE A FAIRLY GOOD REPRESENTATION.
21. THIS IS THE WIDTH OF THE TAB ON THE PLATE THAT FORM ONE SIDE OF THE MOUNTING BOLT SLOT.

Handwritten text on the left margin, possibly bleed-through from the reverse side of the page.



1. (CONT.) REVIEWER: T.G. Wales3. (CONT.) DOCUMENT: Calc. No. M-MSS-806 Rev. 0

8. (CONT.) COMMENT


22. p17- Provide a diagram to show the basis for 9.67 inches and 5.33 inches.

23. p12- Reference attachment 3 for yield strength values.

24. p17 - $\sigma_{allowable} = 19800$ psi

25. p17- State that limit switches have "W" mounting, if this is the case.

26. p18- For conservatism, assume a failure mechanism like this:



27. p19 - Show the 67.5° angle on a diagram.

28. p19- Explain why a shape factor is not used for the flow control valve area.

29. p20- It is not clear where $OD = 0.937$ in came from.

10. (CONT.) RESOLUTION:

22. PAGE 17 REVISED, DIMENSIONS REVISED, CALCULATION REDONE, DIAGRAM IS ATTACHMENT 4.

23. ATTACHMENT 3 IS ALREADY REFERENCED.

24. .33 (TENSILE STRENGTH) IS A ROUNDED OFF FACTOR REPRESENTING $\frac{1}{3}$. $\frac{1}{3}$ OF 60,000 PSI TENSILE STRENGTH IS 20,000 PSI AS SHOWN, FURTHER, IT DOESN'T MATTER SINCE THE ACTUAL STRESS IS APPROXIMATELY $\frac{1}{4}$ OF THE ALLOWABLE.

25. DONE.

26. DISAGREE. IF THE MOUNTING SCREW IS PROPERLY TIGHTENED AS STATED, ITS HEAD WILL TRAP THE AREA UNDER IT AND WILL PREVENT IT FROM FLEXING AS MUCH AS THE AREA OUTSIDE THE CLAMPING INFLUENCE OF THE SCREW HEAD. AGAIN, THE DIFFERENCE WOULD NOT HAVE ANY EFFECT ON THE RESULT OF THE CALCULATION.

27. INSUFFICIENT SPACE FOR A DIAGRAM. WORD EXPLANATION ADDED INSTEAD.

28. THE FLOW CONTROL VALVE IS A FLAT SURFACE. THE SHAPE FACTOR FOR A FLAT SURFACE IS 1 PER REF. 5.

29. THE O.D. MINUS 2 TIMES $\frac{1}{2}$ THE WALL THICKNESS FOR SCHEDULE 40 PIPE AS STATED IN THE CALC.

1. REVIEWERS (CATEGORY) _____ () _____ ()
T.G. Wales (1) _____ () _____ ()
 _____ () _____ () _____ ()
 _____ () _____ () _____ ()

2. DATE SENT: 10-16-85 RETURN TO: D.C. Prevatte BY: 10-18-85

3. DOCUMENT (TITLE/NUMBER/REV.): JET IMPINGEMENT ON MISC MSIV HARDWARE
M-MSS-006 Rev. 1

4. ORIGINATOR: PP&L OTHER 5. SAFETY REL. ASME OTHER _____

6. STATUS: PRELIM FINAL REV. FILE NO. _____

7. REFERENCES ATTACHED: N/A

8. COMMENT:
None

10. RESOLUTION:

9. T.G. Wales 10-18-85
 SUBMITTED DATE

11. _____
 RESOLVED DATE

11
12
13
14

